

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
117 Kearney Lake Lower Unit	Wash Room tap 1	NTW460	October 1, 2020	0.002	Passed	0.1010	Passed	
117 Kearney Lake Lower Unit	Wash Room tap 2	NTW461	October 1, 2020	0.003	Passed	0.0800	Passed	
117 Kearney Lake Lower Unit	Wash Room tap 3	NTW462	October 1, 2020	0.003	Passed	0.0680	Passed	
117 Kearney Lake Lower Unit	Wash Room tap 4	NTW463	October 1, 2020	0.005	Passed	0.0620	Passed	
117 Kearney Lake Lower Unit	Gender Neutral Wash Room tap	NTW464	October 1, 2020	0.003	Passed	0.0890	Passed	
117 Kearney Lake Lower Unit	Staff Kitchen tap	VXD804	May 24, 2023	-	Passed	0.0087	Passed	
117 Kearney Lake Upper Unit	Gender Neutral Wash Room tap	NTW466	October 1, 2020	0.005	Passed	0.1200	Passed	
117 Kearney Lake Upper Unit	Wash Room tap 1	NTW467	October 1, 2020	0.004	Passed	0.0790	Passed	
117 Kearney Lake Upper Unit	Wash Room tap 2	NTW468	October 1, 2020	0.005	Passed	0.0780	Passed	
117 Kearney Lake Upper Unit	Wash Room tap 3	NTW469	October 1, 2020	0.004	Passed	0.0680	Passed	
117 Kearney Lake Upper Unit	Wash Room tap 4	NTW470	October 1, 2020	0.003	Passed	0.0890	Passed	
117 Kearney Lake Upper Unit	Wash Room tap 5	NTW471	October 1, 2020	0.003	Passed	0.0810	Passed	
117 Kearney Lake Upper Unit	Staff Kitchen tap	VXD805	May 24, 2023	-	Passed	0.0015	Passed	
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 1	MPX522	May 13, 2020	0.003	Passed	0.4100	Passed	
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 2	MPX523	May 13, 2020	0.001	Passed	0.0610	Passed	
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 2	MPX529	May 13, 2020	0.001	Passed	0.0840	Passed	
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 3	MPX530	May 13, 2020	0.001	Passed	0.0700	Passed	
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 4	MPX531	May 13, 2020	0.002	Passed	0.4500	Passed	
A. J. Smeltzer Junior High School	Guidance Room Wash Room tap	MPX541	May 13, 2020	0.001	Passed	0.0880	Passed	
A. J. Smeltzer Junior High School	Main Office Wash Room tap	MPX542	May 13, 2020	-	Passed	0.0590	Passed	
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 2	MPX544	May 13, 2020	0.002	Passed	0.1300	Passed	
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 3	MPX545	May 13, 2020	0.002	Passed	0.1500	Passed	
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 4	MPX546	May 13, 2020	0.002	Passed	0.1200	Passed	
A. J. Smeltzer Junior High School	2nd Floor Janitors Closet tap	MPX548	May 13, 2020	0.002	Passed	0.0420	Passed	
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 2	MPX550	May 13, 2020	0.002	Passed	0.0590	Passed	
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 3	MPX551	May 13, 2020	-	Passed	0.0067	Passed	
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 4	MPX552	May 13, 2020	0.001	Passed	0.0084	Passed	
A. J. Smeltzer Junior High School	Class Room 222 tap	MPX553	May 13, 2020	0.001	Passed	0.0250	Passed	
A. J. Smeltzer Junior High School	Class Room 227 tap	MPX563	May 13, 2020	0.001	Passed	0.0530	Passed	
A. J. Smeltzer Junior High School	Staff Room 27A Wash Room tap	MPX565	May 13, 2020	0.004	Passed	0.0280	Passed	
A. J. Smeltzer Junior High School	Wood Shop tap 1	SCA060	March 14, 2022	0.001	Passed	0.0420	Passed	
A. J. Smeltzer Junior High School	Wood Shop tap 2	SCA061	March 14, 2022	0.001	Passed	0.0420	Passed	
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 1	SCA062	March 14, 2022	0.001	Passed	0.0160	Passed	
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 3	SCA063	March 15, 2022	-	Passed	0.0400	Passed	
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 4	SCA064	March 15, 2022	0.001	Passed	0.1600	Passed	
A. J. Smeltzer Junior High School	1st Floor Janitors Closet tap	SCA065	March 15, 2022	-	Passed	0.0110	Passed	
A. J. Smeltzer Junior High School	Class Room 115 Wash Room tap	SCA069	March 15, 2022	0.003	Passed	0.1400	Passed	
A. J. Smeltzer Junior High School	Class Room 115 tap	SCA070	March 15, 2022	0.001	Passed	0.1300	Passed	
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 1	SCA071	March 15, 2022	0.002	Passed	0.0940	Passed	
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 1	SCA072	March 15, 2022	-	Passed	0.0088	Passed	
A. J. Smeltzer Junior High School	Staff Room 27B Wash Room tap	SCA079	March 15, 2022	-	Passed	0.0300	Passed	
A. J. Smeltzer Junior High School	Class Room 26 tap	SCA080	March 15, 2022	0.001	Passed	0.0280	Passed	
A. J. Smeltzer Junior High School	Fountain by 1st Floor Janitors Closet	WBD166	June 7, 2023	-	Passed	0.0410	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
A. J. Smeltzer Junior High School	Fountain by Room 16	WBD167	June 7, 2023	0.001	Passed	0.0005	Passed	
A. J. Smeltzer Junior High School	Kitchen Wash Room tap	WBD168	June 7, 2023	-	Passed	0.0085	Passed	
A. J. Smeltzer Junior High School	Kitchen sink tap 1	WBD169	June 7, 2023	-	Passed	0.0110	Passed	
A. J. Smeltzer Junior High School	Kitchen sink tap 2	WBD170	June 7, 2023	0.001	Passed	0.0140	Passed	
A. J. Smeltzer Junior High School	Kitchen sink tap 3	WBD171	June 7, 2023	-	Passed	0.0140	Passed	
A. J. Smeltzer Junior High School	Fountain by 2nd Floor Janitors Closet	WBD172	June 7, 2023	-	Passed	0.0035	Passed	
A. J. Smeltzer Junior High School	Food Lab sink tap	WBD173	June 7, 2023	0.004	Passed	0.0400	Passed	
A. J. Smeltzer Junior High School	Food Lab washtub tap	WBD174	June 7, 2023	0.003	Passed	0.0230	Passed	
A. J. Smeltzer Junior High School	Food Lab tap 1	WBD175	June 7, 2023	0.001	Passed	0.0190	Passed	
A. J. Smeltzer Junior High School	Food Lab tap 2	WBD196	June 7, 2023	0.001	Passed	0.0200	Passed	
A. J. Smeltzer Junior High School	Food Lab tap 3	WBD197	June 7, 2023	0.001	Passed	0.0200	Passed	
A. J. Smeltzer Junior High School	Food Lab tap 4	WBD198	June 7, 2023	-	Passed	0.0160	Passed	
A. J. Smeltzer Junior High School	Food Lab Wash Room tap	XKK289	October 26, 2023	0.002	Passed	0.0150	Passed	Tap remediated
A. J. Smeltzer Junior High School	Fountain by Food Lab	WBD199	June 7, 2023	0.001	Passed	0.0009	Passed	
A. J. Smeltzer Junior High School	Library Room 43A tap	WBD200	June 7, 2023	0.001	Passed	0.0190	Passed	Tap remediated
A. J. Smeltzer Junior High School	Family Living Class Room tap	XKK288	October 26, 2023	0.003	Passed	0.0140	Passed	Tap remediated
A. J. Smeltzer Junior High School	Staff Room 27 tap	WBD203	June 7, 2023	-	Passed	0.0120	Passed	
Admiral Westphal Elementary	Fountain by Room 16	XGV087	October 12, 2023	0.001	Passed	0.1000	Passed	
Admiral Westphal Elementary	Janitors Closet by Girls Wash Room	MYH082	June 23, 2020	-	Passed	0.0670	Passed	
Admiral Westphal Elementary	Special Needs Wash Room tap by Room 19	MYH083	June 23, 2020	0.001	Passed	0.1600	Passed	
Admiral Westphal Elementary	Class Room 24 tap 1	XGV085	October 12, 2023	-	Passed	0.0410	Passed	Tap remediated
Admiral Westphal Elementary	Class Room 24 tap 2	XGV086	October 12, 2023	-	Passed	0.0430	Passed	Tap remediated
Admiral Westphal Elementary	Room 23 tap	XGV084	October 12, 2023	0.001	Passed	0.0820	Passed	
Admiral Westphal Elementary	Class Room 16 tap	MYH088	June 23, 2020	0.003	Passed	0.5300	Passed	
Admiral Westphal Elementary	Girls Wash Room tap 1 by Room 12	XGV077	October 12, 2023	0.009	Exceeded	0.1900	Passed	Hand washing only
Admiral Westphal Elementary	Girls Wash Room tap 2 by Room 12	XGV078	October 12, 2023	0.010	Exceeded	0.1700	Passed	Hand washing only
Admiral Westphal Elementary	Girls Wash Room tap 3 by Room 12	XGV077	October 12, 2023	0.010	Exceeded	0.1400	Passed	Hand washing only
Admiral Westphal Elementary	Girls Wash Room tap 4 by Room 12	XGV077	October 12, 2023	0.005	Exceeded	0.1200	Passed	Hand washing only
Admiral Westphal Elementary	Room 10 Wash Room tap	XGV081	October 12, 2023	0.002	Passed	0.0440	Passed	Tap remediated
Admiral Westphal Elementary	Boys Wash Room tap 1 by Room 12	XGV073	October 12, 2023	0.008	Exceeded	0.1100	Passed	Hand washing only
Admiral Westphal Elementary	Boys Wash Room tap 2 by Room 12	XGV074	October 12, 2023	0.005	Exceeded	0.1100	Passed	Hand washing only
Admiral Westphal Elementary	Boys Wash Room tap 3 by Room 12	XGV075	October 12, 2023	0.005	Passed	0.1100	Passed	Tap remediated
Admiral Westphal Elementary	Boys Wash Room tap 4 by Room 12	XGV076	October 12, 2023	0.003	Passed	0.0890	Passed	Tap remediated
Admiral Westphal Elementary	Janitors Closet tap by Room 12	MYH099	June 23, 2020	0.014	Exceeded	0.1800	Passed	Hand washing only
Admiral Westphal Elementary	Fountain by Janitors Closet tap	XGV072	October 12, 2023	0.002	Passed	0.1900	Passed	
Admiral Westphal Elementary	Class Room 5 tap	XGV071	October 12, 2023	-	Passed	0.0470	Passed	Tap remediated
Admiral Westphal Elementary	Gender Neutral Wash Room tap by Room 4	XGV070	October 12, 2023	0.001	Passed	0.0580	Passed	Tap remediated
Admiral Westphal Elementary	Janitors Closet tap by Room 4	MYH103	June 23, 2020	0.030	Exceeded	0.2700	Passed	Hand washing only
Admiral Westphal Elementary	Class Room 4 tap	XGV069	October 12, 2023	-	Passed	0.0440	Passed	Tap remediated
Admiral Westphal Elementary	Class Room 3 Wash Room tap	XGV068	October 12, 2023	-	Passed	0.0400	Passed	Tap remediated
Admiral Westphal Elementary	Class Room 3	XGV067	October 12, 2023	0.001	Passed	0.0420	Passed	Tap remediated
Admiral Westphal Elementary	Fountain by Room 2	XGV088	October 12, 2023	0.002	Passed	0.0670	Passed	
Admiral Westphal Elementary	Staff Room Female Wash Room tap 1	XGV065	October 12, 2023	0.001	Passed	0.0550	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Admiral Westphal Elementary	Staff Room Female Wash Room tap 2	XGV066	October 12, 2023	0.008	Exceeded	0.0640	Passed	Hand washing only
Admiral Westphal Elementary	Staff Room Male Wash Room tap 1	MYH109	June 23, 2020	0.003	Passed	0.0780	Passed	
Admiral Westphal Elementary	Staff Kitchen tap	XGV064	October 12, 2023	-	Passed	0.0580	Passed	
Admiral Westphal Elementary	Principal's Office Wash Room tap	XGV082	October 12, 2023	0.002	Passed	0.0780	Passed	Tap remediated
Admiral Westphal Elementary	Fountain by Room 21	XGV083	October 12, 2023	0.001	Passed	0.2700	Passed	
Alderney Elementary	Staff Wash Room tap by Main Entrance	NAN882	June 30, 2020	0.004	Passed	0.1200	Passed	
Alderney Elementary	Janitors Closet tap in Sprinkler Room	NAN883	June 30, 2020	0.003	Passed	0.1800	Passed	
Alderney Elementary	Basement Janitors Closet tap Room 109	NAN889	June 30, 2020	0.001	Passed	0.0790	Passed	
Alderney Elementary	Basement Staff Room tap	WQG748	June 30, 2023	-	Passed	0.0150	Passed	Tap remediated
Alderney Elementary	1st Floor Boys Wash Room tap 1	PZN578	June 30, 2021	0.001	Passed	0.0430	Passed	
Alderney Elementary	1st Floor Boys Wash Room tap 2	PZN579	June 30, 2021	-	Passed	0.0370	Passed	
Alderney Elementary	1st Floor Girls Wash Room tap 1	PZN580	June 30, 2021	0.001	Passed	0.0200	Passed	
Alderney Elementary	1st Floor Girls Wash Room tap 2	PZN581	June 30, 2021	-	Passed	0.0130	Passed	
Alderney Elementary	Basement Girls Wash Room tap 1	PZN582	June 30, 2021	-	Passed	0.0190	Passed	
Alderney Elementary	Basement Girls Wash Room tap 2	PZN583	June 30, 2021	-	Passed	0.0260	Passed	
Alderney Elementary	Basement Girls Wash Room tap 3	PZN584	June 30, 2021	0.001	Passed	0.0340	Passed	
Alderney Elementary	Basement Boys Wash Room tap 1	PZN585	June 30, 2021	-	Passed	0.0097	Passed	
Alderney Elementary	Basement Boys Wash Room tap 2	PZN586	June 30, 2021	-	Passed	0.0091	Passed	
Alderney Elementary	Basement Boys Wash Room tap 3	PZN587	June 30, 2021	-	Passed	0.0130	Passed	
Alderney Elementary	Fountain by Main Entrance	WQG746	June 30, 2023	0.001	Passed	0.0920	Passed	
Alderney Elementary	Fountain by Wash Rooms	WQG749	June 30, 2023	0.001	Passed	0.1800	Passed	
Alderney Elementary	Basement Fountain by Wash Rooms	WQG747	June 30, 2023	-	Passed	-	Passed	
Ash Lee Jefferson Elementary	Class Room 207 tap	MVG462	June 9, 2020	-	Passed	0.4200	Passed	
Ash Lee Jefferson Elementary	Gender Neutral Wash Room 214 tap	MVG464	June 9, 2020	0.001	Passed	0.4400	Passed	
Ash Lee Jefferson Elementary	Gym Office 231 tap	MVG469	June 9, 2020	0.003	Passed	1.6000	Passed	
Ash Lee Jefferson Elementary	Girls Change Room tap	MVG470	June 9, 2020	0.001	Passed	0.2200	Passed	
Ash Lee Jefferson Elementary	Boys Change Room tap	MVG472	June 9, 2020	-	Passed	0.2200	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 1 by Change Room	MVG473	June 9, 2020	0.001	Passed	0.1400	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 2 by Change Room	MVG474	June 9, 2020	0.002	Passed	0.1100	Passed	
Ash Lee Jefferson Elementary	Janitors Closet tap	MVG476	June 9, 2020	-	Passed	0.3000	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 1	MVG477	June 9, 2020	0.005	Passed	0.4800	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 2	MVG478	June 9, 2020	0.001	Passed	0.3100	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 3	MVG479	June 9, 2020	0.001	Passed	0.0610	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 1 by Room 271	MVG481	June 9, 2020	-	Passed	0.3100	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 2 by Room 271	MVG482	June 9, 2020	-	Passed	0.1200	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 3 by Room 271	MVG483	June 9, 2020	-	Passed	0.1100	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 4 by Room 271	MVG484	June 9, 2020	-	Passed	0.1100	Passed	
Ash Lee Jefferson Elementary	Janitors Closet tap	MVG486	June 9, 2020	-	Passed	0.4200	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 1 by Room 281	MVG487	June 9, 2020	-	Passed	0.1200	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 2 by Room 281	MVG488	June 9, 2020	0.002	Passed	0.5900	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 3 by Room 281	MVG489	June 9, 2020	0.001	Passed	0.3000	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 4 by Room 281	MVG490	June 9, 2020	0.001	Passed	0.2700	Passed	
Ash Lee Jefferson Elementary	Class Room 281 tap	MVG491	June 9, 2020	0.002	Passed	0.2400	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ash Lee Jefferson Elementary	Gender Neutral Wash Room 284 tap	MVG492	June 9, 2020	0.001	Passed	0.4400	Passed	
Ash Lee Jefferson Elementary	Class Room 287 tap	MVG493	June 9, 2020	0.002	Passed	0.8200	Passed	
Ash Lee Jefferson Elementary	Class Room 256 tap	MVG494	June 9, 2020	-	Passed	0.0630	Passed	
Ash Lee Jefferson Elementary	Class Room 260 tap	MVG496	June 9, 2020	-	Passed	0.5000	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room 128 tap 2	MVG499	June 9, 2020	0.003	Passed	0.2600	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room 128 tap 3	MVG500	June 9, 2020	0.003	Passed	0.1000	Passed	
Ash Lee Jefferson Elementary	Janitors Closet Room 127 tap	MVG501	June 9, 2020	0.001	Passed	0.2800	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room 126 tap 2	MVG503	June 9, 2020	0.001	Passed	0.1500	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room 126 tap 3	MVG504	June 9, 2020	0.004	Passed	0.1200	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 2	MVG505	June 9, 2020	0.001	Passed	0.5900	Passed	
Ash Lee Jefferson Elementary	Staff Room Wash Room tap 1	MVG506	June 9, 2020	-	Passed	0.0920	Passed	
Ash Lee Jefferson Elementary	Staff Room Wash Room tap 2	MVG507	June 9, 2020	0.002	Passed	0.2300	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 1	MVG509	June 9, 2020	0.001	Passed	1.1000	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 2	MVG510	June 9, 2020	0.004	Passed	0.4400	Passed	
Ash Lee Jefferson Elementary	Boys Wash Room tap 3	MVG511	June 9, 2020	0.002	Passed	0.6900	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 3	MVG512	June 9, 2020	0.000	Passed	0.5800	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 1	MVG513	June 9, 2020	0.001	Passed	0.5500	Passed	
Ash Lee Jefferson Elementary	Class Room 258 tap	SCH1183	March 15, 2022	-	Passed	0.0920	Passed	
Ash Lee Jefferson Elementary	Kitchen Room 219 tap 1	WEK913	June 20, 2023	-	Passed	0.0470	Passed	
Ash Lee Jefferson Elementary	Kitchen Room 219 tap 2	WEK914	June 20, 2023	-	Passed	0.0740	Passed	
Ash Lee Jefferson Elementary	Kitchen Room 219 tap 3	WEK915	June 20, 2023	0.001	Passed	0.0610	Passed	
Ash Lee Jefferson Elementary	Kitchen Room 219 tap 4	WEK916	June 20, 2023	-	Passed	0.0400	Passed	
Ash Lee Jefferson Elementary	Staff Room tap	WEK917	June 20, 2023	-	Passed	0.0450	Passed	
Ash Lee Jefferson Elementary	Fountain by Gym	WEK918	June 20, 2023	-	Passed	0.0720	Passed	
Ash Lee Jefferson Elementary	Fountain by 2nd Floor Wash Rooms	WEK919	June 20, 2023	-	Passed	0.0350	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room tap 3 by Change Room	WEK920	June 20, 2023	-	Passed	0.0310	Passed	Tap remediated
Ash Lee Jefferson Elementary	Fountain by Room 271	WEK921	June 20, 2023	-	Passed	0.0840	Passed	
Ash Lee Jefferson Elementary	Fountain by Room 127	WEK922	June 20, 2023	-	Passed	0.0530	Passed	
Ash Lee Jefferson Elementary	Girls Wash Room 128 tap 1	WEK923	June 20, 2023	-	Passed	0.0310	Passed	Tap remediated
Ash Lee Jefferson Elementary	Boys Wash Room 126 tap 1	WEK924	June 20, 2023	-	Passed	0.0320	Passed	Tap remediated
Ash Lee Jefferson Elementary	Fountain by Room 105	WEK925	June 20, 2023	-	Passed	0.0440	Passed	
Astral Drive Elementary	2nd Floor Boys Wash Room tap 1	XBV399	September 20, 2023	0.001	Passed	0.0610	Passed	Tap remediated
Astral Drive Elementary	2nd Floor Boys Wash Room tap 2	MXV293	June 19, 2020	0.003	Passed	0.1200	Passed	
Astral Drive Elementary	2nd Floor Boys Wash Room tap 3	MXV294	June 19, 2020	0.003	Passed	0.1400	Passed	
Astral Drive Elementary	2nd Floor Girls Wash Room tap 1	MXV295	June 19, 2020	0.003	Passed	0.1100	Passed	
Astral Drive Elementary	2nd Floor Girls Wash Room tap 2	MXV296	June 19, 2020	0.004	Passed	0.0330	Passed	
Astral Drive Elementary	2nd Floor Girls Wash Room tap 3	MXV297	June 19, 2020	-	Passed	0.0100	Passed	
Astral Drive Elementary	Janitors Closet Room 217 tap	MXV298	June 19, 2020	0.001	Passed	0.0600	Passed	
Astral Drive Elementary	Art Room 215 tap	XBV645	September 20, 2023	0.001	Passed	0.0400	Passed	Tap remediated
Astral Drive Elementary	Staff Room 216 tap	XBV401	September 20, 2023	-	Passed	0.0011	Passed	
Astral Drive Elementary	Staff Room 216 Wash Room 1	XBV644	September 20, 2023	-	Passed	0.0071	Passed	Tap remediated
Astral Drive Elementary	Staff Room 216 Wash Room 2	MXV302	June 19, 2020	0.003	Passed	0.1500	Passed	
Astral Drive Elementary	Fountain by Room 216	XBV400	September 20, 2023	-	Passed	0.0120	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Astral Drive Elementary	1st Floor Boys Wash Room tap 1	XBV394	September 20, 2023	-	Passed	0.0370	Passed	Tap remediated
Astral Drive Elementary	1st Floor Boys Wash Room tap 2	MXV305	June 19, 2020	0.004	Passed	0.1600	Passed	
Astral Drive Elementary	1st Floor Boys Wash Room tap 3	MXV306	June 19, 2020	0.001	Passed	0.0170	Passed	
Astral Drive Elementary	1st Floor Girls Wash Room tap 1	MXV307	June 19, 2020	0.005	Passed	0.0660	Passed	
Astral Drive Elementary	1st Floor Girls Wash Room tap 2	XBV392	September 20, 2023	-	Passed	0.0150	Passed	Tap remediated
Astral Drive Elementary	1st Floor Girls Wash Room tap 3	XBV393	September 20, 2023	-	Passed	0.0150	Passed	Tap remediated
Astral Drive Elementary	Class Room 105 tap	XBV397	September 20, 2023	0.001	Passed	0.0960	Passed	Tap remediated
Astral Drive Elementary	Class Room 105 Wash Room tap	MXV311	June 19, 2020	0.041	Exceeded	0.3000	Passed	Hand washing only
Astral Drive Elementary	Main Office Staff Wash Room tap	MXV313	June 19, 2020	0.000	Passed	0.0350	Passed	
Astral Drive Elementary	Fountain by Office	XBV398	September 20, 2023	-	Passed	0.0011	Passed	
Astral Drive Elementary	Class Room 102 Wash Room tap	MXV317	June 19, 2020	0.003	Passed	0.1700	Passed	
Astral Drive Elementary	Janitors Closet 115 tap	MXV318	June 19, 2020	0.001	Passed	0.0300	Passed	
Astral Drive Elementary	Class Room 103 tap	XBV396	September 20, 2023	0.001	Passed	0.0470	Passed	Tap remediated
Astral Drive Elementary	Boiler Room tap	MXV344	June 19, 2020	0.019	Exceeded	0.2100	Passed	Hand washing only
Astral Drive Elementary	Music Room 109 tap	NLS538	August 25, 2020	0.001	Passed	0.0170	Passed	
Astral Drive Elementary	Fountain by Gym	XBV395	September 20, 2023	-	Passed	0.0510	Passed	
Astral Drive Elementary	Class Room 102 tap	NLS540	August 25, 2020	0.001	Passed	0.0450	Passed	
Astral Drive Elementary	Class Room 101 tap	NLS541	August 25, 2020	0.001	Passed	0.0430	Passed	
Astral Drive Elementary	Class Room 104 tap 1	NLS542	August 25, 2020	0.001	Passed	0.0390	Passed	
Astral Drive Elementary	Class Room 107 tap	NLS543	August 25, 2020	0.002	Passed	0.0690	Passed	
Astral Drive Junior High School	Girls Wash Room tap 1 by Room 204	XBV787	September 23, 2023	0.008	Exceeded	0.1100	Passed	Hand washing only
Astral Drive Junior High School	Girls Wash Room tap 2 by Room 204	MXU331	June 19, 2020	0.001	Passed	0.0500	Passed	
Astral Drive Junior High School	Girls Wash Room tap 3 by Room 204	XBV788	September 23, 2023	0.001	Passed	0.0680	Passed	Tap remediated
Astral Drive Junior High School	Girls Wash Room tap 4 by Room 204	MXU333	June 19, 2020	0.002	Passed	0.0480	Passed	
Astral Drive Junior High School	Science Lab 204 tap 1	MXU334	June 19, 2020	0.028	Exceeded	1.0000	Passed	Laboratory or Hand washing only
Astral Drive Junior High School	Science Lab 204 tap 2	MXU335	June 19, 2020	0.031	Exceeded	0.1800	Passed	Laboratory or Hand washing only
Astral Drive Junior High School	Science Lab 204 tap 3	MXU336	June 19, 2020	0.036	Exceeded	0.8300	Passed	Laboratory or Hand washing only
Astral Drive Junior High School	Science Lab 204 tap 4	MXU337	June 19, 2020	0.002	Passed	0.0570	Passed	
Astral Drive Junior High School	Science Lab 206 tap 1	MXU338	June 19, 2020	0.011	Exceeded	0.0760	Passed	Laboratory or Hand washing only
Astral Drive Junior High School	Science Lab 206 tap 2	MXU339	June 19, 2020	0.047	Exceeded	0.4300	Passed	Laboratory or Hand washing only
Astral Drive Junior High School	Class Room Lab 211 tap 1	MXU344	June 19, 2020	0.025	Exceeded	1.6000	Passed	Laboratory or Hand washing only
Astral Drive Junior High School	Class Room Lab 211 tap 2	MXU345	June 19, 2020	0.042	Exceeded	1.5000	Passed	Laboratory or Hand washing only
Astral Drive Junior High School	Class Room Lab 211 tap 3	MXU346	June 19, 2020	0.400	Exceeded	5.6000	Exceeded	Laboratory or Hand washing only
Astral Drive Junior High School	Class Room Lab 211 tap 4	MXU347	June 19, 2020	0.028	Exceeded	2.0000	Exceeded	Laboratory or Hand washing only
Astral Drive Junior High School	Boys Wash Room tap 1 by Room 232	MXU348	June 19, 2020	0.001	Passed	0.0380	Passed	
Astral Drive Junior High School	Boys Wash Room tap 2 by Room 232	MXU349	June 19, 2020	0.001	Passed	0.0310	Passed	
Astral Drive Junior High School	Boys Wash Room tap 3 by Room 232	MXU350	June 19, 2020	0.001	Passed	0.0310	Passed	
Astral Drive Junior High School	Janitors Closet 232 tap	MXU351	June 19, 2020	-	Passed	0.0320	Passed	
Astral Drive Junior High School	Fountain by Room 232	XBV789	September 23, 2023	0.001	Passed	0.0540	Passed	
Astral Drive Junior High School	Office Room 194 tap	XBV732	September 20, 2023	0.032	Exceeded	0.7700	Passed	Hand washing only
Astral Drive Junior High School	Office Wash Room 193 tap	XBV733	September 20, 2023	0.008	Exceeded	0.2100	Passed	Hand washing only
Astral Drive Junior High School	1st Floor Staff Room tap	XBV691	September 20, 2023	-	Passed	0.0530	Passed	
Astral Drive Junior High School	Staff Room Wash Room 181 tap	MXU359	June 19, 2020	0.001	Passed	0.0370	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Astral Drive Junior High School	Staff Room Wash Room 182 tap	MXU360	June 19, 2020	0.001	Passed	0.0360	Passed	
Astral Drive Junior High School	Home Ec. 174 tap 1	XBV728	September 20, 2023	0.011	Exceeded	0.0870	Passed	
Astral Drive Junior High School	Home Ec. 174 tap 2	XBV730	September 20, 2023	0.001	Passed	0.1100	Passed	
Astral Drive Junior High School	Wood Shop 165 tap	XBV731	September 20, 2023	0.001	Passed	0.1500	Passed	Tap remediated
Astral Drive Junior High School	Janitors Closet 164 tap	MXU369	June 19, 2020	0.003	Passed	0.0430	Passed	
Astral Drive Junior High School	1st Floor Canteen tap 1	XBV785	September 20, 2023	0.001	Passed	0.0920	Passed	
Astral Drive Junior High School	1st Floor Canteen tap 2	XBV786	September 20, 2023	0.001	Passed	0.0940	Passed	
Astral Drive Junior High School	Gym Office 153 Wash Room tap	MXU372	June 19, 2020	0.002	Passed	0.0510	Passed	
Astral Drive Junior High School	Girls Locker Room tap 1	MXU373	June 19, 2020	0.001	Passed	0.1000	Passed	
Astral Drive Junior High School	Girls Locker Room tap 2	MXU374	June 19, 2020	0.002	Passed	0.1000	Passed	
Astral Drive Junior High School	Boys Locker Room tap 1	MXU375	June 19, 2020	0.004	Passed	0.1100	Passed	
Astral Drive Junior High School	Boys Locker Room tap 2	MXU376	June 19, 2020	0.001	Passed	0.0440	Passed	
Astral Drive Junior High School	Gym Office 157 Wash Room tap	MXU377	June 19, 2020	0.002	Passed	0.0540	Passed	
Astral Drive Junior High School	Fountain by Room 149	XBV729	September 20, 2023	-	Passed	0.0490	Passed	
Astral Drive Junior High School	Class Room 143 tap	MXU378	June 19, 2020	0.002	Passed	0.0540	Passed	
Astral Drive Junior High School	Girls Wash Room tap 1 by Room 143	MXU361	June 19, 2020	0.002	Passed	0.0410	Passed	
Astral Drive Junior High School	Girls Wash Room tap 2 by Room 143	MXU362	June 19, 2020	-	Passed	0.0400	Passed	
Astral Drive Junior High School	Boys Wash Room tap 1 by Room 143	MXU364	June 19, 2020	0.001	Passed	0.0740	Passed	
Astral Drive Junior High School	Boys Wash Room tap 2 by Room 143	MXU365	June 19, 2020	0.002	Passed	0.0580	Passed	
Astral Drive Junior High School	Art Room 142 tap 1	XBV734	September 20, 2023	0.087	Exceeded	0.1400	Passed	Hand washing only
Astral Drive Junior High School	Art Room 142 tap 2	XBV735	September 20, 2023	0.004	Passed	0.0740	Passed	Tap remediated
Astral Drive Junior High School	Student Services 141 Wash Room tap	XBV737	September 20, 2023	-	Passed	0.0170	Passed	Tap remediated
Astral Drive Junior High School	Resource Room 140 tap	XBV736	September 20, 2023	-	Passed	0.0200	Passed	
Astral Drive Junior High School	1st Floor Boys Wash Room tap 1 by Room 132	XBV790	September 20, 2023	0.001	Passed	0.0340	Passed	Tap remediated
Astral Drive Junior High School	1st Floor Boys Wash Room tap 2 by Room 132	XBV791	September 20, 2023	0.001	Passed	0.0270	Passed	Tap remediated
Astral Drive Junior High School	1st Floor Boys Wash Room tap 3 by Room 132	XBV792	September 20, 2023	0.001	Passed	0.0350	Passed	Tap remediated
Astral Drive Junior High School	Janitors Closet 132 tap	MXU386	June 19, 2020	0.002	Passed	0.0540	Passed	
Astral Drive Junior High School	Fountain by Room 132	XBV784	September 20, 2023	-	Passed	0.0660	Passed	
Astral Drive Junior High School	1st Floor Girls Wash Room tap 1 by Room 133	XBV793	September 20, 2023	0.003	Passed	0.0710	Passed	Tap remediated
Astral Drive Junior High School	1st Floor Girls Wash Room tap 2 by Room 133	MXU391	June 19, 2020	0.004	Passed	0.0920	Passed	
Astral Drive Junior High School	1st Floor Girls Wash Room tap 3 by Room 133	MXU392	June 19, 2020	0.001	Passed	0.0610	Passed	
Astral Drive Junior High School	1st Floor Girls Wash Room tap 4 by Room 133	MXU393	June 19, 2020	0.001	Passed	0.0980	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Fountain by Room 107	TBH367	June 30, 2022	0.016	Exceeded	0.2200	Passed	Fountain out of service. Other sources available.
Atl. Mem. -Terence Bay Elem (Shad Bay)	Fountain by Janitors Closet	TBH369	June 30, 2022	0.008	Exceeded	0.0380	Passed	Fountain out of service. Other sources available.
Atl. Mem. -Terence Bay Elem (Shad Bay)	Girls Wash Room tap	TBH371	June 30, 2022	0.002	Passed	0.3500	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Gym Wash Room tap	TBH373	June 30, 2022	0.002	Passed	0.1200	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Boys Wash Room tap	VXD690	May 24, 2023	0.015	Exceeded	0.5600	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Shad Bay)	Pre-Primary Class Room tap	VXD691	May 24, 2023	-	Passed	0.0960	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Pre-Primary Wash Room tap	RVB217	February 7, 2022	0.001	Passed	0.5200	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Janitors Office tap	RVB222	February 7, 2022	0.002	Passed	0.2400	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Gender Neutral Wash Room tap	RVB258	February 7, 2022	0.001	Passed	0.3600	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Boys Wash Room tap 1	RVB259	February 7, 2022	0.002	Passed	0.5300	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Boys Wash Room tap 2	RVB260	February 7, 2022	0.001	Passed	0.2500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Atl. Mem. -Terence Bay Elem (Shad Bay)	Boys Wash Room tap 3	RVB261	February 7, 2022	0.001	Passed	0.2500	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Boys Wash Room tap 4	RVB262	February 7, 2022	0.003	Passed	0.2400	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Fountain by Boys Wash Room	TBH368	June 30, 2022	0.001	Passed	0.4800	Passed	Fountain out of service. Other sources available.
Atl. Mem. -Terence Bay Elem (Shad Bay)	Janitors Closet tap	RVB263	February 7, 2022	0.002	Passed	0.9900	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Girls Wash Room tap 1	RVB265	February 7, 2022	0.001	Passed	0.4230	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Girls Wash Room tap 2	RVB280	February 7, 2022	0.002	Passed	0.4600	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Girls Wash Room tap 3	RVB281	February 7, 2022	0.001	Passed	0.5900	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Girls Wash Room tap 4	RVB282	February 7, 2022	0.001	Passed	0.5900	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Common Room tap	VXD692	May 24, 2023	0.001	Passed	0.3400	Passed	
Atl. Mem. -Terence Bay Elem (Shad Bay)	Music Room 108 tap	VXD693	May 24, 2023	-	Passed	0.2100	Passed	Tap remediated
Atl. Mem. -Terence Bay Elem (Terence Bay)	Fountain by Girls Wash Room	MUM349	June 4, 2020	0.010	Exceeded	0.6700	Passed	Fountain out of service. Other sources available.
Atl. Mem. -Terence Bay Elem (Terence Bay)	Girls Wash Room tap 1	MUM350	June 4, 2020	0.085	Exceeded	0.0990	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Girls Wash Room tap 2	MUM351	June 4, 2020	0.017	Exceeded	0.3700	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Janitors Closet tap	MUM352	June 4, 2020	0.006	Exceeded	0.2500	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Boys Wash Room tap 1	MUM353	June 4, 2020	0.018	Exceeded	0.0540	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Boys Wash Room tap 2	MUM354	June 4, 2020	0.016	Exceeded	0.0600	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room tap 1 by Reading Room	MUM355	June 4, 2020	0.045	Exceeded	0.1700	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room tap 2 by Reading Room	MUM356	June 4, 2020	0.019	Exceeded	0.2100	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room tap at end of the building	MUM357	June 4, 2020	0.120	Exceeded	0.1300	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room 1 tap	MUM358	June 4, 2020	0.019	Exceeded	0.2100	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room 2 tap	MUM368	June 4, 2020	0.025	Exceeded	0.1200	Passed	Hand washing only
Atl. Mem. -Terence Bay Elem (Terence Bay)	Staff Room tap	MUM369	June 4, 2020	0.015	Exceeded	0.1900	Passed	Hand washing only
Atlantic View Elementary	Class Room 3 Wash Room tap	SWD834	June 9, 2022	0.001	Passed	0.0540	Passed	
Atlantic View Elementary	Fountain by Girls Wash Room	XGE403	October 11, 2023	-	Passed	-	Passed	
Atlantic View Elementary	Girls Wash Room tap 1 by Fountain	SWD836	June 9, 2022	0.002	Passed	0.0330	Passed	
Atlantic View Elementary	Girls Wash Room tap 2 by Fountain	SWD837	June 9, 2022	0.001	Passed	0.0350	Passed	
Atlantic View Elementary	Girls Wash Room tap 3 by Fountain	SWD838	June 9, 2022	0.003	Passed	0.0320	Passed	
Atlantic View Elementary	Janitors Closet tap between Wash Rooms	SWD839	June 9, 2022	-	Passed	0.0018	Passed	
Atlantic View Elementary	Boys Wash Room tap 1 by Janitors Closet	SWD840	June 9, 2022	-	Passed	0.0400	Passed	
Atlantic View Elementary	Boys Wash Room tap 2 by Janitors Closet	SWD841	June 9, 2022	0.001	Passed	0.0310	Passed	
Atlantic View Elementary	Boys Wash Room tap 3 by Janitors Closet	SWD842	June 9, 2022	0.001	Passed	0.0310	Passed	
Atlantic View Elementary	Girls Locker Room tap	XGE399	October 11, 2023	0.007	Exceeded	0.0060	Passed	Hand washing only
Atlantic View Elementary	Gym Staff Wash Room tap	XGE398	October 11, 2023	0.002	Passed	0.0120	Passed	Tap remediated
Atlantic View Elementary	Gym Caretaker Room tap in Gym	SWD846	June 9, 2022	0.002	Passed	0.0260	Passed	
Atlantic View Elementary	Gym Kitchen tap 1	XGE396	October 11, 2023	0.012	Exceeded	0.0130	Passed	Hand washing only
Atlantic View Elementary	Gym Kitchen tap 2	XGE397	October 11, 2023	0.012	Exceeded	0.0110	Passed	Hand washing only
Atlantic View Elementary	Room 9 tap	XGE395	October 11, 2023	0.001	Passed	0.0100	Passed	
Atlantic View Elementary	Staff Kitchen tap	XGE395	October 11, 2023	0.001	Passed	0.0070	Passed	
Atlantic View Elementary	Main Office Sick Room tap	XGE394	October 11, 2023	0.003	Passed	0.0150	Passed	Tap remediated
Atlantic View Elementary	Main Office Staff Wash Room 1 tap	SWD852	June 9, 2022	0.004	Passed	0.0710	Passed	
Atlantic View Elementary	Main Office Staff Wash Room 2 tap	SWD853	June 9, 2022	0.002	Passed	0.0130	Passed	
Atlantic View Elementary	Breakfast Club Room tap	XGE400	October 11, 2023	-	Passed	0.0180	Passed	
Atlantic View Elementary	Fountain by Library	XGE402	October 11, 2023	0.001	Passed	-	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Auburn Drive High School	Science Lab 301 tap	MXA146	June 16, 2020	-	Passed	1.1000	Passed	
Auburn Drive High School	Science Lab 302 tap 1	MXA147	June 16, 2020	-	Passed	0.7600	Passed	
Auburn Drive High School	Science Lab 302 tap 2	MXA148	June 16, 2020	0.001	Passed	0.7600	Passed	
Auburn Drive High School	Science Lab 302 tap 3	MXA149	June 16, 2020	-	Passed	0.9500	Passed	
Auburn Drive High School	Science Lab 302 tap 4	MXA150	June 16, 2020	0.001	Passed	0.9200	Passed	
Auburn Drive High School	Science Lab 303 tap 1	MXA151	June 16, 2020	-	Passed	1.0000	Passed	
Auburn Drive High School	Science Lab 303 tap 2	MXA152	June 16, 2020	0.004	Passed	0.4600	Passed	
Auburn Drive High School	Science Lab 303 tap 3	MXA153	June 16, 2020	0.001	Passed	0.4400	Passed	
Auburn Drive High School	Science Lab 303 tap 4	MXA154	June 16, 2020	0.001	Passed	0.7600	Passed	
Auburn Drive High School	Fountain by Room 304	XCL327	September 22, 2023	-	Passed	-	Passed	
Auburn Drive High School	Fountain by Room 307	XCL307	September 22, 2023	-	Passed	0.0350	Passed	
Auburn Drive High School	Class Room 313 tap 1	XCL304	September 22, 2023	-	Passed	0.1600	Passed	Tap remediated
Auburn Drive High School	Class Room 313 tap 2	XCL305	September 22, 2023	-	Passed	0.0940	Passed	Tap remediated
Auburn Drive High School	Class Room 313 tap 3	XCL306	September 22, 2023	-	Passed	0.0300	Passed	Tap remediated
Auburn Drive High School	Class Room 313 tap 4	MXA160	June 16, 2020	0.002	Passed	0.5200	Passed	
Auburn Drive High School	Class Room 313 tap 5	MXA161	June 16, 2020	-	Passed	0.3500	Passed	
Auburn Drive High School	Prep Room 314 tap	MXA162	June 16, 2020	0.001	Passed	0.5400	Passed	
Auburn Drive High School	Science Lab 314 tap 1	MXA163	June 16, 2020	-	Passed	0.9100	Passed	
Auburn Drive High School	Science Lab 314 tap 2	MXA164	June 16, 2020	0.001	Passed	0.5900	Passed	
Auburn Drive High School	Science Lab 314 tap 3	NBS263	July 7, 2020	0.001	Passed	0.6300	Passed	
Auburn Drive High School	Science Lab 314 tap 4	NBS264	July 7, 2020	0.002	Passed	0.1600	Passed	
Auburn Drive High School	Science Lab 314 tap 5	MXA167	June 16, 2020	-	Passed	1.1000	Passed	
Auburn Drive High School	Science Lab 314 tap 6	MXA168	June 16, 2020	-	Passed	0.7000	Passed	
Auburn Drive High School	Science Lab 314 tap 7	MXA169	June 16, 2020	-	Passed	0.7700	Passed	
Auburn Drive High School	Science Lab 314 tap 8	MXA170	June 16, 2020	-	Passed	0.7400	Passed	
Auburn Drive High School	Science Lab 314 tap 9	MXA171	June 16, 2020	-	Passed	0.7500	Passed	
Auburn Drive High School	Science Lab 315 tap 1	XCL330	September 22, 2023	-	Passed	0.7800	Passed	Tap remediated
Auburn Drive High School	Science Lab 315 tap 2	MXA173	June 16, 2020	0.003	Passed	0.8100	Passed	
Auburn Drive High School	Science Lab 315 tap 3	MXA174	June 16, 2020	-	Passed	0.6400	Passed	
Auburn Drive High School	Science Lab 315 tap 4	MXA175	June 16, 2020	0.002	Passed	0.2100	Passed	
Auburn Drive High School	Science Lab 315 tap 5	XCL331	September 22, 2023	0.005	Passed	0.1300	Passed	Tap remediated
Auburn Drive High School	Science Lab 315 tap 6	XCL332	September 22, 2023	-	Passed	0.0770	Passed	Tap remediated
Auburn Drive High School	Science Lab 315 tap 7	XCL303	September 22, 2023	0.001	Passed	0.0570	Passed	Tap remediated
Auburn Drive High School	Science Lab 315 tap 8	MXA179	June 16, 2020	0.001	Passed	0.8700	Passed	
Auburn Drive High School	Science Lab 315 tap 9	MXA180	June 16, 2020	0.002	Passed	0.4700	Passed	
Auburn Drive High School	Boys Wash Room tap 1 by Room 301	MXA181	June 16, 2020	0.001	Passed	0.5000	Passed	
Auburn Drive High School	Boys Wash Room tap 2 by Room 301	MXA182	June 16, 2020	-	Passed	0.1900	Passed	
Auburn Drive High School	Boys Wash Room tap 3 by Room 301	MXA183	June 16, 2020	0.001	Passed	0.0570	Passed	
Auburn Drive High School	Boys Wash Room tap 4 by Room 301	XCL329	September 22, 2023	-	Passed	0.0690	Passed	Tap remediated
Auburn Drive High School	Boys Wash Room tap 5 by Room 301	MXA185	June 16, 2020	0.001	Passed	0.1600	Passed	
Auburn Drive High School	Staff Wash Room 1 tap by Room 301	XCL311	September 22, 2023	-	Passed	0.0180	Passed	Tap remediated
Auburn Drive High School	Staff Wash Room 2 tap by Room 301	MXA187	June 16, 2020	0.001	Passed	0.6600	Passed	
Auburn Drive High School	Girls Wash Room tap 1 by Room 301	MXA188	June 16, 2020	0.003	Passed	0.4900	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Auburn Drive High School	Girls Wash Room tap 2 by Room 301	MXA189	June 16, 2020	-	Passed	0.5400	Passed	
Auburn Drive High School	Girls Wash Room tap 3 by Room 301	MXA190	June 16, 2020	0.005	Passed	0.3900	Passed	
Auburn Drive High School	Girls Wash Room tap 4 by Room 301	MXA191	June 16, 2020	0.003	Passed	0.1500	Passed	
Auburn Drive High School	Girls Wash Room tap 5 by Room 301	XCL328	September 22, 2023	0.001	Passed	0.0700	Passed	Tap remediated
Auburn Drive High School	Janitors Closet tap by Wash Rooms	MXA193	June 16, 2020	0.001	Passed	0.3600	Passed	
Auburn Drive High School	Fountain by Stairs	XCL317	September 22, 2023	-	Passed	0.0014	Passed	
Auburn Drive High School	Music Room 201 tap	XCL326	September 22, 2023	-	Passed	0.0220	Passed	Tap remediated
Auburn Drive High School	Fountain by Room 202	XCL313	September 22, 2023	-	Passed	-	Passed	
Auburn Drive High School	Fine Arts Room 202 tap 1	MXA197	June 16, 2020	-	Passed	0.9500	Passed	
Auburn Drive High School	Fine Arts Room 202 tap 2	MXA198	June 16, 2020	-	Passed	0.4300	Passed	
Auburn Drive High School	Fine Arts Room 203 tap 1	XCL315	September 22, 2023	-	Passed	0.3500	Passed	Tap remediated
Auburn Drive High School	Fine Arts Room 203 tap 2	XCL316	September 22, 2023	-	Passed	0.3200	Passed	Tap remediated
Auburn Drive High School	Fine Arts Room 204 tap	MXA201	June 16, 2020	-	Passed	0.7300	Passed	
Auburn Drive High School	Fountain by Room 207	XCL342	September 22, 2023	-	Passed	-	Passed	
Auburn Drive High School	Class Room 209 tap	MXA203	June 16, 2020	0.004	Passed	0.2600	Passed	
Auburn Drive High School	Gender Neutral Wash Room 209 tap 1	XCL313	September 22, 2023	-	Passed	0.0680	Passed	Tap remediated
Auburn Drive High School	Gender Neutral Wash Room 209 tap 2	MXA205	June 16, 2020	-	Passed	0.4800	Passed	
Auburn Drive High School	Fountain by Room 212	XCL336	September 22, 2023	-	Passed	0.0023	Passed	
Auburn Drive High School	Janitors Closet tap by Student Services	MXA207	June 16, 2020	-	Passed	0.1500	Passed	
Auburn Drive High School	Student Services tap	XCL318	September 22, 2023	-	Passed	0.0230	Passed	Tap remediated
Auburn Drive High School	Male Staff Room Wash Room tap	MXA209	June 16, 2020	0.001	Passed	0.0580	Passed	
Auburn Drive High School	Female Staff Room Wash Room tap	MXA210	June 16, 2020	-	Passed	0.2900	Passed	
Auburn Drive High School	Staff Room Kitchen tap	XCL319	September 22, 2023	-	Passed	0.0420	Passed	
Auburn Drive High School	Library Wash Room tap	MXA212	June 16, 2020	0.002	Passed	1.0000	Passed	
Auburn Drive High School	Library tap	XCL320	September 22, 2023	-	Passed	0.0450	Passed	
Auburn Drive High School	Cafeteria tap 1	XCL309	September 22, 2023	-	Passed	0.0260	Passed	
Auburn Drive High School	Cafeteria tap 2	MXA215	June 16, 2020	-	Passed	0.0550	Passed	Out-of-Service
Auburn Drive High School	Cafeteria tap 3	XCL310	September 22, 2023	-	Passed	0.0370	Passed	Tap remediated
Auburn Drive High School	Fountain by Cafeteria	XCL308	September 22, 2023	-	Passed	0.0650	Passed	
Auburn Drive High School	Gym Gender Neutral Wash Room 1 tap	XCL344	September 22, 2023	0.002	Passed	0.2000	Passed	Tap remediated
Auburn Drive High School	Gym Gender Neutral Wash Room 2 tap	XCL345	September 22, 2023	0.001	Passed	0.2200	Passed	
Auburn Drive High School	Gym Boys Change Room tap 1	MXA218	June 16, 2020	0.004	Passed	0.4600	Passed	
Auburn Drive High School	Gym Boys Change Room tap 2	MXA219	June 16, 2020	0.001	Passed	0.3000	Passed	
Auburn Drive High School	Gym Female Change Room tap 1	XCL334	September 22, 2023	0.002	Passed	0.2000	Passed	Tap remediated
Auburn Drive High School	Gym Female Change Room tap 2	MXA221	June 16, 2020	-	Passed	0.4700	Passed	
Auburn Drive High School	Gym Office Wash Room tap	MXA223	June 16, 2020	0.001	Passed	0.7600	Passed	
Auburn Drive High School	Fountain in Gym	XCL333	September 22, 2023	-	Passed	0.2000	Passed	
Auburn Drive High School	Fountain by Room 223	XCL335	September 22, 2023	-	Passed	0.0009	Passed	
Auburn Drive High School	Janitors Closet tap in Maintenance Room near Room 223	XCL312	September 22, 2023	-	Passed	0.0230	Passed	Tap remediated
Auburn Drive High School	Food Lab 213 tap 1	XCL337	September 22, 2023	-	Passed	0.0310	Passed	
Auburn Drive High School	Food Lab 213 tap 2	XCL338	September 22, 2023	-	Passed	0.0330	Passed	
Auburn Drive High School	Food Lab 213 tap 3	XCL339	September 22, 2023	-	Passed	0.0240	Passed	
Auburn Drive High School	Food Lab 213 wash tap	NLS564	August 25, 2020	0.002	Passed	0.0470	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Auburn Drive High School	Food Lab 214 tap 1	XCL340	September 22, 2023	-	Passed	0.1300	Passed	
Auburn Drive High School	Food Lab 214 tap 2	XCL341	September 22, 2023	-	Passed	0.1200	Passed	
Auburn Drive High School	Main Floor Girls Wash Room tap 1	MXA232	June 16, 2020	0.004	Passed	0.2000	Passed	
Auburn Drive High School	Main Floor Girls Wash Room tap 2	MXA233	June 16, 2020	0.001	Passed	0.2600	Passed	
Auburn Drive High School	Main Floor Girls Wash Room tap 3	MXA234	June 16, 2020	0.001	Passed	0.1900	Passed	
Auburn Drive High School	Main Floor Girls Wash Room tap 4	MXA235	June 16, 2020	0.001	Passed	0.1600	Passed	
Auburn Drive High School	Main Floor Boys Wash Room tap 1	MXA236	June 16, 2020	0.001	Passed	0.1500	Passed	
Auburn Drive High School	Main Floor Boys Wash Room tap 2	MXA237	June 16, 2020	0.001	Passed	0.1300	Passed	
Auburn Drive High School	Main Floor Boys Wash Room tap 3	XCL343	September 22, 2023	-	Passed	0.0510	Passed	Tap remediated
Auburn Drive High School	Main Floor Boys Wash Room tap 4	MXA239	June 16, 2020	-	Passed	0.2500	Passed	
Auburn Drive High School	Fountain by Room 108	XCL324	September 22, 2023	-	Passed	0.0012	Passed	
Auburn Drive High School	Janitors Closet 110 tap	MXH473	June 17, 2020	0.001	Passed	0.3000	Passed	
Auburn Drive High School	Janitors Closet 111 tap	MXH474	June 17, 2020	0.002	Passed	0.3600	Passed	
Auburn Drive High School	Janitors Closet 112 tap	MXH475	June 17, 2020	0.002	Passed	0.1700	Passed	
Auburn Drive High School	Basement Boys Wash Room tap 1	MXH476	June 17, 2020	0.001	Passed	0.1100	Passed	
Auburn Drive High School	Basement Boys Wash Room tap 2	MXH477	June 17, 2020	0.001	Passed	0.1200	Passed	
Auburn Drive High School	Basement Boys Wash Room tap 3	MXH478	June 17, 2020	0.001	Passed	0.0970	Passed	
Auburn Drive High School	Gender Neutral Wash Room tap by Boys Wash Room	MXH479	June 17, 2020	0.001	Passed	0.1600	Passed	
Auburn Drive High School	Gender Neutral Wash Room tap by Girls Wash Room	XCL325	September 22, 2023	-	Passed	0.0110	Passed	Tap remediated
Auburn Drive High School	Basement Girls Wash Room tap 1	XCL322	September 22, 2023	-	Passed	0.1100	Passed	Tap remediated
Auburn Drive High School	Basement Girls Wash Room tap 2	MXH483	June 17, 2020	0.002	Passed	0.0260	Passed	
Auburn Drive High School	Basement Girls Wash Room tap 3	MXH484	June 17, 2020	0.001	Passed	0.0290	Passed	
Auburn Drive High School	Basement Girls Wash Room tap 4	XCL323	September 22, 2023	-	Passed	0.0730	Passed	Tap remediated
Auburn Drive High School	Basement Girls Wash Room tap 5	MXH486	June 17, 2020	-	Passed	0.0180	Passed	
Auburn Drive High School	Janitors Closet tap by Girls Wash Room	MXH487	June 17, 2020	0.001	Passed	1.0000	Passed	
Auburn Drive High School	Fountain by Basement Gender Neutral Wash Rooms	XCL321	September 22, 2023	-	Passed	0.0009	Passed	
Basinview Drive Elementary	Class Room 131 tap	MSP511	May 27, 2020	-	Passed	0.4200	Passed	
Basinview Drive Elementary	Class Room 132 tap	MSP512	May 27, 2020	0.001	Passed	0.1900	Passed	
Basinview Drive Elementary	Class Room 133 Wash Room tap	MSP513	May 27, 2020	0.001	Passed	0.1200	Passed	
Basinview Drive Elementary	Class Room 133 tap	MSP514	August 26, 2020	-	Passed	0.0110	Passed	
Basinview Drive Elementary	Janitors Closet tap by Room 133	MSP515	May 27, 2020	0.001	Passed	0.0900	Passed	
Basinview Drive Elementary	Gender Neutral Wash Room 137 tap	MSP516	May 27, 2020	-	Passed	0.0980	Passed	
Basinview Drive Elementary	Class Room 138 tap	MSP517	May 27, 2020	0.001	Passed	0.6700	Passed	
Basinview Drive Elementary	Class Room 139 Wash Room tap	MSP518	May 27, 2020	-	Passed	0.0420	Passed	
Basinview Drive Elementary	Class Room 139 tap	MSP519	May 27, 2020	-	Passed	0.0460	Passed	
Basinview Drive Elementary	Staff Wash Room 1 by Room 139	MSP524	May 27, 2020	-	Passed	0.0590	Passed	
Basinview Drive Elementary	Staff Wash Room 2 by Room 139	MSP525	May 27, 2020	-	Passed	0.0750	Passed	
Basinview Drive Elementary	1st Floor Boys Wash Room tap 1	MSP527	May 27, 2020	-	Passed	0.0280	Passed	
Basinview Drive Elementary	1st Floor Boys Wash Room tap 1	MSP528	May 27, 2020	-	Passed	0.0310	Passed	
Basinview Drive Elementary	1st Floor Girls Wash Room tap 1	MSP529	May 27, 2020	0.001	Passed	0.1500	Passed	
Basinview Drive Elementary	1st Floor Girls Wash Room tap 2	MSP530	May 27, 2020	-	Passed	0.1100	Passed	
Basinview Drive Elementary	Class Room tap Room 106	MSP532	May 27, 2020	0.001	Passed	0.1800	Passed	
Basinview Drive Elementary	Class Room tap Room 107	MSP533	May 27, 2020	-	Passed	0.0700	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Basinview Drive Elementary	Boiler Room tap after Room 107	MSP534	May 27, 2020	-	Passed	0.0073	Passed	
Basinview Drive Elementary	Music Room tap	MSP535	May 27, 2020	-	Passed	0.0088	Passed	
Basinview Drive Elementary	Boys Locker Room tap 1	MSP536	May 27, 2020	0.002	Passed	0.0540	Passed	
Basinview Drive Elementary	Boys Locker Room tap 2	MSP537	May 27, 2020	-	Passed	0.0240	Passed	
Basinview Drive Elementary	Girls Locker Room tap 1	MSP540	May 27, 2020	0.002	Passed	0.1600	Passed	
Basinview Drive Elementary	Girls Locker Room tap 2	MSP541	May 27, 2020	0.003	Passed	0.0560	Passed	
Basinview Drive Elementary	Girls Locker Room Wash Room tap	MSP542	May 27, 2020	-	Passed	0.0130	Passed	
Basinview Drive Elementary	Mechanical Room tap after Room 207	MSP545	May 27, 2020	-	Passed	0.0540	Passed	
Basinview Drive Elementary	Class Room 213 Wash Room tap	MSP547	May 27, 2020	-	Passed	0.0210	Passed	
Basinview Drive Elementary	Class Room 213 tap	MSP548	May 27, 2020	0.001	Passed	0.1700	Passed	
Basinview Drive Elementary	2nd Floor Boys Wash Room tap 1	MSP549	May 27, 2020	-	Passed	0.0170	Passed	
Basinview Drive Elementary	2nd Floor Boys Wash Room tap 2	MSP550	May 27, 2020	-	Passed	0.0170	Passed	
Basinview Drive Elementary	2nd Floor Boys Wash Room tap 3	MSP551	May 27, 2020	0.002	Passed	0.0550	Passed	
Basinview Drive Elementary	2nd Floor Girls Wash Room tap 1	MSP552	May 27, 2020	0.001	Passed	0.1000	Passed	
Basinview Drive Elementary	2nd Floor Girls Wash Room tap 2	MSP553	May 27, 2020	-	Passed	0.0330	Passed	
Basinview Drive Elementary	2nd Floor Girls Wash Room tap 3	MSP554	May 27, 2020	-	Passed	0.0370	Passed	
Basinview Drive Elementary	Mechanical Room tap	MSP556	May 27, 2020	-	Passed	0.0061	Passed	
Basinview Drive Elementary	Gender Neutral Staff Wash Room tap	MSP557	May 27, 2020	0.001	Passed	0.0490	Passed	
Basinview Drive Elementary	Class Room 212 tap	NLV834	August 26, 2020	0.000	Passed	0.0060	Passed	
Basinview Drive Elementary	Cafeteria large sink tap	WAT234	June 6, 2023	-	Passed	0.0260	Passed	
Basinview Drive Elementary	Cafeteria small sink tap	WAT235	June 6, 2023	0.001	Passed	0.1700	Passed	
Basinview Drive Elementary	Caretaker Office tap	WAT236	June 6, 2023	0.002	Passed	0.1100	Passed	
Basinview Drive Elementary	Fountain by 1st Floor Girls Wash Room	WAT237	June 6, 2023	-	Passed	0.0270	Passed	
Basinview Drive Elementary	Staff Room tap	WAT238	June 6, 2023	-	Passed	0.0600	Passed	
Basinview Drive Elementary	Fountain in Boys Locker Room	WAT239	June 6, 2023	-	Passed	0.2700	Passed	
Basinview Drive Elementary	Fountain in Girls Locker Room	WAT240	June 6, 2023	-	Passed	0.0012	Passed	
Basinview Drive Elementary	Fountain by 2nd Floor Girls Wash Room	WAT241	June 6, 2023	-	Passed	0.0087	Passed	
Basinview Drive Elementary	Modular Girls Wash Room tap 1	WAT242	June 6, 2023	-	Passed	0.0076	Passed	
Basinview Drive Elementary	Modular Girls Wash Room tap 2	WAT243	June 6, 2023	-	Passed	0.0062	Passed	
Basinview Drive Elementary	Modular Girls Wash Room tap 3	WAT286	June 6, 2023	-	Passed	0.0075	Passed	
Basinview Drive Elementary	Modular Girls Wash Room tap 4	WAT287	June 6, 2023	-	Passed	0.0077	Passed	
Basinview Drive Elementary	Modular Girls Wash Room tap 5	WAT288	June 6, 2023	-	Passed	0.0093	Passed	
Basinview Drive Elementary	Modular Boys Wash Room tap 1	WAT289	June 6, 2023	-	Passed	0.0088	Passed	
Basinview Drive Elementary	Modular Boys Wash Room tap 2	WAT290	June 6, 2023	-	Passed	0.0074	Passed	
Basinview Drive Elementary	Modular Boys Wash Room tap 3	WAT291	June 6, 2023	-	Passed	0.0088	Passed	
Basinview Drive Elementary	Fountain in Modular	WAT292	June 6, 2023	-	Passed	0.0140	Passed	
Basinview Drive Elementary	Modular Gender Neutral Wash Room tap	WAT293	June 6, 2023	-	Passed	0.0270	Passed	
Basinview Drive Elementary	Modular Staff Room tap	WAT294	June 6, 2023	0.001	Passed	0.0550	Passed	
Bay View High School	2nd Floor Fountain 1	JSI651	May 3, 2023	-	Passed	0.1100	Passed	
Bay View High School	2nd Floor Girls Wash Room tap 1	MUV836	June 8, 2020	0.003	Passed	0.4700	Passed	
Bay View High School	2nd Floor Boys Wash Room tap 1	MUV838	June 8, 2020	0.002	Passed	0.1700	Passed	
Bay View High School	2nd Floor Boys Wash Room tap 2	MUV839	June 8, 2020	0.001	Passed	0.1400	Passed	
Bay View High School	2nd Floor Staff Wash Room tap	MUV840	June 8, 2020	0.003	Passed	0.1300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Bay View High School	2nd Floor Janitors Closet tap	MUV841	June 8, 2020	-	Passed	0.1300	Passed	
Bay View High School	Science Lab 2056 tap 2	MUV843	June 8, 2020	0.002	Passed	0.1600	Passed	
Bay View High School	Science Lab 2056 tap 5	MUV846	June 8, 2020	0.001	Passed	0.0930	Passed	
Bay View High School	Chemistry Lab 2062 tap 1	MUV847	June 8, 2020	0.001	Passed	0.2100	Passed	
Bay View High School	Chemistry Lab 2062 tap 2	MUV848	February 10, 2022	0.002	Passed	0.2100	Passed	
Bay View High School	Chemistry Lab 2062 tap 3	MUV849	June 8, 2020	0.001	Passed	0.2300	Passed	
Bay View High School	Chemistry Lab 2062 tap 4	MUV850	June 8, 2020	0.001	Passed	0.1700	Passed	
Bay View High School	Chemistry Lab 2062 tap 7	MUV853	June 8, 2020	0.002	Passed	0.2100	Passed	
Bay View High School	Chemistry Lab 2062 tap 9	MUV855	June 8, 2020	0.003	Passed	0.1400	Passed	
Bay View High School	Chemistry Lab Preparation Room 2064 tap	MUV857	June 8, 2020	0.002	Passed	0.0460	Passed	
Bay View High School	Chemistry Lab 2067 tap 3	MUV860	June 8, 2020	0.005	Passed	0.2600	Passed	
Bay View High School	Chemistry Lab 2067 tap 6	MUV863	June 8, 2020	0.004	Passed	0.2000	Passed	
Bay View High School	Chemistry Lab 2067 tap 7	MUV864	June 8, 2020	0.001	Passed	0.4300	Passed	
Bay View High School	Biology Lab 2068 tap 2	MUV869	June 8, 2020	0.001	Passed	0.3200	Passed	
Bay View High School	Biology Lab 2068 tap 4	MUV871	June 8, 2020	0.003	Passed	0.4000	Passed	
Bay View High School	Biology Lab 2068 tap 5	MUV872	June 8, 2020	0.003	Passed	0.3000	Passed	
Bay View High School	Chemistry Lab 2067 tap 8	MWG705	June 12, 2020	0.002	Passed	0.3400	Passed	
Bay View High School	Chemistry Lab 2067 tap 10	MWG706	June 12, 2020	0.001	Passed	0.2600	Passed	
Bay View High School	Skilled Trades Wash Room tap	MWG707	June 12, 2020	0.001	Passed	0.2500	Passed	
Bay View High School	Skilled Trades Janitors tap	MWG708	June 12, 2020	0.004	Passed	0.2200	Passed	
Bay View High School	Skilled Trades Wash Sink tap	MWG709	June 12, 2020	0.002	Passed	0.3800	Passed	
Bay View High School	Science Lab 2066 tap 2	MWH957	June 12, 2020	0.004	Passed	0.2300	Passed	
Bay View High School	Science Lab 2063 tap 4	MWH961	June 12, 2020	0.005	Passed	0.5400	Passed	
Bay View High School	Science Lab 2058 tap 3	MWH965	June 12, 2020	0.003	Passed	0.2100	Passed	
Bay View High School	Physics Lab 2057 tap 2	MWH969	June 12, 2020	0.002	Passed	0.1300	Passed	
Bay View High School	Physics Lab 2057 tap 5	MWH972	June 12, 2020	0.002	Passed	0.2000	Passed	
Bay View High School	Library tap	MWH982	June 12, 2020	-	Passed	0.4100	Passed	
Bay View High School	Youth Centre Wash Room 1021 tap	MWH983	June 12, 2020	0.002	Passed	0.1700	Passed	
Bay View High School	1st Floor Male Wash Room tap 2	MWH985	June 12, 2020	0.001	Passed	0.1700	Passed	
Bay View High School	Staff Wash Room tap	MWH986	June 12, 2020	0.002	Passed	0.1800	Passed	
Bay View High School	Janitors Closet tap by Room 1016	MWH987	June 12, 2020	0.001	Passed	0.1900	Passed	
Bay View High School	1st Floor Girls Wash Room tap 1	MWH990	June 12, 2020	-	Passed	0.2000	Passed	
Bay View High School	1st Floor Girls Wash Room tap 2	MWH991	June 12, 2020	0.001	Passed	0.4100	Passed	
Bay View High School	Gym Office 1 Wash Room tap	MWH992	June 12, 2020	0.004	Passed	0.3200	Passed	
Bay View High School	Gym Office 2 Wash Room tap	MWH994	June 12, 2020	0.001	Passed	0.1500	Passed	
Bay View High School	Girls Wash Room tap 1 by Cafeteria	MWH995	June 12, 2020	0.002	Passed	0.0900	Passed	
Bay View High School	Girls Wash Room tap 2 by Cafeteria	MWH996	June 12, 2020	0.001	Passed	0.1500	Passed	
Bay View High School	Boys Wash Room tap 1 by Cafeteria	MWH999	June 12, 2020	0.001	Passed	0.1300	Passed	
Bay View High School	Boys Wash Room tap 2 by Cafeteria	MWI000	June 12, 2020	0.001	Passed	0.1100	Passed	
Bay View High School	Tech Ed. 1088 tap	MWI001	June 12, 2020	0.005	Passed	0.3000	Passed	
Bay View High School	Class Room 1109 tap	MWI003	June 12, 2020	0.001	Passed	0.1600	Passed	
Bay View High School	Staff Room 1101 Wash Room 1 tap	MWI005	June 12, 2020	0.001	Passed	0.1700	Passed	
Bay View High School	Staff Room 1101 Wash Room 2 tap	MWI006	June 12, 2020	0.002	Passed	0.1800	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Bay View High School	Admin Wash Room 1040 tap	MWI007	June 12, 2020	0.001	Passed	0.0900	Passed	
Bay View High School	Biology Lab 2068 tap 1	RVO107	February 10, 2022	0.001	Passed	0.1600	Passed	
Bay View High School	Biology Lab 2068 tap 3	RVO108	February 10, 2022	0.001	Passed	0.1700	Passed	
Bay View High School	Science Lab 2056 tap 1	RVO109	February 10, 2022	0.001	Passed	0.1700	Passed	
Bay View High School	Science Lab 2056 tap 3	RVO110	February 10, 2022	0.005	Passed	0.2100	Passed	
Bay View High School	Science Lab 2056 tap 4	RVO111	February 10, 2022	0.002	Passed	0.2000	Passed	
Bay View High School	Science Lab 2063 tap 1	RVO113	February 10, 2022	0.002	Passed	0.1400	Passed	
Bay View High School	Science Lab 2063 tap 2	RVO114	February 10, 2022	0.003	Passed	0.1400	Passed	
Bay View High School	Science Lab 2063 tap 3	RVO115	February 10, 2022	0.002	Passed	0.1700	Passed	
Bay View High School	Science Lab 2063 tap 5	RVO116	February 10, 2022	0.006	Exceeded	0.1900	Passed	Laboratory or Hand washing only
Bay View High School	Chemistry Lab 2062 tap 5	RVO118	February 10, 2022	-	Passed	0.1700	Passed	
Bay View High School	Chemistry Lab 2062 tap 6	RVO119	February 10, 2022	0.001	Passed	0.1800	Passed	
Bay View High School	Chemistry Lab 2062 tap 8	RVO120	February 10, 2022	0.001	Passed	0.2000	Passed	
Bay View High School	Chemistry Lab 2062 tap 10	RVO121	February 10, 2022	0.001	Passed	0.1700	Passed	
Bay View High School	Chemistry Lab 2067 tap 1	RVO122	February 10, 2022	0.001	Passed	0.1900	Passed	
Bay View High School	Chemistry Lab 2067 tap 2	RVO123	February 10, 2022	0.001	Passed	0.1800	Passed	
Bay View High School	Chemistry Lab 2067 tap 4	RVO124	February 10, 2022	0.001	Passed	0.2400	Passed	
Bay View High School	Chemistry Lab 2067 tap 5	RVO125	February 10, 2022	0.001	Passed	0.2000	Passed	
Bay View High School	Chemistry Lab 2067 tap 9	RVO126	February 10, 2022	0.001	Passed	0.2000	Passed	
Bay View High School	Physics Lab 2057 tap 1	RVX263	February 11, 2022	0.006	Exceeded	0.3500	Passed	Laboratory or Hand washing only
Bay View High School	Physics Lab 2057 tap 3	RVX264	February 11, 2022	0.001	Passed	0.1900	Passed	
Bay View High School	Physics Lab 2057 tap 4	RVX265	February 11, 2022	0.003	Passed	0.3500	Passed	
Bay View High School	Science Lab 2058 tap 2	RVX266	February 11, 2022	0.003	Passed	0.2200	Passed	
Bay View High School	Science Lab 2058 tap 4	RVX267	February 11, 2022	0.005	Exceeded	0.3700	Passed	Laboratory or Hand washing only
Bay View High School	Science Lab 2058 tap 1	RVX268	February 11, 2022	0.001	Passed	0.0830	Passed	
Bay View High School	Science Lab 2058 tap 5	RVX269	February 11, 2022	0.004	Passed	0.2900	Passed	
Bay View High School	Science Lab 2066 tap 1	RVX270	February 11, 2022	0.001	Passed	0.1900	Passed	
Bay View High School	Science Lab 2066 tap 3	RVX271	February 11, 2022	0.003	Passed	0.0700	Passed	
Bay View High School	Science Lab 2066 tap 4	RVX272	February 11, 2022	0.001	Passed	0.1800	Passed	
Bay View High School	2nd Floor Girls Wash Room tap 2	RVX289	February 11, 2022	-	Passed	0.0750	Passed	
Bay View High School	1st Floor Male Wash Room tap 1	RVX290	February 11, 2022	0.001	Passed	0.1300	Passed	
Bay View High School	Staff Wash Room tap	RVX291	February 11, 2022	-	Passed	0.1400	Passed	
Bay View High School	Class Room 1016 tap	RVX292	February 11, 2022	-	Passed	0.1600	Passed	
Bay View High School	Girls Locker Room 1031 tap	RVX294	February 11, 2022	-	Passed	0.1200	Passed	
Bay View High School	Boys Locker Room 1032 tap	RVX295	February 11, 2022	-	Passed	0.1300	Passed	
Bay View High School	Nutrition Lab 2055 tap 1	VSJ647	May 3, 2023	0.001	Passed	0.1000	Passed	
Bay View High School	Nutrition Lab 2055 tap 2	VSJ648	May 3, 2023	0.001	Passed	0.1100	Passed	
Bay View High School	Nutrition Lab 2055 tap 3	VSJ649	May 3, 2023	0.001	Passed	0.1100	Passed	
Bay View High School	Nutrition Lab 2055 tap 4	VSJ650	May 3, 2023	0.001	Passed	0.1100	Passed	
Bay View High School	2nd Floor Fountain 2	VSJ652	May 3, 2023	-	Passed	0.1100	Passed	
Bay View High School	Kitchen 2045 counter sink tap 1	VSJ653	May 3, 2023	0.001	Passed	0.1600	Passed	
Bay View High School	Kitchen 2045 back wall sink tap 2	VSJ654	May 3, 2023	0.001	Passed	0.1600	Passed	
Bay View High School	Kitchen 2045 double sink tap 3	VSJ655	May 3, 2023	-	Passed	0.1800	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Bay View High School	Kitchen 2045 sink by fridge tap 4	VSJ656	May 3, 2023	-	Passed	0.2400	Passed	
Bay View High School	Cafeteria Kitchen tap 1	VSJ657	May 3, 2023	0.001	Passed	0.1100	Passed	
Bay View High School	Cafeteria Kitchen tap 2	VSJ658	May 3, 2023	0.001	Passed	0.0960	Passed	
Bay View High School	Cafeteria Kitchen tap 3	VSJ659	May 3, 2023	0.001	Passed	0.1500	Passed	
Bay View High School	Cafeteria Kitchen Prep tap	VSJ660	May 3, 2023	0.001	Passed	0.1000	Passed	
Bay View High School	Cafeteria Kitchen Wash tap	VSJ661	May 3, 2023	0.004	Passed	0.1200	Passed	
Bay View High School	Fountain by Cafeteria	VSJ662	May 3, 2023	0.001	Passed	0.1000	Passed	
Bay View High School	Fountain by Gym	VSJ663	May 3, 2023	-	Passed	0.1200	Passed	
Bay View High School	Fountain by Room 1033	VSJ664	May 3, 2023	0.001	Passed	0.3000	Passed	
Bay View High School	Staff Room 1101 tap	VSJ665	May 3, 2023	0.001	Passed	0.1200	Passed	
Beaver Bank-Kinsac Elementary	Staff Room Male Wash Room	RWE760	February 15, 2022	0.001	Passed	0.0640	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 1 by Room 203	MUQ659	June 4, 2020	0.002	Passed	0.0740	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 1 by Room 201	MUQ664	June 4, 2020	0.003	Passed	0.1800	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 2 by Room 201	MUQ665	June 4, 2020	0.002	Passed	0.1300	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 3 by Room 201	MUQ666	June 4, 2020	0.001	Passed	0.0820	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 1 in Basement	MUQ667	June 4, 2020	0.002	Passed	0.0840	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 2 in Basement	MUQ671	June 4, 2020	0.004	Passed	0.0860	Passed	
Beaver Bank-Kinsac Elementary	Janitors Closet tap in Basement	MUQ672	June 4, 2020	0.001	Passed	0.0820	Passed	
Beaver Bank-Kinsac Elementary	Class Room 202 tap	MUQ674	June 4, 2020	0.001	Passed	0.1700	Passed	
Beaver Bank-Kinsac Elementary	Class Room 203 tap	MUQ675	June 4, 2020	0.003	Passed	0.1900	Passed	
Beaver Bank-Kinsac Elementary	Class Room 217 tap	MUQ680	June 4, 2020	0.002	Passed	0.0410	Passed	
Beaver Bank-Kinsac Elementary	Staff Wash Room tap by Room 217	MUQ681	June 4, 2020	0.001	Passed	0.0260	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 5 by Room 204	MUQ686	June 4, 2020	0.004	Passed	0.0650	Passed	
Beaver Bank-Kinsac Elementary	Janitors Closet 204 tap	MUQ687	June 4, 2020	0.002	Passed	0.0240	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 1 by Room 204	MUQ688	June 4, 2020	0.003	Passed	0.0570	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 2 by Room 204	MUQ689	June 4, 2020	0.001	Passed	0.0520	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 3 by Room 204	MUQ690	June 4, 2020	0.001	Passed	0.0250	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 4 by Room 204	MUQ691	June 4, 2020	0.004	Passed	0.0390	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 5 by Room 204	MUQ692	June 4, 2020	0.002	Passed	0.0620	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 2 by Room 203	RWE755	February 15, 2022	-	Passed	0.0870	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 3 by Room 203	RWE756	February 15, 2022	-	Passed	0.0810	Passed	
Beaver Bank-Kinsac Elementary	Janitors Closet tap by Boys Wash Room	RWE757	February 15, 2022	-	Passed	0.0220	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 1 in Basement	RWE758	February 15, 2022	-	Passed	0.0810	Passed	
Beaver Bank-Kinsac Elementary	Main Office Staff Wash Room tap	RWE759	February 15, 2022	-	Passed	0.0750	Passed	
Beaver Bank-Kinsac Elementary	Staff Room Female Wash Room	RWE761	February 15, 2022	-	Passed	0.0580	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 1 by Room 204	RWE762	February 15, 2022	-	Passed	0.0240	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 2 by Room 204	RWE763	February 15, 2022	-	Passed	0.0240	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 3 by Room 204	RWE764	February 15, 2022	-	Passed	0.0260	Passed	
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 4 by Room 204	RWE765	February 15, 2022	-	Passed	0.0240	Passed	
Beaver Bank-Kinsac Elementary	Fountain by Janitors Closet	WDJ080	June 20, 2023	-	Passed	0.0580	Passed	
Beaver Bank-Kinsac Elementary	Fountain in Basement by Wash Rooms	WDJ081	June 20, 2023	-	Passed	0.0590	Passed	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 2 in Basement	WDJ082	June 20, 2023	-	Passed	0.0360	Passed	Tap remediated
Beaver Bank-Kinsac Elementary	Staff Room tap	WDJ083	June 20, 2023	-	Passed	0.0220	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Beaver Bank-Kinsac Elementary	Fountain by Boys Wash Room	WDJ084	June 20, 2023	-	Passed	0.0250	Passed	
Beaver Bank-Kinsac Elementary	Breakfast Club Room tap in Basement	WDJ085	June 20, 2023	-	Passed	0.0270	Passed	
Beaver Bank-Monarch Drive Elementary	2nd Floor Girls Wash Room tap 1	MUN107	June 4, 2020	0.003	Passed	0.1900	Passed	
Beaver Bank-Monarch Drive Elementary	2nd Floor Girls Wash Room tap 2	MUN108	June 4, 2020	0.002	Passed	0.4800	Passed	
Beaver Bank-Monarch Drive Elementary	2nd Floor Girls Wash Room tap 3	MUN109	June 4, 2020	0.002	Passed	0.2600	Passed	
Beaver Bank-Monarch Drive Elementary	Janitors Closet 210 tap	MUN113	June 4, 2020	0.001	Passed	0.0200	Passed	
Beaver Bank-Monarch Drive Elementary	Class Room 122 tap	MUN114	June 4, 2020	0.002	Passed	0.0130	Passed	
Beaver Bank-Monarch Drive Elementary	Class Room tap Room 124	MUN117	June 4, 2020	0.001	Passed	0.0280	Passed	
Beaver Bank-Monarch Drive Elementary	Class Room tap Room 123	MUN118	June 4, 2020	0.004	Passed	0.0039	Passed	
Beaver Bank-Monarch Drive Elementary	Class Room 121 tap	MUN120	June 4, 2020	0.002	Passed	0.0064	Passed	
Beaver Bank-Monarch Drive Elementary	Class Room 101 tap	MUN136	June 4, 2020	0.001	Passed	0.0120	Passed	
Beaver Bank-Monarch Drive Elementary	Class Room 104 tap	MUN137	June 4, 2020	0.002	Passed	0.0052	Passed	
Beaver Bank-Monarch Drive Elementary	Staff Room Wash Room 1 tap	MUN139	June 4, 2020	0.001	Passed	0.4300	Passed	
Beaver Bank-Monarch Drive Elementary	Staff Room Wash Room 2 tap	MUN140	June 4, 2020	0.003	Passed	0.4100	Passed	
Beaver Bank-Monarch Drive Elementary	Janitors Closet tap by Gym	MUN189	June 4, 2020	0.001	Passed	0.0082	Passed	
Beaver Bank-Monarch Drive Elementary	Girls Change Room tap	MUN191	June 4, 2020	0.002	Passed	0.0056	Passed	
Beaver Bank-Monarch Drive Elementary	Boys Change Room tap	MUN192	June 4, 2020	0.004	Passed	0.0160	Passed	
Beaver Bank-Monarch Drive Elementary	Art Room 205B tap	RWE852	February 15, 2022	-	Passed	0.0610	Passed	
Beaver Bank-Monarch Drive Elementary	2nd Floor Boys Wash Room tap 1	RWE853	February 15, 2022	-	Passed	0.0320	Passed	
Beaver Bank-Monarch Drive Elementary	2nd Floor Boys Wash Room tap 2	RWE854	February 15, 2022	-	Passed	0.0330	Passed	
Beaver Bank-Monarch Drive Elementary	2nd Floor Boys Wash Room tap 3	RWE855	February 15, 2022	-	Passed	0.0320	Passed	
Beaver Bank-Monarch Drive Elementary	Class Room 124 Wash Room tap	RWE856	February 15, 2022	0.001	Passed	0.0069	Passed	
Beaver Bank-Monarch Drive Elementary	Class Room 122 Wash Room tap	RWE857	February 15, 2022	0.001	Passed	0.0083	Passed	
Beaver Bank-Monarch Drive Elementary	Girls Wash Room tap 1 by Room 121	RWE861	February 15, 2022	0.003	Passed	0.0180	Passed	
Beaver Bank-Monarch Drive Elementary	Girls Wash Room tap 2 by Room 121	RWE867	February 15, 2022	0.001	Passed	0.0300	Passed	
Beaver Bank-Monarch Drive Elementary	Girls Wash Room tap 3 by Room 121	RWE868	February 15, 2022	0.001	Passed	0.0980	Passed	
Beaver Bank-Monarch Drive Elementary	Music Room 109 tap	RWE869	February 15, 2022	0.001	Passed	0.0120	Passed	
Beaver Bank-Monarch Drive Elementary	Library Room tap	XKK231	October 26, 2023	0.001	Passed	0.0250	Passed	Tap remediated
Beaver Bank-Monarch Drive Elementary	Fountain by Machine Shop Room	WDJ165	June 15, 2023	0.001	Passed	0.0051	Passed	
Beaver Bank-Monarch Drive Elementary	Fountain by Room 123	WDJ166	June 15, 2023	-	Passed	0.0016	Passed	
Beaver Bank-Monarch Drive Elementary	Boys Wash Room tap 1 by Mechanical Room	WDJ167	June 15, 2023	0.001	Passed	0.0043	Passed	Tap remediated
Beaver Bank-Monarch Drive Elementary	Boys Wash Room tap 2 by Mechanical Room	WDJ168	June 15, 2023	0.002	Passed	0.0087	Passed	Tap remediated
Beaver Bank-Monarch Drive Elementary	Boys Wash Room tap 3 by Mechanical Room	WDJ169	June 15, 2023	0.001	Passed	0.0092	Passed	Tap remediated
Beaver Bank-Monarch Drive Elementary	Fountain by Gym	WDJ170	June 15, 2023	-	Passed	0.0160	Passed	
Beaver Bank-Monarch Drive Elementary	Canteen Room tap	WDJ171	June 15, 2023	-	Passed	0.0006	Passed	
Beaver Bank-Monarch Drive Elementary	Main Office Sick Room tap	WDJ172	June 15, 2023	-	Passed	0.0014	Passed	
Beaver Bank-Monarch Drive Elementary	Staff Kitchen tap	WDJ173	June 15, 2023	-	Passed	0.0009	Passed	
Beaver Bank-Monarch Drive Elementary	Fountain by Room 224	WDJ174	June 15, 2023	-	Passed	-	Passed	
Beaver Bank-Monarch Drive Elementary	Fountain by Girls Wash Room	WDJ175	June 15, 2023	-	Passed	-	Passed	
Bedford South School	Class Room 1014 tap	MYW981	June 25, 2020	0.001	Passed	0.1800	Passed	
Bedford South School	Class Room 1013 tap Room 1013	MYW982	June 25, 2020	0.003	Passed	0.2700	Passed	
Bedford South School	Gender Neutral Wash Room 1016 tap	MYW983	June 25, 2020	0.004	Passed	0.2600	Passed	
Bedford South School	Class Room 1012 tap	MYW984	June 25, 2020	-	Passed	0.1600	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Bedford South School	Class Room 1011 tap	MYW985	June 25, 2020	0.001	Passed	0.0970	Passed	
Bedford South School	Class Room 1027 tap	MYW986	June 25, 2020	-	Passed	0.1600	Passed	
Bedford South School	Class Room 1026 tap	MYW987	June 25, 2020	-	Passed	0.1900	Passed	
Bedford South School	Class Room 1025 tap	MYW988	June 25, 2020	-	Passed	0.1800	Passed	
Bedford South School	Class Room Wash Room 1029 tap	MYW989	June 25, 2020	0.001	Passed	0.3400	Passed	
Bedford South School	Class Room 1021 tap	MYW990	June 25, 2020	-	Passed	0.1700	Passed	
Bedford South School	Class Room 1034 tap	MYX068	June 25, 2020	0.001	Passed	0.2600	Passed	
Bedford South School	Class Room 1033 tap	MYX069	June 25, 2020	-	Passed	0.2300	Passed	
Bedford South School	Gender Neutral Wash Room 1036 tap	MYX070	June 25, 2020	0.001	Passed	0.1600	Passed	
Bedford South School	Class Room 1032 tap	MYX071	June 25, 2020	-	Passed	0.1500	Passed	
Bedford South School	Class Room 1031 tap	MYX072	June 25, 2020	0.002	Passed	0.3100	Passed	
Bedford South School	Boys Locker Room 1060 tap 1	MYX074	June 25, 2020	0.002	Passed	0.2000	Passed	
Bedford South School	Girls Locker Room 1057 tap 1	MYX076	June 25, 2020	0.004	Passed	0.2500	Passed	
Bedford South School	Girls Locker Room 1057 tap 2	MYX077	June 25, 2020	0.005	Passed	0.3100	Passed	
Bedford South School	Gym Office Wash Room tap	MYX141	June 25, 2020	0.001	Passed	0.2700	Passed	
Bedford South School	Arts Room 1069 tap 1	MYX142	June 25, 2020	-	Passed	0.0240	Passed	
Bedford South School	Arts Room 1069 tap 2	MYX143	June 25, 2020	0.001	Passed	0.0500	Passed	
Bedford South School	Gender Neutral Wash Room 1068 tap	MYX144	June 25, 2020	0.002	Passed	0.1600	Passed	
Bedford South School	Gender Neutral Wash Room 1067 tap	MYX145	June 25, 2020	-	Passed	0.1300	Passed	
Bedford South School	Janitors Closet 1066 tap	MYX146	June 25, 2020	-	Passed	0.0940	Passed	
Bedford South School	Storage Room 1079 tap	MYX147	May 25, 2023	0.004	Passed	0.1500	Passed	
Bedford South School	Main Office Wash Room 1081 tap	MYX168	June 25, 2020	-	Passed	0.1100	Passed	
Bedford South School	Library Work Room 1081 tap	MYX169	June 25, 2020	0.001	Passed	0.1700	Passed	
Bedford South School	Boys Wash Room 1043 tap 1	MYX170	June 25, 2020	-	Passed	0.1100	Passed	
Bedford South School	Boys Wash Room 1043 tap 2	MYX171	June 25, 2020	0.001	Passed	0.1100	Passed	
Bedford South School	Boys Wash Room 1043 tap 3	MYX172	June 25, 2020	0.001	Passed	0.1300	Passed	
Bedford South School	Boys Wash Room 1043 tap 4	MYX173	June 25, 2020	-	Passed	0.1200	Passed	
Bedford South School	Janitors Closet 1046 tap	MYX174	June 25, 2020	-	Passed	0.0610	Passed	
Bedford South School	Gender Neutral Wash Room 1047 tap	MYX175	June 25, 2020	0.001	Passed	0.2200	Passed	
Bedford South School	Girls Wash Room 1048 tap 1	MYX191	June 25, 2020	0.001	Passed	0.1400	Passed	
Bedford South School	Girls Wash Room 1048 tap 2	MYX192	June 25, 2020	0.003	Passed	0.2900	Passed	
Bedford South School	Girls Wash Room 1048 tap 3	MYX193	June 25, 2020	0.002	Passed	0.2000	Passed	
Bedford South School	Girls Wash Room 1048 tap 4	MYX194	June 25, 2020	0.001	Passed	0.1400	Passed	
Bedford South School	Class Room 2039 tap 1	MYX196	June 25, 2020	-	Passed	0.1800	Passed	
Bedford South School	Class Room 2039 tap 2	MYX197	June 25, 2020	0.001	Passed	0.1800	Passed	
Bedford South School	Class Room 2038 tap	MYX198	June 25, 2020	0.001	Passed	0.6700	Passed	
Bedford South School	Class Room 2037 tap	MYX199	June 25, 2020	0.001	Passed	0.2700	Passed	
Bedford South School	Class Room 2036 tap 1	MYX200	June 25, 2020	0.001	Passed	0.1600	Passed	
Bedford South School	Class Room 2036 tap 2	MYX221	June 25, 2020	0.001	Passed	0.1900	Passed	
Bedford South School	Class Room 2029 tap 1	MYX222	June 25, 2020	0.001	Passed	0.1400	Passed	
Bedford South School	Class Room 2029 tap 2	MYX223	June 25, 2020	0.001	Passed	0.2500	Passed	
Bedford South School	Class Room 2029 tap 4	MYX225	June 25, 2020	0.001	Passed	0.5300	Passed	
Bedford South School	Class Room 2028 tap 1	MYX226	June 25, 2020	0.001	Passed	0.5300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Bedford South School	Class Room 2028 tap 2	MYX227	June 25, 2020	0.003	Passed	0.6000	Passed	
Bedford South School	Class Room 2028 tap 3	MYX228	June 25, 2020	0.001	Passed	0.2000	Passed	
Bedford South School	Class Room 2028 tap 4	MYX229	June 25, 2020	0.001	Passed	0.2200	Passed	
Bedford South School	Class Room 2027 tap	MYX230	June 25, 2020	0.001	Passed	0.1800	Passed	
Bedford South School	Class Room 2026 tap	MYX242	June 25, 2020	0.001	Passed	0.2600	Passed	
Bedford South School	Tech Ed Room 2071 tap	MYX247	June 25, 2020	0.001	Passed	0.2200	Passed	
Bedford South School	Staff Room Wash Room 2073 tap	MYX248	June 25, 2020	-	Passed	0.0370	Passed	
Bedford South School	Staff Room Wash Room 2074 tap	MYX250	June 25, 2020	-	Passed	0.0290	Passed	
Bedford South School	Class Room 2049 tap	MYX251	June 25, 2020	0.001	Passed	0.2200	Passed	
Bedford South School	Class Room 2047 tap	MYX291	June 25, 2020	-	Passed	0.3700	Passed	
Bedford South School	Class Room 2046 tap	MYX292	June 25, 2020	-	Passed	0.1600	Passed	
Bedford South School	Janitors Closet 2064 tap	MYX294	June 25, 2020	-	Passed	0.0620	Passed	
Bedford South School	Gender Neutral Wash Room 2065 tap	MYX295	June 25, 2020	0.001	Passed	0.1800	Passed	
Bedford South School	Girls Wash Room 2056 tap 2	MYX298	June 25, 2020	0.002	Passed	0.2400	Passed	
Bedford South School	Girls Wash Room 2056 tap 3	MYX299	June 25, 2020	0.003	Passed	0.3100	Passed	
Bedford South School	Girls Wash Room 2056 tap 4	MYX300	June 25, 2020	0.002	Passed	0.2300	Passed	
Bedford South School	Fountain by Room 1061	VXQ646	May 25, 2023	-	Passed	0.0460	Passed	
Bedford South School	Cafeteria/Kitchen Room 1080 tap 1	VXQ647	May 25, 2023	-	Passed	0.0310	Passed	
Bedford South School	Cafeteria/Kitchen Room 1080 tap 2	VXQ648	May 25, 2023	-	Passed	0.0230	Passed	
Bedford South School	Cafeteria/Kitchen Room 1080 tap 3	VXQ649	May 25, 2023	-	Passed	0.0370	Passed	
Bedford South School	Cafeteria/Kitchen Room 1080 tap 4	VXQ650	May 25, 2023	-	Passed	0.0220	Passed	
Bedford South School	Health Room tap	VXQ651	May 25, 2023	-	Passed	0.0350	Passed	
Bedford South School	Fountain by Room 1048	VXQ652	May 23, 2023	-	Passed	0.0760	Passed	
Bedford South School	Boys Locker Room 1060 tap 2	VXQ653	May 25, 2023	-	Passed	0.1800	Passed	Tap remediated
Bedford South School	Staff Room 2075 tap	VXQ654	May 25, 2023	-	Passed	0.1100	Passed	
Bedford South School	Fountain by Room 2065	VXQ655	May 23, 2023	-	Passed	0.0270	Passed	
Bedford South School	Class Room 2048 tap	VXQ656	May 25, 2023	-	Passed	0.1300	Passed	Tap remediated
Bedford South School	Fountain by Room 2029	VXQ657	May 23, 2023	-	Passed	0.0980	Passed	
Bedford South School	Class Room 2029 tap 3	VXQ658	May 25, 2023	-	Passed	0.0540	Passed	Tap remediated
Bedford South School	Boys Wash Room 2055 tap 1	VXQ659	May 25, 2023	-	Passed	0.1000	Passed	Tap remediated
Bedford South School	Boys Wash Room 2055 tap 2	VXQ660	May 25, 2023	-	Passed	0.1000	Passed	Tap remediated
Bedford South School	Boys Wash Room 2055 tap 3	VXQ661	May 25, 2023	-	Passed	0.0930	Passed	Tap remediated
Bedford South School	Boys Wash Room 2055 tap 4	VXQ662	May 25, 2023	0.001	Passed	0.0840	Passed	Tap remediated
Bedford South School	Girls Wash Room 2056 tap 1	VXQ663	May 25, 2023	-	Passed	0.0830	Passed	Tap remediated
Bedford South School	Home Ec. Room 2012 tap 1	VXQ664	May 25, 2023	-	Passed	0.0250	Passed	
Bedford South School	Home Ec. Room 2012 tap 2	VXQ665	May 25, 2023	-	Passed	0.0280	Passed	
Bedford South School	Home Ec. Room 2012 tap 3	VXQ666	May 25, 2023	-	Passed	0.0210	Passed	
Bedford South School	Home Ec. Room 2012 tap 4	VXQ667	May 25, 2023	-	Passed	0.0210	Passed	
Bedford South School	Modular Janitors Closet tap	XCE567	September 21, 2023	-	Passed	0.0130	Passed	
Bedford South School	Modular Girls Wash Room tap 1	XCE568	September 21, 2023	-	Passed	0.0160	Passed	
Bedford South School	Modular Girls Wash Room tap 2	XCE569	September 21, 2023	-	Passed	0.0190	Passed	
Bedford South School	Modular Girls Wash Room tap 3	XCE570	September 21, 2023	-	Passed	0.0200	Passed	
Bedford South School	Modular Boys Wash Room tap 1	XCE571	September 21, 2023	-	Passed	0.0220	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Bedford South School	Modular Boys Wash Room tap 2	XCE572	September 21, 2023	-	Passed	0.0280	Passed	
Bedford South School	Fountain in Modular	XCE573	September 21, 2023	-	Passed	0.0022	Passed	
Bedford South School	Modular Gender Neutral Wash Room tap	XCE574	September 21, 2023	-	Passed	0.0320	Passed	
Bedford South School	Modular Staff Room tap	XCE575	September 21, 2023	0.001	Passed	0.0450	Passed	
Bedford South School	Modular Staff Wash Room tap	XCE576	September 21, 2023	-	Passed	0.0340	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Staff Room Gender Neutral Wash Room 1 tap	MUK854	June 3, 2020	0.001	Passed	0.0370	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Staff Room Gender Neutral Wash Room 2 tap	MUK855	June 3, 2020	0.002	Passed	0.0420	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Class Room 104 tap	MUK857	June 3, 2020	0.001	Passed	0.2800	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Class Room 102 tap	MUK859	June 3, 2020	0.003	Passed	0.2100	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Class Room 101 tap	MUK860	June 3, 2020	0.001	Passed	0.4400	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Class Room 113 tap	MUK875	June 3, 2020	0.003	Passed	0.1500	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Class Room 110 tap	MUK879	June 3, 2020	0.002	Passed	0.2300	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Gym Gender Neutral Wash Room 1 tap	TCM 786	July 5, 2022	0.002	Passed	0.1400	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Gender Neutral Wash Room 131 tap	TCM782	July 5, 2022	0.004	Passed	0.0990	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Janitors Closet tap by Room 131	TCM783	July 5, 2022	-	Passed	0.0230	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Music Room 108 tap	TCM785	July 5, 2022	0.002	Passed	0.0830	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Gym Office Wash Room tap	XKK001	October 26, 2023	0.001	Passed	0.0970	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Gym Gender Neutral Wash Room 2 tap	TCM788	July 5, 2022	0.003	Passed	0.1400	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	2nd Floor Janitors Closet tap	TCM850	June 3, 2020	0.005	Passed	0.0400	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Girls Wash Room 212 tap 1	VQU352	April 26, 2023	0.001	Passed	0.0049	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Girls Wash Room 212 tap 2	VQU353	April 26, 2023	0.001	Passed	0.0031	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Girls Wash Room 212 tap 3	VQU354	April 26, 2023	0.002	Passed	0.0033	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Girls Wash Room 212 tap 4	VQU354	April 26, 2023	0.002	Passed	0.0550	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Boys Wash Room 216 tap 1	VQU356	April 26, 2023	0.002	Passed	0.0055	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Boys Wash Room 216 tap 2	VQU357	April 26, 2023	0.001	Passed	0.0030	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Boys Wash Room 216 tap 3	VQU358	April 26, 2023	0.001	Passed	0.0420	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Boys Wash Room 216 tap 4	VQU359	April 26, 2023	-	Passed	0.0013	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Fountain by Room 212	VQU360	April 26, 2023	-	Passed	0.0005	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Fountain by Room 216	VQU361	April 26, 2023	-	Passed	0.0007	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Staff Room Kitchen tap	VRZ920	May 2, 2023	0.001	Passed	0.1200	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Fountain by Staff Room	VRZ921	May 2, 2023	-	Passed	0.0031	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Cafeteria/Kitchen double compartment sink tap	VRZ922	May 2, 2023	0.001	Passed	0.1000	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Cafeteria/Kitchen hand washing sink tap	VRZ923	May 2, 2023	0.005	Passed	0.5900	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Fountain by Janitors Closet	VRZ924	May 2, 2023	-	Passed	0.0005	Passed	
Beechville-Lakeside-Timberlea Junior Elementary	Boys Wash Room 109 tap 1	VRZ925	May 2, 2023	-	Passed	0.0220	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Boys Wash Room 109 tap 2	VRZ926	May 2, 2023	-	Passed	0.0330	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Boys Wash Room 109 tap 3	VRZ927	May 2, 2023	0.001	Passed	0.0580	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Boys Wash Room 109 tap 4	VRZ928	May 2, 2023	0.001	Passed	0.0800	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Girls Wash Room 107 tap 1	VRZ954	May 2, 2023	0.001	Passed	0.0520	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Girls Wash Room 107 tap 2	VRZ955	May 2, 2023	-	Passed	0.0230	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Girls Wash Room 107 tap 3	VRZ956	May 2, 2023	0.001	Passed	0.0550	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Girls Wash Room 107 tap 4	VRZ957	May 2, 2023	0.001	Passed	0.0310	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Room 100 Gender Neutral Wash Room tap	VRZ958	May 2, 2023	-	Passed	0.0460	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Beechville-Lakeside-Timberlea Junior Elementary	Room 105 Kitchen tap	VRZ959	May 2, 2023	0.001	Passed	0.0200	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Class Room 111 tap	VRZ960	May 2, 2023	0.001	Passed	0.0970	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Class Room 112 tap	XKK002	October 26, 2023	0.001	Passed	0.0180	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Class Room 114 tap	VRZ962	May 2, 2023	0.002	Passed	0.1600	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Class Room 116 tap	VRZ963	May 2, 2023	0.002	Passed	0.2600	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Room 132 Gender Neutral Wash Room tap	VRZ964	May 2, 2023	0.003	Passed	0.0420	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Room 133 Gender Neutral Wash Room tap	VRZ966	May 2, 2023	-	Passed	0.0420	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Art Room 207 tap 1	VRZ967	May 2, 2023	-	Passed	0.0260	Passed	Tap remediated
Beechville-Lakeside-Timberlea Junior Elementary	Art Room 207 tap 2	VRZ968	May 2, 2023	0.001	Passed	0.0450	Passed	Tap remediated
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Female Wash Room tap 1	TCM743	July 5, 2022	-	Passed	0.0170	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Female Wash Room tap 2	TCM744	July 5, 2022	0.001	Passed	0.0180	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Male Wash Room tap	TCM745	July 5, 2022	-	Passed	0.0140	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Kitchen tap	VQU709	April 26, 2023	-	Passed	0.0270	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Boys Wash Room tap 1 by Library	TCM746	July 5, 2022	0.001	Passed	0.0600	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Boys Wash Room tap 2 by Library	TCM747	July 5, 2022	0.001	Passed	0.0580	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Boys Wash Room tap 3 by Library	TCM748	July 5, 2022	-	Passed	0.0450	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Janitors Closet tap by Library	TCM749	July 5, 2022	0.001	Passed	0.0450	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Girls Wash Room tap 1 by Room 203	TCM751	July 5, 2022	0.002	Passed	0.0670	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Girls Wash Room tap 2 by Room 203	TCM752	July 5, 2022	0.000	Passed	0.0630	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Girls Wash Room tap 3 by Room 203	TCM753	July 5, 2022	0.001	Passed	0.0580	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Girls Wash Room tap 4 by Room 203	TCM754	July 5, 2022	0.001	Passed	0.0530	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	French Room 200 tap	TCM758	July 5, 2022	-	Passed	0.0610	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Fountain by 2nd Floor Janitors Closet	VQU710	April 26, 2023	-	Passed	0.0270	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Sewing Room tap	VQU711	April 26, 2023	0.002	Passed	0.1900	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Cooking Room tap 1	XKJ993	October 26, 2023	0.002	Passed	0.1400	Passed	Tap remediated
Beechville-Lakeside-Timberlea Senior Elementary	Cooking Room tap 2	VQU713	April 26, 2023	0.001	Passed	0.1400	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Boys Change Room tap 1	VQU718	April 26, 2023	-	Passed	0.0630	Passed	Tap remediated
Beechville-Lakeside-Timberlea Senior Elementary	Boys Change Room tap 2	TCM763	July 5, 2022	0.001	Passed	0.0640	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Staff Wash Room tap by Room 105	TCM765	July 5, 2022	-	Passed	0.0220	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Staff Wash Room tap by Room 104	TCM766	July 5, 2022	-	Passed	0.0190	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Female Wash Room tap 1	TCM743	July 5, 2022	-	Passed	0.0170	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Female Wash Room tap 2	TCM744	July 5, 2022	0.001	Passed	0.0180	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Male Wash Room tap	TCM745	July 5, 2022	-	Passed	0.0140	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room tap	VQU709	April 26, 2023	-	Passed	0.0270	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Girls Change Room tap 1	TCM767	July 5, 2022	-	Passed	0.0610	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Girls Change Room tap 2	TCM768	July 5, 2022	-	Passed	0.0360	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Metal Room sink tap	TCM769	July 5, 2022	-	Passed	0.1800	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Art Room multi tap sink tap 1	TCM770	July 5, 2022	0.001	Passed	0.0620	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Art Room multi tap sink tap 2	TCM771	July 5, 2022	0.001	Passed	0.0590	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Art Room multi tap sink tap 3	TCM772	July 5, 2022	0.001	Passed	0.0760	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Art Room multi tap sink tap 4	TCM773	July 5, 2022	0.001	Passed	0.0660	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	1st Floor Janitors Closet tap	TCM774	July 5, 2022	0.001	Passed	0.1000	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Fountain by Room 105	VQU714	April 26, 2023	-	Passed	0.0012	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Beechville-Lakeside-Timberlea Senior Elementary	Cafeteria/Kitchen hand washing sink tap	VQU715	April 26, 2023	0.001	Passed	0.0290	Passed	Tap remediated
Beechville-Lakeside-Timberlea Senior Elementary	Cafeteria/Kitchen sink tap	VQU716	April 26, 2023	0.002	Passed	0.0580	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Cafeteria/Kitchen double compartment sink tap	VQU717	April 26, 2023	0.004	Passed	0.5300	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Fountain in Modular	VQU720	April 26, 2023	-	Passed	0.0230	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Modular Staff Room tap	VQU721	April 26, 2023	-	Passed	0.0120	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Modular Staff Room Wash Room tap	VQU722	April 26, 2023	-	Passed	0.0110	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Modular Boys Wash Room tap 1	VQU723	April 26, 2023	-	Passed	0.0100	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Modular Boys Wash Room tap 2	VQU724	April 26, 2023	-	Passed	0.0100	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Modular Girls Wash Room tap 1	VQU725	April 26, 2023	-	Passed	0.0110	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Modular Girls Wash Room tap 2	VQU726	April 26, 2023	-	Passed	0.0100	Passed	
Beechville-Lakeside-Timberlea Senior Elementary	Modular Accessible Wash Room tap	VQU727	April 26, 2023	-	Passed	0.0100	Passed	
Bel Ayr Elementary	Staff Room 120 Wash Room 1 tap	XGE449	October 11, 2023	-	Passed	0.0200	Passed	Tap remediated
Bel Ayr Elementary	Staff Room 120 tap	XGE448	October 11, 2023	-	Passed	0.0180	Passed	
Bel Ayr Elementary	Staff Room 120 Wash Room 2 tap	MXJ927	June 18, 2020	0.001	Passed	0.0590	Passed	
Bel Ayr Elementary	Boys Wash Room tap 1 by Room 124	XGE440	October 11, 2023	-	Passed	0.0150	Passed	Tap remediated
Bel Ayr Elementary	Boys Wash Room tap 2 by Room 124	XGE441	October 11, 2023	-	Passed	0.0123	Passed	Tap remediated
Bel Ayr Elementary	Boys Wash Room tap 3 by Room 124	MXJ931	June 18, 2020	0.002	Passed	0.0570	Passed	
Bel Ayr Elementary	Janitors Closet 124 tap	XGE439	October 11, 2023	-	Passed	0.0120	Passed	Tap remediated
Bel Ayr Elementary	Girls Wash Room tap 1 by Room 124	MXJ933	June 18, 2020	0.003	Passed	0.0840	Passed	
Bel Ayr Elementary	Girls Wash Room tap 2 by Room 124	XGE442	October 11, 2023	-	Passed	0.0180	Passed	Tap remediated
Bel Ayr Elementary	Girls Wash Room tap 3 by Room 124	MXJ935	June 18, 2020	0.003	Passed	0.0410	Passed	
Bel Ayr Elementary	Learning Centre Wash Room tap	MXJ936	June 18, 2020	0.001	Passed	0.0540	Passed	
Bel Ayr Elementary	Girls Wash Room tap 1 by Room 122	MXJ937	June 18, 2020	0.001	Passed	0.3200	Passed	
Bel Ayr Elementary	Girls Wash Room tap 2 by Room 122	MXJ938	June 18, 2020	-	Passed	0.0510	Passed	
Bel Ayr Elementary	Boys Wash Room tap 1 by Room 122	XGE445	October 11, 2023	0.005	Exceeded	0.0190	Passed	Hand washing only
Bel Ayr Elementary	Boys Wash Room tap 2 by Room 122	MXJ940	June 18, 2020	0.002	Passed	0.0620	Passed	
Bel Ayr Elementary	Boys Wash Room tap 3 by Room 122	MXJ941	June 18, 2020	0.001	Passed	0.0510	Passed	
Bel Ayr Elementary	Janitors Closet 123 tap	MXJ944	June 18, 2020	0.002	Passed	0.1100	Passed	
Bel Ayr Elementary	Main Office 118 tap 1	XGE446	October 11, 2023	0.001	Passed	0.0340	Passed	
Bel Ayr Elementary	Main Office 118 tap 2	XGE447	October 11, 2023	0.001	Passed	0.0280	Passed	
Bel Ayr Elementary	Gym Storage Room tap	XGE450	October 11, 2023	0.012	Exceeded	0.0170	Passed	Hand washing only
Bel Ayr Elementary	Fountain by Room 112	XGE443	October 11, 2023	0.001	Passed	0.1300	Passed	
Bel Ayr Elementary	Fountain by Room 123	XGE444	October 11, 2023	0.001	Passed	0.0660	Passed	
Bell Park Academic Centre	Staff Room 218 tap	XCZ708	September 26, 2023	-	Passed	0.0440	Passed	
Bell Park Academic Centre	Staff Room 218 Male Wash Room tap	MYA896	June 22, 2020	0.004	Passed	0.3200	Passed	
Bell Park Academic Centre	Staff Room 218 Female Wash Room tap	MYA897	June 22, 2020	0.002	Passed	0.2300	Passed	
Bell Park Academic Centre	Fountain by Room 218	XCZ707	September 26, 2023	-	Passed	-	Passed	
Bell Park Academic Centre	Class Room 216 tap	RWW641	February 17, 2022	-	Passed	0.0310	Passed	
Bell Park Academic Centre	Girls Wash Room tap 1 by Room 206	MYA899	June 22, 2020	0.002	Passed	0.0650	Passed	
Bell Park Academic Centre	Girls Wash Room tap 2 by Room 206	MYA900	June 22, 2020	0.003	Passed	0.1400	Passed	
Bell Park Academic Centre	Girls Wash Room tap 3 by Room 206	XCZ709	September 26, 2023	-	Passed	0.0320	Passed	
Bell Park Academic Centre	Fountain by Room 206	XCZ713	September 26, 2023	-	Passed	-	Passed	
Bell Park Academic Centre	Boys Wash Room tap 1 by Room 205	XCZ710	September 26, 2023	-	Passed	0.0290	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Bell Park Academic Centre	Boys Wash Room tap 2 by Room 205	XCZ711	September 26, 2023	-	Passed	0.0280	Passed	
Bell Park Academic Centre	Boys Wash Room tap 3 by Room 205	XCZ712	September 26, 2023	-	Passed	0.0310	Passed	
Bell Park Academic Centre	Janitors Closet 203	MYA912	June 22, 2020	0.001	Passed	0.1300	Passed	
Bell Park Academic Centre	Class Room 101 tap	MYA913	June 22, 2020	0.003	Passed	0.1800	Passed	
Bell Park Academic Centre	Class Room 101 Wash Room tap	XCZ743	September 26, 2023	-	Passed	0.0430	Passed	
Bell Park Academic Centre	Fountain by Room 101	XCZ736	September 26, 2023	-	Passed	0.0008	Passed	
Bell Park Academic Centre	Class Room 102 tap	MYA915	June 22, 2020	0.001	Passed	0.4500	Passed	
Bell Park Academic Centre	Class Room 102 Wash Room tap	MYA916	June 22, 2020	0.001	Passed	0.1700	Passed	
Bell Park Academic Centre	Class Room 103 Wash Room tap	XCZ744	September 26, 2023	-	Passed	0.1000	Passed	
Bell Park Academic Centre	Fountain by Room 105	XCZ742	September 26, 2023	-	Passed	-	Passed	
Bell Park Academic Centre	Main Office tap	XCZ705	September 26, 2023	-	Passed	0.0480	Passed	
Bell Park Academic Centre	Staff Wash Room tap by Office	MYH195	June 23, 2020	0.001	Passed	0.1000	Passed	
Bell Park Academic Centre	Kitchen/Cafeteria hand washing tap	XCZ704	September 26, 2023	-	Passed	0.0530	Passed	
Bell Park Academic Centre	Kitchen/Cafeteria triple compartment tap 1	XCZ705	September 26, 2023	-	Passed	0.0450	Passed	
Bell Park Academic Centre	Kitchen/Cafeteria triple compartment tap 2	XCZ706	September 26, 2023	0.001	Passed	0.0450	Passed	
Bell Park Academic Centre	Girls Wash Room tap 1 by Office	XCZ739	September 26, 2023	-	Passed	0.0340	Passed	
Bell Park Academic Centre	Girls Wash Room tap 2 by Office	XCZ740	September 26, 2023	-	Passed	0.0490	Passed	
Bell Park Academic Centre	Girls Wash Room tap 3 by Office	XCZ741	September 26, 2023	-	Passed	0.0310	Passed	
Bell Park Academic Centre	Janitors Closet tap by Boys Wash Room	MYH202	June 23, 2020	0.001	Passed	0.0450	Passed	
Bell Park Academic Centre	Boys Wash Room tap 1 by Office	XCZ737	September 26, 2023	-	Passed	0.0380	Passed	
Bell Park Academic Centre	Boys Wash Room tap 2 by Office	XCZ738	September 26, 2023	-	Passed	0.0300	Passed	
BFEC - BPM	Gender Neutral Wash Room 107 tap	NZB942	October 22, 2020	0.001	Passed	0.0510	Passed	
BFEC - BPM	Staff Room 109 tap	XCZ957	September 26, 2023	-	Passed	0.0320	Passed	
BFEC - BPM	Staff Wash Room 110 tap	NZB940	October 22, 2020	0.001	Passed	0.0480	Passed	
BFEC - BPM	Staff Wash Room 111 tap	NZB941	October 22, 2020	0.001	Passed	0.0470	Passed	
BFEC - BPM	Class Room 124 tap	NZB932	October 22, 2020	-	Passed	0.0310	Passed	
BFEC - BPM	Food Lab 136 tap 1	XCZ959	September 26, 2023	-	Passed	0.0550	Passed	
BFEC - BPM	Food Lab 136 tap 2	XCZ960	September 26, 2023	-	Passed	0.0420	Passed	
BFEC - BPM	Food Lab 136 tap 3	XCZ961	September 26, 2023	-	Passed	0.0300	Passed	
BFEC - BPM	Food Lab 136 tap 4	XCZ962	September 26, 2023	-	Passed	0.0290	Passed	
BFEC - BPM	Janitors Closet 137 tap	NZB931	October 22, 2020	-	Passed	0.0180	Passed	
BFEC - BPM	Fountain by Wash Rooms	XCZ957	September 26, 2023	-	Passed	0.0280	Passed	
BFEC - BPM	Gender Neutral Wash Room 138 tap	OCN147	November 5, 2020	0.003	Passed	0.0890	Passed	
BFEC - BPM	Gender Neutral Wash Room 139 tap	OAM002	October 29, 2020	0.005	Passed	0.1700	Passed	
BFEC - BPM	Gender Neutral Wash Room 140 tap	OCN148	November 5, 2020	0.002	Passed	0.0840	Passed	
BFEC - BPM	Gender Neutral Wash Room 141 tap	OAM000	October 29, 2020	0.005	Passed	0.1600	Passed	
BFEC - BPM	Gender Neutral Wash Room 142 tap	OAM999	October 29, 2020	0.005	Passed	0.1700	Passed	
BFEC - BPM	Gender Neutral Wash Room 143 tap	OAM998	October 29, 2020	0.005	Passed	0.1700	Passed	
BFEC - BPM	Gender Neutral Wash Room 144 tap	NZB927	October 22, 2020	0.001	Passed	0.0450	Passed	
BFEC - Dartmouth	Class Room 17 tap	WHX468	July 6, 2023	0.001	Passed	0.1600	Passed	Tap remediated
BFEC - Dartmouth	1st Floor Boys Wash Room tap 1	SVW026	June 8, 2022	0.005	Exceeded	0.0490	Passed	Hand washing only
BFEC - Dartmouth	1st Floor Boys Wash Room tap 2	SVW027	June 8, 2022	0.008	Exceeded	0.0570	Passed	Hand washing only
BFEC - Dartmouth	1st Floor Boys Wash Room tap 3	WHX466	July 6, 2023	0.015	Exceeded	0.1600	Passed	Hand washing only

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
BFEC - Dartmouth	1st Floor Boys Wash Room tap 4	WHX467	July 6, 2023	0.010	Exceeded	0.1100	Passed	Hand washing only
BFEC - Dartmouth	1st Floor Fountain by Janitors Room	WHX462	July 6, 2023	0.002	Passed	0.1200	Passed	
BFEC - Dartmouth	1st Floor Janitors Closet tap	SVW003	June 8, 2022	-	Passed	0.0180	Passed	
BFEC - Dartmouth	1st Floor Girls Wash Room tap 1	WHX463	July 6, 2023	0.020	Exceeded	0.7900	Passed	Hand washing only
BFEC - Dartmouth	1st Floor Girls Wash Room tap 2	SVW005	June 8, 2022	0.017	Exceeded	0.5300	Passed	Hand washing only
BFEC - Dartmouth	1st Floor Girls Wash Room tap 3	WHX464	July 6, 2023	0.022	Exceeded	0.8900	Passed	Hand washing only
BFEC - Dartmouth	1st Floor Girls Wash Room tap 4	WHX465	July 6, 2023	0.030	Exceeded	0.4500	Passed	Hand washing only
BFEC - Dartmouth	Youth Centre tap 1	SVW009	June 8, 2022	0.003	Passed	0.3100	Passed	
BFEC - Dartmouth	Youth Centre tap 2	SVW010	June 8, 2022	0.001	Passed	0.1100	Passed	
BFEC - Dartmouth	Youth Centre tap 3	SVW012	June 8, 2022	0.170	Exceeded	1.4000	Passed	Hand washing only
BFEC - Dartmouth	Staff Room Male Wash Room tap	SVW012	June 8, 2022	0.003	Passed	0.0300	Passed	
BFEC - Dartmouth	Staff Room Female Wash Room tap	SVW013	June 8, 2022	0.003	Passed	0.0270	Passed	
BFEC - Dartmouth	Staff Wash Room tap by Youth Centre	SVW014	June 8, 2022	0.001	Passed	0.0260	Passed	
BFEC - Dartmouth	2nd Floor Boys Wash Room tap 1	SVW015	June 8, 2022	0.027	Exceeded	0.1100	Passed	Hand washing only
BFEC - Dartmouth	2nd Floor Boys Wash Room tap 2	SVW016	June 8, 2022	0.020	Exceeded	0.0770	Passed	Hand washing only
BFEC - Dartmouth	2nd Floor Boys Wash Room tap 3	SVW017	June 8, 2022	0.024	Exceeded	0.0890	Passed	Hand washing only
BFEC - Dartmouth	2nd Floor Boys Wash Room tap 4	SVW018	June 8, 2022	0.025	Exceeded	0.0980	Passed	Hand washing only
BFEC - Dartmouth	2nd Floor Janitors Closet tap by Wash Rooms	SVW019	June 8, 2022	0.004	Passed	0.0610	Passed	
BFEC - Dartmouth	2nd Floor Fountain By Wash Rooms	WHX469	July 6, 2023	-	Passed	0.0011	Passed	
BFEC - Dartmouth	2nd Floor Girls Wash Room tap 1	SVW021	June 8, 2022	0.094	Exceeded	0.5100	Passed	Hand washing only
BFEC - Dartmouth	2nd Floor Girls Wash Room tap 2	WHX470	July 6, 2023	0.001	Passed	0.0670	Passed	Tap remediated
BFEC - Dartmouth	2nd Floor Girls Wash Room tap 3	WHX124	July 2, 2023	0.002	Passed	0.1000	Passed	Tap remediated
BFEC - Dartmouth	2nd Floor Girls Wash Room tap 4	WHX125	July 2, 2023	0.025	Exceeded	0.4500	Passed	Hand washing only
BFEC - Dartmouth	2nd Floor Janitors Closet tap	SVW025	June 8, 2022	-	Passed	0.0350	Passed	
Bicentennial School	Principle Office Wash Room tap	MYR712	June 24, 2020	0.004	Passed	0.2300	Passed	
Bicentennial School	Office Wash Room 04 tap	MYR713	June 24, 2020	0.006	Exceeded	0.0520	Passed	Hand washing only
Bicentennial School	Janitors Closet tap by Room 18	MYR714	June 24, 2020	0.001	Passed	0.0330	Passed	
Bicentennial School	Boys Wash Room tap 1 by Library	MYR715	June 24, 2020	0.005	Passed	0.1800	Passed	
Bicentennial School	Boys Wash Room tap 2 by Library	MYR716	June 24, 2020	0.001	Passed	0.0300	Passed	
Bicentennial School	Boys Wash Room tap 3 by Library	MYR717	June 24, 2020	0.001	Passed	0.0330	Passed	
Bicentennial School	Boys Wash Room tap 4 by Library	MYR718	June 24, 2020	-	Passed	0.0310	Passed	
Bicentennial School	Boys Wash Room tap 5 by Library	MYR719	June 24, 2020	-	Passed	0.0320	Passed	
Bicentennial School	Boys Wash Room tap 6 by Library	MYR720	June 24, 2020	0.001	Passed	0.0360	Passed	
Bicentennial School	Boys Wash Room tap 7 by Library	MYR721	June 24, 2020	0.001	Passed	0.0310	Passed	
Bicentennial School	Boys Wash Room tap 8 by Library	MYR722	June 24, 2020	0.001	Passed	0.0350	Passed	
Bicentennial School	Staff Gender Neutral Wash Room tap by Library	MYR723	June 24, 2020	0.002	Passed	0.0610	Passed	
Bicentennial School	Fountain by Library	XBG940	September 15, 2023	-	Passed	0.1400	Passed	
Bicentennial School	Staff Gender Neutral Wash Room tap by Library	MYR725	June 24, 2020	0.001	Passed	0.0500	Passed	
Bicentennial School	Girls Wash Room tap 1 by Library	XBG941	September 15, 2023	0.001	Passed	0.0510	Passed	Tap remediated
Bicentennial School	Girls Wash Room tap 2 by Library	MYR727	June 24, 2020	0.002	Passed	0.0580	Passed	
Bicentennial School	Girls Wash Room tap 3 by Library	MYR728	June 24, 2020	0.001	Passed	0.0310	Passed	
Bicentennial School	Girls Wash Room tap 4 by Library	MYR729	June 24, 2020	-	Passed	0.0240	Passed	
Bicentennial School	Girls Wash Room tap 5 by Library	MYR730	June 24, 2020	-	Passed	0.0220	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Bicentennial School	Girls Wash Room tap 6 by Library	MYR731	June 24, 2020	-	Passed	0.0190	Passed	
Bicentennial School	Girls Wash Room tap 7 by Library	MYR732	June 24, 2020	-	Passed	0.0160	Passed	
Bicentennial School	Girls Wash Room tap 8 by Library	MYR733	June 24, 2020	-	Passed	0.0200	Passed	
Bicentennial School	Art Room 19 tap	MYR734	June 24, 2020	0.002	Passed	0.1000	Passed	
Bicentennial School	Learning Centre Wash Room 1 tap	MYR735	June 24, 2020	0.002	Passed	0.3700	Passed	
Bicentennial School	Learning Centre Wash Room 2 tap	MYR736	June 24, 2020	0.002	Passed	0.3200	Passed	
Bicentennial School	Janitors Closet tap by Class Room 2	MYR737	June 24, 2020	-	Passed	0.0170	Passed	
Bicentennial School	Boys Wash Room tap 1 by Class Room 1	MYR738	June 24, 2020	0.001	Passed	0.0190	Passed	
Bicentennial School	Boys Wash Room tap 2 by Class Room 1	XBG942	September 15, 2023	-	Passed	0.0170	Passed	Tap remediated
Bicentennial School	Gym Office Wash Room tap	XBG928	September 15, 2023	0.021	Exceeded	0.1800	Passed	Hand washing only
Bicentennial School	Fountain by Gym Office	XBG938	September 15, 2023	-	Passed	0.0013	Passed	
Bicentennial School	Fountain by Gym	XBG937	September 15, 2023	-	Passed	0.0560	Passed	
Bicentennial School	Excel Room tap by Room 31	XBG929	September 15, 2023	-	Passed	0.0210	Passed	
Bicentennial School	Janitors Closet tap by Room 9	MYR747	June 24, 2020	0.001	Passed	0.0610	Passed	
Bicentennial School	Administrative Office tap	XBG943	September 15, 2023	-	Passed	0.0660	Passed	
Bicentennial School	Administrative Assistant Wash Room tap	MYR751	June 24, 2020	0.003	Passed	0.2000	Passed	
Bicentennial School	Science Lab tap 1 Room 27	MYR752	June 24, 2020	0.180	Exceeded	0.7400	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 2 Room 27	MYR753	June 24, 2020	0.074	Exceeded	1.0000	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 3 Room 27	MYR754	June 24, 2020	0.120	Exceeded	1.1000	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 4 Room 27	MYR755	June 24, 2020	0.052	Exceeded	1.0000	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 5 Room 27	MYR756	June 24, 2020	0.023	Exceeded	0.8500	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 6 Room 27	MYR757	June 24, 2020	0.035	Exceeded	0.9800	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 7 Room 27	MYR758	June 24, 2020	0.079	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 8 Room 27	MYR759	June 24, 2020	0.073	Exceeded	0.7100	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 9 Room 27	MYR760	June 24, 2020	0.008	Exceeded	0.2400	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 10 Room 27	MYR761	June 24, 2020	0.009	Exceeded	0.2600	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 11 Room 27	MYR762	June 24, 2020	0.014	Exceeded	0.3100	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 12 Room 27	MYR763	June 24, 2020	0.007	Exceeded	0.1900	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 13 Room 27	MYR764	June 24, 2020	0.004	Passed	0.1300	Passed	
Bicentennial School	Science Lab tap 14 Room 27	MYR765	June 24, 2020	0.004	Passed	0.1200	Passed	
Bicentennial School	Science Lab tap 15 Room 27	MYR766	June 24, 2020	0.007	Exceeded	0.2400	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 16 Room 27	MYR767	June 24, 2020	0.013	Exceeded	0.2700	Passed	Laboratory or Hand washing only
Bicentennial School	Science Lab tap 17 Room 27	MYR768	June 24, 2020	0.005	Passed	0.1400	Passed	
Bicentennial School	Science Lab tap 18 Room 27	MYR769	June 24, 2020	0.002	Passed	0.1000	Passed	
Bicentennial School	Science Lab tap 19 Room 27	MYR770	June 24, 2020	0.008	Exceeded	0.2100	Passed	Laboratory or Hand washing only
Bicentennial School	Janitors Closet tap by Room 29	MYR771	June 24, 2020	0.001	Passed	0.0370	Passed	
Bicentennial School	Class Room 29 tap	MYR772	June 24, 2020	0.002	Passed	0.1700	Passed	
Bicentennial School	Fountain by Room 31	XBG926	September 15, 2023	-	Passed	0.0011	Passed	
Bicentennial School	Tech Ed sink tap	MYR774	June 24, 2020	0.002	Passed	0.0670	Passed	
Bicentennial School	Class Room 30 tap	XBG927	September 15, 2023	-	Passed	0.0300	Passed	Tap remediated
Bicentennial School	Boys Wash Room tap 1 by Room 30	XBG944	September 15, 2023	0.001	Passed	0.0530	Passed	Tap remediated
Bicentennial School	Boys Wash Room tap 2 by Room 30	XBG945	September 15, 2023	0.001	Passed	0.0610	Passed	Tap remediated
Bicentennial School	Boys Wash Room tap 3 by Room 30	XBG925	September 15, 2023	0.001	Passed	0.1000	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Bicentennial School	Boys Wash Room tap 4 by Room 30	MYR780	June 24, 2020	0.001	Passed	0.0800	Passed	
Bicentennial School	Gender Neutral Wash Room tap by Room 29	MYR781	June 24, 2020	0.001	Passed	0.0280	Passed	
Bicentennial School	Gender Neutral Wash Room tap by Boys Wash Room	MYR782	June 24, 2020	0.001	Passed	0.1300	Passed	
Bicentennial School	Girls Wash Room tap 1 by Room 29	XBG930	September 15, 2023	0.001	Passed	0.1300	Passed	Tap remediated
Bicentennial School	Girls Wash Room tap 2 by Room 29	XBG931	September 15, 2023	0.005	Exceeded	0.2700	Passed	Hand washing only
Bicentennial School	Girls Wash Room tap 3 by Room 29	MYR785	June 24, 2020	0.002	Passed	0.2100	Passed	
Bicentennial School	Girls Wash Room tap 4 by Room 29	XBG932	September 15, 2023	0.001	Passed	0.0650	Passed	Tap remediated
Bicentennial School	Fountain by Room 29	XBG936	September 15, 2023	-	Passed	0.0280	Passed	
Bicentennial School	Staff Room tap	XBG939	September 15, 2023	-	Passed	0.0920	Passed	
Bicentennial School	Fountain by Staff Room	NMK042	August 28, 2020	0.002	Passed	0.0960	Passed	
Brookhouse Elementary	Fountain by Room 205	XKA760	October 25, 2023	-	Passed	0.0510	Passed	
Brookhouse Elementary	Janitors Closet tap by Room 205	MWI331	June 15, 2020	0.001	Passed	0.0330	Passed	
Brookhouse Elementary	Girls Wash Room 208 tap 1	XKA761	October 25, 2023	0.003	Passed	0.0490	Passed	Tap remediated
Brookhouse Elementary	Girls Wash Room 208 tap 2	XKA762	October 25, 2023	0.003	Passed	0.0470	Passed	Tap remediated
Brookhouse Elementary	Girls Wash Room 208 tap 3	XKA763	October 25, 2023	0.001	Passed	0.0350	Passed	Tap remediated
Brookhouse Elementary	Girls Wash Room 208 tap 4	XKA764	October 25, 2023	-	Passed	0.0310	Passed	Tap remediated
Brookhouse Elementary	Staff Wash Room 204 tap	MWI336	June 15, 2020	0.002	Passed	0.4700	Passed	
Brookhouse Elementary	Janitors Closet 136 tap	MWI338	June 15, 2020	0.001	Passed	0.0400	Passed	
Brookhouse Elementary	Boys Wash Room 134 tap 1	XKA765	October 25, 2023	-	Passed	0.0400	Passed	Tap remediated
Brookhouse Elementary	Boys Wash Room 134 tap 2	MWI340	June 15, 2020	0.005	Passed	0.1800	Passed	
Brookhouse Elementary	Boys Wash Room 134 tap 3	MWI341	June 15, 2020	0.002	Passed	0.0590	Passed	
Brookhouse Elementary	Learning Centre Wash Room tap	XKA759	October 25, 2023	-	Passed	0.0470	Passed	Tap remediated
Brookhouse Elementary	Gym Office Wash Room tap	XKA757	October 25, 2023	-	Passed	0.0120	Passed	Tap remediated
Brookhouse Elementary	Boys Wash Room tap 1 by Room 127	MWI344	June 15, 2020	0.003	Passed	0.0500	Passed	
Brookhouse Elementary	Boys Wash Room tap 2 by Room 127	MWI345	June 15, 2020	0.003	Passed	0.0420	Passed	
Brookhouse Elementary	Boys Wash Room tap 3 by Room 127	MWI348	June 15, 2020	0.002	Passed	0.0280	Passed	
Brookhouse Elementary	Janitors Closet tap by Room 127	MWI349	June 15, 2020	0.004	Passed	0.0370	Passed	
Brookhouse Elementary	Staff Room 111 Wash Room 1 tap	XKA750	October 25, 2023	-	Passed	0.0120	Passed	Tap remediated
Brookhouse Elementary	Staff Room 111 Kitchen tap	XKA749	October 25, 2023	-	Passed	0.0086	Passed	
Brookhouse Elementary	Staff Room 111 Wash Room 2 tap	MWI328	June 15, 2020	-	Passed	0.0210	Passed	
Brookhouse Elementary	Girls Wash Room 112 tap 1	MWI353	June 15, 2020	0.002	Passed	0.0300	Passed	
Brookhouse Elementary	Girls Wash Room 112 tap 2	MWI354	June 15, 2020	0.001	Passed	0.0180	Passed	
Brookhouse Elementary	Girls Wash Room 112 tap 3	MWI355	June 15, 2020	0.001	Passed	0.0130	Passed	
Brookhouse Elementary	Girls Wash Room 112 tap 4	MWI356	June 15, 2020	0.001	Passed	0.0130	Passed	
Brookhouse Elementary	Fountain by Room 118	XKA756	October 25, 2023	-	Passed	0.3400	Passed	
Brookhouse Elementary	Boys Wash Room 125 tap 1	XKA753	October 25, 2023	-	Passed	0.0200	Passed	Tap remediated
Brookhouse Elementary	Boys Wash Room 125 tap 2	XKA754	October 25, 2023	-	Passed	0.0180	Passed	Tap remediated
Brookhouse Elementary	Boys Wash Room 125 tap 3	XKA755	October 25, 2023	-	Passed	0.0300	Passed	Tap remediated
Brookhouse Elementary	Fountain by Room 125	XKA752	October 25, 2023	-	Passed	0.0540	Passed	
Brookhouse Elementary	Principal's Office Wash Room 116 tap	MWI395	June 15, 2020	0.003	Passed	0.0830	Passed	
Brookhouse Elementary	Fountain by Room 105	XKA766	October 25, 2023	0.001	Passed	0.4200	Passed	
Brookhouse Elementary	Fountain by Room 136	XKA758	October 25, 2023	-	Passed	0.0530	Passed	
Brookhouse Elementary	Office Room 115 tap	XKA751	October 25, 2023	-	Passed	0.0180	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Brookside Junior High School	Boys Wash Room tap 1	TBH498	June 30, 2022	0.002	Passed	0.5300	Passed	
Brookside Junior High School	Boys Wash Room tap 2	TBH499	June 30, 2022	0.004	Passed	0.5600	Passed	
Brookside Junior High School	Gender Neutral Wash Room 1 tap	TBH501	June 30, 2022	0.001	Passed	0.5000	Passed	
Brookside Junior High School	Gender Neutral Wash Room 2 tap	TBH502	June 30, 2022	0.002	Passed	0.5300	Passed	
Brookside Junior High School	Girls Wash Room tap 1	TBH503	June 30, 2022	0.002	Passed	0.5200	Passed	
Brookside Junior High School	Girls Wash Room tap 2	TBH504	June 30, 2022	0.002	Passed	0.5200	Passed	
Brookside Junior High School	Girls Wash Room tap 3	TBH505	June 30, 2022	0.001	Passed	0.5000	Passed	
Brookside Junior High School	Boiler Room tap	TBH507	June 30, 2022	0.001	Passed	0.4800	Passed	
Brookside Junior High School	Janitors Closet tap	TBH511	June 30, 2022	0.002	Passed	0.4900	Passed	
Brookside Junior High School	Principal's Office Wash Room tap	TBH512	June 30, 2022	0.003	Passed	0.8100	Passed	
Brookside Junior High School	2nd Floor Male Staff Wash Room tap	TBH514	June 30, 2022	0.002	Passed	0.5600	Passed	
Brookside Junior High School	2nd Floor Girls Wash Room tap 1	TBH517	June 30, 2022	0.002	Passed	0.5500	Passed	
Brookside Junior High School	2nd Floor Girls Wash Room tap 2	TBH518	June 30, 2022	0.002	Passed	0.5600	Passed	
Brookside Junior High School	2nd Floor Girls Wash Room tap 3	TBH519	June 30, 2022	0.001	Passed	0.5600	Passed	
Brookside Junior High School	2nd Floor Janitors Closet tap	TBH520	June 30, 2022	0.001	Passed	0.4900	Passed	
Brookside Junior High School	2nd Floor Boys Wash Room tap 1	TBH521	June 30, 2022	0.004	Passed	0.5400	Passed	
Brookside Junior High School	2nd Floor Boys Wash Room tap 2	TBH522	June 30, 2022	0.002	Passed	0.4900	Passed	
Brookside Junior High School	2nd Floor Boys Wash Room tap 3	TBH523	June 30, 2022	0.002	Passed	0.5200	Passed	
Brookside Junior High School	Special Needs Wash Room tap	TBH530	June 30, 2022	0.003	Passed	0.5100	Passed	
Brookside Junior High School	Class Room 215 tap 1	VXD699	May 24, 2023	0.001	Passed	0.3000	Passed	
Brookside Junior High School	Class Room 215 tap 2	VXD700	May 24, 2023	0.001	Passed	0.3000	Passed	Tap remediated
Brookside Junior High School	Class Room 215 tap 3	VXD701	May 24, 2023	0.001	Passed	0.3100	Passed	Tap remediated
Brookside Junior High School	Class Room 215 tap 4	VXD702	May 24, 2023	0.001	Passed	0.2900	Passed	
Brookside Junior High School	Class Room 215 tap 5	VXD703	May 24, 2023	0.002	Passed	0.3900	Passed	
Brookside Junior High School	Kitchen/Cafe tap 1	VXD732	May 24, 2023	0.003	Passed	0.3700	Passed	
Brookside Junior High School	Kitchen/Cafe tap 2	VXD733	May 24, 2023	0.003	Passed	0.3700	Passed	
Brookside Junior High School	Kitchen/Cafe tap 3	VXD734	May 24, 2023	0.006	Exceeded	0.4000	Passed	Hand washing only
Brookside Junior High School	Boys Wash Room tap 3	VXD735	June 30, 2022	0.015	Exceeded	0.6200	Passed	Hand washing only
Brookside Junior High School	Girls Wash Room tap 4	VXD736	May 24, 2023	0.003	Passed	0.3800	Passed	Tap remediated
Brookside Junior High School	Fountain by Room 106	XFR010	October 10, 2023	-	Passed	0.0110	Passed	
Brookside Junior High School	Staff Room Kitchen tap	VXD738	May 24, 2023	-	Passed	0.3800	Passed	
Brookside Junior High School	2nd Floor Female Staff Room tap 1	VXD739	May 24, 2023	0.001	Passed	0.4100	Passed	Tap remediated
Brookside Junior High School	2nd Floor Female Staff Room tap 2	VXD740	May 24, 2023	0.001	Passed	0.3900	Passed	Tap remediated
Brookside Junior High School	Fountain by Room 208	XFR011	October 10, 2023	0.001	Passed	0.0220	Passed	
Burton Ettinger Elementary	Class Room 218 tap	MRX345	May 25, 2020	0.003	Passed	0.0540	Passed	
Burton Ettinger Elementary	Class Room 221 tap	MRX347	May 25, 2020	0.003	Passed	0.1600	Passed	
Burton Ettinger Elementary	Class Room 223 tap	MRX349	May 25, 2020	0.004	Passed	0.2000	Passed	
Burton Ettinger Elementary	Janitors Closet 224 tap	MRX351	May 25, 2020	0.006	Exceeded	0.1300	Passed	Hand washing only
Burton Ettinger Elementary	Janitors Closet 238 tap	MRX353	May 25, 2020	0.001	Passed	0.0160	Passed	
Burton Ettinger Elementary	Gender Neutral Wash Room 231 tap	MRX354	May 25, 2020	0.002	Passed	0.1600	Passed	
Burton Ettinger Elementary	Girls Wash Room 236 tap 1	MRX355	May 25, 2020	-	Passed	0.1700	Passed	
Burton Ettinger Elementary	Girls Wash Room 236 tap 2	MRX356	May 25, 2020	-	Passed	0.0600	Passed	
Burton Ettinger Elementary	Staff Female Wash Room 236 tap	MRX357	May 25, 2020	-	Passed	0.0076	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Burton Ettinger Elementary	Boys Wash Room 237 tap 2	MRX360	May 25, 2020	0.001	Passed	0.0120	Passed	
Burton Ettinger Elementary	Staff Male Wash Room 237 tap	MRX361	May 25, 2020	-	Passed	0.0630	Passed	
Burton Ettinger Elementary	Staff Room 104 Wash Room tap 1	MRX363	May 25, 2020	0.005	Passed	0.0550	Passed	
Burton Ettinger Elementary	Girls Wash Room tap 2 by Room 108	MRX367	May 25, 2020	0.002	Passed	0.0920	Passed	
Burton Ettinger Elementary	Staff Wash Room tap by Room 108	MRX369	May 25, 2020	0.002	Passed	0.0840	Passed	
Burton Ettinger Elementary	Boys Wash Room tap 1 by Room 108	MRX370	May 25, 2020	0.002	Passed	0.0800	Passed	
Burton Ettinger Elementary	Boys Wash Room tap 3 by Room 108	MRX372	May 25, 2020	0.002	Passed	0.1200	Passed	
Burton Ettinger Elementary	Gym Girls Locker Room tap	MRX374	May 25, 2020	0.005	Passed	0.1100	Passed	
Burton Ettinger Elementary	Gender Neutral Locker Room in Gym	MRX375	May 25, 2020	0.003	Passed	0.0850	Passed	
Burton Ettinger Elementary	Janitors Closet 111A double compartment sink	MRX377	May 25, 2020	0.001	Passed	0.1000	Passed	
Burton Ettinger Elementary	Girls Wash Room tap 1 by Room 116	MRX379	May 25, 2020	0.001	Passed	0.3300	Passed	
Burton Ettinger Elementary	Girls Wash Room tap 2 by Room 116	MRX380	May 25, 2020	-	Passed	0.0420	Passed	
Burton Ettinger Elementary	Girls Wash Room tap 3 by Room 116	MRX381	May 25, 2020	-	Passed	0.2700	Passed	
Burton Ettinger Elementary	Boys Wash Room 116 tap 2	MRX383	May 25, 2020	0.002	Passed	0.0140	Passed	
Burton Ettinger Elementary	Fountain by Room 224	WGN115	June 28, 2023	-	Passed	0.0180	Passed	
Burton Ettinger Elementary	Fountain by Room 236	VVU925	May 17, 2023	-	Passed	0.0990	Passed	
Burton Ettinger Elementary	Fountain by Office Room 101	VVU926	May 17, 2023	0.001	Passed	0.0970	Passed	
Burton Ettinger Elementary	Staff Room 104 tap	VVU927	May 17, 2023	-	Passed	0.0730	Passed	Tap remediated
Burton Ettinger Elementary	Girls Wash Room tap 1 by Room 108	VVU928	May 17, 2023	-	Passed	0.0110	Passed	Tap remediated
Burton Ettinger Elementary	Girls Wash Room tap 3 by Room 108	VVU929	May 17, 2023	-	Passed	0.0180	Passed	Tap remediated
Burton Ettinger Elementary	Boys Wash Room tap 2 by Room 108	VVU930	May 17, 2023	-	Passed	0.0590	Passed	Tap remediated
Burton Ettinger Elementary	Staff Room 104 Wash Room tap 2	VVU931	May 17, 2023	-	Passed	0.0041	Passed	Tap remediated
Burton Ettinger Elementary	Janitors Closet tap by Room 102	VVU931	May 17, 2023	0.001	Passed	0.0350	Passed	Tap remediated
Burton Ettinger Elementary	Class Room 222 tap	VVU933	May 17, 2023	-	Passed	0.0940	Passed	Tap remediated
Burton Ettinger Elementary	Class Room 220 tap	VVU934	May 17, 2023	-	Passed	0.0780	Passed	Tap remediated
Burton Ettinger Elementary	Fountain by Room 112	VVU935	May 17, 2023	-	Passed	0.0230	Passed	
Burton Ettinger Elementary	Boys Wash Room 116 tap 1	vvu936	May 17, 2023	0.001	Passed	0.0260	Passed	Tap remediated
Burton Ettinger Elementary	Art Room 111 tap	VVU937	May 17, 2023	-	Passed	0.0370	Passed	Tap remediated
Burton Ettinger Elementary	Boys Wash Room 237 tap 1	VVU938	May 17, 2023	-	Passed	0.0110	Passed	Tap remediated
Burton Ettinger Elementary	Staff Room 227 tap	VVU939	May 17, 2023	0.002	Passed	0.0720	Passed	
Caldwell Road Elementary	Class Room Wash Room 1a tap	MQE455	May 14, 2020	0.003	Passed	0.1900	Passed	
Caldwell Road Elementary	Boys Wash Room tap 1 by Room 6	MQE456	May 14, 2020	0.001	Passed	0.3200	Passed	
Caldwell Road Elementary	Boys Wash Room tap 2 by Room 6	MQE457	May 14, 2020	0.002	Passed	0.1700	Passed	
Caldwell Road Elementary	Boys Wash Room tap 3 by Room 6	MQE458	May 14, 2020	0.001	Passed	0.1000	Passed	
Caldwell Road Elementary	Janitors Closet tap 1 by Room 6	MQE459	May 14, 2020	0.001	Passed	0.0760	Passed	
Caldwell Road Elementary	Girls Wash Room tap 1 by Room 6	MQE461	May 14, 2020	0.003	Passed	0.1300	Passed	
Caldwell Road Elementary	Girls Wash Room tap 2 by Room 6	MQE462	May 14, 2020	0.002	Passed	0.0760	Passed	
Caldwell Road Elementary	Girls Wash Room tap 3 by Room 6	MQE463	May 14, 2020	0.001	Passed	0.0520	Passed	
Caldwell Road Elementary	Learning Centre Wash Room tap by Room 7	MQE464	May 14, 2020	0.002	Passed	0.1400	Passed	
Caldwell Road Elementary	Boys Wash Room tap 1 by Gym	MQE465	May 14, 2020	0.003	Passed	0.1900	Passed	
Caldwell Road Elementary	Boys Wash Room tap 2 by Gym	MQE466	May 14, 2020	0.001	Passed	0.0390	Passed	
Caldwell Road Elementary	Girls Wash Room tap 1 by Gym	MQE467	May 14, 2020	0.002	Passed	0.1500	Passed	
Caldwell Road Elementary	Girls Wash Room tap 2 by Gym	XDW318	September 28, 2023	-	Passed	0.0200	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Caldwell Road Elementary	Fountain by Main Entrance	XDW316	September 28, 2023	-	Passed	0.0300	Passed	
Caldwell Road Elementary	2nd Floor Girls Wash Room tap	XDW322	September 28, 2023	-	Passed	0.0210	Passed	Tap remediated
Caldwell Road Elementary	2nd Floor Boys Wash Room tap	MQE471	May 14, 2020	0.004	Passed	0.0960	Passed	
Caldwell Road Elementary	Fountain by Room 208	XDW321	September 28, 2023	0.001	Passed	0.0640	Passed	
Caldwell Road Elementary	2nd Floor Janitors Closet tap by Room 208	MQE473	May 14, 2020	0.002	Passed	0.0950	Passed	
Caldwell Road Elementary	1st Floor Staff Kitchen tap	XDW319	September 28, 2023	-	Passed	0.0140	Passed	
Caldwell Road Elementary	1st Floor Staff Wash Room 1 tap	MQE476	May 14, 2020	-	Passed	0.0200	Passed	
Caldwell Road Elementary	1st Floor Staff Wash Room 2 tap	MQE477	May 14, 2020	-	Passed	0.0130	Passed	
Caldwell Road Elementary	Fountain by Room 6	XDW317	September 28, 2023	-	Passed	0.0260	Passed	
Caldwell Road Elementary	Music Room 122 tap	XDW320	September 28, 2023	0.003	Passed	0.2500	Passed	
Caledonia Junior High School	Class Room 108 tap	WIH458	July 7, 2023	0.001	Passed	0.1200	Passed	Tap remediated
Caledonia Junior High School	Fountain by Room 109	WIH479	July 7, 2023	0.004	Passed	0.1100	Passed	
Caledonia Junior High School	1st Floor Boys Wash Room tap 1	MXU490	June 18, 2020	0.002	Passed	0.2200	Passed	
Caledonia Junior High School	1st Floor Boys Wash Room tap 2	WIH456	July 7, 2023	0.001	Passed	0.1100	Passed	Tap remediated
Caledonia Junior High School	1st Floor Boys Wash Room tap 3	WIH457	July 7, 2023	0.001	Passed	0.1000	Passed	Tap remediated
Caledonia Junior High School	Janitors Closet tap by 1st Floor Wash Rooms	MXU493	June 18, 2020	0.001	Passed	0.0320	Passed	
Caledonia Junior High School	1st Floor Girls Wash Room tap 1	WIH453	July 7, 2023	0.049	Exceeded	0.4800	Passed	Hand washing only
Caledonia Junior High School	1st Floor Girls Wash Room tap 2	WIH454	July 7, 2023	0.016	Exceeded	0.2500	Passed	Hand washing only
Caledonia Junior High School	1st Floor Girls Wash Room tap 3	WIH480	July 7, 2023	0.005	Exceeded	0.1600	Passed	Hand washing only
Caledonia Junior High School	1st Floor Girls Wash Room tap 4	MXU497	June 18, 2020	0.003	Passed	0.3700	Passed	
Caledonia Junior High School	1st Floor Girls Wash Room tap 5	WIH455	July 7, 2023	0.002	Passed	0.0960	Passed	Tap remediated
Caledonia Junior High School	Class Room 109 tap 1	MXU506	June 18, 2020	0.003	Passed	0.2100	Passed	
Caledonia Junior High School	Class Room 109 tap 2	WIH460	July 7, 2023	0.001	Passed	0.0710	Passed	Tap remediated
Caledonia Junior High School	Staff Room 110 tap	WIH461	July 7, 2023	-	Passed	0.0680	Passed	
Caledonia Junior High School	Staff Room 110 Wash Room 1 tap	WIH462	July 7, 2023	0.002	Passed	0.0820	Passed	Tap remediated
Caledonia Junior High School	Staff Room 110 Wash Room 2 tap	WIH463	July 7, 2023	-	Passed	0.0610	Passed	Tap remediated
Caledonia Junior High School	Janitors Closet 112 tap	MXU511	June 18, 2020	0.001	Passed	0.0230	Passed	
Caledonia Junior High School	Gender Neutral Wash Room 115 tap	WIH459	July 7, 2023	0.001	Passed	0.1500	Passed	Tap remediated
Caledonia Junior High School	Fountain by Room 115	WIH452	July 7, 2023	0.002	Passed	0.1200	Passed	
Caledonia Junior High School	Science Lab tap 1	MXU515	June 18, 2020	0.053	Exceeded	0.4300	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 2	MXU516	June 18, 2020	0.068	Exceeded	0.6700	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 3	MXU517	June 18, 2020	0.410	Exceeded	3.0000	Exceeded	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 4	MXU518	June 18, 2020	0.270	Exceeded	1.8000	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 5	MXU519	June 18, 2020	0.170	Exceeded	0.9900	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 6	MXU520	June 18, 2020	0.004	Passed	0.0710	Passed	
Caledonia Junior High School	Science Lab tap 7	MXU521	June 18, 2020	1.200	Exceeded	8.2000	Exceeded	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 8	MXU522	June 18, 2020	0.100	Exceeded	0.3700	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 9	MXU523	June 18, 2020	0.074	Exceeded	0.8700	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 10	MXU524	June 18, 2020	0.410	Exceeded	3.5000	Exceeded	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 11	MXU525	June 18, 2020	0.270	Exceeded	0.9600	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 12	MXU526	June 18, 2020	0.060	Exceeded	0.5700	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 13	MXU527	June 18, 2020	0.230	Exceeded	0.9500	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Science Lab tap 14	MXU528	June 18, 2020	0.047	Exceeded	1.2000	Passed	Laboratory or Hand washing only

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Caledonia Junior High School	Science Lab tap 15	MXU529	June 18, 2020	0.021	Exceeded	1.1000	Passed	Laboratory or Hand washing only
Caledonia Junior High School	Family Studies 215 tap 1	WIH464	July 7, 2023	-	Passed	0.0170	Passed	
Caledonia Junior High School	Family Studies 215 tap 2	WIH465	July 7, 2023	-	Passed	0.0210	Passed	
Caledonia Junior High School	Family Studies 215 tap 3	WIH466	July 7, 2023	-	Passed	0.0210	Passed	
Caledonia Junior High School	Family Studies 215 tap 4	WIH467	July 7, 2023	-	Passed	0.0330	Passed	
Caledonia Junior High School	Family Studies 215 tap 5	WIH468	July 7, 2023	-	Passed	0.0360	Passed	
Caledonia Junior High School	Class Room 207 tap 1	WIH469	July 7, 2023	-	Passed	0.0750	Passed	Tap remediated
Caledonia Junior High School	Class Room 207 tap 2	WIH481	July 7, 2023	0.001	Passed	0.0530	Passed	Hand washing only
Caledonia Junior High School	Class Room 207 tap 3	WIH470	July 7, 2023	0.011	Exceeded	0.1800	Passed	Hand washing only
Caledonia Junior High School	2nd Floor Girls Wash Room tap 1	WIH471	July 7, 2023	0.003	Passed	0.1100	Passed	Tap remediated
Caledonia Junior High School	2nd Floor Girls Wash Room tap 2	WIH472	July 7, 2023	0.001	Passed	0.0850	Passed	Tap remediated
Caledonia Junior High School	2nd Floor Girls Wash Room tap 3	MXU541	June 18, 2020	0.005	Passed	0.1300	Passed	
Caledonia Junior High School	Janitors Closet tap by 2nd Floor Wash Rooms	WIH476	July 7, 2023	0.002	Passed	0.1000	Passed	Tap remediated
Caledonia Junior High School	2nd Floor Boys Wash Room tap 1	WIH473	July 7, 2023	0.003	Passed	0.0920	Passed	Tap remediated
Caledonia Junior High School	2nd Floor Boys Wash Room tap 2	WIH474	July 7, 2023	0.013	Exceeded	0.0780	Passed	Hand washing only
Caledonia Junior High School	2nd Floor Boys Wash Room tap 3	WIH475	July 7, 2023	0.007	Exceeded	0.0900	Passed	Hand washing only
Caledonia Junior High School	Fountain by Science Lab	WIH478	July 7, 2023	-	Passed	0.0220	Passed	
Caledonia Junior High School	Fountain by Room 213	WIH477	July 7, 2023	0.002	Passed	0.0840	Passed	
Caudle Park Elementary	1st Floor Boys Wash Room tap 1	MPX380	May 13, 2020	0.002	Passed	0.1100	Passed	
Caudle Park Elementary	1st Floor Boys Wash Room tap 2	MPX381	May 13, 2020	0.001	Passed	0.0920	Passed	
Caudle Park Elementary	1st Floor Janitors Closet tap	MPX382	May 13, 2020	-	Passed	0.0440	Passed	
Caudle Park Elementary	1st Floor Staff Wash Room tap 1	MPX383	May 13, 2020	0.002	Passed	0.0300	Passed	
Caudle Park Elementary	1st Floor Staff Wash Room tap 2	MPX384	May 13, 2020	0.002	Passed	0.0420	Passed	
Caudle Park Elementary	1st Floor Girls Wash Room tap 1	MPX385	May 13, 2020	0.002	Passed	0.1500	Passed	
Caudle Park Elementary	1st Floor Girls Wash Room tap 2	MPX386	May 13, 2020	0.001	Passed	0.1000	Passed	
Caudle Park Elementary	1st Floor Girls Wash Room tap 3	MPX387	May 13, 2020	0.002	Passed	0.0990	Passed	
Caudle Park Elementary	Main Office Wash Room tap	MPX388	May 13, 2020	-	Passed	0.1100	Passed	
Caudle Park Elementary	2nd Floor Boys Wash Room tap 2	MPX392	May 13, 2020	0.001	Passed	0.0730	Passed	
Caudle Park Elementary	2nd Floor Boys Wash Room tap 3	MPX393	May 13, 2020	0.001	Passed	0.0840	Passed	
Caudle Park Elementary	2nd Floor Boys Wash Room tap 4	MPX394	May 13, 2020	0.001	Passed	0.1500	Passed	
Caudle Park Elementary	2nd Floor Janitors Closet tap	MPX395	May 13, 2020	-	Passed	0.0320	Passed	
Caudle Park Elementary	2nd Floor Staff Room Wash Room tap	MPX396	May 13, 2020	0.001	Passed	0.2000	Passed	
Caudle Park Elementary	2nd Floor Girls Wash Room tap 1	MPX397	May 13, 2020	0.003	Passed	0.1800	Passed	
Caudle Park Elementary	2nd Floor Girls Wash Room tap 2	MPX398	May 13, 2020	0.001	Passed	0.0850	Passed	
Caudle Park Elementary	2nd Floor Girls Wash Room tap 3	MPX399	May 13, 2020	0.001	Passed	0.0590	Passed	
Caudle Park Elementary	2nd Floor Girls Wash Room tap 4	MPX400	May 13, 2020	0.001	Passed	0.0720	Passed	
Caudle Park Elementary	3rd Floor Boys Wash Room tap	MPX402	May 13, 2020	0.001	Passed	0.0170	Passed	
Caudle Park Elementary	3rd Floor Girls Wash Room tap	MPX403	May 13, 2020	0.001	Passed	0.1800	Passed	
Caudle Park Elementary	3rd Floor Janitors Closet tap	MPX404	May 13, 2020	-	Passed	0.0230	Passed	
Caudle Park Elementary	Class Room tap Room 101	NFZ878	July 30, 2020	0.001	Passed	0.0800	Passed	
Caudle Park Elementary	2nd Floor Boys Wash Room tap 1	NFZ879	July 30, 2020	-	Passed	0.0580	Passed	
Caudle Park Elementary	Fountain by Room 101	WCN489	June 13, 2023	-	Passed	0.0490	Passed	
Caudle Park Elementary	Fountain by Room 202	WCN490	June 13, 2023	-	Passed	0.0240	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Caudle Park Elementary	2nd Floor Staff Room tap	WCN491	June 13, 2023	-	Passed	0.0220	Passed	
Caudle Park Elementary	Fountain by Room 303	WCN492	June 13, 2023	-	Passed	0.1900	Passed	
Cavalier Drive School	Main Office Wash Room tap	MPQ776	May 12, 2020	0.003	Passed	0.0310	Passed	
Cavalier Drive School	Wash Room by Room 104 tap 2	MPQ782	May 12, 2020	0.001	Passed	0.0340	Passed	
Cavalier Drive School	Class Room 108 tap	MPQ783	May 12, 2020	0.004	Passed	0.0200	Passed	
Cavalier Drive School	Class Room 110 tap	MPQ784	May 12, 2020	0.004	Passed	0.4400	Passed	
Cavalier Drive School	1st Floor Janitors Closet tap	MPQ791	May 12, 2020	0.001	Passed	0.0230	Passed	
Cavalier Drive School	Staff Room Wash Room tap 2	MPQ796	May 12, 2020	0.002	Passed	0.0190	Passed	
Cavalier Drive School	Class Room 152 tap 1	MPQ803	May 12, 2020	0.001	Passed	0.0170	Passed	
Cavalier Drive School	2nd Floor Janitors Closet tap	MPQ814	May 12, 2020	-	Passed	0.0058	Passed	
Cavalier Drive School	Class Room 205 tap	MPQ815	May 12, 2020	0.003	Passed	0.0210	Passed	
Cavalier Drive School	Class Room 201 tap	MPQ817	May 12, 2020	0.003	Passed	0.2300	Passed	
Cavalier Drive School	Class Room 204 tap	MPQ819	May 12, 2020	0.001	Passed	0.0210	Passed	
Cavalier Drive School	Class Room tap Room 206	MPQ824	May 12, 2020	0.003	Passed	0.0150	Passed	
Cavalier Drive School	Class Room Wash Room tap Room 206	MPQ825	May 12, 2020	0.003	Passed	0.0680	Passed	
Cavalier Drive School	Class Room 111 tap	SCH537	March 15, 2022	0.001	Passed	0.0450	Passed	
Cavalier Drive School	Class Room 156 tap	SCH553	March 15, 2022	0.002	Passed	0.1200	Passed	
Cavalier Drive School	Class Room 152 tap 2	SCH555	March 15, 2022	0.001	Passed	0.0520	Passed	
Cavalier Drive School	Class Room 203 tap	SCH556	March 15, 2022	0.001	Passed	0.0430	Passed	
Cavalier Drive School	Class Room 202 tap	SCH557	March 15, 2022	0.002	Passed	0.0620	Passed	
Cavalier Drive School	Class Room 204 Wash Room tap	SCH558	March 15, 2022	0.001	Passed	0.0370	Passed	
Cavalier Drive School	Fountain by Room 107	WBC863	June 7, 2023	-	Passed	0.0008	Passed	
Cavalier Drive School	Fountain by Room 102	WBC864	June 7, 2023	0.003	Passed	0.0530	Passed	
Cavalier Drive School	Learning Centre tap	WBC865	June 7, 2023	0.001	Passed	0.0210	Passed	
Cavalier Drive School	Staff Room Kitchen tap	WBC866	June 7, 2023	-	Passed	0.0110	Passed	
Cavalier Drive School	Fountain by Room 165	WBC867	June 7, 2023	-	Passed	0.0300	Passed	
Cavalier Drive School	Wash Room by Room 102 tap 1	WBC868	June 7, 2023	0.001	Passed	0.0220	Passed	Tap remediated
Cavalier Drive School	Wash Room by Room 102 tap 2	WBC869	June 7, 2023	0.001	Passed	0.0210	Passed	Tap remediated
Cavalier Drive School	Wash Room by Room 104 tap 1	WBC870	June 7, 2023	-	Passed	0.0330	Passed	Tap remediated
Cavalier Drive School	1st Floor Boys Wash Room tap 1	WBC871	June 7, 2023	-	Passed	0.0130	Passed	Tap remediated
Cavalier Drive School	1st Floor Boys Wash Room tap 2	WBC872	June 7, 2023	-	Passed	0.0081	Passed	Tap remediated
Cavalier Drive School	Kitchen tap by Room 167	WBC886	June 7, 2023	0.001	Passed	0.0500	Passed	
Cavalier Drive School	Gym Boys Wash Room tap	WBC887	June 7, 2023	0.001	Passed	0.0270	Passed	Tap remediated
Cavalier Drive School	Gym Girls Wash Room tap	WBC888	June 7, 2023	-	Passed	0.0230	Passed	Tap remediated
Cavalier Drive School	1st Floor Girls Wash Room tap 1	WBC889	June 7, 2023	0.001	Passed	0.0840	Passed	Tap remediated
Cavalier Drive School	1st Floor Girls Wash Room tap 2	WBC890	June 7, 2023	0.001	Passed	0.0098	Passed	Tap remediated
Cavalier Drive School	1st Floor Girls Wash Room tap 3	WBC891	June 7, 2023	0.001	Passed	0.0100	Passed	Tap remediated
Cavalier Drive School	Fountain by Room 209	WBC892	June 7, 2023	-	Passed	0.0300	Passed	
Cavalier Drive School	Fountain by Room 204	WBC893	June 7, 2023	-	Passed	0.0006	Passed	
Cavalier Drive School	Staff Room Wash Room tap 1	WBC894	June 7, 2023	-	Passed	0.0110	Passed	Tap remediated
Cavalier Drive School	2nd Floor Boys Wash Room tap 1	WBC895	June 7, 2023	-	Passed	0.0100	Passed	Tap remediated
Cavalier Drive School	2nd Floor Boys Wash Room tap 2	WBC906	June 7, 2023	-	Passed	0.0055	Passed	Tap remediated
Cavalier Drive School	2nd Floor Boys Wash Room tap 3	WBC907	June 7, 2023	-	Passed	0.0140	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Cavalier Drive School	2nd Floor Girls Wash Room tap 1	WBC908	June 7, 2023	-	Passed	0.0210	Passed	Tap remediated
Cavalier Drive School	2nd Floor Girls Wash Room tap 2	WBC909	June 7, 2023	-	Passed	0.0097	Passed	Tap remediated
Cavalier Drive School	2nd Floor Girls Wash Room tap 3	WBC910	June 7, 2023	-	Passed	0.0064	Passed	Tap remediated
Central Spryfield Elementary	Class Room 100C tap	MRD008	May 20, 2020	-	Passed	0.0600	Passed	
Central Spryfield Elementary	Girls Wash Room tap 1 by Room 100C	MRD009	May 20, 2020	-	Passed	0.1000	Passed	
Central Spryfield Elementary	Girls Wash Room tap 2 by Room 100C	MRD010	May 20, 2020	0.001	Passed	0.0990	Passed	
Central Spryfield Elementary	Girls Wash Room tap 3 by Room 100C	MRD011	May 20, 2020	0.001	Passed	0.0600	Passed	
Central Spryfield Elementary	Janitors Closet tap by Caretaker Office	MRD014	May 20, 2020	0.001	Passed	0.0670	Passed	
Central Spryfield Elementary	Class Room 100B tap	MRD016	May 20, 2020	0.002	Passed	0.1700	Passed	
Central Spryfield Elementary	Janitors Closet 212 tap	MRD020	May 20, 2020	0.002	Passed	0.0520	Passed	
Central Spryfield Elementary	Fountain by Room 200B	MRD027	May 20, 2020	0.004	Passed	0.1300	Passed	
Central Spryfield Elementary	Class Room 200B tap	MRD028	May 20, 2020	0.003	Passed	0.0610	Passed	
Central Spryfield Elementary	Janitors Closet 113 tap	NKV272	August 21, 2020	0.000	Passed	0.0080	Passed	
Central Spryfield Elementary	Fountain by Room 100B	VQL997	April 25, 2023	-	Passed	0.0055	Passed	
Central Spryfield Elementary	Boys Wash Room tap 1 by Caretaker Office	VQL998	April 25, 2023	-	Passed	0.0068	Passed	
Central Spryfield Elementary	Boys Wash Room tap 2 by Caretaker Office	VQL999	April 25, 2023	-	Passed	0.0095	Passed	Tap remediated
Central Spryfield Elementary	Staff Room 112 tap	VQM000	April 25, 2023	0.000	Passed	0.0065	Passed	
Central Spryfield Elementary	Staff Room 112 Wash Room tap 1	VQM001	April 25, 2023	-	Passed	0.0006	Passed	Tap remediated
Central Spryfield Elementary	Staff Room 112 Wash Room tap 2	VQM002	April 25, 2023	-	Passed	0.0046	Passed	Tap remediated
Central Spryfield Elementary	Boys Wash Room tap 1 by Room 104	VQM003	April 25, 2023	0.001	Passed	0.0140	Passed	Tap remediated
Central Spryfield Elementary	Boys Wash Room tap 2 by Room 104	VQM004	April 25, 2023	-	Passed	0.0080	Passed	Tap remediated
Central Spryfield Elementary	Boys Wash Room tap 3 by Room 104	VQM005	April 25, 2023	-	Passed	0.0083	Passed	Tap remediated
Central Spryfield Elementary	Girls Wash Room tap 1 by Room 104	VQM006	April 25, 2023	-	Passed	0.0013	Passed	Tap remediated
Central Spryfield Elementary	Girls Wash Room tap 2 by Room 104	VQM007	April 25, 2023	0.001	Passed	0.0340	Passed	Tap remediated
Central Spryfield Elementary	Girls Wash Room tap 3 by Room 104	VQM048	April 25, 2023	-	Passed	0.0013	Passed	Tap remediated
Central Spryfield Elementary	Fountain by Room 104	VQM049	April 25, 2023	0.001	Passed	0.0085	Passed	
Central Spryfield Elementary	Kitchen 104 tap	VQM050	April 25, 2023	-	Passed	0.0012	Passed	
Central Spryfield Elementary	Learning Centre 103 tap	VQM051	April 25, 2023	-	Passed	0.0006	Passed	
Central Spryfield Elementary	Learning Centre 103 Wash Room tap	VQM052	April 25, 2023	-	Passed	0.0012	Passed	Tap remediated
Central Spryfield Elementary	Kitchen 116 tap 1	VQM053	April 25, 2023	-	Passed	0.0047	Passed	
Central Spryfield Elementary	Fountain by Room 212	VQM054	April 25, 2023	0.001	Passed	0.0040	Passed	
Central Spryfield Elementary	Girls Wash Room 215 tap 1	VQM055	April 25, 2023	-	Passed	0.0005	Passed	
Central Spryfield Elementary	Girls Wash Room 215 tap 2	VQM056	April 25, 2023	-	Passed	0.0005	Passed	Tap remediated
Central Spryfield Elementary	Girls Wash Room 215 tap 3	VQM083	April 25, 2023	-	Passed	0.0023	Passed	
Central Spryfield Elementary	Boys Wash Room 214 tap 1	VQM084	April 25, 2023	-	Passed	0.0006	Passed	
Central Spryfield Elementary	Boys Wash Room 214 tap 2	VQM085	April 25, 2023	-	Passed	0.0007	Passed	Tap remediated
Central Spryfield Elementary	Boys Wash Room 214 tap 3	VQM086	April 25, 2023	-	Passed	0.0011	Passed	Tap remediated
Central Spryfield Elementary	Guidance Room 217 Wash Room tap	VQM087	April 25, 2023	-	Passed	0.0010	Passed	Tap remediated
Central Spryfield Elementary	Guidance Room 217 tap	VQM088	April 25, 2023	-	Passed	0.0015	Passed	
Charles P. Allen High School	Gender Neutral Wash Room 2008A tap	MNX510	May 1, 2020	-	Passed	0.2800	Passed	
Charles P. Allen High School	Boys Wash Room 2029 tap 1	MNX512	May 1, 2020	-	Passed	0.5600	Passed	
Charles P. Allen High School	Boys Wash Room 2029 tap 2	MNX513	May 1, 2020	-	Passed	0.4700	Passed	
Charles P. Allen High School	Boys Wash Room 2029 tap 3	MNX514	May 1, 2020	-	Passed	0.6500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Charles P. Allen High School	Girls Wash Room 2030 tap 1	MNX515	May 1, 2020	-	Passed	0.7500	Passed	
Charles P. Allen High School	Girls Wash Room 2030 tap 2	MNX516	May 1, 2020	-	Passed	0.7000	Passed	
Charles P. Allen High School	Girls Wash Room 2030 tap 3	MNX517	May 1, 2020	-	Passed	0.6800	Passed	
Charles P. Allen High School	Janitors Closet 2032 tap	MNX519	May 1, 2020	-	Passed	0.3800	Passed	
Charles P. Allen High School	Gender Neutral Wash Room 2031 tap	MNX524	May 1, 2020	-	Passed	0.0790	Passed	
Charles P. Allen High School	Class Room 2028	MNX525	May 1, 2020	-	Passed	0.6600	Passed	
Charles P. Allen High School	Staff Room 2044 tap	MNX526	May 1, 2020	-	Passed	0.3600	Passed	
Charles P. Allen High School	Staff Room Wash Room 2044B tap 1	MNX527	May 1, 2020	-	Passed	0.2700	Passed	
Charles P. Allen High School	Staff Room Wash Room 2044B tap 2	MNX528	May 1, 2020	-	Passed	0.3100	Passed	
Charles P. Allen High School	Boys Wash Room 2045 tap 1	MNX529	May 1, 2020	-	Passed	0.7400	Passed	
Charles P. Allen High School	Boys Wash Room 2045 tap 2	MNX530	May 1, 2020	-	Passed	0.6500	Passed	
Charles P. Allen High School	Boys Wash Room 2045 tap 3	MNX531	May 1, 2020	-	Passed	0.7900	Passed	
Charles P. Allen High School	Girls Wash Room 2046 tap 1	MNX532	May 1, 2020	-	Passed	0.9900	Passed	
Charles P. Allen High School	Girls Wash Room 2046 tap 2	MNX533	May 1, 2020	-	Passed	0.6900	Passed	
Charles P. Allen High School	Girls Wash Room 2046 tap 3	MNX541	May 1, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	Gender Neutral Wash Room 2047 tap	MNX542	May 1, 2020	-	Passed	0.3700	Passed	
Charles P. Allen High School	Janitors Closet 2048 tap	MNX543	May 1, 2020	0.004	Passed	0.4400	Passed	
Charles P. Allen High School	Locker Room 2068 tap 1	MOE400	May 4, 2020	-	Passed	1.0000	Passed	
Charles P. Allen High School	Locker Room 2068 tap 2	MOE401	May 4, 2020	-	Passed	1.2000	Passed	
Charles P. Allen High School	Locker Room 2067 tap 1	MOE402	May 4, 2020	0.001	Passed	0.8400	Passed	
Charles P. Allen High School	Locker Room 2067 tap 2	MOE403	May 4, 2020	-	Passed	0.8200	Passed	
Charles P. Allen High School	Locker Room 2066 tap 1	MOE404	May 4, 2020	0.003	Passed	0.8200	Passed	
Charles P. Allen High School	Locker Room 2066 tap 2	MOE405	May 4, 2020	0.001	Passed	0.4900	Passed	
Charles P. Allen High School	Locker Room 2065 tap 1	MOE406	May 4, 2020	-	Passed	0.5900	Passed	
Charles P. Allen High School	Locker Room 2065 tap 2	MOE407	May 4, 2020	-	Passed	0.5400	Passed	
Charles P. Allen High School	Learning Centre 1002 tap	MPM943	May 11, 2020	-	Passed	0.9300	Passed	
Charles P. Allen High School	Wash Room 1005 tap	MPM945	May 11, 2020	-	Passed	0.4600	Passed	
Charles P. Allen High School	Class Room 1004 tap	MPM946	May 11, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	Class Room 1015 tap	MPM948	May 11, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	Class Room 1016 tap	MPM949	May 11, 2020	-	Passed	0.8100	Passed	
Charles P. Allen High School	Class Room 1024 tap 1	MPM950	May 11, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room 1024 tap 2	MPM951	May 11, 2020	-	Passed	0.9400	Passed	
Charles P. Allen High School	Class Room 1027 tap 1	MPM952	May 11, 2020	-	Passed	0.0720	Passed	
Charles P. Allen High School	Class Room 1027 tap 2	MPM953	May 11, 2020	-	Passed	0.7400	Passed	
Charles P. Allen High School	Class Room 1026 tap	MPM954	May 11, 2020	-	Passed	0.8300	Passed	
Charles P. Allen High School	Boys Wash Room 1028 tap 1	MPM955	May 11, 2020	-	Passed	0.8500	Passed	
Charles P. Allen High School	Boys Wash Room 1028 tap 2	MPM956	May 11, 2020	-	Passed	0.8400	Passed	
Charles P. Allen High School	Boys Wash Room 1028 tap 3	MPM957	May 11, 2020	-	Passed	0.8000	Passed	
Charles P. Allen High School	Janitors Closet 1031 tap	MPM958	May 11, 2020	-	Passed	0.5400	Passed	
Charles P. Allen High School	Staff Wash Room 1030 tap	MPM959	May 11, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Girls Wash Room 1029 tap 1	MPM960	May 11, 2020	-	Passed	0.5400	Passed	
Charles P. Allen High School	Girls Wash Room 1029 tap 2	MPM961	May 11, 2020	-	Passed	0.6500	Passed	
Charles P. Allen High School	Girls Wash Room 1029 tap 3	MPM962	May 11, 2020	-	Passed	0.6000	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Charles P. Allen High School	Caretaker Room 1066 tap	MPM964	May 11, 2020	-	Passed	0.4100	Passed	
Charles P. Allen High School	Janitors Closet 1065 tap	MPM965	May 11, 2020	0.001	Passed	0.1300	Passed	
Charles P. Allen High School	Girls Wash Room 1055 tap 1	MPM966	May 11, 2020	0.002	Passed	0.4400	Passed	
Charles P. Allen High School	Girls Wash Room 1055 tap 2	MPM967	May 11, 2020	0.002	Passed	0.5500	Passed	
Charles P. Allen High School	Girls Wash Room 1055 tap 3	MPM968	May 11, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	Staff Wash Room 1056 tap	MPM969	May 11, 2020	-	Passed	1.0000	Passed	
Charles P. Allen High School	Janitors Closet 1057 tap	MPM970	May 11, 2020	0.001	Passed	0.3200	Passed	
Charles P. Allen High School	Boys Wash Room 1054 tap 1	MPM971	May 11, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	Boys Wash Room 1054 tap 2	MPM972	May 11, 2020	-	Passed	0.6900	Passed	
Charles P. Allen High School	Boys Wash Room 1054 tap 3	MPM973	May 11, 2020	-	Passed	0.7700	Passed	
Charles P. Allen High School	Staff Wash Room 1048	MPM975	May 11, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room 3004 tap	MSA126	May 25, 2020	-	Passed	0.2100	Passed	
Charles P. Allen High School	Class Room 3028 tap	MSA128	May 25, 2020	-	Passed	0.8100	Passed	
Charles P. Allen High School	Boys Wash Room 3029 tap 1	MSA130	May 25, 2020	-	Passed	0.4900	Passed	
Charles P. Allen High School	Boys Wash Room 3029 tap 2	MSA131	May 25, 2020	-	Passed	0.5200	Passed	
Charles P. Allen High School	Boys Wash Room 3029 tap 3	MSA132	May 25, 2020	-	Passed	0.5500	Passed	
Charles P. Allen High School	Janitors Closet 3032 tap	MSA133	May 25, 2020	0.001	Passed	0.3800	Passed	
Charles P. Allen High School	Staff Wash Room 3031 tap	MSA134	May 25, 2020	-	Passed	0.2600	Passed	
Charles P. Allen High School	Girls Wash Room 3030 tap 1	MSA135	May 25, 2020	-	Passed	0.6500	Passed	
Charles P. Allen High School	Girls Wash Room 3030 tap 2	MSA136	May 25, 2020	-	Passed	0.5600	Passed	
Charles P. Allen High School	Girls Wash Room 3030 tap 3	MSA137	May 25, 2020	-	Passed	0.6500	Passed	
Charles P. Allen High School	Gender Neutral Wash Room 3059	MSA138	May 25, 2020	-	Passed	0.3800	Passed	
Charles P. Allen High School	Class Room 3060 tap 1	MSA139	May 25, 2020	-	Passed	0.8900	Passed	
Charles P. Allen High School	Class Room 3060 tap 2	MSA140	May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room 3060 tap 3	MSA141	May 25, 2020	-	Passed	0.5900	Passed	
Charles P. Allen High School	Mechanical Room ST.9.1 tap	MSA142	May 25, 2020	-	Passed	0.1100	Passed	
Charles P. Allen High School	Class Room 3061 tap	MSA143	May 25, 2020	-	Passed	0.1500	Passed	
Charles P. Allen High School	Science Lab 3062 tap 1	MSA144	May 25, 2020	-	Passed	0.1700	Passed	
Charles P. Allen High School	Science Lab 3062 tap 2	MSA145	May 25, 2020	-	Passed	0.0970	Passed	
Charles P. Allen High School	Science Lab 3062 tap 3	MSA146	May 25, 2020	-	Passed	1.2000	Passed	
Charles P. Allen High School	Change Room 3052A	MSA147	May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room 3051 tap 1	MSA148	May 25, 2020	-	Passed	0.2200	Passed	
Charles P. Allen High School	Class Room 3051 tap 2	MSA149	May 25, 2020	-	Passed	0.9300	Passed	
Charles P. Allen High School	Class Room 3051 tap 3	MSA150	May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room 3051 tap 4	MSA151	May 25, 2020	-	Passed	0.1100	Passed	
Charles P. Allen High School	Class Room 3051 tap 5	MSA152	May 25, 2020	-	Passed	1.2000	Passed	
Charles P. Allen High School	Class Room 3050 tap	MSA153	May 25, 2020	-	Passed	0.1100	Passed	
Charles P. Allen High School	Class Room 3049 tap 1	MSA154	May 25, 2020	-	Passed	0.3600	Passed	
Charles P. Allen High School	Class Room 3049 tap 2	MSA155	May 25, 2020	-	Passed	0.1600	Passed	
Charles P. Allen High School	Girls Wash Room 3046 tap 1	MSA157	May 25, 2020	-	Passed	0.7100	Passed	
Charles P. Allen High School	Girls Wash Room 3046 tap 2	MSA158	May 25, 2020	-	Passed	0.6200	Passed	
Charles P. Allen High School	Girls Wash Room 3046 tap 3	MSA159	May 25, 2020	-	Passed	0.6200	Passed	
Charles P. Allen High School	Staff Wash Room 3047 tap	MSA160	May 25, 2020	-	Passed	0.6800	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Charles P. Allen High School	Chemistry Lab 3044 tap 1	MSA161	May 25, 2020	0.003	Passed	0.7500	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 2	MSA162	May 25, 2020	-	Passed	0.5000	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 3	MSA163	May 25, 2020	-	Passed	0.6400	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 4	MSA164	May 25, 2020	-	Passed	0.6100	Passed	
Charles P. Allen High School	Multipurpose Lab 3041 tap 1	MSA165	May 25, 2020	-	Passed	0.8300	Passed	
Charles P. Allen High School	Multipurpose Lab 3041 tap 2	MSA166	May 25, 2020	-	Passed	0.8100	Passed	
Charles P. Allen High School	Multipurpose Lab 3041 tap 3	MSA167	May 25, 2020	-	Passed	1.0000	Passed	
Charles P. Allen High School	Multipurpose Lab 3041 tap 4	MSA168	May 25, 2020	-	Passed	0.3700	Passed	
Charles P. Allen High School	Multipurpose Lab 3041 tap 5	MSA169	May 25, 2020	-	Passed	1.2000	Passed	
Charles P. Allen High School	Multipurpose Lab 3041 tap 6	MSA170	May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Boys Wash Room 3045 tap 1	MSA171	May 25, 2020	-	Passed	0.9300	Passed	
Charles P. Allen High School	Boys Wash Room 3045 tap 2	MSA172	May 25, 2020	-	Passed	0.8300	Passed	
Charles P. Allen High School	Boys Wash Room 3045 tap 3	MSA173	May 25, 2020	-	Passed	1.0000	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 1	MSA174	May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 2	MSA175	May 25, 2020	-	Passed	0.7400	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 3	MSA176	May 25, 2020	-	Passed	0.6100	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 4	MSA177	May 25, 2020	-	Passed	0.8000	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 5	MSA178	May 25, 2020	-	Passed	0.7900	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 6	MSA179	May 25, 2020	-	Passed	0.6800	Passed	
Charles P. Allen High School	Chemistry Lab 3044 tap 7	MSA180	May 25, 2020	-	Passed	0.9900	Passed	
Charles P. Allen High School	Janitors Closet 3048 tap	MSA181	May 25, 2020	-	Passed	0.2600	Passed	
Charles P. Allen High School	Multipurpose Lab 3041 tap 7	MSA182	May 25, 2020	-	Passed	0.1600	Passed	
Charles P. Allen High School	Multipurpose Lab 3041 tap 8	MSA183	May 25, 2020	-	Passed	0.2800	Passed	
Charles P. Allen High School	Music Room 1069 tap	NES631	July 24, 2020	-	Passed	0.0620	Passed	
Charles P. Allen High School	Fountain by Room 1015	WBC983	June 7, 2023	-	Passed	0.1800	Passed	
Charles P. Allen High School	Fountain by Room 1003	WBC984	June 7, 2023	-	Passed	0.2600	Passed	
Charles P. Allen High School	Fountain by Room 1054	WBC985	June 7, 2023	-	Passed	0.0820	Passed	
Charles P. Allen High School	Fountain by Wash Room 2008A	WBC986	June 7, 2023	-	Passed	0.2100	Passed	
Charles P. Allen High School	Fountain by Class Room 2028	WBC987	June 7, 2023	-	Passed	0.2100	Passed	
Charles P. Allen High School	Fountain by Learning Centre 2049	WBC988	June 7, 2023	-	Passed	0.1000	Passed	
Charles P. Allen High School	Fountain by Locker Room 2065	WBC989	June 7, 2023	-	Passed	0.2300	Passed	
Charles P. Allen High School	Fountain by Locker Room 2067	WBC990	June 7, 2023	-	Passed	0.2900	Passed	
Charles P. Allen High School	Fountain before Room 3046	WBC991	June 7, 2023	-	Passed	0.1100	Passed	
Charles P. Allen High School	Fountain by Room 3028	WBC992	June 7, 2023	-	Passed	0.1900	Passed	
Charles P. Allen High School	Fountain by Room 3006	WBD033	June 7, 2023	-	Passed	0.2400	Passed	
Charles P. Allen High School	Cafeteria tap 1	WBD034	June 7, 2023	-	Passed	0.1000	Passed	
Charles P. Allen High School	Cafeteria tap 2	WBD035	June 7, 2023	-	Passed	0.2600	Passed	
Chebucto Heights Elementary	2nd Floor Girls Wash Room tap 1	MQS753	May 19, 2020	0.002	Passed	0.0910	Passed	
Chebucto Heights Elementary	2nd Floor Girls Wash Room tap 2	MQS754	May 19, 2020	0.004	Passed	0.0700	Passed	
Chebucto Heights Elementary	2nd Floor Girls Wash Room tap 3	MQS755	May 19, 2020	0.002	Passed	0.1500	Passed	
Chebucto Heights Elementary	2nd Floor Boys Wash Room tap 1	MQS757	May 19, 2020	0.003	Passed	0.0670	Passed	
Chebucto Heights Elementary	2nd Floor Boys Wash Room tap 2	MQS758	May 19, 2020	0.003	Passed	0.0620	Passed	
Chebucto Heights Elementary	2nd Floor Boys Wash Room tap 3	MQS759	May 19, 2020	0.001	Passed	0.0720	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Chebucto Heights Elementary	2nd Floor Boys Wash Room tap 4	MQS760	May 19, 2020	0.002	Passed	0.0730	Passed	
Chebucto Heights Elementary	Class Room 203 tap	MQS761	May 19, 2020	0.003	Passed	0.0220	Passed	
Chebucto Heights Elementary	Janitors Closet tap by Room 202	MQS762	May 19, 2020	0.001	Passed	0.0069	Passed	
Chebucto Heights Elementary	Class Room 202 tap	MQS763	May 19, 2020	0.002	Passed	0.0150	Passed	
Chebucto Heights Elementary	Class Room 116 tap 2	MQS766	May 19, 2020	0.002	Passed	0.0900	Passed	
Chebucto Heights Elementary	Class Room 213 tap	MQS767	May 19, 2020	0.003	Passed	0.0780	Passed	
Chebucto Heights Elementary	Boys Locker Room 152 tap	MQS768	May 19, 2020	0.002	Passed	0.1200	Passed	
Chebucto Heights Elementary	Janitors Closet 157 tap	MQS769	May 19, 2020	0.002	Passed	0.1800	Passed	
Chebucto Heights Elementary	Girls Locker Room 147 tap	MQS771	May 19, 2020	0.002	Passed	0.0960	Passed	
Chebucto Heights Elementary	Janitors Closet tap by Gym	MQS773	May 19, 2020	0.001	Passed	0.1600	Passed	
Chebucto Heights Elementary	Girls Wash Room 114 tap 1	MQS775	May 19, 2020	-	Passed	0.0130	Passed	
Chebucto Heights Elementary	Girls Wash Room 114 tap 2	MQS776	May 19, 2020	0.001	Passed	0.0180	Passed	
Chebucto Heights Elementary	Girls Wash Room 114 tap 3	MQS777	May 19, 2020	0.002	Passed	0.0430	Passed	
Chebucto Heights Elementary	Boys Wash Room 115 tap 1	MQS778	May 19, 2020	0.001	Passed	0.0028	Passed	
Chebucto Heights Elementary	Boys Wash Room 115 tap 2	MQS779	May 19, 2020	-	Passed	0.0018	Passed	
Chebucto Heights Elementary	Boys Wash Room 115 tap 3	MQS780	May 19, 2020	-	Passed	0.0025	Passed	
Chebucto Heights Elementary	Boys Wash Room 115 tap 4	MQS781	May 19, 2020	0.001	Passed	0.0078	Passed	
Chebucto Heights Elementary	Class Room 120 tap	MQS782	May 19, 2020	0.002	Passed	0.0330	Passed	
Chebucto Heights Elementary	Janitors Closet 121 tap	MQS784	May 19, 2020	-	Passed	0.0057	Passed	
Chebucto Heights Elementary	Class Room 124 Wash Room tap	MQS786	May 19, 2020	0.001	Passed	0.0220	Passed	
Chebucto Heights Elementary	Staff Wash Room 112 tap 1	MQS788	May 19, 2020	0.001	Passed	0.0260	Passed	
Chebucto Heights Elementary	Staff Wash Room 112 tap 2	MQS789	May 19, 2020	0.001	Passed	0.0240	Passed	
Chebucto Heights Elementary	Health Room 109 Wash Room tap	MQS792	May 19, 2020	0.002	Passed	0.1400	Passed	
Chebucto Heights Elementary	Class Room 212 tap	NKX388	August 21, 2020	0.000	Passed	0.0100	Passed	
Chebucto Heights Elementary	Class Room 116 tap 1	NKX389	August 21, 2020	0.004	Passed	0.0100	Passed	
Chebucto Heights Elementary	Class Room 124 tap	NKX390	August 21, 2020	0.001	Passed	0.0040	Passed	
Chebucto Heights Elementary	Fountain by Room 132	VQL844	April 25, 2023	-	Passed	0.0120	Passed	
Chebucto Heights Elementary	Gender Neutral Wash Room 120 tap	VQL845	April 25, 2023	-	Passed	0.0230	Passed	Tap remediated
Chebucto Heights Elementary	Staff Room tap	VQL846	April 25, 2023	-	Passed	0.0240	Passed	
Chebucto Heights Elementary	Fountain by Gym	VQL847	April 25, 2023	-	Passed	0.0620	Passed	
Chebucto Heights Elementary	Gym Office Wash Room tap	VQL848	April 25, 2023	0.001	Passed	0.0620	Passed	Tap remediated
Chebucto Heights Elementary	Class Room 212A tap	VQL849	April 25, 2023	0.001	Passed	0.0370	Passed	Tap remediated
Chebucto Heights Elementary	2nd Floor Girls Wash Room tap 4	VQL850	April 25, 2023	-	Passed	0.0480	Passed	Tap remediated
Chebucto Heights Elementary	Fountain by Room 220	VQL851	April 25, 2023	-	Passed	0.0024	Passed	
Chebucto Heights Elementary	Gym Kitchen tap	VQL852	May 19, 2020	0.003	Passed	0.5000	Passed	Tap remediated
Chebucto Heights Elementary	Break Room tap	VQL853	April 25, 2023	0.001	Passed	0.0560	Passed	
Citadel High School	Biology Lab 209 tap 1	MTU825	June 1, 2020	-	Passed	0.0400	Passed	
Citadel High School	Biology Lab 209 tap 2	MTU826	June 1, 2020	-	Passed	0.0600	Passed	
Citadel High School	Biology Lab 209 tap 3	MTU827	June 1, 2020	-	Passed	0.0480	Passed	
Citadel High School	Biology Lab 209 tap 4	MTU828	June 1, 2020	-	Passed	0.0330	Passed	
Citadel High School	Biology Lab 209 tap 5	MTU829	June 1, 2020	-	Passed	0.0300	Passed	
Citadel High School	Science Lab 210 tap 2	MTU831	June 1, 2020	0.003	Passed	0.2400	Passed	
Citadel High School	Science Lab 210 tap 3	MTU832	June 1, 2020	0.002	Passed	0.1500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Citadel High School	Science Lab 210 tap 4	MTU833	June 1, 2020	-	Passed	0.0320	Passed	
Citadel High School	Science Lab 210 tap 5	MTU834	June 1, 2020	-	Passed	0.0170	Passed	
Citadel High School	Physics Lab 212 tap 1	MTU839	June 1, 2020	0.002	Passed	0.2300	Passed	
Citadel High School	Physics Lab 212 tap 2	MTU840	June 1, 2020	0.002	Passed	0.1800	Passed	
Citadel High School	Physics Lab 212 tap 3	MTU841	June 1, 2020	0.002	Passed	0.1500	Passed	
Citadel High School	Physics Lab 212 tap 4	MTU842	June 1, 2020	-	Passed	0.0220	Passed	
Citadel High School	Physics Lab 212 tap 5	MTU843	June 1, 2020	-	Passed	0.0170	Passed	
Citadel High School	Physics Lab 213 tap 1	MTU844	June 1, 2020	0.001	Passed	0.0620	Passed	
Citadel High School	Physics Lab 213 tap 2	MTU845	June 1, 2020	-	Passed	0.0270	Passed	
Citadel High School	Physics Lab 213 tap 3	MTU846	June 1, 2020	-	Passed	0.0350	Passed	
Citadel High School	Physics Lab 213 tap 4	MTU847	June 1, 2020	0.001	Passed	0.0840	Passed	
Citadel High School	Physics Lab 213 tap 5	MTU848	June 1, 2020	-	Passed	0.0310	Passed	
Citadel High School	2nd Floor Boys Wash Room tap 1	MTU855	June 1, 2020	0.001	Passed	0.0980	Passed	
Citadel High School	2nd Floor Boys Wash Room tap 2	MTU856	June 1, 2020	0.001	Passed	0.0550	Passed	
Citadel High School	2nd Floor Boys Wash Room tap 3	MTU857	June 1, 2020	0.001	Passed	0.0700	Passed	
Citadel High School	2nd Floor Boys Wash Room tap 4	MTU858	June 1, 2020	-	Passed	0.0490	Passed	
Citadel High School	2nd Floor Boys Wash Room tap 5	MTU859	June 1, 2020	0.001	Passed	0.0400	Passed	
Citadel High School	2nd Floor Girls Wash Room tap 1	MTU862	June 1, 2020	-	Passed	0.0440	Passed	
Citadel High School	2nd Floor Girls Wash Room tap 2	MTU863	June 1, 2020	0.001	Passed	0.0710	Passed	
Citadel High School	2nd Floor Girls Wash Room tap 3	MTU864	June 1, 2020	0.001	Passed	0.1100	Passed	
Citadel High School	2nd Floor Girls Wash Room tap 4	MTU868	June 1, 2020	0.001	Passed	0.0940	Passed	
Citadel High School	2nd Floor Girls Wash Room tap 5	MTU869	June 1, 2020	0.001	Passed	0.0590	Passed	
Citadel High School	Class Room Wash Room 220 tap	MTU870	June 1, 2020	-	Passed	0.0180	Passed	
Citadel High School	Library sink tap	MTU872	June 1, 2020	-	Passed	0.0930	Passed	
Citadel High School	Class Room tap by Room 221	MTU873	June 1, 2020	-	Passed	0.0910	Passed	
Citadel High School	Janitors Closet tap by Room 221	MTU874	June 1, 2020	-	Passed	0.0200	Passed	
Citadel High School	Boiler Room tap	MTU887	June 1, 2020	-	Passed	0.2400	Passed	
Citadel High School	1st Floor Boys Wash Room tap 1	MTU888	June 1, 2020	0.001	Passed	0.0930	Passed	
Citadel High School	1st Floor Boys Wash Room tap 2	MTU889	June 1, 2020	-	Passed	0.0470	Passed	
Citadel High School	1st Floor Boys Wash Room tap 3	MTU890	June 1, 2020	0.003	Passed	0.0760	Passed	
Citadel High School	1st Floor Boys Wash Room tap 5	MTU895	June 1, 2020	-	Passed	0.0440	Passed	
Citadel High School	Janitors Closet tap by Staff Room	MTU898	June 1, 2020	-	Passed	0.1300	Passed	
Citadel High School	1st Floor Girls Wash Room tap 1 by JC	MTU899	June 1, 2020	0.002	Passed	0.1000	Passed	
Citadel High School	1st Floor Girls Wash Room tap 2 by JC	MTU900	June 1, 2020	0.003	Passed	0.3700	Passed	
Citadel High School	1st Floor Girls Wash Room tap 3 by JC	MTU901	June 1, 2020	0.001	Passed	0.1400	Passed	
Citadel High School	1st Floor Girls Wash Room tap 4 by JC	MTU902	June 1, 2020	0.001	Passed	0.0870	Passed	
Citadel High School	Tech Ed tap Room 115	MTU906	June 1, 2020	-	Passed	0.0170	Passed	
Citadel High School	Gender Neutral Wash Room tap Room 120	MTU907	June 1, 2020	-	Passed	0.0540	Passed	
Citadel High School	Class Room tap Room 120	MTU908	June 1, 2020	-	Passed	0.0660	Passed	
Citadel High School	Girls Locker Room tap 1	MTU913	June 1, 2020	-	Passed	0.0510	Passed	
Citadel High School	Janitors Closet tap near Gym	MTU915	June 1, 2020	0.002	Passed	0.1700	Passed	
Citadel High School	Boys Locker Room tap 1	MTU917	June 1, 2020	0.001	Passed	0.2600	Passed	
Citadel High School	Boys Locker Room tap 2 Room 153	MTU918	June 1, 2020	0.003	Passed	0.1200	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Citadel High School	Recycling Room tap	MTU920	June 1, 2020	-	Passed	0.0590	Passed	
Citadel High School	Drama Room tap Room 122	MTU921	June 1, 2020	-	Passed	0.0230	Passed	
Citadel High School	Boys Wash Room tap 1 by Room 122	MTU922	June 1, 2020	0.001	Passed	0.0400	Passed	
Citadel High School	Boys Wash Room tap 2 by Room 122	MTU923	June 1, 2020	-	Passed	0.0310	Passed	
Citadel High School	Boys Wash Room tap 3 by Room 122	MTU924	June 1, 2020	-	Passed	0.0640	Passed	
Citadel High School	Boys Wash Room tap 4 by Room 122	MTU925	June 1, 2020	-	Passed	0.0380	Passed	
Citadel High School	Janitors Closet tap by Boys Wash Room	MTU926	June 1, 2020	-	Passed	0.0320	Passed	
Citadel High School	1st Floor Girls Wash Room tap 1	MTU927	June 1, 2020	-	Passed	0.0520	Passed	
Citadel High School	1st Floor Girls Wash Room tap 2	MTU928	June 1, 2020	-	Passed	0.0470	Passed	
Citadel High School	1st Floor Girls Wash Room tap 4	MTU930	June 1, 2020	0.002	Passed	0.0360	Passed	
Citadel High School	1st Floor Girls Wash Room tap 5	MTU931	June 1, 2020	0.002	Passed	0.0990	Passed	
Citadel High School	1st Floor Girls Wash Room tap 6	MTU932	June 1, 2020	0.001	Passed	0.0410	Passed	
Citadel High School	1st Floor Girls Wash Room tap 7	MTU933	June 1, 2020	0.001	Passed	0.0570	Passed	
Citadel High School	Class Room 301 tap 1	MTV128	June 1, 2020	-	Passed	0.0360	Passed	
Citadel High School	Class Room 301 tap 2	MTV129	June 1, 2020	-	Passed	0.0250	Passed	
Citadel High School	Class Room 302 tap 1	MTV130	June 1, 2020	-	Passed	0.1400	Passed	
Citadel High School	Class Room 302 tap 2	MTV131	June 1, 2020	-	Passed	0.1300	Passed	
Citadel High School	Class Room 311 tap 2	MTV135	June 1, 2020	0.001	Passed	0.1600	Passed	
Citadel High School	Class Room 311 tap 3	MTV136	June 1, 2020	0.001	Passed	0.0920	Passed	
Citadel High School	Class Room 311 tap 4	MTV137	June 1, 2020	-	Passed	0.0580	Passed	
Citadel High School	Class Room 311 tap 5	MTV155	June 1, 2020	0.001	Passed	0.0880	Passed	
Citadel High School	Class Room 312 tap 1	MTV156	June 1, 2020	0.001	Passed	0.1100	Passed	
Citadel High School	Class Room 312 tap 2	MTV157	June 1, 2020	0.001	Passed	0.0690	Passed	
Citadel High School	Class Room 312 tap 3	MTV158	June 1, 2020	-	Passed	0.0610	Passed	
Citadel High School	Class Room 312 tap 4	MTV159	June 1, 2020	-	Passed	0.0560	Passed	
Citadel High School	Class Room 314 tap 1	MTV160	June 1, 2020	0.001	Passed	0.0560	Passed	
Citadel High School	Class Room 314 tap 2	MTV161	June 1, 2020	-	Passed	0.0400	Passed	
Citadel High School	Class Room 314 tap 3	MTV162	June 1, 2020	0.001	Passed	0.0530	Passed	
Citadel High School	Class Room 314 tap 4	MTV163	June 1, 2020	0.001	Passed	0.0710	Passed	
Citadel High School	Class Room 314 tap 5	MTV164	June 1, 2020	-	Passed	0.0420	Passed	
Citadel High School	Class Room 314 tap 6	MTV165	June 1, 2020	-	Passed	0.0490	Passed	
Citadel High School	Class Room 314 tap 7	MTV166	June 1, 2020	-	Passed	0.0510	Passed	
Citadel High School	Class Room 314 tap 8	MTV167	June 1, 2020	-	Passed	0.0480	Passed	
Citadel High School	Class Room 314 tap 9	MTV168	June 1, 2020	-	Passed	0.0160	Passed	
Citadel High School	Class Room 314 tap 10	MTV169	June 1, 2020	-	Passed	0.0300	Passed	
Citadel High School	Class Room 315 tap 1	MTV170	June 1, 2020	0.001	Passed	0.1000	Passed	
Citadel High School	Class Room 315 tap 2	MTV171	June 1, 2020	-	Passed	0.0430	Passed	
Citadel High School	Class Room 315 tap 3	MTV172	June 1, 2020	0.001	Passed	0.0520	Passed	
Citadel High School	Class Room 315 tap 4	MTV173	June 1, 2020	-	Passed	0.0510	Passed	
Citadel High School	Class Room 315 tap 5	MTV174	June 1, 2020	-	Passed	0.0430	Passed	
Citadel High School	Class Room 315 tap 6	MTV188	June 1, 2020	-	Passed	0.0380	Passed	
Citadel High School	Class Room 315 tap 7	MTV189	June 1, 2020	-	Passed	0.0220	Passed	
Citadel High School	Class Room 315 tap 8	MTV190	June 1, 2020	-	Passed	0.0140	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Citadel High School	Class Room 315 tap 9	MTV191	June 1, 2020	-	Passed	0.0140	Passed	
Citadel High School	Boys Wash Room 316 tap 1	MTV192	June 1, 2020	-	Passed	0.0550	Passed	
Citadel High School	Boys Wash Room 316 tap 2	MTV193	June 1, 2020	-	Passed	0.0410	Passed	
Citadel High School	Boys Wash Room 316 tap 3	MTV194	June 1, 2020	0.001	Passed	0.0590	Passed	
Citadel High School	Boys Wash Room 316 tap 4	MTV195	June 1, 2020	0.002	Passed	0.3300	Passed	
Citadel High School	Boys Wash Room 316 tap 5	MTV196	June 1, 2020	0.001	Passed	0.1200	Passed	
Citadel High School	Girls Wash Room tap 1 by Room 316	MTV197	June 1, 2020	0.001	Passed	0.2400	Passed	
Citadel High School	Girls Wash Room tap 2 by Room 316	MTV198	June 1, 2020	0.001	Passed	0.1400	Passed	
Citadel High School	Girls Wash Room tap 3 by Room 316	MTV199	June 1, 2020	0.002	Passed	0.4400	Passed	
Citadel High School	Girls Wash Room tap 4 by Room 316	MTV200	June 1, 2020	0.001	Passed	0.3000	Passed	
Citadel High School	Girls Wash Room tap 5 by Room 316	MTV201	June 1, 2020	0.001	Passed	0.3000	Passed	
Citadel High School	Class Room 321 tap 1	MTV205	June 1, 2020	-	Passed	0.1100	Passed	
Citadel High School	Class Room 321 tap 2	MTV206	June 1, 2020	-	Passed	0.0410	Passed	
Citadel High School	Class Room 321 tap 3	MTV207	June 1, 2020	-	Passed	0.0380	Passed	
Citadel High School	Class Room 321 tap 4	MTV208	June 1, 2020	-	Passed	0.0310	Passed	
Citadel High School	Gender Neutral Wash Room tap by Room 321	MTV209	June 1, 2020	-	Passed	0.0410	Passed	
Citadel High School	Storage Room tap by 3rd Floor Janitors Closet	MTV210	June 1, 2020	-	Passed	0.1800	Passed	
Citadel High School	3rd Floor Janitors Closet tap	MTV211	June 1, 2020	-	Passed	0.0330	Passed	
Citadel High School	Class Room 312 tap 5	MTV215	June 1, 2020	0.001	Passed	0.1300	Passed	
Citadel High School	1st Floor Girls Wash Room tap 3	NDO548	July 17, 2020	-	Passed	0.0360	Passed	
Citadel High School	1st Floor Girls Wash Room tap 5 by JC	NDO549	July 17, 2020	0.001	Passed	0.0480	Passed	
Citadel High School	2nd Floor Fountain by Elevator	VYO044	May 30, 2023	-	Passed	0.0950	Passed	
Citadel High School	1st Floor Fountain by Elevator	VYO045	May 30, 2023	-	Passed	0.0680	Passed	
Citadel High School	Cafeteria/Kitchen tap 1	VYO046	May 30, 2023	0.001	Passed	0.4800	Passed	
Citadel High School	Cafeteria/Kitchen tap 2	VYO047	May 30, 2023	0.001	Passed	0.2000	Passed	
Citadel High School	Cafeteria/Kitchen tap 3	VYO048	May 30, 2023	-	Passed	0.1200	Passed	
Citadel High School	Cafeteria/Kitchen tap 4	VYO049	May 30, 2023	-	Passed	0.1000	Passed	
Citadel High School	Cafeteria/Kitchen tap 5	VYO050	May 30, 2023	-	Passed	0.3600	Passed	
Citadel High School	Fountain by Room 103	VYO051	May 30, 2023	-	Passed	0.0980	Passed	
Citadel High School	Fountain by Room 106	VYO052	May 30, 2023	-	Passed	0.0630	Passed	
Citadel High School	1st Floor Boys Wash Room tap 4	VYO053	May 30, 2023	-	Passed	0.1500	Passed	Tap remediated
Citadel High School	3rd Floor Staff Room tap 1	VYO073	May 30, 2023	-	Passed	0.1100	Passed	
Citadel High School	3rd Floor Staff Room tap 2	VYO074	May 30, 2023	-	Passed	0.1700	Passed	
Citadel High School	3rd Floor Staff Room tap 3	VYO075	May 30, 2023	-	Passed	0.1200	Passed	
Citadel High School	2nd Floor Staff Room tap 1	VYO076	May 30, 2023	-	Passed	0.1800	Passed	
Citadel High School	2nd Floor Staff Room tap 2	VYO077	May 30, 2023	-	Passed	0.1100	Passed	
Citadel High School	Fountain by Room 308	VYO078	May 30, 2023	-	Passed	0.0760	Passed	
Citadel High School	Fountain by Room 305	VYO079	May 30, 2023	-	Passed	0.1500	Passed	
Citadel High School	2nd Floor Teen Health Room tap	VYO080	May 30, 2023	-	Passed	0.1500	Passed	
Citadel High School	Fountain by Room 203	VYO081	May 30, 2023	-	Passed	0.0890	Passed	
Citadel High School	Fountain by Room 206	VYO082	May 30, 2023	-	Passed	0.0980	Passed	
Citadel High School	1st Floor Staff Room tap 1	VYO113	May 30, 2023	0.001	Passed	0.2200	Passed	
Citadel High School	1st Floor Staff Room tap 2	VYO114	May 30, 2023	0.001	Passed	0.1300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Citadel High School	Main Office tap 1	VYO115	May 30, 2023	-	Passed	0.1100	Passed	
Citadel High School	Main Office tap 2	VYO116	May 30, 2023	-	Passed	0.1200	Passed	
Citadel High School	Fountain by Girls Locker Room	VYO117	May 30, 2023	-	Passed	0.1200	Passed	
Citadel High School	Fountain by Boys Locker Room	VYO118	May 30, 2023	-	Passed	0.1400	Passed	
Citadel High School	Girls Locker Room tap 2	VYO119	May 30, 2023	-	Passed	0.2200	Passed	Tap remediated
Citadel High School	1st Floor Staff Wash Room	VYO120	May 30, 2023	-	Passed	0.3200	Passed	Tap remediated
Citadel High School	Science Lab 210 tap 1	VYO121	May 30, 2023	-	Passed	0.1600	Passed	Tap remediated
Clayton Park Junior High School	Janitors Closet tap by Room 214	MRM448	May 21, 2020	-	Passed	0.0580	Passed	
Clayton Park Junior High School	Boys Wash Room tap 1 by Room 200	MRM449	May 21, 2020	-	Passed	0.0200	Passed	
Clayton Park Junior High School	Boys Wash Room tap 2 by Room 200	MRM450	May 21, 2020	0.001	Passed	0.0390	Passed	
Clayton Park Junior High School	Staff Wash Room tap by Room 200	MRM453	May 21, 2020	-	Passed	0.0160	Passed	
Clayton Park Junior High School	Girls Wash Room tap 1 by Room 200	MRM454	May 21, 2020	0.002	Passed	0.4200	Passed	
Clayton Park Junior High School	Girls Wash Room tap 2 by Room 200	MRM455	May 21, 2020	0.001	Passed	0.3500	Passed	
Clayton Park Junior High School	Girls Wash Room tap 3 by Room 200	MRM456	May 21, 2020	0.001	Passed	0.2400	Passed	
Clayton Park Junior High School	Class Room 145 tap	MRM469	May 21, 2020	0.005	Passed	0.2200	Passed	
Clayton Park Junior High School	Conference Room 134 Wash Room tap	MRM470	May 21, 2020	0.004	Passed	0.0950	Passed	
Clayton Park Junior High School	Wash Room tap by Conference Room 134	MRM472	May 21, 2020	-	Passed	0.1100	Passed	
Clayton Park Junior High School	Boys Locker Room tap by Room 121	MRM473	May 21, 2020	0.001	Passed	0.0370	Passed	
Clayton Park Junior High School	Boys Wash Room tap 1 by Room 100	MRM476	May 21, 2020	-	Passed	0.0084	Passed	
Clayton Park Junior High School	Boys Wash Room tap 2 by Room 100	MRM477	May 21, 2020	-	Passed	0.0140	Passed	
Clayton Park Junior High School	Boys Wash Room tap 3 by Room 100	MRM478	May 21, 2020	0.002	Passed	0.0530	Passed	
Clayton Park Junior High School	Janitors Closet tap by Room 100	MRM480	May 21, 2020	-	Passed	0.0099	Passed	
Clayton Park Junior High School	Girls Wash Room tap 1 by Room 104	MRM481	May 21, 2020	-	Passed	0.0600	Passed	
Clayton Park Junior High School	Girls Wash Room tap 2 by Room 104	MRM482	May 21, 2020	-	Passed	0.0840	Passed	
Clayton Park Junior High School	Janitors Closet tap by Room 003	MRM485	May 21, 2020	0.001	Passed	0.0650	Passed	
Clayton Park Junior High School	Class Room tap Room 023	MRM488	May 21, 2020	-	Passed	0.0830	Passed	
Clayton Park Junior High School	Class Room tap Room 025	MRM489	May 21, 2020	-	Passed	0.0470	Passed	
Clayton Park Junior High School	Principals Office Wash Room tap Room 117	MRM490	May 21, 2020	0.001	Passed	0.0280	Passed	
Clayton Park Junior High School	Art Room tap by Gym	MRM491	May 21, 2020	0.001	Passed	0.0730	Passed	
Clayton Park Junior High School	Fountain by Room 118	WAT319	June 6, 2023	-	Passed	0.0180	Passed	
Clayton Park Junior High School	Family Studies tap 1 by Room 106	WAT320	June 6, 2023	0.001	Passed	0.0480	Passed	
Clayton Park Junior High School	Family Studies tap 2 by Room 106	WAT321	June 6, 2023	-	Passed	0.0450	Passed	
Clayton Park Junior High School	Family Studies tap 4 by Room 106	WAT323	June 6, 2023	-	Passed	0.0230	Passed	
Clayton Park Junior High School	Family Studies tap 5 by Room 106	WAT324	June 6, 2023	-	Passed	0.0220	Passed	
Clayton Park Junior High School	Staff Room 104 tap	WAT325	June 6, 2023	-	Passed	0.0320	Passed	
Clayton Park Junior High School	Fountain by Room 100B	WAT326	June 6, 2023	-	Passed	0.0410	Passed	
Clayton Park Junior High School	Fountain by Room 200	WAT327	May 21, 2020	-	Passed	0.0340	Passed	
Clayton Park Junior High School	Boys Wash Room tap 3 by Room 200	WAT329	June 6, 2023	-	Passed	0.0220	Passed	
Clayton Park Junior High School	Family Studies tap 3 by Room 106	WAT332	June 6, 2023	-	Passed	0.0420	Passed	
Clayton Park Junior High School	Band Room Kitchen tap by Room 144	WAT362	June 6, 2023	0.004	Passed	0.0660	Passed	Tap remediated
Clayton Park Junior High School	Band Room Closet Kitchen tap by Room 144	WAT363	June 6, 2023	0.003	Passed	0.0410	Passed	Tap remediated
Clayton Park Junior High School	Class Room 214 tap	WAT364	June 6, 2023	0.002	Passed	0.2300	Passed	Tap remediated
Clayton Park Junior High School	Girls Wash Room tap 3 by Room 104	WAT365	June 6, 2023	-	Passed	0.0260	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Clayton Park Junior High School	Girls Locker Room tap by Room 114	WAT366	June 6, 2023	0.001	Passed	0.1000	Passed	Tap remediated
Clayton Park Junior High School	Conference Room 134 tap	WAT367	June 6, 2023	0.001	Passed	0.0360	Passed	
Clayton Park Junior High School	Modular Janitors Closet tap	WAT368	June 6, 2023	-	Passed	0.1100	Passed	
Clayton Park Junior High School	Modular Girls Wash Room tap 1	WAT369	June 6, 2023	-	Passed	0.1100	Passed	
Clayton Park Junior High School	Modular Girls Wash Room tap 2	WAT370	June 6, 2023	-	Passed	0.0940	Passed	
Clayton Park Junior High School	Modular Girls Wash Room tap 3	WAT371	June 6, 2023	0.001	Passed	0.1000	Passed	
Clayton Park Junior High School	Modular Boys Wash Room tap 1	WAT375	June 6, 2023	-	Passed	0.0650	Passed	
Clayton Park Junior High School	Modular Boys Wash Room tap 2	WAT376	June 6, 2023	-	Passed	0.0620	Passed	
Clayton Park Junior High School	Modular Staff Wash Room tap	WAT377	June 6, 2023	-	Passed	0.2400	Passed	
Clayton Park Junior High School	Fountain in Modular	WAT378	June 6, 2023	-	Passed	0.0037	Passed	
Clayton Park Junior High School	Modular Gender Neutral Wash Room tap	WAT379	June 6, 2023	-	Passed	0.0960	Passed	
Colby Village Elementary	Class Room 203 tap	XDA400	September 26, 2023	-	Passed	0.0150	Passed	Tap remediated
Colby Village Elementary	Boys Wash Room 216 tap 1	XDA401	September 26, 2023	0.001	Passed	0.1200	Passed	Tap remediated
Colby Village Elementary	Boys Wash Room 216 tap 2	MWG571	June 12, 2020	0.004	Passed	0.1300	Passed	
Colby Village Elementary	Boys Wash Room 216 tap 3	MWG572	June 12, 2020	0.003	Passed	0.0270	Passed	
Colby Village Elementary	Boys Wash Room 216 tap 4	MWG573	June 12, 2020	0.003	Passed	0.0250	Passed	
Colby Village Elementary	Janitors Closet tap by Gym	MWG574	June 12, 2020	0.001	Passed	0.0520	Passed	
Colby Village Elementary	Fountain by Gym	XDA385	September 26, 2023	-	Passed	0.0710	Passed	
Colby Village Elementary	Girls Wash Room 214 tap 1	MWG576	June 12, 2020	0.004	Passed	0.0660	Passed	
Colby Village Elementary	Girls Wash Room 214 tap 2	MWG577	June 12, 2020	0.004	Passed	0.0640	Passed	
Colby Village Elementary	Girls Wash Room 214 tap 3	XDA399	September 26, 2023	-	Passed	0.0170	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 214 tap 4	MWG579	June 12, 2020	0.005	Passed	0.0670	Passed	
Colby Village Elementary	Gender Neutral Wash Room 215 tap	MWG580	June 12, 2020	0.004	Passed	0.0700	Passed	
Colby Village Elementary	Gender Neutral Wash Room 217 tap	XDA384	September 26, 2023	-	Passed	0.0650	Passed	Tap remediated
Colby Village Elementary	Boys Wash Room 114 tap 1	XDA402	June 12, 2020	-	Passed	0.0140	Passed	
Colby Village Elementary	Boys Wash Room 114 tap 2	MWG583	June 12, 2020	0.003	Passed	0.2600	Passed	
Colby Village Elementary	Boys Wash Room 114 tap 3	XDA403	September 26, 2023	-	Passed	0.0068	Passed	Tap remediated
Colby Village Elementary	Boys Wash Room 114 tap 4	XDA404	September 26, 2023	-	Passed	0.0061	Passed	Tap remediated
Colby Village Elementary	Janitors Closet tap by Staff Room 105	MWG586	June 12, 2020	0.001	Passed	0.0470	Passed	
Colby Village Elementary	Fountain by Staff Room 105	XDA377	September 26, 2023	-	Passed	0.0039	Passed	
Colby Village Elementary	Girls Wash Room 110 tap 1	XDA378	September 26, 2023	0.003	Passed	0.2600	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 110 tap 2	XDA379	September 26, 2023	0.002	Passed	0.1400	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 110 tap 3	XDA380	September 26, 2023	0.001	Passed	0.0390	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 110 tap 4	XDA381	September 26, 2023	0.001	Passed	0.0520	Passed	Tap remediated
Colby Village Elementary	Staff Room Wash Room 105B tap	XDA382	September 26, 2023	-	Passed	0.0260	Passed	Tap remediated
Colby Village Elementary	Staff Room Wash Room 105A tap	XDA383	September 26, 2023	-	Passed	0.0260	Passed	Tap remediated
Colby Village Elementary	Staff Room 105 tap	XDA376	September 26, 2023	-	Passed	0.0280	Passed	
Cole Harbour District High School	Breakfast Room tap 1	XDF150	September 27, 2023	-	Passed	0.0210	Passed	
Cole Harbour District High School	Breakfast Room tap 2	XDF151	September 27, 2023	-	Passed	0.0190	Passed	
Cole Harbour District High School	Breakfast Room tap 3	XDF152	September 27, 2023	-	Passed	0.0140	Passed	
Cole Harbour District High School	Breakfast Room tap 4	XDF153	September 27, 2023	-	Passed	0.0130	Passed	
Cole Harbour District High School	Fountain by Room 308	XDF149	September 27, 2023	-	Passed	0.0820	Passed	
Cole Harbour District High School	Staff Wash Room tap by Room 308	MXH629	June 17, 2020	0.001	Passed	0.0660	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Cole Harbour District High School	Boys Wash Room tap 1 by Room 309	MXH630	June 17, 2020	0.004	Passed	0.2500	Passed	
Cole Harbour District High School	Boys Wash Room tap 2 by Room 309	MXH631	June 17, 2020	0.002	Passed	0.3400	Passed	
Cole Harbour District High School	Janitors Closet tap by Room 309	MXH632	June 17, 2020	0.001	Passed	0.1600	Passed	
Cole Harbour District High School	Girls Wash Room tap 1 by Room 309	XDF154	September 27, 2023	0.001	Passed	0.1500	Passed	Tap remediated
Cole Harbour District High School	Girls Wash Room tap 2 by Room 309	MXH635	June 17, 2020	0.003	Passed	0.2300	Passed	
Cole Harbour District High School	Server Room tap in Library	XDF154	September 27, 2023	0.025	Exceeded	0.0560	Passed	Hand washing only
Cole Harbour District High School	Learning Centre Wash Room tap	MXH638	June 17, 2020	0.001	Passed	1.2000	Passed	
Cole Harbour District High School	Learning Centre tap	XDF169	September 27, 2023	-	Passed	0.1300	Passed	
Cole Harbour District High School	Gender Neutral Wash Room tap by Learning Centre	MXH640	June 17, 2020	-	Passed	0.7000	Passed	
Cole Harbour District High School	Fountain by Room 208	XDF147	September 27, 2023	-	Passed	0.0530	Passed	
Cole Harbour District High School	Staff Room 208 tap	XDF148	September 27, 2023	-	Passed	0.0480	Passed	
Cole Harbour District High School	Staff Wash Room tap by Room 208	MXH642	June 17, 2020	0.004	Passed	0.0710	Passed	
Cole Harbour District High School	Boys Wash Room tap 1 by Cafeteria	XDF167	September 27, 2023	0.001	Passed	0.0620	Passed	Tap remediated
Cole Harbour District High School	Boys Wash Room tap 2 by Cafeteria	MXH645	June 17, 2020	0.001	Passed	0.1100	Passed	
Cole Harbour District High School	Boys Wash Room tap 3 by Cafeteria	MXH646	June 17, 2020	0.002	Passed	0.0950	Passed	
Cole Harbour District High School	Janitors Closet tap by Cafeteria	MXH647	June 17, 2020	0.001	Passed	0.0450	Passed	
Cole Harbour District High School	Girls Wash Room tap 1 by Janitors Closet	MXH648	June 17, 2020	0.005	Passed	0.1900	Passed	
Cole Harbour District High School	Girls Wash Room tap 2 by Janitors Closet	MXH649	June 17, 2020	0.002	Passed	0.1200	Passed	
Cole Harbour District High School	Girls Wash Room tap 3 by Janitors Closet	XDF168	September 27, 2023	0.001	Passed	0.0490	Passed	Tap remediated
Cole Harbour District High School	Student Services Gender Neutral Wash Room tap	MXH651	June 17, 2020	-	Passed	0.5600	Passed	
Cole Harbour District High School	Fountain by Cafeteria	XDF141	September 27, 2023	-	Passed	0.4900	Passed	
Cole Harbour District High School	Cafeteria/Kitchen handwashing tap	XDF144	September 27, 2023	-	Passed	0.0610	Passed	
Cole Harbour District High School	Cafeteria/Kitchen single compartment sink tap	XDF143	September 27, 2023	-	Passed	0.0770	Passed	
Cole Harbour District High School	Cafeteria/Kitchen triple compartment sink tap	XDF142	September 27, 2023	-	Passed	0.0850	Passed	
Cole Harbour District High School	Male Locker Room tap 1	XDF170	September 27, 2023	-	Passed	0.1800	Passed	Tap remediated
Cole Harbour District High School	Male Locker Room tap 2	MXH656	June 17, 2020	-	Passed	0.7900	Passed	
Cole Harbour District High School	Male Locker Room tap 3	MXH657	June 17, 2020	0.001	Passed	0.7800	Passed	
Cole Harbour District High School	Male Locker Room tap 4	MXH658	June 17, 2020	-	Passed	0.8200	Passed	
Cole Harbour District High School	Student Services Gender Neutral Wash Room tap	MXH659	June 17, 2020	0.002	Passed	0.8000	Passed	
Cole Harbour District High School	Female Locker Room tap 1	MXH660	June 17, 2020	-	Passed	0.6200	Passed	
Cole Harbour District High School	Female Locker Room tap 2	MXH661	June 17, 2020	0.001	Passed	0.6200	Passed	
Cole Harbour District High School	Female Locker Room tap 3	MXH662	June 17, 2020	-	Passed	0.4900	Passed	
Cole Harbour District High School	Female Locker Room tap 4	MXH663	June 17, 2020	-	Passed	0.4100	Passed	
Cole Harbour District High School	Air Handler Room tap	MXH664	June 17, 2020	-	Passed	0.3300	Passed	
Cole Harbour District High School	Fountain by Gym	XDF145	September 27, 2023	-	Passed	0.2200	Passed	
Cole Harbour District High School	Fountain in Skilled Trades Room	XDF146	September 27, 2023	0.001	Passed	0.3600	Passed	
Cole Harbour District High School	Staff Wash Room tap in main Office	MXH667	June 17, 2020	0.001	Passed	0.3700	Passed	
Cole Harbour District High School	Janitors Closet tap in Mechanical Room	XDF171	September 27, 2023	-	Passed	0.0220	Passed	Tap remediated
Cole Harbour District High School	Science Lab 120 tap 1	MXH669	June 17, 2020	0.006	Exceeded	0.1100	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 120 tap 2	MXH670	June 17, 2020	0.370	Exceeded	1.7000	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 120 tap 3	MXH671	June 17, 2020	0.013	Exceeded	0.8500	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 120 tap 4	MXH672	June 17, 2020	0.080	Exceeded	0.6500	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 120 tap 5	MXH673	June 17, 2020	0.036	Exceeded	1.1000	Passed	Laboratory or Hand washing only

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Cole Harbour District High School	Science Lab 120 tap 6	MXH674	June 17, 2020	0.100	Exceeded	0.9400	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 120 tap 7	MXH675	June 17, 2020	0.016	Exceeded	0.7400	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 120 tap 8	MXH676	June 17, 2020	0.026	Exceeded	0.9200	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Lab sink between Room 120 and 119	XDF166	September 27, 2023	0.004	Passed	0.0500	Passed	Tap remediated
Cole Harbour District High School	Science Lab 119 tap 1	MXH678	June 17, 2020	0.007	Exceeded	0.5600	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 2	MXH679	June 17, 2020	0.066	Exceeded	0.7400	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 3	MXH680	June 17, 2020	0.220	Exceeded	0.4700	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 4	MXH681	June 17, 2020	0.120	Exceeded	0.5000	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 5	MXH682	June 17, 2020	0.067	Exceeded	0.7200	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 6	MXH683	June 17, 2020	0.007	Exceeded	0.3900	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 7	MXH684	June 17, 2020	0.030	Exceeded	0.8500	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Fountain by Room 108	XDF161	September 27, 2023	0.002	Passed	0.0980	Passed	
Cole Harbour District High School	Girls Wash Room tap 1 by Room 108	XDF164	September 27, 2023	0.001	Passed	0.0430	Passed	Tap remediated
Cole Harbour District High School	Girls Wash Room tap 2 by Room 108	MXH687	June 17, 2020	0.004	Passed	0.1600	Passed	
Cole Harbour District High School	Staff Wash Room tap By Room 108	XDF162	September 27, 2023	-	Passed	0.0170	Passed	Tap remediated
Cole Harbour District High School	Boys Wash Room tap 1 by Room 108	MXH689	June 17, 2020	0.002	Passed	0.0950	Passed	
Cole Harbour District High School	Boys Wash Room tap 2 by Room 108	XDF163	September 27, 2023	0.001	Passed	0.0420	Passed	Tap remediated
Cole Harbour District High School	Fountain by Room 117	XDF156	September 27, 2023	-	Passed	0.1300	Passed	
Cole Harbour District High School	Janitors Closet tap by Room 117	XDF157	September 27, 2023	-	Passed	0.0150	Passed	Tap remediated
Cole Harbour District High School	Gender Neutral Wash Room tap Room 116	MXH694	June 17, 2020	0.003	Passed	0.3600	Passed	
Cole Harbour District High School	Science Lab 115 tap 1	MXH696	June 17, 2020	0.094	Exceeded	0.8200	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 115 tap 2	MXH697	June 17, 2020	0.061	Exceeded	0.3200	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 115 tap 3	MXH698	June 17, 2020	0.030	Exceeded	0.7900	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 115 tap 4	MXH699	June 17, 2020	0.093	Exceeded	0.5600	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 114 tap 1	MXH700	June 17, 2020	0.052	Exceeded	2.4000	Exceeded	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 114 tap 2	MXH701	June 17, 2020	0.017	Exceeded	1.5000	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 114 tap 3	MXH702	June 17, 2020	0.007	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 114 tap 4	MXH703	June 17, 2020	0.010	Exceeded	0.1600	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 113 tap 1	MXH704	June 17, 2020	0.083	Exceeded	0.7500	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 113 tap 2	MXH705	June 17, 2020	0.011	Exceeded	1.1000	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 113 tap 3	MXH706	June 17, 2020	1.100	Exceeded	0.5200	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Janitors Closet 112 tap	XDF165	September 27, 2023	0.001	Passed	0.0860	Passed	Tap remediated
Cole Harbour District High School	Class Room 109 tap 1	XDF158	September 27, 2023	0.002	Passed	0.1000	Passed	Tap remediated
Cole Harbour District High School	Class Room 109 tap 2	XDF159	September 27, 2023	0.001	Passed	0.0700	Passed	Tap remediated
Cole Harbour District High School	Class Room 116 tap	XDF160	September 27, 2023	0.001	Passed	0.2800	Passed	Tap remediated
Cole Harbour District High School	Class Room 117 tap	NMD829	August 27, 2020	0.000	Passed	0.0260	Passed	
Cole Harbour District High School	Class Room 118 tap	NMD841	August 27, 2020	0.000	Passed	0.0040	Passed	
Colonel John Stuart Elementary	Fountain by Main Entrance	XGX863	October 13, 2023	-	Passed	0.0810	Passed	
Colonel John Stuart Elementary	Wash Room by Gym	MWG653	June 12, 2020	0.001	Passed	0.1700	Passed	
Colonel John Stuart Elementary	Class Room 101 tap	NMD725	August 27, 2020	0.001	Passed	0.1600	Passed	
Colonel John Stuart Elementary	Class Room 102 tap 1	XGX861	October 13, 2023	-	Passed	0.0520	Passed	
Colonel John Stuart Elementary	Class Room 102 tap 2	XGX862	October 13, 2023	-	Passed	0.0480	Passed	
Colonel John Stuart Elementary	Staff Room Wash Room 1 tap	MWG656	June 12, 2020	0.001	Passed	0.0510	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Colonel John Stuart Elementary	Staff Room Wash Room 2 tap	MWG657	June 12, 2020	0.002	Passed	0.0840	Passed	
Colonel John Stuart Elementary	Staff Room tap	XGX859	October 13, 2023	-	Passed	0.0200	Passed	
Colonel John Stuart Elementary	Janitors Closet by Wash Rooms tap	MWG659	June 12, 2020	0.001	Passed	0.1000	Passed	
Colonel John Stuart Elementary	Girls Wash Room tap 1 by fountain	MWG660	June 12, 2020	0.004	Passed	0.0990	Passed	
Colonel John Stuart Elementary	Girls Wash Room tap 2 by fountain	MWG661	June 12, 2020	0.004	Passed	0.0670	Passed	
Colonel John Stuart Elementary	Girls Wash Room tap 3 by fountain	MWG662	June 12, 2020	0.003	Passed	0.0540	Passed	
Colonel John Stuart Elementary	Girls Wash Room tap 4 by fountain	MWG663	June 12, 2020	0.004	Passed	0.0880	Passed	
Colonel John Stuart Elementary	Fountain between Wash Rooms	XGX860	October 13, 2023	-	Passed	0.0290	Passed	
Colonel John Stuart Elementary	Boys Wash Room tap 1 by fountain	MWG665	June 12, 2020	0.003	Passed	0.1700	Passed	
Colonel John Stuart Elementary	Boys Wash Room tap 2 by fountain	MWG666	June 12, 2020	0.003	Passed	0.1100	Passed	
Colonel John Stuart Elementary	Boys Wash Room tap 3 by fountain	MWG667	June 12, 2020	0.004	Passed	0.0930	Passed	
Creighton Park Elementary	Staff Room 107 tap	XBL635	September 19, 2023	-	Passed	0.0130	Passed	
Creighton Park Elementary	Fountain by Main Entrance	XBL541	September 19, 2023	-	Passed	0.0270	Passed	
Creighton Park Elementary	Girls Wash Room 109 tap 1	XBL629	September 19, 2023	-	Passed	0.0150	Passed	Tap remediated
Creighton Park Elementary	Girls Wash Room 109 tap 2	MYR665	June 24, 2020	0.001	Passed	0.0790	Passed	
Creighton Park Elementary	Girls Wash Room 109 tap 3	MYR666	June 24, 2020	0.003	Passed	0.1800	Passed	
Creighton Park Elementary	Girls Wash Room 109 tap 4	MYR667	June 24, 2020	0.002	Passed	0.1100	Passed	
Creighton Park Elementary	Fountain by Room 110	XBL628	September 19, 2023	-	Passed	0.1200	Passed	
Creighton Park Elementary	Boys Wash Room 111 tap 1	XBL630	September 19, 2023	-	Passed	0.0033	Passed	Tap remediated
Creighton Park Elementary	Boys Wash Room 111 tap 2	XBL631	September 19, 2023	-	Passed	0.0046	Passed	Tap remediated
Creighton Park Elementary	Boys Wash Room 111 tap 3	MYR672	June 24, 2020	-	Passed	0.0080	Passed	
Creighton Park Elementary	Janitors Closet tap in Boys Wash Room 111	XBL632	September 19, 2023	0.001	Passed	0.0065	Passed	Tap remediated
Creighton Park Elementary	Janitors Closet tap in Boiler Room	MYR673	June 24, 2020	0.001	Passed	0.0170	Passed	
Creighton Park Elementary	Gym Office 125 tap	XBL596	September 19, 2023	0.001	Passed	0.0680	Passed	Tap remediated
Creighton Park Elementary	Class Room 126 tap	XKK081	October 26, 2023	0.004	Passed	0.2500	Passed	Tap remediated
Creighton Park Elementary	Boys Wash Room 122 tap	XBL594	September 19, 2023	-	Passed	0.0120	Passed	Tap remediated
Creighton Park Elementary	Fountain by Room 121	XBL633	September 19, 2023	-	Passed	0.1000	Passed	
Creighton Park Elementary	Janitors Closet 121 tap	MYR687	June 24, 2020	0.005	Passed	0.0640	Passed	
Creighton Park Elementary	Girls Wash Room 120 tap	MYR705	June 24, 2020	-	Passed	0.0082	Passed	
Creighton Park Elementary	Class Room 101 Wash Room tap	XBL593	September 19, 2023	0.001	Passed	0.0320	Passed	Tap remediated
Creighton Park Elementary	Class Room 102 Wash Room tap	XBL637	September 19, 2023	0.003	Passed	0.0550	Passed	Tap remediated
Creighton Park Elementary	Class Room 103 Wash Room tap	XBL636	September 19, 2023	0.001	Passed	0.0310	Passed	Tap remediated
Creighton Park Elementary	Boys Wash Room 204 tap 1	XBL595	September 19, 2023	-	Passed	0.0840	Passed	Tap remediated
Creighton Park Elementary	Boys Wash Room 204 tap 2	MYR677	June 24, 2020	0.001	Passed	0.0150	Passed	
Creighton Park Elementary	Janitors Closet 205 tap	XBL600	September 19, 2023	-	Passed	0.0070	Passed	Tap remediated
Creighton Park Elementary	Girls Wash Room 206 tap 1	XBL598	September 19, 2023	0.001	Passed	0.0076	Passed	Tap remediated
Creighton Park Elementary	Girls Wash Room 206 tap 2	XBL599	September 19, 2023	-	Passed	0.0067	Passed	Tap remediated
Creighton Park Elementary	Class Room 208 tap	XBL540	September 19, 2023	0.003	Passed	0.0370	Passed	Tap remediated
Creighton Park Elementary	Staff Room 203 Wash Room tap	XKK062	October 26, 2023	-	Passed	0.0230	Passed	Tap remediated
Creighton Park Elementary	Staff Room 203 tap	XBL601	September 19, 2023	0.001	Passed	0.0340	Passed	Tap remediated
Creighton Park Elementary	Fountain by Room 201	XBL597	September 19, 2023	-	Passed	0.0013	Passed	
Cunard Junior High School	Boys Wash Room 209 tap 1	MRE108	May 20, 2020	0.002	Passed	0.1700	Passed	
Cunard Junior High School	Boys Wash Room 209 tap 2	MRE109	May 20, 2020	0.001	Passed	0.0900	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Cunard Junior High School	Boys Wash Room 209 tap 3	MRE110	May 20, 2020	0.001	Passed	0.0680	Passed	
Cunard Junior High School	Boys Wash Room 209 tap 4	MRE111	May 20, 2020	0.001	Passed	0.0630	Passed	
Cunard Junior High School	Janitors Closet 210 tap	MRE112	May 20, 2020	-	Passed	0.0190	Passed	
Cunard Junior High School	Girls Wash Room 211 tap 1	MRE114	May 20, 2020	-	Passed	0.0760	Passed	
Cunard Junior High School	Girls Wash Room 211 tap 2	MRE115	May 20, 2020	0.001	Passed	0.0470	Passed	
Cunard Junior High School	Girls Wash Room 211 tap 3	MRE116	May 20, 2020	-	Passed	0.0550	Passed	
Cunard Junior High School	Girls Wash Room 211 tap 4	MRE117	May 20, 2020	-	Passed	0.0390	Passed	
Cunard Junior High School	Fountain by Room 211	VQL894	April 25, 2023	-	Passed	0.0017	Passed	
Cunard Junior High School	Family Studies 212 tap 1	VQL890	April 25, 2023	-	Passed	0.0024	Passed	
Cunard Junior High School	Family Studies 212 tap 2	VQL891	April 25, 2023	-	Passed	0.0013	Passed	
Cunard Junior High School	Family Studies 212 tap 3	VQL892	April 25, 2023	-	Passed	0.0015	Passed	
Cunard Junior High School	Guidance Room 215 tap	MRE121	May 20, 2020	0.003	Passed	0.0520	Passed	
Cunard Junior High School	Gender Neutral Wash Room 216 tap	MRE122	May 20, 2020	-	Passed	0.0300	Passed	
Cunard Junior High School	Staff Room 200 tap	VQL893	April 25, 2023	-	Passed	0.0021	Passed	
Cunard Junior High School	Boys Wash Room 107 tap 1	VQL889	April 25, 2023	-	Passed	0.0036	Passed	Tap remediated
Cunard Junior High School	Boys Wash Room 107 tap 2	MRE126	May 20, 2020	0.001	Passed	0.0560	Passed	
Cunard Junior High School	Boys Wash Room 107 tap 3	MRE127	May 20, 2020	-	Passed	0.0220	Passed	
Cunard Junior High School	Boys Wash Room 107 tap 4	MRE136	May 20, 2020	0.001	Passed	0.0300	Passed	
Cunard Junior High School	Janitors Closet 108 tap	MRE137	May 20, 2020	0.003	Passed	0.0810	Passed	
Cunard Junior High School	Girls Wash Room 109 tap 1	VQL887	April 25, 2023	-	Passed	0.0019	Passed	Tap remediated
Cunard Junior High School	Girls Wash Room 109 tap 2	MRE140	May 20, 2020	0.003	Passed	0.0390	Passed	
Cunard Junior High School	Girls Wash Room 109 tap 3	MRE141	May 20, 2020	0.004	Passed	0.0350	Passed	
Cunard Junior High School	Girls Wash Room 109 tap 4	VQL888	April 25, 2023	-	Passed	0.0022	Passed	Tap remediated
Cunard Junior High School	Wood Shop 113 tap	MRE144	May 20, 2020	0.003	Passed	0.3200	Passed	
Cunard Junior High School	Main Office Wash Room tap	MRE145	May 20, 2020	-	Passed	0.0190	Passed	
Cunard Junior High School	Class Room 106 tap	NKX298	August 14, 2020	0.000	Passed	0.0041	Passed	
Cunard Junior High School	Fountain by Room 108	VQL886	April 25, 2023	-	Passed	0.0017	Passed	
Dartmouth High School	Main Office Wash Room tap	MYV801	June 24, 2020	-	Passed	0.1300	Passed	
Dartmouth High School	Fountain by Office	XBD404	September 15, 2023	-	Passed	0.1000	Passed	
Dartmouth High School	Health Centre Gender Neutral Wash Room tap	MYV803	June 24, 2020	0.001	Passed	0.9100	Passed	
Dartmouth High School	Fountain by Health Centre	XBD400	September 15, 2023	-	Passed	0.1700	Passed	
Dartmouth High School	Boys Wash Room tap 1 by Gym	MYV805	June 24, 2020	0.001	Passed	0.0260	Passed	
Dartmouth High School	Boys Wash Room tap 2 by Gym	MYV806	June 24, 2020	0.001	Passed	0.0320	Passed	
Dartmouth High School	Girls Wash Room tap 1 by Gym	MYV807	June 24, 2020	0.002	Passed	0.0390	Passed	
Dartmouth High School	Girls Wash Room tap 1 by Gym	MYV808	June 24, 2020	0.001	Passed	0.0470	Passed	
Dartmouth High School	Girls Locker Room 164 tap 1	MYV809	June 24, 2020	0.001	Passed	0.0310	Passed	
Dartmouth High School	Girls Locker Room 164 tap 2	MYV810	June 24, 2020	0.001	Passed	0.0980	Passed	
Dartmouth High School	Gym Office Wash Room 161 tap	NAI329	June 29, 2020	0.003	Passed	0.6500	Passed	
Dartmouth High School	Gym Office Wash Room 162 tap	MYV811	June 24, 2020	-	Passed	0.6300	Passed	
Dartmouth High School	Boys Locker Room 166 tap 1	MYV812	June 24, 2020	0.001	Passed	0.0160	Passed	
Dartmouth High School	Boys Locker Room 166 tap 2	NAI301	June 29, 2020	-	Passed	0.2000	Passed	
Dartmouth High School	Female Change Room 165 tap 1	MYV815	June 24, 2020	-	Passed	0.2900	Passed	
Dartmouth High School	Female Change Room 165 tap 2	MYV816	June 24, 2020	-	Passed	0.3600	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Dartmouth High School	Wash Room 107 tap	RVY018	February 14, 2022	0.017	Exceeded	0.6000	Passed	Hand washing only
Dartmouth High School	Fountain by Room 107	XBD392	September 15, 2023	-	Passed	0.0320	Passed	
Dartmouth High School	Chemistry Lab 106 tap 1	RVY014	February 14, 2022	-	Passed	0.4200	Passed	
Dartmouth High School	Chemistry Lab 106 tap 2	MYV819	June 24, 2020	0.001	Passed	0.0280	Passed	
Dartmouth High School	Chemistry Lab 106 tap 3	MYV820	June 24, 2020	0.002	Passed	0.2800	Passed	
Dartmouth High School	Chemistry Lab 106 tap 4	MYV821	June 24, 2020	0.001	Passed	0.3800	Passed	
Dartmouth High School	Chemistry Lab 106 tap 5	MYV822	June 24, 2020	0.001	Passed	0.3900	Passed	
Dartmouth High School	Chemistry Lab 106 tap 6	MYV823	June 24, 2020	0.001	Passed	0.0890	Passed	
Dartmouth High School	Chemistry Lab 106 tap 7	MYV824	June 24, 2020	0.001	Passed	0.1700	Passed	
Dartmouth High School	Chemistry Lab 106 tap 8	MYV825	June 24, 2020	0.001	Passed	0.2500	Passed	
Dartmouth High School	Chemistry Lab 106 tap 9	MYV826	June 24, 2020	0.001	Passed	0.1700	Passed	
Dartmouth High School	Physics Lab tap 1 by Room 106	RVY015	February 14, 2022	0.007	Exceeded	0.2800	Passed	Laboratory or hand washing only
Dartmouth High School	Physics Lab tap 2 by Room 106	RVY016	February 14, 2022	0.009	Exceeded	0.9700	Passed	Laboratory or hand washing only
Dartmouth High School	Physics Lab Wash Room tap	RVY017	February 14, 2022	0.001	Passed	0.9700	Passed	
Dartmouth High School	Fountain near Physics Lab	XBD397	September 15, 2023	-	Passed	0.0005	Passed	
Dartmouth High School	Boys Wash Room tap 1 by Room 106	RVY019	February 14, 2022	0.001	Passed	1.3000	Passed	
Dartmouth High School	Boys Wash Room tap 2 by Room 106	RVY020	February 14, 2022	0.001	Passed	0.4200	Passed	
Dartmouth High School	Boys Wash Room tap 3 by Room 106	RVY021	February 14, 2022	-	Passed	0.4100	Passed	
Dartmouth High School	Janitors Closet tap by Room 106	MYV834	June 24, 2020	0.001	Passed	0.0880	Passed	
Dartmouth High School	Girls Wash Room tap 1 by Room 107	RVY022	February 14, 2022	-	Passed	0.4000	Passed	
Dartmouth High School	Girls Wash Room tap 2 by Room 107	RVY023	February 14, 2022	-	Passed	0.4200	Passed	
Dartmouth High School	Girls Wash Room tap 3 by Room 107	RVY024	February 14, 2022	0.001	Passed	0.2200	Passed	
Dartmouth High School	Class Room 112 tap	XDB395	September 15, 2023	0.038	Exceeded	0.6700	Passed	Hand washing only
Dartmouth High School	Class Room 114 tap	RVY046	February 14, 2022	0.002	Passed	0.4400	Passed	
Dartmouth High School	Class Room 116 tap	RVY026	February 14, 2022	0.003	Passed	0.2300	Passed	
Dartmouth High School	Fountain by Room 115	XBD394	September 15, 2023	-	Passed	0.0021	Passed	
Dartmouth High School	Girls Wash Room tap 1 by Room 112	MYV844	June 24, 2020	0.002	Passed	1.6000	Passed	
Dartmouth High School	Girls Wash Room tap 2 by Room 112	MYV845	June 24, 2020	0.001	Passed	0.3100	Passed	
Dartmouth High School	Girls Wash Room tap 3 by Room 112	MYV846	June 24, 2020	0.001	Passed	0.1800	Passed	
Dartmouth High School	Girls Wash Room tap 4 by Room 112	MYV847	June 24, 2020	0.001	Passed	0.2100	Passed	
Dartmouth High School	Janitors Closet tap by Room 112	MYV848	June 24, 2020	-	Passed	1.1000	Passed	
Dartmouth High School	Boys Wash Room tap 1 by Room 112	MYV849	June 24, 2020	-	Passed	0.1900	Passed	
Dartmouth High School	Boys Wash Room tap 2 by Room 112	XDB396	September 15, 2023	0.003	Passed	0.0890	Passed	Tap remediated
Dartmouth High School	Boys Wash Room tap 3 by Room 112	MYV851	June 24, 2020	0.002	Passed	0.5300	Passed	
Dartmouth High School	Boys Wash Room tap 4 by Room 112	MYV852	June 24, 2020	0.003	Passed	0.1300	Passed	
Dartmouth High School	Learning Centre tap 1	XBD398	September 15, 2023	-	Passed	0.0160	Passed	
Dartmouth High School	Learning Centre tap 2	XBD399	September 15, 2023	-	Passed	0.0380	Passed	
Dartmouth High School	Boys Wash Room tap 1 near Library	MYV855	June 24, 2020	0.001	Passed	0.0750	Passed	
Dartmouth High School	Boys Wash Room tap 2 near Library	MYV856	June 24, 2020	-	Passed	0.1100	Passed	
Dartmouth High School	Fountain by Library	XBD408	September 15, 2023	-	Passed	0.0230	Passed	
Dartmouth High School	Girls Wash Room tap 1 near Library	MYV858	June 24, 2020	0.001	Passed	0.0940	Passed	
Dartmouth High School	Girls Wash Room tap 2 near Library	MYV859	June 24, 2020	0.001	Passed	0.2700	Passed	
Dartmouth High School	Music Room 125 tap	XDB393	September 15, 2023	-	Passed	0.0440	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Dartmouth High School	Staff Room Wash Room 1 tap	RVY027	February 14, 2022	-	Passed	0.2700	Passed	
Dartmouth High School	Staff Room Wash Room 2 tap	RVY028	February 14, 2022	-	Passed	0.2700	Passed	
Dartmouth High School	Janitors Closet tap by Staff Room	MYV863	June 24, 2020	0.003	Passed	0.0820	Passed	
Dartmouth High School	Family Studies tap 1	XDW838	September 29, 2023	0.001	Passed	0.0690	Passed	
Dartmouth High School	Family Studies tap 2	XDW839	September 29, 2023	0.001	Passed	0.0490	Passed	
Dartmouth High School	Family Studies tap 3	XDW840	September 29, 2023	0.001	Passed	0.0820	Passed	
Dartmouth High School	Family Studies tap 4	XDW841	September 29, 2023	0.001	Passed	0.0420	Passed	
Dartmouth High School	Family Studies tap 5	XDW842	September 29, 2023	-	Passed	0.0370	Passed	
Dartmouth High School	Class Room 120 tap 1	MYV870	June 24, 2020	0.001	Passed	0.1300	Passed	
Dartmouth High School	Class Room 120 tap 2	RVY044	February 14, 2022	0.001	Passed	0.1400	Passed	
Dartmouth High School	Tech Ed Room tap	MYV872	June 24, 2020	0.001	Passed	1.7000	Passed	
Dartmouth High School	Cafeteria/Kitchen tap 1	XBD405	September 15, 2023	0.001	Passed	0.0490	Passed	
Dartmouth High School	Cafeteria/Kitchen tap 2	XBD406	September 15, 2023	0.001	Passed	0.0470	Passed	
Dartmouth High School	Cafeteria/Kitchen tap 3	XBD407	September 15, 2023	0.001	Passed	0.0740	Passed	
Dartmouth High School	Fountain by Room 251	XBD390	September 15, 2023	-	Passed	0.0480	Passed	
Dartmouth High School	Air Handling Room 251 tap	RVY030	February 14, 2022	0.001	Passed	0.2300	Passed	
Dartmouth High School	Staff Wash Room tap by Room 213	RVY031	February 14, 2022	0.001	Passed	0.2000	Passed	
Dartmouth High School	Biology Lab tap 1 Room 213	RVY032	February 14, 2022	0.005	Passed	0.2300	Passed	
Dartmouth High School	Biology Lab tap 2 Room 213	RVY033	February 14, 2022	0.001	Passed	0.1900	Passed	
Dartmouth High School	Biology Lab tap 3 Room 213	RVY034	February 14, 2022	0.002	Passed	0.1500	Passed	
Dartmouth High School	Biology Lab tap 4 Room 213	RVY035	February 14, 2022	0.002	Passed	0.1600	Passed	
Dartmouth High School	Biology Lab tap 5 Room 213	RVY036	February 14, 2022	0.009	Exceeded	0.4900	Passed	Laboratory or hand washing only
Dartmouth High School	Class Room 213A tap	RVY037	February 14, 2022	0.002	Passed	0.2300	Passed	
Dartmouth High School	Boys Wash Room tap 1 by Room 213	RVY038	February 14, 2022	0.001	Passed	0.1100	Passed	
Dartmouth High School	Boys Wash Room tap 2 by Room 213	MYV886	June 24, 2020	0.003	Passed	0.1100	Passed	
Dartmouth High School	Boys Wash Room tap 3 by Room 213	MYV887	June 24, 2020	0.002	Passed	0.1100	Passed	
Dartmouth High School	Janitors Closet tap by Room 213	RVY039	February 14, 2022	0.002	Passed	0.4000	Passed	
Dartmouth High School	Girls Wash Room tap 1 by Room 213	RVY040	February 14, 2022	0.002	Passed	0.2400	Passed	
Dartmouth High School	Girls Wash Room tap 2 by Room 213	MYV890	June 24, 2020	0.005	Passed	0.1200	Passed	
Dartmouth High School	Girls Wash Room tap 3 by Room 213	MYV891	June 24, 2020	0.004	Passed	0.1100	Passed	
Dartmouth High School	Girls Wash Room tap 4 by Room 213	MYV892	June 24, 2020	0.004	Passed	0.1100	Passed	
Dartmouth High School	Art Room 222 tap	RVY041	February 14, 2022	0.002	Passed	0.2600	Passed	
Dartmouth High School	Class Room tap 1 Room 223	MYV894	June 24, 2020	0.002	Passed	0.2000	Passed	
Dartmouth High School	Class Room tap 2 Room 223	MYV895	June 24, 2020	0.001	Passed	0.4600	Passed	
Dartmouth High School	Fountain by Room 209	XBD391	September 15, 2023	-	Passed	0.0330	Passed	
Dartmouth High School	Girls Wash Room tap 1 by Room 201	MYV898	June 24, 2020	0.001	Passed	0.3200	Passed	
Dartmouth High School	Girls Wash Room tap 2 by Room 201	RVY043	February 14, 2022	0.001	Passed	0.2300	Passed	
Dartmouth High School	Music Storage Room 201 tap	RVY042	February 14, 2022	0.011	Exceeded	0.4400	Passed	Out-of-Service
Dartmouth High School	Fountain by Room 201	MYV900	June 24, 2020	-	Passed	0.3400	Passed	Out-of-Service
Dartmouth High School	Girls Wash Room tap 1 by Room 208	MYV901	June 24, 2020	0.004	Passed	1.2000	Passed	
Dartmouth High School	Girls Wash Room tap 2 by Room 208	RVY047	February 14, 2022	-	Passed	1.5000	Passed	
Dartmouth High School	Girls Wash Room tap 3 by Room 208	MYV903	June 24, 2020	0.002	Passed	0.3300	Passed	
Dartmouth High School	Girls Wash Room tap 4 by Room 208	MYV904	June 24, 2020	0.001	Passed	0.1500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Dartmouth High School	Janitors Closet tap by Room 208	RVY045	February 14, 2022	0.001	Passed	0.2600	Passed	
Dartmouth High School	Boys Wash Room tap 1 by Room 208	MYV906	June 24, 2020	0.002	Passed	1.6000	Passed	
Dartmouth High School	Boys Wash Room tap 2 by Room 208	MYV907	June 24, 2020	0.001	Passed	0.6400	Passed	
Dartmouth High School	Boys Wash Room tap 3 by Room 208	MYV908	June 24, 2020	0.001	Passed	0.5100	Passed	
Dartmouth High School	Boys Wash Room tap 4 by Room 208	MYV909	June 24, 2020	0.001	Passed	0.5600	Passed	
Dartmouth High School	2nd Floor Staff Room tap 1	XBD401	September 15, 2023	-	Passed	0.0580	Passed	
Dartmouth High School	2nd Floor Staff Room tap 2	XBD402	September 15, 2023	-	Passed	0.0360	Passed	
Dartmouth High School	2nd Floor Staff Room tap 3	XBD403	September 15, 2023	-	Passed	0.0310	Passed	
Dartmouth South Academy	Main Office Wash Room tap	MYV778	June 24, 2020	-	Passed	0.5100	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 140 tap	MYV779	June 24, 2020	-	Passed	0.0850	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 142 tap 1	MYV780	June 24, 2020	0.001	Passed	0.1100	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 142 tap 2	MYV781	June 24, 2020	0.001	Passed	0.0940	Passed	
Dartmouth South Academy	Class Room 148 Wash Room tap 1	MYV782	June 24, 2020	-	Passed	0.0880	Passed	
Dartmouth South Academy	Class Room 148 Wash Room tap 2	MYV783	June 24, 2020	0.001	Passed	0.1200	Passed	
Dartmouth South Academy	Class Room 148 tap	MYV784	June 24, 2020	-	Passed	0.1600	Passed	
Dartmouth South Academy	Class Room 150 tap	MYV785	June 24, 2020	-	Passed	0.0480	Passed	
Dartmouth South Academy	Class Room 152 tap	MYV786	June 24, 2020	-	Passed	0.1200	Passed	
Dartmouth South Academy	Class Room 155 tap	MYV787	June 24, 2020	-	Passed	0.2400	Passed	
Dartmouth South Academy	Class Room 153 tap	MYV788	June 24, 2020	0.001	Passed	0.2400	Passed	
Dartmouth South Academy	Class Room 151 tap	MYV789	June 24, 2020	-	Passed	0.3400	Passed	
Dartmouth South Academy	Class Room 149 tap	NAI211	June 29, 2020	-	Passed	0.2600	Passed	
Dartmouth South Academy	Learning Centre Room 145 tap 1	XAD763	September 14, 2023	-	Passed	0.0540	Passed	
Dartmouth South Academy	Learning Centre Room 145 tap 2	XAD764	September 14, 2023	-	Passed	0.2200	Passed	
Dartmouth South Academy	Learning Centre Wash Room 145 tap	MYV793	June 24, 2020	-	Passed	0.0790	Passed	
Dartmouth South Academy	Janitors Closet Room 141 tap	MYV794	June 24, 2020	0.002	Passed	0.0890	Passed	
Dartmouth South Academy	Fountain by Room 135	XAD762	September 14, 2023	-	Passed	0.1100	Passed	
Dartmouth South Academy	Gym Change Room 133DB Wash Room tap	MYV797	June 24, 2020	0.001	Passed	0.2900	Passed	
Dartmouth South Academy	Gym Change Room 133DN tap	MYV798	June 24, 2020	0.001	Passed	0.1400	Passed	
Dartmouth South Academy	Gym Change Room 133DA tap	MYV799	June 24, 2020	0.001	Passed	0.1800	Passed	
Dartmouth South Academy	Music Room 131 tap 1	MYV800	June 24, 2020	-	Passed	0.2000	Passed	
Dartmouth South Academy	Music Room 131 tap 2	NAI150	June 29, 2020	-	Passed	0.0830	Passed	
Dartmouth South Academy	Library Room 102 tap	NAI151	June 29, 2020	-	Passed	0.0840	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106E tap	NAI152	June 29, 2020	0.002	Passed	0.1100	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106D tap	NAI153	June 29, 2020	-	Passed	0.0600	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106C tap	NAI154	June 29, 2020	0.001	Passed	0.0770	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106B tap	NAI155	June 29, 2020	-	Passed	0.0690	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106A tap	NAI156	June 29, 2020	-	Passed	0.0520	Passed	
Dartmouth South Academy	Fountain by Room 110A	XAB765	September 14, 2023	-	Passed	0.0540	Passed	
Dartmouth South Academy	Tech Ed Room 108 tap	NAI158	June 29, 2020	-	Passed	0.1600	Passed	
Dartmouth South Academy	Janitors Closet Room 112 tap	NAI159	June 29, 2020	-	Passed	0.1400	Passed	
Dartmouth South Academy	Innovation Lab Room 114 tap	XAB767	September 14, 2023	-	Passed	0.1700	Passed	
Dartmouth South Academy	Youth Health Room 107 tap	XAB766	September 14, 2023	-	Passed	0.0650	Passed	
Dartmouth South Academy	Recycle Room 101A tap	XAB761	September 14, 2023	-	Passed	0.1300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Dartmouth South Academy	Kitchen Room 103A tap 1	XAB755	September 14, 2023	-	Passed	0.1400	Passed	
Dartmouth South Academy	Kitchen Room 103A tap 2	XAB756	September 14, 2023	-	Passed	0.1200	Passed	
Dartmouth South Academy	Kitchen Room 103A sink tap 3	XAB760	September 14, 2023	-	Passed	0.1300	Passed	
Dartmouth South Academy	Janitors Closet Room 103B tap	NAI168	June 29, 2020	-	Passed	0.3800	Passed	
Dartmouth South Academy	Staff Room 204 tap	XAB753	September 14, 2023	-	Passed	0.1100	Passed	
Dartmouth South Academy	Staff Room Wash Room 204A tap	NAI170	June 29, 2020	0.002	Passed	0.1400	Passed	
Dartmouth South Academy	Staff Room Wash Room 204B tap	NAI171	June 29, 2020	0.001	Passed	0.0720	Passed	
Dartmouth South Academy	Fountain by Room 204	XAB752	September 14, 2023	-	Passed	0.1200	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206E tap	NAI174	June 29, 2020	0.001	Passed	0.0500	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206D tap	NAI175	June 29, 2020	0.002	Passed	0.0710	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206C tap	NAI176	June 29, 2020	0.001	Passed	0.1000	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206B tap	NAI177	June 29, 2020	0.001	Passed	0.0700	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206A tap	NAI178	June 29, 2020	-	Passed	0.0800	Passed	
Dartmouth South Academy	Family Studies Room 208 tap 1	XAB747	September 14, 2023	-	Passed	0.1200	Passed	
Dartmouth South Academy	Family Studies Room 208 tap 2	XAB748	September 14, 2023	-	Passed	0.1200	Passed	
Dartmouth South Academy	Family Studies Room 208 tap 3	XAB749	September 14, 2023	-	Passed	0.1300	Passed	
Dartmouth South Academy	Family Studies Room 208 tap 4	XAB750	September 14, 2023	-	Passed	0.1300	Passed	
Dartmouth South Academy	Family Studies Room 208 tap 5	XAB751	September 14, 2023	-	Passed	0.1200	Passed	
Dartmouth South Academy	Janitors Closet Room 214 tap	NAI190	June 29, 2020	-	Passed	0.2100	Passed	
Dartmouth South Academy	Art Room 230 tap 1	NAI191	June 29, 2020	0.002	Passed	0.1600	Passed	
Dartmouth South Academy	Art Room 230 tap 2	NAI192	June 29, 2020	0.001	Passed	0.1100	Passed	
Dartmouth South Academy	Art Room 230 tap 3	NAI193	June 29, 2020	-	Passed	0.8400	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 236 tap	NAI194	June 29, 2020	0.001	Passed	0.0700	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 238 tap 1	NAI195	June 29, 2020	0.001	Passed	0.1100	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 238 tap 2	NAI196	June 29, 2020	0.001	Passed	0.2100	Passed	
Dartmouth South Academy	Class Room 244 tap	NAI197	June 29, 2020	-	Passed	0.3900	Passed	
Dartmouth South Academy	Class Room 251 tap	NAI199	June 29, 2020	-	Passed	0.4800	Passed	
Dartmouth South Academy	Class Room 247 tap	NAI200	June 29, 2020	0.002	Passed	1.2000	Passed	
Dartmouth South Academy	Class Room 245 tap	NAI206	June 29, 2020	-	Passed	0.4500	Passed	
Dartmouth South Academy	Class Room 241 tap	NAI207	June 29, 2020	-	Passed	0.0700	Passed	
Dartmouth South Academy	Learning Centre Wash Room 239 tap	NAI208	June 29, 2020	0.002	Passed	0.0530	Passed	
Dartmouth South Academy	Janitors Closet Room 231 tap	NAI209	June 29, 2020	-	Passed	0.0370	Passed	
Dartmouth South Academy	Fountain by Room 231	XAB754	September 14, 2023	-	Passed	0.1000	Passed	
Dartmouth Teachers Centre	Operations Female Wash Room tap 1	XGV157	October 12, 2023	0.002	Passed	0.0310	Passed	
Dartmouth Teachers Centre	Operations Female Wash Room tap 2	XGV158	October 12, 2023	0.001	Passed	0.0220	Passed	
Dartmouth Teachers Centre	Operations Kitchen tap	XGV159	October 12, 2023	-	Passed	0.0270	Passed	
Dartmouth Teachers Centre	Operations Fountain by Meeting Room	XGV160	October 12, 2023	0.001	Passed	0.1200	Passed	
Dartmouth Teachers Centre	Operations Fountain by Wood Shop	XGV161	October 12, 2023	0.001	Passed	0.0300	Passed	
Dartmouth Teachers Centre	Operations Male Wash Room tap	XGV162	October 12, 2023	-	Passed	0.0150	Passed	
Dartmouth Teachers Centre	Operations Gender Neutral Wash Room tap	XGV163	October 12, 2023	-	Passed	0.0120	Passed	
Dartmouth Teachers Centre	Operations Paint Shop tap	XGV164	October 12, 2023	-	Passed	0.0170	Passed	
Dartmouth Teachers Centre	Operations Wood Shop tap	XGV164	October 12, 2023	-	Passed	0.0089	Passed	
Dartmouth Teachers Centre	Operations Wood Shop Lunch Room tap	XGV165	October 12, 2023	-	Passed	0.0190	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Dartmouth Teachers Centre	Music Centre Fountain by Entrance	XGT696	October 12, 2023	-	Passed	0.0780	Passed	
Dartmouth Teachers Centre	Music Centre Staff Wash Room tap	XGT697	October 12, 2023	-	Passed	0.0200	Passed	
Dartmouth Teachers Centre	Music Centre 2nd Floor Janitors Closet tap	XGT698	October 12, 2023	-	Passed	0.0110	Passed	
Dartmouth Teachers Centre	Music Centre Girls Wash Room tap 1	XGT699	October 12, 2023	0.001	Passed	0.0380	Passed	
Dartmouth Teachers Centre	Music Centre Girls Wash Room tap 2	XGT700	October 12, 2023	0.001	Passed	0.0390	Passed	
Dartmouth Teachers Centre	Music Centre Jarnold Room tap	XGT701	October 12, 2023	0.006	Exceeded	0.0240	Passed	Hand washing only
Dartmouth Teachers Centre	Music Centre Boys Wash Room tap 1	XGT702	October 12, 2023	0.003	Passed	0.0710	Passed	
Dartmouth Teachers Centre	Music Centre Boys Wash Room tap 2	XGT703	October 12, 2023	0.002	Passed	0.0880	Passed	
Dartmouth Teachers Centre	Music Centre Boys Wash Room tap 3	XGT704	October 12, 2023	0.001	Passed	0.0370	Passed	
Dartmouth Teachers Centre	Music Centre 1st Floor Janitors Closet tap	XGT705	October 12, 2023	-	Passed	0.0330	Passed	
Duc d'Anville Elementary	Class Room 230 tap	MRM311	May 21, 2020	0.002	Passed	0.0670	Passed	
Duc d'Anville Elementary	Boys Wash Room tap 1 by Room 230	MRM312	May 21, 2020	-	Passed	0.0140	Passed	
Duc d'Anville Elementary	Boys Wash Room tap 2 by Room 230	MRM313	May 21, 2020	0.001	Passed	0.0170	Passed	
Duc d'Anville Elementary	Boys Wash Room tap 3 by Room 230	MRM314	May 21, 2020	0.001	Passed	0.0220	Passed	
Duc d'Anville Elementary	Boys Wash Room tap 4 by Room 230	MRM315	May 21, 2020	0.001	Passed	0.0250	Passed	
Duc d'Anville Elementary	Girls Wash Room 250 tap 1	MRM318	May 21, 2020	0.001	Passed	0.0690	Passed	
Duc d'Anville Elementary	Girls Wash Room 250 tap 2	MRM319	May 21, 2020	-	Passed	0.0150	Passed	
Duc d'Anville Elementary	Girls Wash Room 250 tap 3	MRM320	May 21, 2020	-	Passed	0.0095	Passed	
Duc d'Anville Elementary	Girls Wash Room 250 tap 4	MRM328	May 21, 2020	-	Passed	0.0120	Passed	
Duc d'Anville Elementary	Staff Room 260 Wash Room tap	MRM329	May 21, 2020	0.001	Passed	0.0480	Passed	
Duc d'Anville Elementary	Boys Wash Room tap 1 by Room 134	MRM331	May 21, 2020	0.001	Passed	0.0780	Passed	
Duc d'Anville Elementary	Boys Wash Room tap 2 by Room 134	MRM332	May 21, 2020	-	Passed	0.0200	Passed	
Duc d'Anville Elementary	Boys Wash Room tap 3 by Room 134	MRM333	May 21, 2020	0.001	Passed	0.0140	Passed	
Duc d'Anville Elementary	Girls Wash Room 150 tap 1	MRM336	May 21, 2020	0.003	Passed	0.1200	Passed	
Duc d'Anville Elementary	Girls Wash Room 150 tap 2	MRM337	May 21, 2020	0.001	Passed	0.0096	Passed	
Duc d'Anville Elementary	Girls Wash Room 150 tap 3	MRM339	May 21, 2020	-	Passed	0.0150	Passed	
Duc d'Anville Elementary	Resources Room 326 Wash Room tap	MRM340	May 21, 2020	0.001	Passed	0.0200	Passed	
Duc d'Anville Elementary	Janitors Closet tap by Room 326	MRM341	May 21, 2020	0.001	Passed	0.0180	Passed	
Duc d'Anville Elementary	Class Room 405 tap	MRM342	May 21, 2020	0.001	Passed	0.6000	Passed	
Duc d'Anville Elementary	Gym Office 415 Wash Room tap	MRM343	May 21, 2020	0.001	Passed	0.0400	Passed	
Duc d'Anville Elementary	Janitors Closet tap by Room 415	MRM344	May 21, 2020	0.001	Passed	0.0230	Passed	
Duc d'Anville Elementary	Boys Wash Room 421 tap 1	MRM345	May 21, 2020	0.001	Passed	0.0390	Passed	
Duc d'Anville Elementary	Boys Wash Room 421 tap 2	MRM346	May 21, 2020	0.001	Passed	0.0650	Passed	
Duc d'Anville Elementary	Girls Wash Room 425 tap 1	MRM347	May 21, 2020	-	Passed	0.0180	Passed	
Duc d'Anville Elementary	Girls Wash Room 425 tap 2	MRM348	May 21, 2020	0.001	Passed	0.0180	Passed	
Duc d'Anville Elementary	Class Room 312 Wash Room tap	MRM350	May 21, 2020	0.004	Passed	0.0700	Passed	
Duc d'Anville Elementary	Class Room 311 Wash Room tap	MRM351	May 21, 2020	0.001	Passed	0.0440	Passed	
Duc d'Anville Elementary	Class Room 306 Wash Room tap	MRM352	May 21, 2020	0.003	Passed	0.0760	Passed	
Duc d'Anville Elementary	Class Room 307 Wash Room tap	MRM353	May 21, 2020	0.001	Passed	0.0510	Passed	
Duc d'Anville Elementary	Fountain in Modular	SHS313	June 6, 2023	-	Passed	0.0018	Passed	Out-of-Service
Duc d'Anville Elementary	Caretaker Room tap in Boys Wash Room	SWA358	June 8, 2022	-	Passed	0.0082	Passed	
Duc d'Anville Elementary	Gender Neutral Wash Room 146 tap	SWA360	June 8, 2022	-	Passed	0.0110	Passed	
Duc d'Anville Elementary	Fountain by Room 146	WAT029	June 6, 2023	-	Passed	0.0990	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Duc d'Anville Elementary	Fountain by Room 320	WAT030	June 6, 2023	-	Passed	0.0120	Passed	
Duc d'Anville Elementary	Fountain by 2nd Floor Wash Rooms	WAT031	June 6, 2023	0.002	Passed	0.0690	Passed	
Duc d'Anville Elementary	Staff Room 260 tap	WAT032	June 6, 2023	-	Passed	0.0100	Passed	
Duc d'Anville Elementary	Modular Staff Room tap	WAT033	June 6, 2023	-	Passed	0.0043	Passed	
Duc d'Anville Elementary	Modular Staff Room Wash Room tap	WAT034	June 6, 2023	-	Passed	0.0049	Passed	
Duc d'Anville Elementary	Modular Accessible Wash Room tap	WAT035	June 6, 2023	-	Passed	0.0079	Passed	
Duc d'Anville Elementary	Modular Girls Wash Room tap 1	WAT036	June 6, 2023	-	Passed	0.0064	Passed	
Duc d'Anville Elementary	Modular Girls Wash Room tap 2	WAT037	June 6, 2023	-	Passed	0.0070	Passed	
Duc d'Anville Elementary	Modular Boys Wash Room tap 1	WAT038	June 6, 2023	-	Passed	0.0110	Passed	
Duc d'Anville Elementary	Modular Boys Wash Room tap 2	WAT039	June 6, 2023	-	Passed	0.0089	Passed	
Duc d'Anville Elementary	Modular Janitors Closet tap	WAT040	June 6, 2023	-	Passed	0.0055	Passed	
Dutch Settlement Elementary	Boys Wash Room 121 tap	MYZ477	June 6, 2023	0.001	Passed	0.3800	Passed	
Dutch Settlement Elementary	Janitors Closet 120 tap	MYZ478	June 6, 2023	0.001	Passed	0.2300	Passed	
Dutch Settlement Elementary	Girls Wash Room 119 tap 1	MYZ479	June 6, 2023	0.002	Passed	0.5000	Passed	
Dutch Settlement Elementary	Girls Wash Room 119 tap 2	MYZ480	June 25, 2020	0.002	Passed	0.2600	Passed	
Dutch Settlement Elementary	Staff Wash Room 112A tap	MYZ481	June 25, 2020	0.003	Passed	0.2800	Passed	
Dutch Settlement Elementary	Staff Kitchen 112 tap	MYZ482	June 25, 2020	0.001	Passed	0.0990	Passed	
Dutch Settlement Elementary	Class Room Wash Room 109 B tap	MYZ483	June 25, 2020	0.001	Passed	0.2500	Passed	
Dutch Settlement Elementary	Janitors Closet 104 tap	MYZ484	June 25, 2020	0.001	Passed	0.0980	Passed	
Dutch Settlement Elementary	Girls Wash Room 107 tap 2	MYZ510	June 25, 2020	-	Passed	0.0570	Passed	
Dutch Settlement Elementary	Boys Wash Room 105 tap 1	MYZ511	June 25, 2020	0.001	Passed	0.0680	Passed	
Dutch Settlement Elementary	Boys Wash Room 105 tap 2	MYZ512	June 25, 2020	0.002	Passed	0.0540	Passed	
Dutch Settlement Elementary	Kitchen 103 tap	MYZ513	June 25, 2020	0.002	Passed	0.5800	Passed	
Dutch Settlement Elementary	Class Room 102 Wash Room tap	MYZ514	June 25, 2020	0.002	Passed	0.7000	Passed	
Dutch Settlement Elementary	Girls Wash Room 107 tap 1	PHC298	April 8, 2021	-	Passed	0.0088	Passed	
Dutch Settlement Elementary	Gym Storage Room tap	PHC299	April 8, 2021	-	Passed	0.0087	Passed	
Dutch Settlement Elementary	Gym Office Wash Room tap	PHC300	April 8, 2021	-	Passed	0.0210	Passed	
East St. Margaret's Elementary	2nd Floor Boys Wash Room tap 1	SOY026	May 10, 2022	0.001	Passed	0.2100	Passed	
East St. Margaret's Elementary	2nd Floor Boys Wash Room tap 2	SOY027	May 10, 2022	0.001	Passed	0.2200	Passed	
East St. Margaret's Elementary	2nd Floor Girls Wash Room tap 1	SOY028	May 10, 2022	0.001	Passed	0.5600	Passed	
East St. Margaret's Elementary	2nd Floor Girls Wash Room tap 2	SOY029	May 10, 2022	0.002	Passed	0.5200	Passed	
East St. Margaret's Elementary	2nd Floor Girls Wash Room tap 3	SOY030	May 10, 2022	0.005	Exceeded	0.9900	Passed	Hand washing only
East St. Margaret's Elementary	2nd Floor Gender Neutral Wash Room 1 tap	SOY031	May 10, 2022	0.014	Exceeded	0.1600	Passed	Hand washing only
East St. Margaret's Elementary	2nd Floor Gender Neutral Wash Room 2 tap	SOY032	May 10, 2022	0.003	Passed	0.1600	Passed	
East St. Margaret's Elementary	1st Floor Girls Wash Room tap 1	SOY033	May 10, 2022	-	Passed	0.1500	Passed	
East St. Margaret's Elementary	1st Floor Girls Wash Room tap 2	SOY034	May 10, 2022	0.001	Passed	0.1800	Passed	
East St. Margaret's Elementary	Class Room 11 tap	SOY035	May 10, 2022	0.001	Passed	0.3800	Passed	
East St. Margaret's Elementary	Janitors Closet Room 5 tap	SOY036	May 10, 2022	0.001	Passed	0.1800	Passed	
Eastern Passage Education Centre	Class Room 1095 tap	NCE082	July 10, 2020	-	Passed	0.0790	Passed	
Eastern Passage Education Centre	Class Room 1091 tap 1	NCE083	July 10, 2020	0.001	Passed	0.0710	Passed	
Eastern Passage Education Centre	Class Room 1091 tap 2	NCE084	July 10, 2020	0.001	Passed	0.0730	Passed	
Eastern Passage Education Centre	Science Lab Room 1086 tap 1	NCE085	July 10, 2020	0.001	Passed	28.0000	Exceeded	Laboratory or Hand washing only
Eastern Passage Education Centre	Science Lab Room 1086 tap 2	NCE086	July 10, 2020	-	Passed	0.6400	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Eastern Passage Education Centre	Science Lab Room 1086 tap 3	NCE087	July 10, 2020	-	Passed	0.2400	Passed	
Eastern Passage Education Centre	Science Lab Room 1086 tap 4	NCE088	July 10, 2020	-	Passed	0.5200	Passed	
Eastern Passage Education Centre	Science Lab Room 1086 tap 5	NCE089	July 10, 2020	-	Passed	0.1900	Passed	
Eastern Passage Education Centre	Science Lab Room 1086 tap 6	NCE090	July 10, 2020	0.001	Passed	8.7000	Exceeded	Laboratory or Hand washing only
Eastern Passage Education Centre	Science Lab Room 1085 tap 1	NCE091	July 10, 2020	0.015	Exceeded	6.3000	Exceeded	Laboratory or Hand washing only
Eastern Passage Education Centre	Science Lab Room 1085 tap 2	NCE092	July 10, 2020	0.001	Passed	1.0000	Passed	
Eastern Passage Education Centre	Science Lab Room 1085 tap 3	NCE093	July 10, 2020	0.002	Passed	0.5200	Passed	
Eastern Passage Education Centre	Science Lab Room 1085 tap 4	NCE094	July 10, 2020	0.001	Passed	0.5300	Passed	
Eastern Passage Education Centre	Science Lab Room 1085 tap 5	NCE095	July 10, 2020	0.002	Passed	3.0000	Exceeded	Laboratory or Hand washing only
Eastern Passage Education Centre	Science Lab Room 1085 tap 6	NCE096	July 10, 2020	0.001	Passed	1.9000	Passed	
Eastern Passage Education Centre	Learning Centre Wash Room 1081 tap	NCE097	July 10, 2020	0.002	Passed	0.2100	Passed	
Eastern Passage Education Centre	Learning Centre 1079 tap	WFH175	June 22, 2023	-	Passed	0.1200	Passed	
Eastern Passage Education Centre	Class Room 1076 tap	WFH034	June 22, 2023	-	Passed	0.0560	Passed	Tap remediated
Eastern Passage Education Centre	Class Room 1072 tap 1	NCE100	July 10, 2020	0.001	Passed	1.7000	Passed	
Eastern Passage Education Centre	Class Room 1072 tap 2	WFH033	June 22, 2023	-	Passed	0.0800	Passed	Tap remediated
Eastern Passage Education Centre	Janitors Closet 1100 tap	NCE102	July 10, 2020	-	Passed	0.1900	Passed	
Eastern Passage Education Centre	Gender Neutral Wash Room 1011 tap	WFH035	June 22, 2023	-	Passed	0.1800	Passed	Tap remediated
Eastern Passage Education Centre	Music Room 1064 tap	NMV188	August 31, 2020	0.001	Passed	0.0950	Passed	
Eastern Passage Education Centre	Art Room 1061 tap	NCE106	July 10, 2020	0.001	Passed	0.5500	Passed	
Eastern Passage Education Centre	Fountain by Room 1100	PXW842	June 24, 2021	0.001	Passed	0.1980	Passed	Out-of-Service
Eastern Passage Education Centre	Girls Wash Room 1102 tap 1	NCE107	July 10, 2020	0.001	Passed	0.3500	Passed	
Eastern Passage Education Centre	Girls Wash Room 1102 tap 2	NCE108	July 10, 2020	0.002	Passed	0.3500	Passed	
Eastern Passage Education Centre	Girls Wash Room 1102 tap 3	NCE109	July 10, 2020	0.001	Passed	0.2600	Passed	
Eastern Passage Education Centre	Girls Wash Room 1102 tap 4	NCE110	July 10, 2020	-	Passed	0.2300	Passed	
Eastern Passage Education Centre	Male Wash Room 1103 tap 1	NCE112	July 10, 2020	0.002	Passed	0.1800	Passed	
Eastern Passage Education Centre	Male Wash Room 1103 tap 2	NCE113	July 10, 2020	0.001	Passed	0.1500	Passed	
Eastern Passage Education Centre	Male Wash Room 1103 tap 3	NCE114	July 10, 2020	0.002	Passed	0.3600	Passed	
Eastern Passage Education Centre	Male Wash Room 1103 tap 4	NCE115	July 10, 2020	0.001	Passed	0.2200	Passed	
Eastern Passage Education Centre	Fountain by Room 1104	WFH176	June 22, 2023	-	Passed	0.1300	Passed	
Eastern Passage Education Centre	Cafeteria Double Sink tap	WFH036	June 22, 2023	-	Passed	0.0480	Passed	
Eastern Passage Education Centre	Cafeteria Hand Wash tap	WFH037	June 22, 2023	-	Passed	0.0260	Passed	
Eastern Passage Education Centre	Fountain by Room 1056	WFH184	June 22, 2023	-	Passed	0.0040	Passed	
Eastern Passage Education Centre	Female Locker Room tap 1 Room 1043	NCE117	July 10, 2020	0.004	Passed	0.3400	Passed	
Eastern Passage Education Centre	Female Locker Room tap 2 Room 1043	NCE118	July 10, 2020	0.001	Passed	0.4800	Passed	
Eastern Passage Education Centre	Gym Office Wash Room 1046 tap	NCE119	July 10, 2020	0.001	Passed	1.2000	Passed	
Eastern Passage Education Centre	Gym Office Wash Room 1048 tap	WFH181	June 22, 2023	0.001	Passed	1.5000	Passed	Tap remediated
Eastern Passage Education Centre	Male Locker Room 1050 tap 1	WFH182	June 22, 2023	0.005	Passed	1.1000	Passed	Tap remediated
Eastern Passage Education Centre	Male Locker Room 1050 tap 2	WFH183	June 22, 2023	0.002	Passed	1.3000	Passed	Tap remediated
Eastern Passage Education Centre	Gender Neutral Wash Room 1037 tap	NCE124	July 10, 2020	0.001	Passed	0.6600	Passed	
Eastern Passage Education Centre	Janitors Closet 1035 tap	NCE125	July 10, 2020	0.002	Passed	0.5500	Passed	
Eastern Passage Education Centre	Gender Neutral Wash Room tap by Room 1029	NCE126	July 10, 2020	0.002	Passed	0.2300	Passed	
Eastern Passage Education Centre	Family Studies Room 1029 tap 1	WFH177	June 22, 2023	-	Passed	0.0680	Passed	
Eastern Passage Education Centre	Family Studies Room 1029 tap 2	WFH178	June 22, 2023	-	Passed	0.0360	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Eastern Passage Education Centre	Family Studies Room 1029 tap 3	WFH179	June 22, 2023	-	Passed	0.0580	Passed	
Eastern Passage Education Centre	Family Studies Room 1029 tap 4	WFH180	June 22, 2023	-	Passed	0.0280	Passed	
Eastern Passage Education Centre	Office Wash Room 1025 tap	NCE131	July 10, 2020	-	Passed	0.1900	Passed	
Eastern Passage Education Centre	Janitors Closet 2036 tap	NCE133	July 10, 2020	-	Passed	0.1100	Passed	
Eastern Passage Education Centre	Fountain by Room 2036	WFH039	June 22, 2023	-	Passed	0.0025	Passed	
Eastern Passage Education Centre	Tech Ed Room 2029 tap	WFH040	June 22, 2023	-	Passed	0.0910	Passed	Tap remediated
Eastern Passage Education Centre	Staff Room Wash Room 2026 tap	NCE135	July 10, 2020	0.001	Passed	0.4400	Passed	
Eastern Passage Education Centre	Staff Room Wash Room 2027 tap	NCE136	July 10, 2020	0.002	Passed	0.5500	Passed	
Eastern Passage Education Centre	Staff Room 2025 tap	WFH043	June 22, 2023	-	Passed	0.0130	Passed	
Eastern Passage Education Centre	Class Room 2065 tap	NCE138	July 10, 2020	-	Passed	1.1000	Passed	
Eastern Passage Education Centre	Class Room 2061 tap 1							Out-of-Service
Eastern Passage Education Centre	Class Room 2061 tap 2	WFH038	June 22, 2023	-	Passed	0.1400	Passed	Tap remediated
Eastern Passage Education Centre	Class Room 2058 tap	NCE141	July 10, 2020	0.001	Passed	0.8500	Passed	
Eastern Passage Education Centre	Class Room 2053 tap 1	WFH042	June 22, 2023	-	Passed	0.3400	Passed	Tap remediated
Eastern Passage Education Centre	Class Room 2053 tap 2	NCE143	July 10, 2020	-	Passed	0.6900	Passed	
Eastern Passage Education Centre	Class Room 2050 tap	NCE144	July 10, 2020	-	Passed	0.5300	Passed	
Eastern Passage Education Centre	Class Room 2046 tap 1	WFH041	June 22, 2023	-	Passed	0.1100	Passed	Tap remediated
Eastern Passage Education Centre	Class Room 2046 tap 2	NCE146	July 10, 2020	-	Passed	0.8700	Passed	
Eastern Passage Education Centre	Janitors Closet 2071 tap	NCE147	July 10, 2020	0.001	Passed	0.1600	Passed	
Eastern Passage Education Centre	Fountain by Room 2072	NCE148	July 10, 2020	0.001	Passed	0.3800	Passed	Out-of-Service
Eastern Passage Education Centre	Gender Neutral Wash Room tap Room 2072	NCE149	July 10, 2020	0.003	Passed	0.5100	Passed	
Eastern Passage Education Centre	Boys Wash Room tap 1 by Room 2072	NCE150	July 10, 2020	0.001	Passed	0.3800	Passed	
Eastern Passage Education Centre	Boys Wash Room tap 2 by Room 2072	NCE151	July 10, 2020	0.001	Passed	0.3600	Passed	
Eastern Passage Education Centre	Boys Wash Room tap 2 by Room 2072	NCE152	July 10, 2020	0.001	Passed	0.4400	Passed	
Eastern Passage Education Centre	Boys Wash Room tap 3 by Room 2072	NCE153	July 10, 2020	0.002	Passed	0.3000	Passed	
Eastern Passage Education Centre	Girls Wash Room tap 1 by Room 2074	NCE154	July 10, 2020	0.003	Passed	0.5600	Passed	
Eastern Passage Education Centre	Girls Wash Room tap 2 by Room 2074	NCE155	July 10, 2020	0.004	Passed	0.6200	Passed	
Eastern Passage Education Centre	Girls Wash Room tap 3 by Room 2074	NCE156	July 10, 2020	0.002	Passed	0.5100	Passed	
Eastern Passage Education Centre	Girls Wash Room tap 4 by Room 2074	NCE157	July 10, 2020	0.005	Passed	0.2000	Passed	
Eastern Shore District High School	Girls Wash Room tap 1 by Room 225	NAI278	June 26, 2020	0.005	Passed	0.1300	Passed	
Eastern Shore District High School	Girls Wash Room tap 2 by Room 225	WGQ871	June 29, 2023	0.002	Passed	0.0590	Passed	Tap remediated
Eastern Shore District High School	Janitors Closet tap by Room 225	RXI401	February 18, 2022	0.001	Passed	0.1900	Passed	
Eastern Shore District High School	Fountain by Room 225	RXI402	February 18, 2022	-	Passed	-	Passed	
Eastern Shore District High School	Boys Wash Room tap 1 by Room 224	WGQ869	June 29, 2023	0.015	Exceeded	0.0210	Passed	Hand washing only
Eastern Shore District High School	Boys Wash Room tap 2 by Room 224	WGQ870	June 29, 2023	0.006	Exceeded	0.0180	Passed	Hand washing only
Eastern Shore District High School	Class Room 220 tap	NAI284	June 26, 2020	0.002	Passed	0.2400	Passed	
Eastern Shore District High School	Science Lab 217 tap 1	RWW763	February 17, 2022	0.001	Passed	0.0880	Passed	
Eastern Shore District High School	Science Lab 217 tap 2	NAI286	June 26, 2020	0.002	Passed	0.2600	Passed	
Eastern Shore District High School	Science Lab 217 tap 3	RWW764	February 17, 2022	0.016	Exceeded	0.8600	Passed	Laboratory or hand washing only
Eastern Shore District High School	Science Lab 217 tap 4	NAI291	June 26, 2020	0.002	Passed	0.2600	Passed	
Eastern Shore District High School	Science Lab 217 tap 5	NAI292	June 26, 2020	0.004	Passed	0.3700	Passed	
Eastern Shore District High School	Science Lab 217 tap 6	NAI293	June 26, 2020	0.003	Passed	0.4000	Passed	
Eastern Shore District High School	Science Lab 217 tap 1a	RWW765	February 17, 2022	0.022	Exceeded	1.2000	Passed	Laboratory or hand washing only

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Eastern Shore District High School	Science Lab 217 tap 2a	RWW766	February 17, 2022	0.005	Exceeded	0.1800	Passed	Laboratory or hand washing only
Eastern Shore District High School	Science Lab 217 tap 3a	RWW767	February 17, 2022	0.180	Exceeded	0.0870	Passed	Laboratory or hand washing only
Eastern Shore District High School	Science Lab 217 tap 4a	NAI297	June 26, 2020	0.005	Exceeded	0.3000	Passed	Laboratory or hand washing only
Eastern Shore District High School	Science Lab 217 tap 5a	NAI298	February 17, 2022	0.010	Exceeded	0.0470	Passed	Laboratory or hand washing only
Eastern Shore District High School	Science Lab 217 tap 6a	NAI299	June 26, 2020	0.003	Passed	0.1100	Passed	
Eastern Shore District High School	Science Lab 217 tap 1b	RWW769	February 17, 2022	0.004	Passed	0.0640	Passed	
Eastern Shore District High School	Science Lab 217 tap 2b	RWW770	February 17, 2022	0.003	Passed	0.0630	Passed	
Eastern Shore District High School	Science Lab 217 tap 3b	RWW771	February 17, 2022	0.009	Exceeded	0.0720	Passed	Laboratory or hand washing only
Eastern Shore District High School	Science Lab 217 tap 4b	NAI305	June 26, 2020	0.002	Passed	0.2800	Passed	
Eastern Shore District High School	Science Lab 217 tap 5b	RWW773	February 17, 2022	0.015	Exceeded	0.0400	Passed	Laboratory or hand washing only
Eastern Shore District High School	Science Lab 217 tap 6b	NAI307	June 26, 2020	0.002	Passed	0.2300	Passed	
Eastern Shore District High School	Science Lab 217 tap 1c	RWW787	February 17, 2022	0.023	Exceeded	1.0000	Passed	Laboratory or hand washing only
Eastern Shore District High School	Science Lab 217 tap 2c	RWW788	February 17, 2022	0.005	Exceeded	0.1100	Passed	Laboratory or hand washing only
Eastern Shore District High School	Science Lab 317 tap 3c	NAI310	June 26, 2020	0.004	Passed	0.4300	Passed	
Eastern Shore District High School	Science Lab 219 tap 1a	RWW789	February 17, 2022	0.002	Passed	0.0460	Passed	
Eastern Shore District High School	Science Lab 219 tap 2	RWW790	February 17, 2022	-	Passed	0.0220	Passed	
Eastern Shore District High School	Science Lab 219 tap 3	RWW791	February 17, 2022	0.001	Passed	0.0740	Passed	
Eastern Shore District High School	Science Lab 219 tap 4	RWW792	February 17, 2022	0.003	Passed	1.9000	Passed	
Eastern Shore District High School	Science Lab 219 tap 5	RWW793	February 17, 2022	-	Passed	0.0260	Passed	
Eastern Shore District High School	Science Lab 219 tap 6	RWW794	February 17, 2022	0.001	Passed	0.0560	Passed	
Eastern Shore District High School	Science Lab 219 tap 1a	RXI397	February 18, 2022	-	Passed	0.0570	Passed	
Eastern Shore District High School	Staff Wash Room 201a tap 1	RXI403	February 18, 2022	-	Passed	0.0660	Passed	
Eastern Shore District High School	Staff Wash Room 201a tap 2	NAI338	June 26, 2020	0.005	Passed	0.0300	Passed	
Eastern Shore District High School	Class Room 201a tap	RXI404	February 18, 2022	-	Passed	0.0930	Passed	
Eastern Shore District High School	Boys Wash Room tap 1 by Room 202	WGQ864	June 29, 2023	0.001	Passed	0.0190	Passed	Tap remediated
Eastern Shore District High School	Boys Wash Room tap 2 by Room 202	WGQ865	June 29, 2023	-	Passed	0.0160	Passed	Tap remediated
Eastern Shore District High School	Boys Wash Room tap 3 by Room 202	WGQ866	June 29, 2023	0.002	Passed	0.0097	Passed	Tap remediated
Eastern Shore District High School	Fountain by Boys Wash Room / Room 202	NAI380	June 26, 2020	0.002	Passed	0.1200	Passed	
Eastern Shore District High School	Staff Wash Room tap by Janitors Closet	RXI410	February 18, 2022	0.001	Passed	0.1500	Passed	
Eastern Shore District High School	Janitors Closet in Janitors Sink Room	NAI350	June 26, 2020	0.001	Passed	0.0740	Passed	
Eastern Shore District High School	Girls Wash Room tap 1 by Room 201c	WGQ862	June 29, 2023	0.002	Passed	0.0540	Passed	Tap remediated
Eastern Shore District High School	Girls Wash Room tap 2 by Room 201c	WGQ862	June 30, 2023	0.013	Exceeded	0.2700	Passed	Hand washing only
Eastern Shore District High School	Girls Wash Room tap 3 by Room 201c	WGQ863	June 29, 2023	0.001	Passed	0.0470	Passed	Tap remediated
Eastern Shore District High School	Food Lab 212 double compartment sink tap	WGQ867	June 29, 2023	-	Passed	0.0075	Passed	
Eastern Shore District High School	Food Lab 212 single compartment sink tap	WGQ868	June 29, 2023	-	Passed	0.0084	Passed	
Eastern Shore District High School	Gender Neutral Wash Room 212 tap	RXI414	February 18, 2022	-	Passed	0.1400	Passed	
Eastern Shore District High School	Class Room 213 tap	RXI415	February 18, 2022	0.001	Passed	0.1800	Passed	
Eastern Shore District High School	Class Room 123b tap	NAI361	June 26, 2020	0.003	Passed	0.6200	Passed	
Eastern Shore District High School	Class Room 122 tap	NAI362	June 26, 2020	0.005	Passed	0.1900	Passed	
Eastern Shore District High School	Girls Wash Room tap 1 by Janitors Closet Room C	RXI416	February 18, 2022	0.001	Passed	0.1500	Passed	
Eastern Shore District High School	Girls Wash Room tap 2 by Janitors Closet Room C	NAI364	June 26, 2020	0.002	Passed	0.0890	Passed	
Eastern Shore District High School	Janitors Closet Room C tap	RXI417	February 18, 2022	0.001	Passed	0.1300	Passed	
Eastern Shore District High School	Fountain by Janitors Room C	RXI418	February 18, 2022	-	Passed	-	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Eastern Shore District High School	Boys Wash Room tap by Room 119a	NAI367	June 26, 2020	0.002	Passed	0.0490	Passed	
Eastern Shore District High School	Class Room 116 tap	NAI368	June 26, 2020	0.003	Passed	0.1400	Passed	
Eastern Shore District High School	Gym Office Wash Room tap	NAI369	June 26, 2020	0.004	Passed	0.6700	Passed	
Eastern Shore District High School	Main Office Wash Room 1081 tap	RXI419	February 18, 2022	-	Passed	0.1100	Passed	
Eastern Shore District High School	Youth Centre Gender Neutral Wash Room 1 tap	NAI373	June 26, 2020	0.001	Passed	0.5100	Passed	
Eastern Shore District High School	Youth Centre Gender Neutral Wash Room 2 tap	NAI374	June 26, 2020	-	Passed	0.2900	Passed	
Eastern Shore District High School	Boys Wash Room tap 1 by Fountain	NAI375	June 26, 2020	0.005	Passed	0.2600	Passed	
Eastern Shore District High School	Boys Wash Room tap 2 by Fountain	WGQ858	June 29, 2023	0.003	Passed	0.1100	Passed	Tap remediated
Eastern Shore District High School	Boys Wash Room tap 3 by Fountain	RXI421	February 18, 2022	0.004	Passed	0.3300	Passed	
Eastern Shore District High School	Staff Wash Room tap by Caretakers Office	NAI378	June 26, 2020	0.003	Passed	0.1500	Passed	
Eastern Shore District High School	Janitors Closet tap in Caretakers Office	NAI379	June 26, 2020	-	Passed	0.0410	Passed	
Eastern Shore District High School	Fountain by Boys Wash Room	WGQ872	June 29, 2023	-	Passed	-	Passed	
Eastern Shore District High School	Girls Wash Room tap 1 by Main Office	WGQ855	June 30, 2023	0.003	Passed	0.1300	Passed	Tap remediated
Eastern Shore District High School	Girls Wash Room tap 2 by Main Office	WGQ856	June 30, 2023	0.003	Passed	0.1500	Passed	Tap remediated
Eastern Shore District High School	Girls Wash Room tap 3 by Main Office	WGQ857	June 30, 2023	0.003	Passed	0.1800	Passed	Tap remediated
Eastern Shore District High School	Fountain by Girls Wash Room	RXI425	February 18, 2022	-	Passed	-	Passed	
Eastern Shore District High School	Cafeteria 113 single compartment sink 1 tap	WGQ859	June 29, 2023	-	Passed	0.0120	Passed	
Eastern Shore District High School	Cafeteria 113 single compartment sink 2 tap	WGQ860	June 29, 2023	-	Passed	0.0130	Passed	
Eastern Shore District High School	Cafeteria 113 double compartment sink tap	WGQ861	June 29, 2023	-	Passed	0.0130	Passed	
Ecole Beaufort (SJAM)	Class Room 217 tap	QH0089	August 5, 2021	-	Passed	0.0800	Passed	
Ecole Beaufort (SJAM)	Janitors Closet 104 tap	QH0091	August 5, 2021	-	Passed	0.0440	Passed	
Ecole Beaufort (SJAM)	Girls Wash Room 105 tap 1	QH0092	August 5, 2021	-	Passed	0.0640	Passed	
Ecole Beaufort (SJAM)	Girls Wash Room 105 tap 2	QH0093	August 5, 2021	-	Passed	0.0420	Passed	
Ecole Beaufort (SJAM)	Girls Wash Room 105 tap 3	QH0094	August 5, 2021	-	Passed	0.0410	Passed	
Ecole Beaufort (SJAM)	Class Room 106 tap	QH0095	August 5, 2021	-	Passed	0.0620	Passed	
Ecole Beaufort (SJAM)	Gender Neutral Wash Room 110 tap	QH0096	August 5, 2021	-	Passed	0.0390	Passed	
Ecole Beaufort (SJAM)	Gender Neutral Wash Room 216 tap	QH0097	August 5, 2021	-	Passed	0.0580	Passed	
Ecole Beaufort (SJAM)	Class Room 212 Wash Room tap	QH0098	August 5, 2021	-	Passed	0.0710	Passed	
Ecole Beaufort (SJAM)	Staff Room Wash Room tap	QH0099	August 5, 2021	-	Passed	0.0520	Passed	
Ecole Beaufort (SJAM)	Janitors Closet 204 tap	QH0101	August 5, 2021	-	Passed	0.0300	Passed	
Ecole Beaufort (SJAM)	Boys Wash Room tap 1	QH0102	August 5, 2021	0.002	Passed	0.2200	Passed	
Ecole Beaufort (SJAM)	Boys Wash Room tap 2	QH0103	August 5, 2021	0.001	Passed	0.3100	Passed	
Ecole Beaufort (SJAM)	Gender Neutral Wash Room 209	QH0104	August 5, 2021	0.001	Passed	0.2700	Passed	
Ecole Beaufort (SJAM)	Basement Boys Wash Room tap 1	QH0105	August 5, 2021	0.001	Passed	0.0570	Passed	
Ecole Beaufort (SJAM)	Basement Boys Wash Room tap 2	QH0106	August 5, 2021	-	Passed	0.0190	Passed	
Ecole Beaufort (SJAM)	Basement Boys Wash Room tap 3	QH0107	August 5, 2021	0.001	Passed	0.0180	Passed	
Ecole Beaufort (SJAM)	Basement Boys Wash Room tap 4	QH0108	August 5, 2021	-	Passed	0.0150	Passed	
Ecole Beaufort (SJAM)	Basement Girls Wash Room tap 1	QH0109	August 5, 2021	0.002	Passed	0.0570	Passed	
Ecole Beaufort (SJAM)	Basement Girls Wash Room tap 2	QH0110	August 5, 2021	0.002	Passed	0.0300	Passed	
Ecole Beaufort (SJAM)	Basement Girls Wash Room tap 3	QH0111	August 5, 2021	0.002	Passed	0.0240	Passed	
Ecole Beaufort (SJAM)	Basement Girls Wash Room tap 4	QH0112	August 5, 2021	0.001	Passed	0.0160	Passed	
Ecole Beaufort (SJAM)	Basement Girls Wash Room tap 5	QH0113	August 5, 2021	0.001	Passed	0.0120	Passed	
Ecole Beaufort (SJAM)	Basement Caretakers Office tap	QH0114	August 5, 2021	-	Passed	0.0160	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ecole Beaufort (SJAM)	Hallway Sink by Room B203 tap	QH115	August 5, 2021	0.001	Passed	0.0150	Passed	
Ecole Beaufort (SJAM)	Gender Neutral Wash Room B203 tap	QH117	August 5, 2021	-	Passed	0.0100	Passed	
Ecole Beaufort (SJAM)	Staff Room tap	VTZ759	May 9, 2023	-	Passed	0.0230	Passed	
Ecole Beaufort (SJAM)	Fountain by Room 204	VTZ758	May 9, 2023	-	Passed	0.0009	Passed	
Ecole Beaufort (SJAM)	Fountain by B102	VTZ760	May 9, 2023	-	Passed	0.0011	Passed	
Ecole Beaufort (SJAM)	Fountain by Room B203	VTZ761	May 9, 2023	-	Passed	0.0110	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 1 by Fan Room	MQZ703	May 20, 2020	0.001	Passed	0.1100	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 2 by Fan Room	MQZ704	May 20, 2020	0.001	Passed	0.0660	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 3 by Fan Room	MQZ705	May 20, 2020	0.001	Passed	0.0670	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 4 by Fan Room	MQZ706	May 20, 2020	0.001	Passed	0.0620	Passed	
Elizabeth Sutherland School	Janitors Closet tap by Room 7	MQZ707	May 20, 2020	0.002	Passed	0.0810	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 1 by Janitors Closet	MQZ709	May 20, 2020	0.002	Passed	0.0740	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 2 by Janitors Closet	VPX696	April 21, 2023	-	Passed	0.0110	Passed	Tap remediated
Elizabeth Sutherland School	Boys Wash Room tap 3 by Janitors Closet	VPX697	April 21, 2023	-	Passed	0.0100	Passed	Tap remediated
Elizabeth Sutherland School	Boys Wash Room tap 4 by Janitors Closet	MQZ712	May 20, 2020	0.003	Passed	0.0590	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 3 by Canteen	MQZ715	May 20, 2020	0.001	Passed	0.0360	Passed	
Elizabeth Sutherland School	Janitors Closet tap by Canteen	MQZ717	May 20, 2020	-	Passed	0.0140	Passed	
Elizabeth Sutherland School	Art Room tap 2	MQZ725	May 20, 2020	0.001	Passed	0.0330	Passed	
Elizabeth Sutherland School	Staff Room Wash Room tap 1	MQZ727	May 20, 2020	-	Passed	0.0170	Passed	
Elizabeth Sutherland School	Staff Room Wash Room tap 2	MQZ728	May 20, 2020	-	Passed	0.0170	Passed	
Elizabeth Sutherland School	Staff Room Wash Room tap 3	MQZ729	May 20, 2020	0.012	Exceeded	0.5900	Passed	Hand washing only
Elizabeth Sutherland School	Girls Wash Room tap 1 by Gym	MQZ734	May 20, 2020	0.001	Passed	0.0820	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 2 by Gym	MQZ735	May 20, 2020	0.001	Passed	0.0860	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 3 by Gym	MQZ736	May 20, 2020	0.001	Passed	0.0890	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 4 by Gym	MQZ737	May 20, 2020	-	Passed	0.0790	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 5 by Gym	MRV249	May 22, 2020	-	Passed	0.0660	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 6 by Gym	MQZ738	May 20, 2020	0.002	Passed	0.0840	Passed	
Elizabeth Sutherland School	Janitors Closet tap by Gym	MQZ740	May 20, 2020	0.002	Passed	0.0770	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 1 by Gym	VPX709	April 21, 2023	-	Passed	0.0200	Passed	Tap remediated
Elizabeth Sutherland School	Boys Wash Room tap 2 by Gym	MQZ742	May 20, 2020	0.003	Passed	0.0350	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 3 by Gym	MQZ743	May 20, 2020	0.001	Passed	0.0230	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 4 by Gym	MQZ744	May 20, 2020	0.004	Passed	0.0360	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 5 by Gym	MQZ745	May 20, 2020	0.001	Passed	0.0920	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 6 by Gym	MQZ746	May 20, 2020	0.002	Passed	0.0240	Passed	
Elizabeth Sutherland School	Boys Locker Room tap 1	MQZ747	May 20, 2020	0.001	Passed	0.0970	Passed	
Elizabeth Sutherland School	Boys Locker Room tap 2	MQZ748	May 20, 2020	0.001	Passed	0.0560	Passed	
Elizabeth Sutherland School	Girls Locker Room tap 2	MQZ750	May 20, 2020	0.001	Passed	0.0150	Passed	
Elizabeth Sutherland School	Girls Locker Room tap 3	MQZ751	May 20, 2020	0.004	Passed	0.0900	Passed	
Elizabeth Sutherland School	Science Room bath sink tap	MRV247	May 22, 2020	0.018	Exceeded	0.2500	Passed	Hand washing only
Elizabeth Sutherland School	Science Room Closet sink tap	MRV248	May 22, 2020	0.002	Passed	0.0650	Passed	
Elizabeth Sutherland School	Girls Locker Room tap 1	NKX242	August 21, 2020	0.000	Passed	0.0130	Passed	
Elizabeth Sutherland School	Music Room tap	NKX243	August 21, 2020	0.000	Passed	0.0190	Passed	
Elizabeth Sutherland School	Caretaker Room tap	VPX685	April 21, 2023	-	Passed	0.0029	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Elizabeth Sutherland School	Art Room tap 1	VPX687	April 21, 2023	-	Passed	0.0072	Passed	Tap remediated
Elizabeth Sutherland School	Food Lab tap 1	VPX688	April 21, 2023	0.002	Passed	0.0120	Passed	
Elizabeth Sutherland School	Food Lab tap 2	VPX689	April 21, 2023	-	Passed	0.1300	Passed	
Elizabeth Sutherland School	Food Lab tap 3	VPX690	April 21, 2023	-	Passed	0.0420	Passed	
Elizabeth Sutherland School	Food Lab tap 4	VPX691	April 21, 2023	-	Passed	0.1500	Passed	
Elizabeth Sutherland School	Fountain by Gym	VPX692	April 21, 2023	-	Passed	0.0550	Passed	
Elizabeth Sutherland School	Health Room Wash Room tap	VPX693	April 21, 2023	-	Passed	0.0065	Passed	
Elizabeth Sutherland School	Health Room tap	VPX694	April 21, 2023	-	Passed	0.0087	Passed	
Elizabeth Sutherland School	Fountain by Janitors Closet	VPX695	April 21, 2023	-	Passed	0.0180	Passed	
Elizabeth Sutherland School	Fountain by Canteen	VPX698	May 20, 2020	-	Passed	0.0250	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 1 by Canteen	VPX699	April 21, 2023	0.001	Passed	0.0400	Passed	Tap remediated
Elizabeth Sutherland School	Girls Wash Room tap 2 by Canteen	VPX700	April 21, 2023	-	Passed	0.0087	Passed	Tap remediated
Elizabeth Sutherland School	Girls Wash Room tap 4 by Canteen	VPX705	April 21, 2023	-	Passed	0.0085	Passed	Tap remediated
Elizabeth Sutherland School	Boys Wash Room tap 1 by Canteen	VPX702	April 21, 2023	-	Passed	0.0180	Passed	Tap remediated
Elizabeth Sutherland School	Boys Wash Room tap 2 by Canteen	VPX703	April 21, 2023	-	Passed	0.0220	Passed	Tap remediated
Elizabeth Sutherland School	Boys Wash Room tap 3 by Canteen	VPX704	April 21, 2023	-	Passed	0.0240	Passed	Tap remediated
Elizabeth Sutherland School	Boys Wash Room tap 4 by Canteen	VPX705	April 21, 2023	-	Passed	0.0140	Passed	Tap remediated
Elizabeth Sutherland School	Fountain by Main Office	VPX706	April 21, 2023	-	Passed	0.0280	Passed	
Elizabeth Sutherland School	Science Room island sink tap	VPX707	April 21, 2023	0.003	Passed	0.2900	Passed	Tap remediated
Elizabeth Sutherland School	Resource Centre tap	VPX708	April 21, 2023	0.001	Passed	0.1200	Passed	
Elizabeth Sutherland School	Modular Boys Wash Room tap 1	XAB620	September 14, 2023	-	Passed	0.0980	Passed	
Elizabeth Sutherland School	Modular Boys Wash Room tap 2	XAB621	September 14, 2023	-	Passed	0.0670	Passed	
Elizabeth Sutherland School	Modular Boys Wash Room tap 3	XAB622	September 14, 2023	-	Passed	0.0700	Passed	
Elizabeth Sutherland School	Modular Girls Wash Room tap 1	XAB623	September 14, 2023	-	Passed	0.0750	Passed	
Elizabeth Sutherland School	Modular Girls Wash Room tap 2	XAB624	September 14, 2023	-	Passed	0.0670	Passed	
Elizabeth Sutherland School	Modular Girls Wash Room tap 3	XAB625	September 14, 2023	-	Passed	0.0710	Passed	
Elizabeth Sutherland School	Modular Girls Wash Room tap 4	XAB626	September 14, 2023	0.001	Passed	0.0880	Passed	
Elizabeth Sutherland School	Fountain in Modular	XAB627	September 14, 2023	-	Passed	0.0061	Passed	
Elizabeth Sutherland School	Modular Gender Neutral Wash Room tap	XAB628	September 14, 2023	0.001	Passed	0.1800	Passed	
Elizabeth Sutherland School	Modular Janitors Closet tap	XAB629	September 14, 2023	0.001	Passed	0.1200	Passed	
Elizabeth Sutherland School	Modular Staff Room Wash Room tap	XAB655	September 14, 2023	0.001	Passed	0.1300	Passed	
Elizabeth Sutherland School	Modular Staff Room tap	XAB656	September 14, 2023	-	Passed	0.1000	Passed	
Ellenvale Junior High School	Chemistry Lab tap 1 Room 208	MVH128	June 9, 2020	0.001	Passed	0.0400	Passed	
Ellenvale Junior High School	Chemistry Lab tap 2 Room 208	MVH129	June 9, 2020	-	Passed	0.0069	Passed	
Ellenvale Junior High School	Chemistry Lab tap 3 Room 208	MVH130	June 9, 2020	-	Passed	0.0140	Passed	
Ellenvale Junior High School	Chemistry Lab tap 4 Room 208	MVH131	June 9, 2020	0.002	Passed	0.1200	Passed	
Ellenvale Junior High School	Chemistry Lab tap 5 Room 208	MVH132	June 9, 2020	0.001	Passed	0.0280	Passed	
Ellenvale Junior High School	Fountain by Back Staircase	XDF317	September 27, 2023	-	Passed	0.1000	Passed	
Ellenvale Junior High School	Kitchen sink tap 1 Room 211	XDF318	September 27, 2023	0.002	Passed	0.0290	Passed	
Ellenvale Junior High School	Kitchen sink tap 2 Room 211	XDF319	September 27, 2023	0.001	Passed	0.0430	Passed	
Ellenvale Junior High School	Kitchen sink tap 3 Room 211	XDF322	September 27, 2023	0.001	Passed	0.0360	Passed	
Ellenvale Junior High School	Kitchen sink tap 4 Room 211	XDF323	September 27, 2023	0.001	Passed	0.0850	Passed	
Ellenvale Junior High School	Kitchen sink tap 5 Room 211	XDF324	September 27, 2023	0.002	Passed	0.1300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ellenvale Junior High School	Kitchen sink tap 6 Room 211	XDF325	September 27, 2023	0.002	Passed	0.1100	Passed	
Ellenvale Junior High School	Staff Wash Room by Room 212	MVH140	June 9, 2020	0.001	Passed	0.0890	Passed	
Ellenvale Junior High School	Fountain by Room 210	XDF331	September 27, 2023	0.001	Passed	0.0370	Passed	
Ellenvale Junior High School	Class Room 219 tap	NLK028	August 24, 2020	0.000	Passed	0.0160	Passed	
Ellenvale Junior High School	Fountain by Room 219	XDF326	September 27, 2023	-	Passed	0.0710	Passed	
Ellenvale Junior High School	2nd Floor Girls Wash Room tap 1 by Front Staircase	MVH144	June 9, 2020	0.002	Passed	0.2800	Passed	
Ellenvale Junior High School	2nd Floor Girls Wash Room tap 2 by Front Staircase	XDF327	September 27, 2023	0.001	Passed	0.1300	Passed	Tap remediated
Ellenvale Junior High School	2nd Floor Girls Wash Room tap 3 by Front Staircase	XDF328	September 27, 2023	0.001	Passed	0.0830	Passed	Tap remediated
Ellenvale Junior High School	Janitors Closet tap by 2nd Floor Girls Wash Room	MVH147	June 9, 2020	0.001	Passed	0.0910	Passed	
Ellenvale Junior High School	2nd Floor Boys Wash Room tap 1 by Room 220	MVH148	June 9, 2020	0.005	Passed	0.2600	Passed	
Ellenvale Junior High School	2nd Floor Boys Wash Room tap 2 by Room 220	XDF329	September 27, 2023	0.002	Passed	0.0880	Passed	Tap remediated
Ellenvale Junior High School	2nd Floor Boys Wash Room tap 3 by Room 220	MVH150	June 9, 2020	0.003	Passed	0.3900	Passed	
Ellenvale Junior High School	2nd Floor Boys Wash Room tap 4 by Room 220	XDF330	September 27, 2023	0.006	Exceeded	0.1100	Passed	Hand washing only
Ellenvale Junior High School	Staff Wash Room tap inside Room 101	XDF313	September 27, 2023	0.001	Passed	0.0700	Passed	Tap remediated
Ellenvale Junior High School	Staff Kitchen 103 tap	XDF300	September 27, 2023	-	Passed	0.0360	Passed	
Ellenvale Junior High School	Staff Room 103 Male Staff Wash tap	XDF301	September 27, 2023	-	Passed	0.0690	Passed	Tap remediated
Ellenvale Junior High School	Staff Room 103 Female Staff Wash tap	MVH155	June 9, 2020	0.004	Passed	0.0950	Passed	
Ellenvale Junior High School	Fountain by Room 103	XDF299	September 27, 2023	-	Passed	0.0530	Passed	
Ellenvale Junior High School	Janitors Closet tap by Room 105	MVH157	June 9, 2020	-	Passed	0.0270	Passed	
Ellenvale Junior High School	Gender Neutral Wash Room 105 tap	MVH159	June 9, 2020	0.003	Passed	0.0420	Passed	
Ellenvale Junior High School	Laundry tub tap Room 109	XDF311	September 23, 2023	-	Passed	0.0150	Passed	
Ellenvale Junior High School	Fountain by Room 110	XDF316	September 27, 2023	0.001	Passed	0.1600	Passed	
Ellenvale Junior High School	Class Room 112 tap	MVH164	June 9, 2020	-	Passed	0.0500	Passed	
Ellenvale Junior High School	Gender Neutral Wash Room 118 tap	XDF314	September 27, 2023	0.001	Passed	0.0940	Passed	Tap remediated
Ellenvale Junior High School	Gender Neutral Wash Room 119 tap	XDF315	September 27, 2023	-	Passed	0.0370	Passed	Tap remediated
Ellenvale Junior High School	Fountain by Room 116	XDF312	September 27, 2023	-	Passed	0.0310	Passed	
Ellenvale Junior High School	1st Floor Girls Wash Room tap 1 by Front Staircase	XDF306	September 27, 2023	0.004	Passed	0.1000	Passed	Tap remediated
Ellenvale Junior High School	1st Floor Girls Wash Room tap 2 by Front Staircase	XDF307	September 27, 2023	0.001	Passed	0.0540	Passed	Tap remediated
Ellenvale Junior High School	1st Floor Girls Wash Room tap 3 by Front Staircase	MVH170	June 9, 2020	0.005	Passed	0.2300	Passed	
Ellenvale Junior High School	1st Floor Girls Wash Room tap 4 by Front Staircase	XDF308	September 27, 2023	0.002	Passed	0.1000	Passed	Tap remediated
Ellenvale Junior High School	1st Floor Boys Wash Room tap 1 by Room 101	XDF302	September 27, 2023	0.001	Passed	0.1800	Passed	Tap remediated
Ellenvale Junior High School	1st Floor Boys Wash Room tap 2 by Room 101	XDF303	September 27, 2023	0.001	Passed	0.1100	Passed	Tap remediated
Ellenvale Junior High School	1st Floor Boys Wash Room tap 3 by Room 101	XDF304	September 27, 2023	0.001	Passed	0.1100	Passed	Tap remediated
Ellenvale Junior High School	1st Floor Boys Wash Room tap 4 by Room 101	XDF305	September 27, 2023	0.001	Passed	0.1100	Passed	Tap remediated
Ellenvale Junior High School	Laundry tub tap Room 111	NLK023	August 24, 2020	0.001	Passed	0.0150	Passed	Out-of-Service
Ellenvale Junior High School	Class Room 105 tap	XDF310	September 27, 2023	0.001	Passed	0.0240	Passed	Tap remediated
Ellenvale Junior High School	Class Room 110 tap	NLK025	August 24, 2020	0.001	Passed	0.0150	Passed	
Ellenvale Junior High School	Modular Room 306	XBL521	September 19, 2023	-	Passed	0.2300	Passed	
Ellenvale Junior High School	Modular Wash Room tap 1 by Room 306	XBL575	September 19, 2023	-	Passed	0.1100	Passed	
Ellenvale Junior High School	Modular Wash Room tap 2 by Room 306	XBL576	September 19, 2023	-	Passed	0.1100	Passed	
Ellenvale Junior High School	Modular Wash Room tap 3 by Room 306	XBL577	September 19, 2023	-	Passed	0.1100	Passed	
Ellenvale Junior High School	Modular Wash Room tap 4 by Room 306	XBL520	September 19, 2023	-	Passed	0.1200	Passed	
Ellenvale Junior High School	Modular Wash Room tap 1 by Room 305	XBL572	September 19, 2023	-	Passed	0.1100	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ellenvale Junior High School	Modular Wash Room tap 2 by Room 305	XBL573	September 19, 2023	-	Passed	0.1000	Passed	
Ellenvale Junior High School	Modular Wash Room tap 3 by Room 305	XBL574	September 19, 2023	-	Passed	0.1000	Passed	
Ellenvale Junior High School	Fountain in Modular	XBL571	September 19, 2023	-	Passed	0.1300	Passed	
Ellenvale Junior High School	Modular Staff Room Wash Room tap	XBL570	September 19, 2023	-	Passed	0.1000	Passed	
Ellenvale Junior High School	Modular Janitors Closet	XBL569	September 19, 2023	-	Passed	0.0770	Passed	
Ellenvale Junior High School	Modular Staff Room tap	XBL568	September 19, 2023	-	Passed	0.1000	Passed	
Eric Graves Memorial Junior High School	Family Studies tap 1 Room 201	XKA689	October 25, 2023	0.001	Passed	0.0170	Passed	
Eric Graves Memorial Junior High School	Family Studies tap 2 Room 201	XKA690	October 25, 2023	0.001	Passed	0.0230	Passed	
Eric Graves Memorial Junior High School	Family Studies tap 3 Room 201	XKA691	October 25, 2023	-	Passed	0.0190	Passed	
Eric Graves Memorial Junior High School	Family Studies tap 4 Room 201	XKA692	October 25, 2023	0.001	Passed	0.0250	Passed	
Eric Graves Memorial Junior High School	Family Studies tap 5 Room 201	XKA693	October 25, 2023	0.001	Passed	0.0210	Passed	
Eric Graves Memorial Junior High School	Fountain by Room 202	XKA694	October 25, 2023	0.004	Passed	0.1800	Passed	
Eric Graves Memorial Junior High School	Janitors Closet tap by Room 202	XKA707	October 25, 2023	0.001	Passed	0.0450	Passed	Tap remediated
Eric Graves Memorial Junior High School	Boys Wash Room tap 1 by Room 208	XKA708	October 25, 2023	0.002	Passed	0.0490	Passed	Tap remediated
Eric Graves Memorial Junior High School	Boys Wash Room tap 2 by Room 208	XKA709	October 25, 2023	0.002	Passed	0.0530	Passed	Tap remediated
Eric Graves Memorial Junior High School	Boys Wash Room tap 3 by Room 208	XKA710	October 25, 2023	0.002	Passed	0.0740	Passed	Tap remediated
Eric Graves Memorial Junior High School	Boys Wash Room tap 4 by Room 208	XKA711	October 25, 2023	0.002	Passed	0.0820	Passed	Tap remediated
Eric Graves Memorial Junior High School	Staff Wash Room by Room 208	MVH202	June 9, 2020	0.004	Passed	0.1300	Passed	
Eric Graves Memorial Junior High School	Girls Wash Room tap 1 by Room 208	XKA695	October 25, 2023	0.013	Exceeded	0.1500	Passed	Hand washing only
Eric Graves Memorial Junior High School	Girls Wash Room tap 2 by Room 208	XKA696	October 25, 2023	0.005	Passed	0.0770	Passed	Tap remediated
Eric Graves Memorial Junior High School	Girls Wash Room tap 3 by Room 208	XKA697	October 25, 2023	0.001	Passed	0.0540	Passed	Tap remediated
Eric Graves Memorial Junior High School	Girls Wash Room tap 4 by Room 208	XKA698	October 25, 2023	0.001	Passed	0.0290	Passed	Tap remediated
Eric Graves Memorial Junior High School	Fountain by Room 208	XKA699	October 25, 2023	-	Passed	0.0620	Passed	
Eric Graves Memorial Junior High School	Class Room tap Room 210	MVH208	June 9, 2020	0.003	Passed	0.0550	Passed	
Eric Graves Memorial Junior High School	Chemistry Lab tap 1 Room 210	MVH209	June 9, 2020	0.062	Exceeded	1.2000	Passed	Laboratory or Hand washing only
Eric Graves Memorial Junior High School	Chemistry Lab tap 2 Room 210	MVH210	June 9, 2020	0.320	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Eric Graves Memorial Junior High School	Chemistry Lab tap 3 Room 210	MVH211	June 9, 2020	0.160	Exceeded	1.1000	Passed	Laboratory or Hand washing only
Eric Graves Memorial Junior High School	Chemistry Lab tap 4 Room 210	MVH212	June 9, 2020	0.220	Exceeded	1.0000	Passed	Laboratory or Hand washing only
Eric Graves Memorial Junior High School	Chemistry Lab tap 5 Room 210	MVH213	June 9, 2020	0.130	Exceeded	1.2000	Passed	Laboratory or Hand washing only
Eric Graves Memorial Junior High School	Janitors Closet tap by Room 215	MVH214	June 9, 2020	0.002	Passed	0.0810	Passed	
Eric Graves Memorial Junior High School	Computer Lab 112 tap	NLS527	August 24, 2020	0.001	Passed	0.0070	Passed	
Eric Graves Memorial Junior High School	Computer Lab 112 Gender Neutral Wash Room tap	XKA704	October 25, 2023	0.001	Passed	0.0220	Passed	Tap remediated
Eric Graves Memorial Junior High School	Janitors Closet tap by Room 111	MVH223	June 9, 2020	0.003	Passed	0.1900	Passed	
Eric Graves Memorial Junior High School	Caretakers Office 110 tap	NLS529	August 24, 2020	0.000	Passed	0.0050	Passed	
Eric Graves Memorial Junior High School	Caretakers Office 110 Wash Room tap	MVH222	June 9, 2020	0.004	Passed	0.4400	Passed	
Eric Graves Memorial Junior High School	Staff Room 109 tap	XKA700	October 25, 2023	-	Passed	0.0056	Passed	
Eric Graves Memorial Junior High School	Staff Room 109 Mens Wash Room tap 1	XKA701	October 25, 2023	0.024	Exceeded	0.0790	Passed	Hand washing only
Eric Graves Memorial Junior High School	Staff Room 109 Mens Wash Room tap 2	MVH218	June 9, 2020	0.004	Passed	0.0420	Passed	
Eric Graves Memorial Junior High School	Staff Room 109 Womens Wash Room tap 1	XKA702	October 25, 2023	0.001	Passed	0.0220	Passed	Tap remediated
Eric Graves Memorial Junior High School	Staff Room 109 Womens Wash Room tap 2	NLS528	August 24, 2020	0.000	Passed	0.0080	Passed	
Eric Graves Memorial Junior High School	Fountain by Room 108	XKA706	October 25, 2023	0.002	Passed	0.0940	Passed	
Eric Graves Memorial Junior High School	Principal's Office 108 Wash Room tap	XKA703	October 25, 2023	0.003	Passed	0.0760	Passed	Tap remediated
Eric Graves Memorial Junior High School	Resource Room 105 Wash Room tap	XKA687	October 25, 2023	-	Passed	0.0450	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Eric Graves Memorial Junior High School	Resource Room 105 tap	XKA688	October 25, 2023	-	Passed	0.0330	Passed	
Eric Graves Memorial Junior High School	Gym Storage Room tap	XKA705	October 25, 2023	0.029	Exceeded	0.2400	Passed	Hand washing only
Eric Graves Memorial Junior High School	Fountain by Gym	XKA678	October 25, 2023	0.003	Passed	0.4100	Passed	
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 1	XKA683	October 25, 2023	0.005	Exceeded	0.1500	Passed	Hand washing only
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 2	XKA684	October 25, 2023	0.003	Passed	0.0710	Passed	Tap remediated
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 3	XKA685	October 25, 2023	0.002	Passed	0.0330	Passed	Tap remediated
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 4	XKA686	October 25, 2023	0.001	Passed	0.0300	Passed	Tap remediated
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 1	XKA679	October 25, 2023	0.003	Passed	0.0670	Passed	Tap remediated
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 2	XKA680	October 25, 2023	0.001	Passed	0.0430	Passed	Tap remediated
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 3	XKA681	October 25, 2023	0.003	Passed	0.0500	Passed	Tap remediated
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 4	XKA682	October 25, 2023	0.003	Passed	0.0550	Passed	Tap remediated
Eric Graves Memorial Junior High School	Tech Ed. tap	XKA677	October 25, 2023	-	Passed	0.0230	Passed	Tap remediated
Fairview Heights Elementary	VP Office Wash Room tap	MSG780	May 26, 2020	0.003	Passed	0.1200	Passed	
Fairview Heights Elementary	VP Office Kitchen tap	VVU854	May 17, 2023	-	Passed	0.0420	Passed	
Fairview Heights Elementary	Gender Neutral Wash Room tap Room P2	MSG782	May 26, 2020	0.001	Passed	0.1600	Passed	
Fairview Heights Elementary	Kitchen tap Room P2	VVU853	May 17, 2023	-	Passed	0.0530	Passed	
Fairview Heights Elementary	Boys Wash Room tap 1 by Gym	MSG784	May 26, 2020	0.001	Passed	0.0470	Passed	
Fairview Heights Elementary	Boys Wash Room tap 2 by Gym	MSG785	May 26, 2020	0.001	Passed	0.0350	Passed	
Fairview Heights Elementary	Boys Wash Room tap 3 by Gym	MSG786	May 26, 2020	-	Passed	0.0120	Passed	
Fairview Heights Elementary	Janitors Closet tap by Gym	MSG787	May 26, 2020	0.001	Passed	0.0120	Passed	
Fairview Heights Elementary	Girls Wash Room tap 1 by Gym	MSG788	May 26, 2020	-	Passed	0.0120	Passed	
Fairview Heights Elementary	Girls Wash Room tap 2 by Gym	MSG789	May 26, 2020	0.001	Passed	0.0092	Passed	
Fairview Heights Elementary	Girls Wash Room tap 3 by Gym	MSG790	May 26, 2020	-	Passed	0.0079	Passed	
Fairview Heights Elementary	Boys Wash Room tap 1 at bottom of stairs	MSG792	May 26, 2020	0.001	Passed	0.0700	Passed	
Fairview Heights Elementary	Boys Wash Room tap 2 at bottom of stairs	MSG793	May 26, 2020	0.001	Passed	0.0150	Passed	
Fairview Heights Elementary	Boys Wash Room tap 3 at bottom of stairs	MSG794	May 26, 2020	0.002	Passed	0.1800	Passed	
Fairview Heights Elementary	Staff Wash Room tap	MSG795	May 26, 2020	0.001	Passed	0.0081	Passed	
Fairview Heights Elementary	Girls Wash Room tap 1 by caretaker Room	MSG796	May 26, 2020	0.001	Passed	0.0240	Passed	
Fairview Heights Elementary	Girls Wash Room tap 2 by caretaker Room	MSG797	May 26, 2020	-	Passed	0.0100	Passed	
Fairview Heights Elementary	Girls Wash Room tap 3 by caretaker Room	MSG798	May 26, 2020	-	Passed	0.0077	Passed	
Fairview Heights Elementary	Fountain by Room 12	VVU855	May 17, 2023	-	Passed	0.0810	Passed	
Fairview Heights Elementary	Caretaker Room tap	VVU856	May 17, 2023	0.001	Passed	0.0280	Passed	
Fairview Heights Elementary	Fountain by Room 6	VVU857	May 17, 2023	-	Passed	0.0530	Passed	
Fairview Heights Elementary - Annex	Janitors Closet / Boiler Room tap	MRM940	May 21, 2020	-	Passed	0.0140	Passed	
Fairview Heights Elementary - Annex	Boys Wash Room tap 1 by Gym	MRM944	May 21, 2020	0.001	Passed	0.0840	Passed	
Fairview Heights Elementary - Annex	Boys Wash Room tap 2 by Gym	MRM945	May 21, 2020	0.001	Passed	0.1400	Passed	
Fairview Heights Elementary - Annex	Boys Wash Room tap 3 by Gym	MRM946	May 21, 2020	-	Passed	0.0490	Passed	
Fairview Heights Elementary - Annex	Girls Wash Room tap 1 by Gym	MRM947	May 21, 2020	0.001	Passed	0.0470	Passed	
Fairview Heights Elementary - Annex	Girls Wash Room tap 2 by Gym	MRM948	May 21, 2020	0.001	Passed	0.2800	Passed	
Fairview Heights Elementary - Annex	Girls Wash Room tap 3 by Gym	MRM949	May 21, 2020	0.004	Passed	0.2200	Passed	
Fairview Heights Elementary - Annex	Girls Wash Room tap 4 by Gym	MRM978	May 21, 2020	0.001	Passed	0.1200	Passed	
Fairview Heights Elementary - Annex	Main Office Wash Room tap by Room 5	MRM982	May 21, 2020	-	Passed	0.2900	Passed	
Fairview Heights Elementary - Annex	Work Room tap	VVU750	May 17, 2023	-	Passed	0.0150	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Fairview Heights Elementary - Annex	Staff Kitchen tap by Gym	VVU751	May 17, 2023	-	Passed	0.0500	Passed	
Fairview Heights Elementary - Annex	Fountain by Room 3	VVU752	May 17, 2023	-	Passed	0.0950	Passed	
Fairview Heights Elementary - Annex	Admin Room tap off the Gym	VVU753	May 17, 2023	0.004	Passed	0.1300	Passed	
Fairview Heights Elementary - Annex	Modular Staff Room Wash Room tap	VVU760	May 17, 2023	-	Passed	0.0240	Passed	
Fairview Heights Elementary - Annex	Fountain in Modular	VVU754	May 17, 2023	-	Passed	0.0220	Passed	
Fairview Heights Elementary - Annex	Modular Staff Room tap	VVU755	May 17, 2023	-	Passed	0.0230	Passed	
Fairview Heights Elementary - Annex	Modular Boys Wash Room tap 1	VVU756	May 17, 2023	-	Passed	0.0360	Passed	
Fairview Heights Elementary - Annex	Modular Boys Wash Room tap 2	VVU757	May 17, 2023	-	Passed	0.0260	Passed	
Fairview Heights Elementary - Annex	Modular Girls Wash Room tap 1	VVU758	May 17, 2023	-	Passed	0.0280	Passed	
Fairview Heights Elementary - Annex	Modular Girls Wash Room tap 2	VVU759	May 17, 2023	-	Passed	0.0270	Passed	
Fairview Junior High School	Class Room 205 tap	MRO187	May 22, 2020	0.002	Passed	0.6400	Passed	
Fairview Junior High School	Male Staff Wash Room tap by Room 208	MRO188	May 22, 2020	0.002	Passed	0.0510	Passed	
Fairview Junior High School	Female Staff Wash Room tap by Room 208	MRO189	May 22, 2020	0.002	Passed	0.0470	Passed	
Fairview Junior High School	Janitors Closet tap by Staff Wash Rooms	MRO190	May 22, 2020	0.003	Passed	0.0630	Passed	
Fairview Junior High School	Boys Wash Room tap 1 by Room 205	MRO191	May 22, 2020	0.001	Passed	0.0260	Passed	
Fairview Junior High School	Boys Wash Room tap 2 by Room 205	MRO192	May 22, 2020	0.001	Passed	0.0210	Passed	
Fairview Junior High School	Boys Wash Room tap 3 by Room 205	MRO193	May 22, 2020	0.001	Passed	0.0240	Passed	
Fairview Junior High School	Boys Wash Room tap 4 by Room 205	MRO194	May 22, 2020	0.002	Passed	0.0200	Passed	
Fairview Junior High School	Girls Wash Room tap 1 by Room 205	MRO196	May 22, 2020	0.004	Passed	0.1300	Passed	
Fairview Junior High School	Girls Wash Room tap 2 by Room 205	MRO197	May 22, 2020	0.002	Passed	0.1500	Passed	
Fairview Junior High School	Girls Wash Room tap 3 by Room 205	MRO198	May 22, 2020	0.001	Passed	0.0990	Passed	
Fairview Junior High School	Girls Wash Room tap 4 by Room 205	MRO199	May 22, 2020	0.003	Passed	0.0540	Passed	
Fairview Junior High School	Art Room 239 tap 1	MRO200	May 22, 2020	0.003	Passed	0.1900	Passed	
Fairview Junior High School	Art Room 239 tap 2	MRO201	May 22, 2020	0.001	Passed	0.0180	Passed	
Fairview Junior High School	Janitors Closet tap by Room 239	MRO202	May 22, 2020	0.002	Passed	0.0270	Passed	
Fairview Junior High School	Girls Wash Room tap 1 by Room 228	MRO203	May 22, 2020	0.002	Passed	0.0140	Passed	
Fairview Junior High School	Girls Wash Room tap 2 by Room 228	MRO204	May 22, 2020	0.002	Passed	0.0210	Passed	
Fairview Junior High School	Gender Neutral Staff Wash Room tap by Room 228	MRO206	May 22, 2020	0.004	Passed	0.0720	Passed	
Fairview Junior High School	Gender Neutral Staff Wash Room tap by Room 230	MRO207	May 22, 2020	0.003	Passed	0.0370	Passed	
Fairview Junior High School	Boys Wash Room tap 1 by Room 230	MRO208	May 22, 2020	0.001	Passed	0.0140	Passed	
Fairview Junior High School	Boys Wash Room tap 2 by Room 230	MRO209	May 22, 2020	0.002	Passed	0.0380	Passed	
Fairview Junior High School	Boys Wash Room tap 3 by Room 230	MRO215	May 22, 2020	0.002	Passed	0.0150	Passed	
Fairview Junior High School	Janitors Closet 131 tap	MRO221	May 22, 2020	0.002	Passed	0.1300	Passed	
Fairview Junior High School	Staff Wash Room tap in Office Room 137	MRO222	May 22, 2020	0.001	Passed	0.0820	Passed	
Fairview Junior High School	Staff Room 144 Wash Room 1 tap	MRO224	May 22, 2020	0.001	Passed	0.0150	Passed	
Fairview Junior High School	Staff Room 144 Wash Room 2 tap	MRO443	May 22, 2020	0.001	Passed	0.0200	Passed	
Fairview Junior High School	Gender Neutral Wash Room 140 tap	MRO444	May 22, 2020	0.002	Passed	0.0150	Passed	
Fairview Junior High School	Learning Centre Wash Room tap	MRO445	May 22, 2020	0.001	Passed	0.0120	Passed	
Fairview Junior High School	Staff Wash Room by Gender Neutral Wash Room	MRO448	May 22, 2020	0.001	Passed	0.0310	Passed	
Fairview Junior High School	Janitors Closet tap by Staff Wash Rooms	MRO449	May 22, 2020	0.002	Passed	0.0270	Passed	
Fairview Junior High School	Boys Wash Room tap 1 by Room 108	MRO450	May 22, 2020	0.001	Passed	0.0250	Passed	
Fairview Junior High School	Boys Wash Room tap 2 by Room 108	MRO451	May 22, 2020	0.001	Passed	0.0190	Passed	
Fairview Junior High School	Girls Wash Room tap 1 by Room 107	MRO460	May 22, 2020	0.002	Passed	0.0360	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Fairview Junior High School	Girls Wash Room tap 2 by Room 107	MRO461	May 22, 2020	0.001	Passed	0.0200	Passed	
Fairview Junior High School	Girls Wash Room tap 3 by Room 107	MRO462	May 22, 2020	0.001	Passed	0.0190	Passed	
Fairview Junior High School	Girls Wash Room tap 4 by Room 107	MRO463	May 22, 2020	0.001	Passed	0.0200	Passed	
Fairview Junior High School	Class Room 160 tap 1	MRO464	May 22, 2020	0.002	Passed	0.2300	Passed	
Fairview Junior High School	Class Room 160 tap 2	MRO465	May 22, 2020	-	Passed	0.5400	Passed	
Fairview Junior High School	Wood Shop tap	MRO467	May 22, 2020	0.002	Passed	0.1800	Passed	
Fairview Junior High School	Caretaker Room 007 Wash Room tap	MRO471	May 22, 2020	-	Passed	0.0068	Passed	
Fairview Junior High School	Boys Locker Room 006 tap 1	MRO472	May 22, 2020	0.003	Passed	0.0720	Passed	
Fairview Junior High School	Boys Locker Room 006 tap 2	MRO473	May 22, 2020	0.001	Passed	0.0130	Passed	
Fairview Junior High School	Girls Locker Room 005 tap 1	MRO475	May 22, 2020	0.003	Passed	0.0076	Passed	
Fairview Junior High School	Girls Locker Room 005 tap 2	MRO476	May 22, 2020	0.001	Passed	0.0047	Passed	
Fairview Junior High School	Kitchen 246 tap	VZI177	May 31, 2023	0.001	Passed	0.0650	Passed	
Fairview Junior High School	Kitchen 247 tap	VZI178	May 31, 2023	0.002	Passed	0.1300	Passed	
Fairview Junior High School	Kitchen 248 tap 1	VZI179	May 31, 2023	0.001	Passed	0.0540	Passed	
Fairview Junior High School	Kitchen 248 tap 2	VZI180	May 31, 2023	0.001	Passed	0.1100	Passed	
Fairview Junior High School	Kitchen 248 tap 3	VGM952	June 28, 2023	-	Passed	0.0370	Passed	Tap remediated
Fairview Junior High School	Kitchen 236 tap 1	VZI182	May 31, 2023	-	Passed	0.0500	Passed	
Fairview Junior High School	Kitchen 236 tap 2	VZI183	May 31, 2023	-	Passed	0.0390	Passed	
Fairview Junior High School	Kitchen 236 tap 3	VZI184	May 31, 2023	-	Passed	0.0240	Passed	
Fairview Junior High School	Kitchen 236 tap 4	VZI185	May 31, 2023	-	Passed	0.0170	Passed	
Fairview Junior High School	Kitchen 236 tap 5	VZI186	May 31, 2023	-	Passed	0.0180	Passed	
Fairview Junior High School	Kitchen 230 tap 1	VZI207	May 31, 2023	0.001	Passed	0.0230	Passed	
Fairview Junior High School	Fountain by Room 230	VZI208	May 31, 2023	-	Passed	0.0290	Passed	
Fairview Junior High School	Fountain by Room 205	VZI209	May 31, 2023	-	Passed	0.0250	Passed	
Fairview Junior High School	Girls Wash Room tap 3 by Room 228	VZI210	May 31, 2023	-	Passed	0.0110	Passed	Tap remediated
Fairview Junior High School	Fountain by Room 107	VZI211	May 31, 2023	-	Passed	0.0950	Passed	
Fairview Junior High School	Gender Neutral Wash Room tap by Room 110	VZI212	May 22, 2020	0.001	Passed	0.0150	Passed	
Fairview Junior High School	Staff Room 144 tap	VZI213	May 31, 2023	-	Passed	0.0720	Passed	
Fairview Junior High School	Fountain by Boys Locker Room	VZI214	May 31, 2023	0.001	Passed	0.0470	Passed	
Fairview Junior High School	Physical Education Wash Room 103 tap	VZI215	May 31, 2023	0.001	Passed	0.0780	Passed	Tap remediated
Fairview Junior High School	Boiler Room 014 tap	VZI216	May 31, 2023	0.002	Passed	0.0140	Passed	Tap remediated
Fairview Junior High School	Janitors Closet 009 tap	VZI217	May 31, 2023	0.001	Passed	0.0560	Passed	Tap remediated
Fairview Junior High School	Computer Lab 012 tap	VZI218	May 31, 2023	-	Passed	0.0340	Passed	Tap remediated
Fairview Junior High School	Fountain by Learning Centre	VZI219	May 31, 2023	-	Passed	0.0230	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 1	MUT708	June 5, 2020	0.002	Passed	0.0820	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 3	MUT710	June 5, 2020	0.004	Passed	0.1300	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 4	MUT711	June 5, 2020	0.003	Passed	0.1300	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 8	MUT715	June 5, 2020	0.003	Passed	0.1900	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 9	MUT716	June 5, 2020	0.002	Passed	0.1500	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 10	MUT717	June 5, 2020	0.002	Passed	0.1200	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 11	MUT718	June 5, 2020	0.002	Passed	0.1200	Passed	
Five Bridges Junior High School	Class Room 307 tap	MUT723	June 5, 2020	0.005	Passed	0.0560	Passed	
Five Bridges Junior High School	3rd Floor Staff Wash Room 1 tap	MUT724	June 5, 2020	0.002	Passed	0.0770	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Five Bridges Junior High School	3rd Floor Staff Wash Room 2 tap	MUT725	June 5, 2020	0.002	Passed	0.1000	Passed	
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 1	MUT726	June 5, 2020	0.002	Passed	0.1000	Passed	
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 2	MUT727	June 5, 2020	0.004	Passed	0.0910	Passed	
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 3	MUT728	June 5, 2020	0.003	Passed	0.0490	Passed	
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 4	MUT729	June 5, 2020	0.002	Passed	0.1000	Passed	
Five Bridges Junior High School	3rd Floor Janitors Closet tap	MUT731	June 5, 2020	0.001	Passed	0.1100	Passed	
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 1	MUT732	June 5, 2020	0.002	Passed	0.0770	Passed	
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 2	MUT733	June 5, 2020	0.001	Passed	0.0600	Passed	
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 5	MUT736	June 5, 2020	0.003	Passed	0.0700	Passed	
Five Bridges Junior High School	2nd Floor Girls Locker Room tap 1	MUT740	June 5, 2020	0.002	Passed	0.0820	Passed	
Five Bridges Junior High School	2nd Floor Girls Locker Room tap 2	MUT741	June 5, 2020	0.001	Passed	0.0760	Passed	
Five Bridges Junior High School	2nd Floor Boys Locker Room tap Room 215	MUT744	June 5, 2020	-	Passed	0.0670	Passed	
Five Bridges Junior High School	2nd Floor Boys Wash Room tap 1	MUT748	June 5, 2020	0.001	Passed	0.0530	Passed	
Five Bridges Junior High School	2nd Floor Boys Wash Room tap 2	MUT749	June 5, 2020	0.001	Passed	0.0670	Passed	
Five Bridges Junior High School	2nd Floor Boys Wash Room tap 3	MUT750	June 5, 2020	0.001	Passed	0.0420	Passed	
Five Bridges Junior High School	2nd Floor Boys Wash Room tap 4	MUT751	June 5, 2020	0.001	Passed	0.0370	Passed	
Five Bridges Junior High School	Janitors Closet tap by 2nd Floor Wash Rooms	MUT753	June 5, 2020	0.001	Passed	0.1100	Passed	
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 1	MUT754	June 5, 2020	0.003	Passed	0.0720	Passed	
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 2	MUT755	June 5, 2020	0.001	Passed	0.0610	Passed	
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 3	MUT756	June 5, 2020	0.004	Passed	0.0920	Passed	
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 5	MUT758	June 5, 2020	0.002	Passed	0.0610	Passed	
Five Bridges Junior High School	Main Office Wash Room tap	MUT759	June 5, 2020	0.002	Passed	0.1300	Passed	
Five Bridges Junior High School	1st Floor Boys Wash Room tap 1	MUT760	June 5, 2020	0.002	Passed	0.0720	Passed	
Five Bridges Junior High School	1st Floor Boys Wash Room tap 2	MUT761	June 5, 2020	0.001	Passed	0.0580	Passed	
Five Bridges Junior High School	Janitors Closet tap by 1st Floor Wash Rooms	MUT764	June 5, 2020	0.001	Passed	0.0290	Passed	
Five Bridges Junior High School	1st Floor Girls Wash Room tap 1	MUT765	June 5, 2020	0.002	Passed	0.0540	Passed	
Five Bridges Junior High School	1st Floor Girls Wash Room tap 3	MUT767	June 5, 2020	0.001	Passed	0.0480	Passed	
Five Bridges Junior High School	1st Floor Girls Wash Room tap 4	MUT788	June 5, 2020	0.001	Passed	0.0430	Passed	
Five Bridges Junior High School	Staff Male Wash Room 157 tap	MUT789	June 5, 2020	0.001	Passed	0.0430	Passed	
Five Bridges Junior High School	Staff Female Wash Room 158 tap	MUT790	June 5, 2020	0.001	Passed	0.0520	Passed	
Five Bridges Junior High School	Wood Shop 106 tap 1	MWG744	June 12, 2020	0.002	Passed	0.0800	Passed	
Five Bridges Junior High School	Wood Shop 106 tap 2	MWG745	June 12, 2020	0.001	Passed	0.0700	Passed	
Five Bridges Junior High School	Computer Lab tap	MWG746	June 12, 2020	-	Passed	0.0710	Passed	
Five Bridges Junior High School	Boiler Room tap	MWG747	June 12, 2020	-	Passed	0.0140	Passed	
Five Bridges Junior High School	Art Room	MWG778	June 12, 2020	0.002	Passed	0.2200	Passed	
Five Bridges Junior High School	Art Room tap 1	MWG779	June 12, 2020	0.003	Passed	0.0960	Passed	
Five Bridges Junior High School	Art Room tap 2	MWG780	June 12, 2020	0.004	Passed	0.1300	Passed	
Five Bridges Junior High School	1st Floor Music Room tap	MWG798	June 12, 2020	0.001	Passed	0.0940	Passed	
Five Bridges Junior High School	Staff Wash Room 108 tap	MWVG799	June 12, 2020	-	Passed	0.0880	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 2	RWW532	February 17, 2022	0.011	Exceeded	0.1300	Passed	Laboratory or hand washing only
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 5	RWW533	February 17, 2022	0.008	Exceeded	0.0950	Passed	Laboratory or hand washing only
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 6	RWW534	February 17, 2022	0.003	Passed	0.0630	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 7	RWW535	February 17, 2022	0.002	Passed	0.0460	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 12	RWW536	February 17, 2022	0.005	Exceeded	0.0630	Passed	
Five Bridges Junior High School	3rd Floor Chemistry Lab Storage Room 300A tap	RWW537	February 17, 2022	0.012	Exceeded	0.0680	Passed	Laboratory or hand washing only
Five Bridges Junior High School	Physics Lab 303 tap	RWW538	February 17, 2022	0.069	Exceeded	0.2800	Passed	Laboratory or hand washing only
Five Bridges Junior High School	Physics Lab Storage Room 303A tap	RWW539	February 17, 2022	0.011	Exceeded	0.0360	Passed	Laboratory or hand washing only
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 3	RWW540	February 17, 2022	0.003	Passed	0.0660	Passed	
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 4	RWW541	February 17, 2022	0.003	Passed	0.0640	Passed	
Five Bridges Junior High School	Gym Office Wash Room 209A tap	RWW562	February 17, 2022	0.030	Exceeded	0.1900	Passed	Hand washing only
Five Bridges Junior High School	Gym Office Wash Room 211A tap	RWW563	February 17, 2022	0.004	Passed	0.1900	Passed	
Five Bridges Junior High School	3rd Floor Biology Lab 325 tap 1	RWW565	February 17, 2022	0.003	Passed	0.0360	Passed	
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 4	RWW566	February 17, 2022	-	Passed	0.0160	Passed	
Five Bridges Junior High School	1st Floor Boys Wash Room tap 3	RWW567	February 17, 2022	0.001	Passed	0.0240	Passed	
Five Bridges Junior High School	1st Floor Girls Wash Room tap 2	RWW568	February 17, 2022	0.002	Passed	0.0340	Passed	
Five Bridges Junior High School	Fountain by 1st Floor Wash Rooms	VRZ830	May 2, 2023	-	Passed	0.0099	Passed	
Five Bridges Junior High School	Kitchen/Café tap 1	VRZ831	May 2, 2023	0.002	Passed	0.0680	Passed	
Five Bridges Junior High School	Kitchen/Café tap 2	VRZ832	May 2, 2023	0.003	Passed	0.0640	Passed	
Five Bridges Junior High School	Fountain by 3rd Floor Wash Rooms	VRZ833	May 2, 2023	-	Passed	0.0250	Passed	
Five Bridges Junior High School	Fountain by 2nd Floor Wash Rooms	VRZ834	May 2, 2023	-	Passed	0.0200	Passed	
Five Bridges Junior High School	Learning Centre tap Room 223	VRZ835	May 2, 2023	0.001	Passed	0.0310	Passed	
Five Bridges Junior High School	Learning Centre Room 227 tap	VRZ836	May 2, 2023	0.002	Passed	0.0460	Passed	
Five Bridges Junior High School	Learning Centre Room 225 tap	VRZ837	May 2, 2023	0.002	Passed	0.0230	Passed	
Five Bridges Junior High School	Family Studies tap 1	VRZ838	May 2, 2023	0.001	Passed	0.1700	Passed	
Five Bridges Junior High School	Family Studies tap 2	VRZ839	May 2, 2023	0.001	Passed	0.0510	Passed	
Five Bridges Junior High School	Family Studies tap 3	VRZ842	May 2, 2023	0.001	Passed	0.0400	Passed	
Five Bridges Junior High School	Family Studies tap 4	VRZ843	May 2, 2023	0.001	Passed	0.2300	Passed	
Fleming Tower School	Class Room 2 tap	MOE426	May 4, 2020	0.002	Passed	0.1200	Passed	
Fleming Tower School	Boys Wash Room tap 1	OXM596	February 24, 2021	0.001	Passed	0.1000	Passed	
Fleming Tower School	Boys Wash Room tap 2	OXM597	February 24, 2021	-	Passed	0.0200	Passed	
Fleming Tower School	Boys Wash Room tap 3	OXM598	February 24, 2021	-	Passed	0.0140	Passed	
Fleming Tower School	Girls Wash Room tap 1	VPX381	April 21, 2023	-	Passed	0.0160	Passed	Tap remediated
Fleming Tower School	Girls Wash Room tap 2	OXM600	February 24, 2021	0.001	Passed	0.0220	Passed	
Fleming Tower School	Girls Wash Room tap 3	OXM601	February 24, 2021	-	Passed	0.0150	Passed	
Fleming Tower School	Fountain by Entrance	VPX380	April 21, 2023	-	Passed	0.0220	Passed	
Fleming Tower School	Staff Wash Room tap	MOE427	May 4, 2020	0.002	Passed	0.1100	Passed	
Fleming Tower School	Staff Room tap	VPX382	April 21, 2023	-	Passed	0.0160	Passed	
Gaetz Brook Junior High School	Gender Neutral Wash Room 306 tap	NAN920	June 30, 2020	0.002	Passed	0.1400	Passed	
Gaetz Brook Junior High School	Staff Room Kitchen tap	WGQ487	June 27, 2023	0.001	Passed	0.2100	Passed	
Gaetz Brook Junior High School	Staff Room Wash Room 1 tap	WGQ488	June 27, 2023	-	Passed	0.1300	Passed	Tap remediated
Gaetz Brook Junior High School	Staff Room Wash Room 2 tap	NAN923	June 30, 2020	0.005	Passed	0.5900	Passed	
Gaetz Brook Junior High School	Girls Wash Room tap 1 by Room 305	WGQ509	June 27, 2023	-	Passed	0.1300	Passed	Tap remediated
Gaetz Brook Junior High School	Girls Wash Room tap 2 by Room 305	WGQ510	June 27, 2023	-	Passed	0.1400	Passed	Tap remediated
Gaetz Brook Junior High School	3rd Floor Fountain by Girls Wash Room	WGQ511	June 27, 2023	0.034	Exceeded	0.6300	Passed	Fountain out of service. Other sources available.
Gaetz Brook Junior High School	Janitors Closet tap by Fountain	NAN927	June 30, 2020	0.004	Passed	0.1500	Passed	
Gaetz Brook Junior High School	3rd Floor Boys Wash Room tap 1 by Janitors Closet	WGQ508	June 27, 2023	0.001	Passed	0.1700	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Gaetz Brook Junior High School	3rd Floor Boys Wash Room tap 2 by Janitors Closet	NAN929	June 30, 2020	0.001	Passed	0.1400	Passed	
Gaetz Brook Junior High School	Ms. O'Connell Room tap	WGQ507	June 27, 2023	0.040	Exceeded	1.6000	Passed	Hand washing only
Gaetz Brook Junior High School	Sci Lab tap by Room 300	NAN931	June 30, 2020	0.054	Exceeded	0.1800	Passed	Hand washing only
Gaetz Brook Junior High School	Class Room 300 tap 1	NAN932	June 30, 2020	1.400	Exceeded	1.9000	Passed	Hand washing only
Gaetz Brook Junior High School	Class Room 300 tap 2	NAN933	June 30, 2020	0.024	Exceeded	0.2600	Passed	Hand washing only
Gaetz Brook Junior High School	Class Room 300 tap 3	NAN934	June 30, 2020	0.013	Exceeded	0.4100	Passed	Hand washing only
Gaetz Brook Junior High School	Class Room 300 tap 4	NAN935	June 30, 2020	0.039	Exceeded	0.5500	Passed	Hand washing only
Gaetz Brook Junior High School	Class Room 300 tap 5	NAN936	June 30, 2020	0.110	Exceeded	1.3000	Passed	Hand washing only
Gaetz Brook Junior High School	Laundry Room 203 tub tap	WGQ491	June 27, 2023	0.004	Passed	0.2300	Passed	Tap remediated
Gaetz Brook Junior High School	Girls Wash Room tap 1 by Room 204	NAN938	June 30, 2020	0.001	Passed	0.1200	Passed	
Gaetz Brook Junior High School	Girls Wash Room tap 2 by Room 204	NAN939	June 30, 2020	0.001	Passed	0.1200	Passed	
Gaetz Brook Junior High School	2nd Floor Fountain by Girls Wash Room	WGQ502	June 27, 2023	0.004	Passed	0.2700	Passed	
Gaetz Brook Junior High School	Janitors Closet by Fountain	NAN941	June 30, 2020	0.001	Passed	0.1300	Passed	
Gaetz Brook Junior High School	2nd Floor Boys Wash Room tap 1 by Janitors Closet	NAN942	June 30, 2020	0.001	Passed	0.1200	Passed	
Gaetz Brook Junior High School	2nd Floor Boys Wash Room tap 2 by Janitors Closet	WGQ506	June 27, 2023	-	Passed	0.1100	Passed	Tap remediated
Gaetz Brook Junior High School	Guidance Room tap	WGQ503	June 27, 2023	0.006	Exceeded	0.1300	Passed	Hand washing only
Gaetz Brook Junior High School	Fountain in Boys Locker Room	NAN945	June 30, 2020	0.001	Passed	0.0990	Passed	
Gaetz Brook Junior High School	Boys Locker Room tap	NAN946	June 30, 2020	0.001	Passed	0.0900	Passed	
Gaetz Brook Junior High School	Girls Locker Room tap	WGQ504	June 27, 2023	0.001	Passed	0.2000	Passed	Tap remediated
Gaetz Brook Junior High School	Main Office Staff Wash Room tap	WGQ505	June 27, 2023	0.001	Passed	0.5600	Passed	Tap remediated
Gaetz Brook Junior High School	Girls Wash Room tap 1 by Room 105	WGQ498	June 27, 2023	0.001	Passed	0.1400	Passed	Hand washing only
Gaetz Brook Junior High School	Girls Wash Room tap 2 by Room 105	NAN950	June 30, 2020	0.002	Passed	0.1400	Passed	
Gaetz Brook Junior High School	Fountain by 1st Floor Girls Wash Room	WGQ497	June 27, 2023	0.002	Passed	0.2900	Passed	Fountain out of service. Other sources available.
Gaetz Brook Junior High School	Janitors Closet by fountain	NAN952	June 30, 2020	0.001	Passed	0.1200	Passed	
Gaetz Brook Junior High School	1st Floor Boys Wash Room tap 1 by Janitors Closet	WGQ499	June 27, 2023	0.001	Passed	0.1200	Passed	Tap remediated
Gaetz Brook Junior High School	1st Floor Boys Wash Room tap 2 by Janitors Closet	WGQ500	June 27, 2023	0.001	Passed	0.1300	Passed	Tap remediated
Gaetz Brook Junior High School	Kitchen/Cafeteria tap 1	WGQ492	June 27, 2023	0.002	Passed	0.1800	Passed	Tap remediated
Gaetz Brook Junior High School	Kitchen/Cafeteria handwashing tap	WGQ493	June 27, 2023	0.001	Passed	0.1400	Passed	Tap remediated
Gaetz Brook Junior High School	Kitchen/Cafeteria Wash Room tap	WGQ496	June 27, 2023	0.001	Passed	0.1300	Passed	Tap remediated
Gaetz Brook Junior High School	Kitchen/Cafeteria triple compartment sink tap 1	WGQ494	June 27, 2023	0.001	Passed	0.2000	Passed	Tap remediated
Gaetz Brook Junior High School	Kitchen/Cafeteria triple compartment sink tap 2	WGQ495	June 27, 2023	0.001	Passed	0.2100	Passed	Tap remediated
Gaetz Brook Junior High School	Photo Room tap	NAN960	June 30, 2020	3.300	Exceeded	4.9000	Exceeded	Hand washing only
Gaetz Brook Junior High School	Tech Ed tap	WGQ490	June 27, 2023	0.200	Exceeded	1.5000	Passed	Hand washing only
Gaetz Brook Junior High School	Tech Ed by Art Room tap	WGQ489	June 27, 2023	0.004	Passed	0.1900	Passed	Tap remediated
Gaetz Brook Junior High School	Janitors Closet tap in Art Room	NAN961	June 30, 2020	0.094	Exceeded	2.8000	Exceeded	Hand washing only
Gaetz Brook Junior High School	Art Room tap	WGQ501	June 27, 2023	0.002	Passed	0.5200	Passed	Tap remediated
George Bissett Elementary	Girls Wash Room tap 1 by Room 207	MXK042	June 18, 2020	-	Passed	0.3000	Passed	
George Bissett Elementary	Girls Wash Room tap 2 by Room 207	MXK043	June 18, 2020	0.001	Passed	0.1200	Passed	
George Bissett Elementary	Janitors Closet by Girls Wash Room	MXK044	June 18, 2020	-	Passed	0.0550	Passed	
George Bissett Elementary	Boys Wash Room 215 tap 1	MXK045	June 18, 2020	0.001	Passed	0.4800	Passed	
George Bissett Elementary	Boys Wash Room 215 tap 2	MXK046	June 18, 2020	0.001	Passed	0.2000	Passed	
George Bissett Elementary	Staff Room 221 tap	XCL358	September 22, 2023	-	Passed	0.0120	Passed	
George Bissett Elementary	Staff Room 221 Wash Room tap	MXK048	June 18, 2020	-	Passed	0.0150	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
George Bissett Elementary	Kitchen sink tap by Office	XCL357	September 22, 2023	-	Passed	0.0120	Passed	Tap remediated
George Bissett Elementary	Girls Wash Room 224 tap 1	MXK050	June 18, 2020	-	Passed	0.2500	Passed	
George Bissett Elementary	Girls Wash Room 224 tap 2	MXK051	June 18, 2020	0.003	Passed	0.1900	Passed	
George Bissett Elementary	Girls Wash Room 224 tap 3	MXK052	June 18, 2020	0.001	Passed	0.0460	Passed	
George Bissett Elementary	Girls Wash Room 224 tap 4	MXK053	June 18, 2020	-	Passed	0.0150	Passed	
George Bissett Elementary	Janitors Closet 226 tap	MXK055	June 18, 2020	0.002	Passed	0.1100	Passed	
George Bissett Elementary	Boys Wash Room 228 tap 1	XCL359	September 22, 2023	-	Passed	0.0130	Passed	Tap remediated
George Bissett Elementary	Boys Wash Room 228 tap 2	MXK057	June 18, 2020	-	Passed	0.3900	Passed	
George Bissett Elementary	Boys Wash Room 228 tap 3	MXK058	June 18, 2020	0.001	Passed	0.3600	Passed	
George Bissett Elementary	Boys Wash Room 228 tap 4	MXK059	June 18, 2020	-	Passed	0.2100	Passed	
George Bissett Elementary	Girls Wash Room 110 tap 1	MXK060	June 18, 2020	0.001	Passed	0.3700	Passed	
George Bissett Elementary	Girls Wash Room 110 tap 2	MXK061	June 18, 2020	-	Passed	0.3600	Passed	
George Bissett Elementary	Girls Wash Room 110 tap 3	MXK062	June 18, 2020	0.001	Passed	0.2100	Passed	
George Bissett Elementary	Boys Wash Room 114 tap 1	MXK063	June 18, 2020	0.001	Passed	0.3800	Passed	
George Bissett Elementary	Boys Wash Room 114 tap 2	MXK064	June 18, 2020	-	Passed	0.5100	Passed	
George Bissett Elementary	Boys Wash Room 114 tap 3	MXK065	June 18, 2020	-	Passed	0.4100	Passed	
George Bissett Elementary	Boys Wash Room 114 tap 4	MXK066	June 18, 2020	0.003	Passed	0.4500	Passed	
George Bissett Elementary	Fountain by Room 228	XCL360	September 22, 2023	-	Passed	0.0630	Passed	
George Bissett Elementary	Fountain by Room 109	XCL362	September 22, 2023	-	Passed	0.1200	Passed	
George Bissett Elementary	Fountain by Room 215	XCL361	September 22, 2023	-	Passed	0.0490	Passed	
Georges P. Vanier Junior High School	Principals Office Wash Room tap	MVG411	June 9, 2020	0.001	Passed	0.1800	Passed	
Georges P. Vanier Junior High School	Science Lab tap 1 Room 161	MVG414	June 9, 2020	0.006	Exceeded	0.5800	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 2 Room 161	MVG415	June 9, 2020	0.039	Exceeded	1.5000	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 3 Room 161	MVG416	June 9, 2020	0.067	Exceeded	0.8400	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 4 Room 161	MVG417	June 9, 2020	0.340	Exceeded	1.5000	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Class Room tap Room 164	MVG418	June 9, 2020	0.004	Passed	0.8700	Passed	
Georges P. Vanier Junior High School	Class Room tap 1 Room 146	MVG419	June 9, 2020	0.004	Passed	0.6500	Passed	
Georges P. Vanier Junior High School	Class Room tap 2 Room 146	MVG420	June 9, 2020	0.001	Passed	0.3500	Passed	
Georges P. Vanier Junior High School	Class Room tap 3 Room 146	MVG421	June 9, 2020	-	Passed	0.0760	Passed	
Georges P. Vanier Junior High School	Janitors Closet tap Room 124	MVG429	June 9, 2020	-	Passed	0.0500	Passed	
Georges P. Vanier Junior High School	Boys Wash Room tap 2 Room 116	MVG431	June 9, 2020	0.001	Passed	0.1600	Passed	
Georges P. Vanier Junior High School	Boys Wash Room tap 3 Room 116	MVG432	June 9, 2020	0.001	Passed	0.0570	Passed	
Georges P. Vanier Junior High School	Gym Office 106 Wash Room tap	MVG434	June 9, 2020	0.004	Passed	0.1700	Passed	
Georges P. Vanier Junior High School	Science Lab tap 1 Room 241	MVG436	June 9, 2020	0.200	Exceeded	0.8900	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 2 Room 241	MVG437	June 9, 2020	0.130	Exceeded	0.6200	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 3 Room 241	MVG438	June 9, 2020	0.150	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 4 Room 241	MVG439	June 9, 2020	0.037	Exceeded	0.4500	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 5 Room 241	MVG440	June 9, 2020	0.110	Exceeded	0.4600	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 1 Room 220	MVG446	June 9, 2020	0.028	Exceeded	0.6400	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 2 Room 220	MVG447	June 9, 2020	0.051	Exceeded	0.4100	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 3 Room 220	MVG448	June 9, 2020	0.057	Exceeded	0.2300	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	Science Lab tap 4 Room 220	MVG449	June 9, 2020	0.008	Exceeded	1.1000	Passed	Laboratory or Hand washing only
Georges P. Vanier Junior High School	2nd Floor Boys Wash Room tap 2	MVG456	June 9, 2020	0.002	Passed	0.0930	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Georges P. Vanier Junior High School	2nd Floor Boys Wash Room tap 3	MVG457	June 9, 2020	0.002	Passed	0.0680	Passed	
Georges P. Vanier Junior High School	Cafeteria tap 1	WEK778	June 20, 2023	-	Passed	0.0360	Passed	
Georges P. Vanier Junior High School	Cafeteria tap 2	WEK779	June 20, 2023	-	Passed	0.0270	Passed	
Georges P. Vanier Junior High School	Fountain by Main Office	WEK780	June 20, 2023	-	Passed	0.0700	Passed	
Georges P. Vanier Junior High School	Fountain by Room 124	WEK781	June 20, 2023	-	Passed	0.0330	Passed	
Georges P. Vanier Junior High School	Girls Wash Room 120 tap 1	WEK782	June 20, 2023	0.001	Passed	0.0570	Passed	Tap remediated
Georges P. Vanier Junior High School	Girls Wash Room 120 tap 2	WEK783	June 20, 2023	-	Passed	0.2100	Passed	Tap remediated
Georges P. Vanier Junior High School	Girls Wash Room 120 tap 3	WEK784	June 20, 2023	0.001	Passed	0.1800	Passed	Tap remediated
Georges P. Vanier Junior High School	Boys Wash Room 116 tap 1	WEK785	June 20, 2023	-	Passed	0.1400	Passed	Tap remediated
Georges P. Vanier Junior High School	Gym Office 105 Wash Room tap	WEK786	June 20, 2023	0.001	Passed	0.1500	Passed	Tap remediated
Georges P. Vanier Junior High School	Learning Centre 158 tap	WEK787	June 20, 2023	-	Passed	0.0540	Passed	
Georges P. Vanier Junior High School	Fountain by Girls Wash Room	WEK788	June 20, 2023	-	Passed	0.0450	Passed	
Georges P. Vanier Junior High School	Girls Wash Room 210 tap 2	WEK790	June 20, 2023	0.002	Passed	0.1100	Passed	Tap remediated
Georges P. Vanier Junior High School	Girls Wash Room 210 tap 3	WEK791	June 20, 2023	0.001	Passed	0.0710	Passed	Tap remediated
Georges P. Vanier Junior High School	Girls Wash Room 210 tap 4	WEK792	June 20, 2023	0.002	Passed	0.0710	Passed	Tap remediated
Georges P. Vanier Junior High School	Fountain by Room 240	WEK793	June 20, 2023	0.001	Passed	0.1400	Passed	
Georges P. Vanier Junior High School	2nd Floor Boys Wash Room tap 1	WEK794	June 20, 2023	-	Passed	0.0440	Passed	Tap remediated
Georges P. Vanier Junior High School	Staff Room 216 tap 1	WEK795	June 20, 2023	-	Passed	0.0230	Passed	Tap remediated
Georges P. Vanier Junior High School	Staff Room 216 Wash Room tap	WEK796	June 20, 2023	-	Passed	0.0270	Passed	Tap remediated
Georges P. Vanier Junior High School	Food Lab 231 tap 1	WEK797	June 20, 2023	-	Passed	0.0340	Passed	
Georges P. Vanier Junior High School	Food Lab 231 tap 2	WEK798	June 20, 2023	-	Passed	0.0430	Passed	
Georges P. Vanier Junior High School	Food Lab 231 tap 3	WEK799	June 20, 2023	0.001	Passed	0.0590	Passed	
Georges P. Vanier Junior High School	Food Lab 231 tap 4	WEK800	June 20, 2023	-	Passed	0.0510	Passed	
Georges P. Vanier Junior High School	Modular Girls Wash Room tap 2	WEK805	June 20, 2023	-	Passed	0.0340	Passed	
Georges P. Vanier Junior High School	Clothes Lab 224 tap	WEK801	June 20, 2023	0.002	Passed	0.0710	Passed	Tap remediated
Georges P. Vanier Junior High School	Modular Class Room 12 tap	WEK802	June 20, 2023	-	Passed	0.0800	Passed	
Georges P. Vanier Junior High School	Modular Staff Wash Room 1 tap	WEK803	June 20, 2023	-	Passed	0.1400	Passed	
Georges P. Vanier Junior High School	Modular Girls Wash Room tap 1	WEK804	June 20, 2023	-	Passed	0.0360	Passed	
Georges P. Vanier Junior High School	Modular Girls Wash Room tap 3	WEK806	June 20, 2023	-	Passed	0.0330	Passed	
Georges P. Vanier Junior High School	Fountain by Staff Room	WEK807	June 20, 2023	-	Passed	0.0430	Passed	
Georges P. Vanier Junior High School	Modular Girls Wash Room tap 4	WEK808	June 20, 2023	0.001	Passed	0.0370	Passed	
Georges P. Vanier Junior High School	Modular Boys Wash Room tap 1	WEK809	June 20, 2023	-	Passed	0.0290	Passed	
Georges P. Vanier Junior High School	Modular Boys Wash Room tap 2	WEK810	June 20, 2023	-	Passed	0.0280	Passed	
Georges P. Vanier Junior High School	Fountain in Modular	WEK811	June 20, 2023	-	Passed	0.0330	Passed	
Georges P. Vanier Junior High School	Modular Staff Wash Room 2 tap	WEK812	June 20, 2023	-	Passed	0.0450	Passed	
Georges P. Vanier Junior High School	Modular Janitors Closet tap	WEK813	June 20, 2023	-	Passed	0.1100	Passed	
Georges P. Vanier Junior High School	Modular Staff Room tap	WEK814	June 20, 2023	-	Passed	0.0890	Passed	
Georges P. Vanier Junior High School	Janitors Closet 212 tap	WEK815	June 20, 2023	-	Passed	0.0300	Passed	Tap remediated
Georges P. Vanier Junior High School	Girls Wash Room 210 tap 1	WEK789	June 20, 2023	0.005	Passed	0.0520	Passed	Tap remediated
Gorsebrook Junior High School	Gym Gender Neutral Wash Room tap	MSZ162	May 28, 2020	0.002	Passed	0.1500	Passed	
Gorsebrook Junior High School	Gym Office tap	MSZ163	May 28, 2020	0.002	Passed	0.1400	Passed	
Gorsebrook Junior High School	Girls Locker Room tap	MSZ164	May 28, 2020	0.003	Passed	1.9000	Passed	
Gorsebrook Junior High School	Gender Neutral Wash Room 1 tap by Room 3	MSZ166	May 28, 2020	0.001	Passed	0.2500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Gorsebrook Junior High School	Gender Neutral Wash Room 2 tap by Room 3	MSZ167	May 28, 2020	0.004	Passed	0.2700	Passed	
Gorsebrook Junior High School	1st Floor Staff Room Kitchen tap	MSZ170	May 28, 2020	-	Passed	0.0270	Passed	
Gorsebrook Junior High School	Class Room 12 tap	MSZ171	May 28, 2020	0.002	Passed	0.2100	Passed	
Gorsebrook Junior High School	Janitors Closet tap by Room 18	MSZ172	May 28, 2020	0.001	Passed	0.0530	Passed	
Gorsebrook Junior High School	Male Staff Wash Room tap by Room 18	MSZ173	May 28, 2020	0.002	Passed	0.0620	Passed	
Gorsebrook Junior High School	Boys Wash Room tap 1 by Room 18	MSZ174	May 28, 2020	0.001	Passed	0.2500	Passed	
Gorsebrook Junior High School	Boys Wash Room tap 2 by Room 18	MSZ175	May 28, 2020	0.004	Passed	0.1100	Passed	
Gorsebrook Junior High School	Boys Wash Room tap 3 by Room 18	MSZ176	May 28, 2020	0.004	Passed	0.2200	Passed	
Gorsebrook Junior High School	Boys Wash Room tap 4 by Room 18	MSZ177	May 28, 2020	0.001	Passed	0.2500	Passed	
Gorsebrook Junior High School	Female Staff Wash Room tap by Room 16	MSZ179	May 28, 2020	0.003	Passed	0.2300	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 1 by Room 16	MSZ180	May 28, 2020	0.002	Passed	0.1900	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 2 by Room 16	MSZ181	May 28, 2020	0.004	Passed	0.0530	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 3 by Room 16	MSZ182	May 28, 2020	0.002	Passed	0.3000	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 4 by Room 16	MSZ183	May 28, 2020	0.001	Passed	0.0780	Passed	
Gorsebrook Junior High School	Resource Room 11 Wash Room tap 1	MSZ186	May 28, 2020	0.002	Passed	0.0490	Passed	
Gorsebrook Junior High School	Resource Room 11 Wash Room tap 2	MSZ187	May 28, 2020	0.001	Passed	0.0530	Passed	
Gorsebrook Junior High School	Basement Girls Wash Room tap 1	MSZ193	May 28, 2020	0.003	Passed	0.2000	Passed	
Gorsebrook Junior High School	Janitors Closet tap Room 30	MUV532	June 8, 2020	0.001	Passed	0.1300	Passed	
Gorsebrook Junior High School	Wood Work Room 28 tap	MUV533	June 8, 2020	-	Passed	0.2500	Passed	
Gorsebrook Junior High School	Basement Boys Wash Room tap 2	SCH300	March 15, 2022	0.001	Passed	0.0630	Passed	
Gorsebrook Junior High School	Boys Locker Room tap	SCH596	March 15, 2022	-	Passed	0.0660	Passed	
Gorsebrook Junior High School	Art Room 3 tap	SCH597	March 15, 2022	0.001	Passed	0.1200	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 5 by Room 16	SCH598	March 15, 2022	-	Passed	0.0820	Passed	
Gorsebrook Junior High School	Basement Boys Wash Room tap 1	SCH599	March 15, 2022	0.004	Passed	0.0930	Passed	
Gorsebrook Junior High School	Basement Boys Wash Room tap 3	SCH601	March 15, 2022	0.001	Passed	0.0680	Passed	
Gorsebrook Junior High School	Basement Class Room 29 tap	SCH602	March 15, 2022	0.003	Passed	0.1200	Passed	
Gorsebrook Junior High School	Basement Girls Wash Room tap 2	SCH603	March 15, 2022	0.002	Passed	0.2600	Passed	
Gorsebrook Junior High School	Storage Room 32 tap	SCH613	March 15, 2022	0.004	Passed	0.1000	Passed	
Gorsebrook Junior High School	Fountain by Gym	VTZ857	May 9, 2023	0.001	Passed	0.0980	Passed	
Gorsebrook Junior High School	1st Floor Staff Wash Room tap	VTZ858	May 9, 2023	-	Passed	0.0370	Passed	
Gorsebrook Junior High School	Fountain by Main Office	VTZ859	March 15, 2022	-	Passed	0.0009	Passed	
Gorsebrook Junior High School	Fountain by Room 16	VTZ860	May 9, 2023	0.000	Passed	0.0340	Passed	
Gorsebrook Junior High School	Resource Room 11 tap	VTZ861	May 9, 2023	-	Passed	0.0530	Passed	
Gorsebrook Junior High School	Basement Food Lab tap 1	VTZ862	May 9, 2023	0.001	Passed	0.0430	Passed	
Gorsebrook Junior High School	Basement Food Lab tap 3	VTZ864	May 9, 2023	0.001	Passed	0.0720	Passed	
Gorsebrook Junior High School	Basement Girls Wash Room tap 3	VTZ866	May 9, 2023	-	Passed	0.0310	Passed	Tap remediated
Gorsebrook Junior High School	Basement Food Lab tap 2	VYZ863	May 9, 2023	-	Passed	0.0710	Passed	
Gorsebrook Junior High School	Basement Food Lab tap 4	VYZ865	May 9, 2023	0.001	Passed	0.1100	Passed	
Graham Creighton Junior High School	Administrative Office Wash Room tap	MYA071	June 22, 2020	0.002	Passed	0.2800	Passed	
Graham Creighton Junior High School	Science Room 184 tap	MYA072	June 22, 2020	-	Passed	1.3000	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 1 by Room 184	MYA073	June 22, 2020	-	Passed	0.1400	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 2 by Room 184	MYA074	June 22, 2020	-	Passed	0.1300	Passed	
Graham Creighton Junior High School	Janitors Closet tap	MYA075	June 22, 2020	0.004	Passed	1.2000	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Graham Creighton Junior High School	Fountain between Wash Rooms near 174	XCF286	September 21, 2023	-	Passed	0.1800	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 1 before Room 162	MYA077	June 22, 2020	0.001	Passed	0.1400	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 2 before Room 162	MYA078	June 22, 2020	0.001	Passed	0.1300	Passed	
Graham Creighton Junior High School	Learning Centre 162 tap	xcf287	September 21, 2023	0.001	Passed	0.0930	Passed	
Graham Creighton Junior High School	Class Room 165 tap	MYA080	June 22, 2020	-	Passed	0.2700	Passed	
Graham Creighton Junior High School	Girls Wash Room 112 tap 1	MYA081	June 22, 2020	0.004	Passed	0.3100	Passed	
Graham Creighton Junior High School	Girls Wash Room 112 tap 2	MYA082	June 22, 2020	0.001	Passed	0.2400	Passed	
Graham Creighton Junior High School	Girls Wash Room 112 tap 3	MYA083	June 22, 2020	0.004	Passed	0.2200	Passed	
Graham Creighton Junior High School	Gender Neutral Wash Room 113 tap	MYA084	June 22, 2020	0.002	Passed	0.1000	Passed	
Graham Creighton Junior High School	Fountain by Room 113	XCF280	September 21, 2023	-	Passed	0.0830	Passed	
Graham Creighton Junior High School	Janitors Closet tap between Wash Rooms	MYA086	June 22, 2020	0.004	Passed	0.3100	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 1 by Room 113	MYA087	June 22, 2020	0.003	Passed	0.2400	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 2 by Room 113	MYA088	June 22, 2020	0.001	Passed	0.2200	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 3 by Room 113	MYA089	June 22, 2020	0.001	Passed	0.3600	Passed	
Graham Creighton Junior High School	Girls Locker Room tap 1	MYA091	June 22, 2020	-	Passed	0.3900	Passed	
Graham Creighton Junior High School	Girls Locker Room tap 2	MYA092	June 22, 2020	-	Passed	0.3300	Passed	
Graham Creighton Junior High School	Gym Office Wash Room tap	MYA093	June 22, 2020	-	Passed	0.1300	Passed	
Graham Creighton Junior High School	Boys Locker Room tap 1	MYA094	June 22, 2020	-	Passed	0.7100	Passed	
Graham Creighton Junior High School	Boys Locker Room tap 2	MYA095	June 22, 2020	0.001	Passed	0.3200	Passed	
Graham Creighton Junior High School	Community Area Wash Room 134 tap	XCF288	September 21, 2023	-	Passed	0.3700	Passed	
Graham Creighton Junior High School	Community Are Meeting Room 135 tap	XCF289	September 21, 2023	-	Passed	0.1300	Passed	
Graham Creighton Junior High School	Janitors Closet tap before Room 121	NAM737	June 30, 2020	0.001	Passed	0.1100	Passed	
Graham Creighton Junior High School	Cafeteria 121 tap 1	XCF282	September 21, 2023	-	Passed	0.0970	Passed	
Graham Creighton Junior High School	Cafeteria 121 tap 2	XCF283	September 21, 2023	-	Passed	0.0900	Passed	
Graham Creighton Junior High School	Cafeteria 121 tap 3	XCF284	September 21, 2023	-	Passed	0.0760	Passed	
Graham Creighton Junior High School	Cafeteria 121 tap 4	XCF285	September 21, 2023	-	Passed	0.0660	Passed	
Graham Creighton Junior High School	Fountain by Room 121	XCF281	September 21, 2023	-	Passed	0.1500	Passed	
Graham Creighton Junior High School	Art Room tap 1	MYA104	June 22, 2020	-	Passed	0.2800	Passed	
Graham Creighton Junior High School	Art Room tap 2	MYA105	June 22, 2020	0.001	Passed	0.1200	Passed	
Graham Creighton Junior High School	Tech Ed. Room tap	MYA106	June 22, 2020	0.003	Passed	0.2600	Passed	
Graham Creighton Junior High School	Staff Room tap	XCF279	September 21, 2021	-	Passed	0.0710	Passed	
Graham Creighton Junior High School	Staff Room Wash Room tap	MYA108	June 22, 2020	-	Passed	0.2300	Passed	
Graham Creighton Junior High School	Library tap	XCF297	September 21, 2023	-	Passed	0.0950	Passed	
Graham Creighton Junior High School	Staff Wash Room tap in Gym	MYA110	June 22, 2020	0.001	Passed	0.1700	Passed	
Graham Creighton Junior High School	Fountain by Room 230	XCF290	September 21, 2023	-	Passed	0.1400	Passed	
Graham Creighton Junior High School	Staff Wash Room 230 tap	MYA112	June 22, 2020	-	Passed	0.1900	Passed	
Graham Creighton Junior High School	2nd Floor Girls Wash Room tap 1	MYA113	June 22, 2020	-	Passed	0.1500	Passed	
Graham Creighton Junior High School	2nd Floor Girls Wash Room tap 2	MYA114	June 22, 2020	-	Passed	0.1600	Passed	
Graham Creighton Junior High School	Janitors Closet tap by Girls Wash Room	MYA115	June 22, 2020	-	Passed	0.3700	Passed	
Graham Creighton Junior High School	2nd Floor Fountain between Wash Rooms	XCF292	September 21, 2023	0.001	Passed	0.1000	Passed	
Graham Creighton Junior High School	2nd Floor Boys Wash Room tap 1	MYA117	June 22, 2020	0.002	Passed	0.3300	Passed	
Graham Creighton Junior High School	2nd Floor Boys Wash Room tap 2	MYA118	June 22, 2020	-	Passed	0.1800	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 1 by Room 205	MYA119	June 22, 2020	-	Passed	0.1700	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Graham Creighton Junior High School	Girls Wash Room tap 2 by Room 205	MYA120	June 22, 2020	0.001	Passed	0.1100	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 3 by Room 205	MYA126	June 22, 2020	0.001	Passed	0.4300	Passed	
Graham Creighton Junior High School	Staff Wash Room 205 tap	MYA127	June 22, 2020	0.001	Passed	0.0930	Passed	
Graham Creighton Junior High School	Fountain by Room 208	XCF291	September 21, 2023	-	Passed	0.0110	Passed	
Graham Creighton Junior High School	Boys Wash Room 208 tap 1	MYA129	June 22, 2020	0.001	Passed	0.5200	Passed	
Graham Creighton Junior High School	Boys Wash Room 208 tap 2	MYA130	June 22, 2020	0.001	Passed	0.1300	Passed	
Graham Creighton Junior High School	Boys Wash Room 208 tap 3	MYA131	June 22, 2020	0.001	Passed	0.2000	Passed	
Graham Creighton Junior High School	Janitors Closet tap by Room 208	MYA132	June 22, 2020	0.001	Passed	0.1100	Passed	
Graham Creighton Junior High School	Family Studies 209 tap 1	XCF294	September 21, 2023	0.001	Passed	0.2400	Passed	
Graham Creighton Junior High School	Family Studies 209 tap 2	XCF293	September 21, 2023	0.001	Passed	0.0140	Passed	
Graham Creighton Junior High School	Family Studies 209 tap 3	XCF295	September 21, 2023	-	Passed	0.0140	Passed	
Graham Creighton Junior High School	Family Studies 209 tap 4	XCF296	September 21, 2023	-	Passed	0.0220	Passed	
Grosvenor-Wentworth Park Elementary	Fountain in Modular	VVK781	May 16, 2023	-	Passed	0.0180	Passed	
Grosvenor-Wentworth Park Elementary	Janitors Closet tap near Room 113	MUL566	June 3, 2020	0.001	Passed	0.0490	Passed	
Grosvenor-Wentworth Park Elementary	Class Room tap Room 113	MUL568	June 3, 2020	0.001	Passed	0.0860	Passed	
Grosvenor-Wentworth Park Elementary	Girls Wash Room tap 1 by Room 122	MUL570	June 3, 2020	-	Passed	0.0600	Passed	
Grosvenor-Wentworth Park Elementary	Girls Wash Room tap 2 by Room 122	MUL571	June 3, 2020	0.002	Passed	0.0860	Passed	
Grosvenor-Wentworth Park Elementary	Boys Wash Room tap 1 by Room 122	MUL573	June 3, 2020	0.001	Passed	0.0740	Passed	
Grosvenor-Wentworth Park Elementary	Boys Wash Room tap 2 by Room 122	MUL574	June 3, 2020	0.001	Passed	0.0890	Passed	
Grosvenor-Wentworth Park Elementary	Gym Office Wash Room tap	MUL576	June 3, 2020	0.004	Passed	0.0580	Passed	
Grosvenor-Wentworth Park Elementary	Class Room tap Room 145	MUL577	June 3, 2020	0.001	Passed	0.1000	Passed	
Grosvenor-Wentworth Park Elementary	Boys Wash Room tap 1 by Room 145	MUL578	June 3, 2020	-	Passed	0.0420	Passed	
Grosvenor-Wentworth Park Elementary	Boys Wash Room tap 2 by Room 145	MUL579	June 3, 2020	0.001	Passed	0.0640	Passed	
Grosvenor-Wentworth Park Elementary	Janitors Closet tap between Wash Room's	MUL580	June 3, 2020	0.002	Passed	0.0290	Passed	
Grosvenor-Wentworth Park Elementary	Girls Wash Room tap 1 after Room 145	MUL581	June 3, 2020	0.001	Passed	0.0450	Passed	
Grosvenor-Wentworth Park Elementary	Girls Wash Room tap 2 after Room 145	MUL582	June 3, 2020	0.001	Passed	0.0300	Passed	
Grosvenor-Wentworth Park Elementary	Class Room tap Room 7	MUL583	June 3, 2020	0.002	Passed	0.1200	Passed	
Grosvenor-Wentworth Park Elementary	Girls Wash Room tap 2 by Room 7	MUL585	June 3, 2020	-	Passed	0.0210	Passed	
Grosvenor-Wentworth Park Elementary	Girls Wash Room tap 3 by Room 7	MUL586	June 3, 2020	-	Passed	0.0200	Passed	
Grosvenor-Wentworth Park Elementary	Girls Wash Room tap 4 by Room 7	MUL587	June 3, 2020	0.001	Passed	0.0560	Passed	
Grosvenor-Wentworth Park Elementary	Girls Wash Room tap 5 by Room 7	MUL588	June 3, 2020	0.002	Passed	0.0300	Passed	
Grosvenor-Wentworth Park Elementary	Boys Wash Room tap 1 after Room 7	MUL591	June 3, 2020	-	Passed	0.0120	Passed	
Grosvenor-Wentworth Park Elementary	Boys Wash Room tap 2 after Room 7	MUL592	June 3, 2020	-	Passed	0.0060	Passed	
Grosvenor-Wentworth Park Elementary	Boys Wash Room tap 3 after Room 7	MUL593	June 3, 2020	-	Passed	0.0073	Passed	
Grosvenor-Wentworth Park Elementary	Boys Wash Room tap 4 after Room 7	MUL594	June 3, 2020	-	Passed	0.0049	Passed	
Grosvenor-Wentworth Park Elementary	Janitors Closet tap after Boys Wash Room	MUL595	June 3, 2020	0.001	Passed	0.0200	Passed	
Grosvenor-Wentworth Park Elementary	Staff Room tap	VVK773	May 16, 2023	-	Passed	0.0150	Passed	
Grosvenor-Wentworth Park Elementary	Staff Wash Room tap	VVK774	May 16, 2023	-	Passed	0.0069	Passed	Tap remediated
Grosvenor-Wentworth Park Elementary	Fountain by Girls Wash Room	VVK775	May 16, 2023	-	Passed	0.0830	Passed	
Grosvenor-Wentworth Park Elementary	Girls Wash Room tap 1 by Room 7	VVK776	May 16, 2023	-	Passed	0.0160	Passed	Tap remediated
Grosvenor-Wentworth Park Elementary	Fountain by Wash Room's	VVK777	May 16, 2023	-	Passed	0.0150	Passed	
Grosvenor-Wentworth Park Elementary	Class Room tap before Room 122	VVK778	May 16, 2023	-	Passed	0.0140	Passed	Tap remediated
Grosvenor-Wentworth Park Elementary	Fountain by Janitors Closet	VVK779	May 16, 2023	-	Passed	0.0270	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Grosvenor-Wentworth Park Elementary	Class Room tap by Room 113	VVK780	May 16, 2023	0.001	Passed	0.1600	Passed	Tap remediated
Grosvenor-Wentworth Park Elementary	Modular Janitors Closet tap	VVK782	May 16, 2023	-	Passed	0.0150	Passed	
Grosvenor-Wentworth Park Elementary	Modular Girls Wash Room tap 1	VVK783	May 16, 2023	-	Passed	0.0180	Passed	
Grosvenor-Wentworth Park Elementary	Modular Girls Wash Room tap 2	VVK784	May 16, 2023	-	Passed	0.0130	Passed	
Grosvenor-Wentworth Park Elementary	Modular Girls Wash Room tap 3	VVK785	May 16, 2023	-	Passed	0.0170	Passed	
Grosvenor-Wentworth Park Elementary	Modular Girls Wash Room tap 4	VVK786	May 16, 2023	-	Passed	0.0160	Passed	
Grosvenor-Wentworth Park Elementary	Modular Staff Room tap	VVK787	May 16, 2023	0.001	Passed	0.0170	Passed	
Grosvenor-Wentworth Park Elementary	Modular Boys Wash Room tap 1	VVK788	May 16, 2023	-	Passed	0.0090	Passed	
Grosvenor-Wentworth Park Elementary	Modular Boys Wash Room tap 2	VVK789	May 16, 2023	-	Passed	0.0077	Passed	
Halifax Central Junior High School	1st Floor Boys Wash Room tap 1	MTN565	May 28, 2020	-	Passed	0.0220	Passed	
Halifax Central Junior High School	1st Floor Boys Wash Room tap 2	MTN566	May 28, 2020	-	Passed	0.0210	Passed	
Halifax Central Junior High School	1st Floor Boys Wash Room tap 3	MTN567	May 28, 2020	-	Passed	0.0210	Passed	
Halifax Central Junior High School	1st Floor Boys Wash Room tap 4	MTN568	May 28, 2020	-	Passed	0.0200	Passed	
Halifax Central Junior High School	Art Room tap Room 7	MTN569	May 28, 2020	0.004	Passed	0.7800	Passed	
Halifax Central Junior High School	Wood Shop sink tap	MTN570	May 28, 2020	0.001	Passed	0.5000	Passed	
Halifax Central Junior High School	Girls Locker Room tap 1	MTN572	May 28, 2020	-	Passed	0.0390	Passed	
Halifax Central Junior High School	Girls Locker Room tap 2	MTN587	May 28, 2020	-	Passed	0.0390	Passed	
Halifax Central Junior High School	Boys Locker Room tap 1	MTN588	May 28, 2020	-	Passed	0.0082	Passed	
Halifax Central Junior High School	Boys Locker Room tap 2	MTN589	May 28, 2020	-	Passed	0.0078	Passed	
Halifax Central Junior High School	Gender Neutral Wash Room tap	MTN590	May 28, 2020	-	Passed	0.0065	Passed	
Halifax Central Junior High School	Girls Wash Room tap 1 by Room 4	MTN592	May 28, 2020	0.001	Passed	0.1600	Passed	
Halifax Central Junior High School	Girls Wash Room tap 2 by Room 4	MTN593	May 28, 2020	0.001	Passed	0.0780	Passed	
Halifax Central Junior High School	Girls Wash Room tap 3 by Room 4	MTN594	May 28, 2020	0.001	Passed	0.0450	Passed	
Halifax Central Junior High School	Girls Wash Room tap 4 by Room 4	MTN595	May 28, 2020	-	Passed	0.0370	Passed	
Halifax Central Junior High School	Girls Wash Room tap 5 by Room 4	MTN596	May 28, 2020	-	Passed	0.0320	Passed	
Halifax Central Junior High School	Class Room tap Room 17	MTN602	May 28, 2020	-	Passed	0.0250	Passed	
Halifax Central Junior High School	Girls Wash Room tap 1 by Room 9	MTN606	May 28, 2020	0.001	Passed	0.1200	Passed	
Halifax Central Junior High School	Girls Wash Room tap 2 by Room 9	MTN607	May 28, 2020	0.001	Passed	0.1200	Passed	
Halifax Central Junior High School	Girls Wash Room tap 3 by Room 9	MTN608	May 28, 2020	0.001	Passed	0.0730	Passed	
Halifax Central Junior High School	Girls Wash Room tap 4 by Room 9	MTN609	May 28, 2020	-	Passed	0.0200	Passed	
Halifax Central Junior High School	Girls Wash Room tap 5 by Room 9	MTN610	May 28, 2020	-	Passed	0.0190	Passed	
Halifax Central Junior High School	Gender Neutral Wash Room tap Room 22	MTN613	May 28, 2020	-	Passed	0.0130	Passed	
Halifax Central Junior High School	VP Office Wash Room tap	MTN614	May 28, 2020	0.002	Passed	0.0800	Passed	
Halifax Central Junior High School	Boys Wash Room tap 1 by Office	MTN615	May 28, 2020	-	Passed	0.0150	Passed	
Halifax Central Junior High School	Boys Wash Room tap 2 by Office	MTN616	May 28, 2020	-	Passed	0.0140	Passed	
Halifax Central Junior High School	Boys Wash Room tap 3 by Office	MTN617	May 28, 2020	-	Passed	0.0140	Passed	
Halifax Central Junior High School	Boys Wash Room tap 4 by Office	MTN618	May 28, 2020	-	Passed	0.0140	Passed	
Halifax Central Junior High School	Chemistry Lab tap 1	MTN619	May 28, 2020	0.001	Passed	0.0170	Passed	
Halifax Central Junior High School	Chemistry Lab tap 2	MTN620	May 28, 2020	0.001	Passed	0.0120	Passed	
Halifax Central Junior High School	Storage Room in Gym tap (right back corner)	NFZ852	July 30, 2020	0.003	Passed	0.0810	Passed	
Halifax Central Junior High School	Fountain by Boys Wash Room	VUA363	May 9, 2023	-	Passed	0.0018	Passed	
Halifax Central Junior High School	Fountain by Room 4	VUA364	May 9, 2023	-	Passed	0.1300	Passed	
Halifax Central Junior High School	Fountain by Gym	VUA365	May 9, 2023	-	Passed	0.0008	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Halifax Central Junior High School	1st Floor First Aid Room tap	VUA366	May 9, 2023	-	Passed	0.0190	Passed	
Halifax Central Junior High School	Staff Room tap	VUA3678	May 9, 2023	-	Passed	0.0540	Passed	
Halifax Central Junior High School	Family Studies tap 1 Room 9	VUA368	May 9, 2023	0.002	Passed	0.2800	Passed	
Halifax Central Junior High School	Family Studies tap 2 Room 9	VUA369	May 9, 2023	-	Passed	0.1500	Passed	
Halifax Central Junior High School	Family Studies tap 3 Room 9	VUA370	May 9, 2023	0.001	Passed	0.2300	Passed	
Halifax Central Junior High School	Fountain by Room 9	VUA371	May 9, 2023	-	Passed	0.0005	Passed	
Halifax Central Junior High School	Upstairs Fountain	VUA372	May 9, 2023	-	Passed	0.0006	Passed	
Halifax West High School	Class Room B329 tap 2	MUJ166	June 2, 2020	-	Passed	0.0770	Passed	
Halifax West High School	Class Room B327 tap	MUJ167	June 2, 2020	-	Passed	0.2000	Passed	
Halifax West High School	Class Room B322 tap	MUJ168	June 2, 2020	-	Passed	0.8300	Passed	
Halifax West High School	Class Room B315 tap	MUJ169	June 2, 2020	-	Passed	0.4200	Passed	
Halifax West High School	Class Room B317 tap	MUJ170	June 2, 2020	-	Passed	0.1400	Passed	
Halifax West High School	Class Room B316 tap	MUJ171	June 2, 2020	-	Passed	0.0310	Passed	
Halifax West High School	Class Room A354 tap	MUJ173	June 2, 2020	0.001	Passed	0.7100	Passed	
Halifax West High School	Class Room A353 tap 1	MUJ174	June 2, 2020	-	Passed	0.3400	Passed	
Halifax West High School	Class Room A353 tap 2	MUJ175	June 2, 2020	-	Passed	0.1100	Passed	
Halifax West High School	Class Room A353 tap 3	MUJ176	June 2, 2020	-	Passed	0.3600	Passed	
Halifax West High School	Class Room A353 tap 4	MUJ177	June 2, 2020	-	Passed	0.6400	Passed	
Halifax West High School	Room A352 tap 1	MUJ178	June 2, 2020	0.004	Passed	0.3100	Passed	
Halifax West High School	Room A352 tap 2	VYN902	May 30, 2023	0.001	Passed	0.1400	Passed	Tap remediated
Halifax West High School	Room A352 tap 3	MUJ180	June 2, 2020	0.002	Passed	0.9800	Passed	
Halifax West High School	Room A352 tap 4	VYN903	May 30, 2023	0.004	Passed	0.4800	Passed	Tap remediated
Halifax West High School	Room A352 tap 5	MUJ182	June 2, 2020	0.001	Passed	0.8500	Passed	
Halifax West High School	Room A351 tap 1	MUJ183	June 2, 2020	-	Passed	0.9100	Passed	
Halifax West High School	Room A351 tap 2	VYN904	May 30, 2023	0.001	Passed	0.0430	Passed	Tap remediated
Halifax West High School	Room A351 tap 3	VYN905	May 30, 2023	0.001	Passed	0.4600	Passed	Tap remediated
Halifax West High School	Room A351 tap 4	MUJ186	June 2, 2020	-	Passed	0.7400	Passed	
Halifax West High School	Room A351 tap 5	MUJ187	June 2, 2020	0.002	Passed	0.1800	Passed	
Halifax West High School	Room A350 tap 3	MUJ190	June 2, 2020	0.002	Passed	0.1100	Passed	
Halifax West High School	Room A350 tap 4	XKK301	October 26, 2023	-	Passed	0.0430	Passed	Tap remediated
Halifax West High School	Room A350 tap 5	MUJ192	June 2, 2020	0.002	Passed	0.4200	Passed	
Halifax West High School	Fountain by Room A350	VYN901	May 30, 2023	-	Passed	0.0530	Passed	
Halifax West High School	Room A340 tap 1	MUJ195	June 2, 2020	0.001	Passed	0.6000	Passed	
Halifax West High School	Room A340 tap 2	MUJ196	June 2, 2020	0.001	Passed	0.4300	Passed	
Halifax West High School	Room A340 tap 3	VYN908	May 30, 2023	0.003	Passed	0.5900	Passed	Tap remediated
Halifax West High School	Room A340 tap 4	MUJ198	June 2, 2020	0.002	Passed	0.5400	Passed	
Halifax West High School	Gender Neutral Wash Room A332 tap	MUJ193	June 2, 2020	-	Passed	0.0370	Passed	
Halifax West High School	Dressing Room B22 tap 1	MUJ203	June 2, 2020	-	Passed	0.0720	Passed	
Halifax West High School	Dressing Room B22 tap 2	MUJ204	June 2, 2020	0.001	Passed	0.1600	Passed	
Halifax West High School	Tech Ed Room B214 tap	MUJ205	June 2, 2020	0.001	Passed	0.2400	Passed	
Halifax West High School	Main Office Wash Room tap	MUJ209	June 2, 2020	-	Passed	0.1400	Passed	
Halifax West High School	Gym Gender Neutral Wash Room tap	MUJ212	June 2, 2020	-	Passed	0.0350	Passed	
Halifax West High School	Gym Office A267	MUJ214	June 2, 2020	0.001	Passed	0.2700	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Halifax West High School	Girls Locker Room 1 tap	MUJ215	June 2, 2020	0.001	Passed	0.4500	Passed	
Halifax West High School	Boys Locker Room 1 tap	MUJ216	June 2, 2020	-	Passed	0.1800	Passed	
Halifax West High School	Boys Locker Room 2 tap	MUJ217	June 2, 2020	-	Passed	0.3400	Passed	
Halifax West High School	Girls Locker Room 2 tap	MUJ218	June 2, 2020	0.002	Passed	0.2000	Passed	
Halifax West High School	Gym Office A264 tap	MUJ219	June 2, 2020	-	Passed	0.4500	Passed	
Halifax West High School	Boys Wash Room A221 tap 1	MUJ221	June 2, 2020	-	Passed	0.0740	Passed	
Halifax West High School	Boys Wash Room A221 tap 2	MUJ222	June 2, 2020	-	Passed	0.1100	Passed	
Halifax West High School	Boys Wash Room A221 tap 3	MUJ223	June 2, 2020	-	Passed	0.1500	Passed	
Halifax West High School	Boys Wash Room A221 tap 4	MUJ224	June 2, 2020	0.002	Passed	0.0910	Passed	
Halifax West High School	Janitors Closet tap by Room A221	MUJ225	June 2, 2020	-	Passed	0.0320	Passed	
Halifax West High School	Girls Wash Room A224 tap 1	MUJ290	June 2, 2020	0.001	Passed	0.1200	Passed	
Halifax West High School	Girls Wash Room A224 tap 2	MUJ291	June 2, 2020	-	Passed	0.1700	Passed	
Halifax West High School	Girls Wash Room A224 tap 3	MUJ292	June 2, 2020	-	Passed	0.2100	Passed	
Halifax West High School	Girls Wash Room A224 tap 4	MUJ293	June 2, 2020	-	Passed	0.1600	Passed	
Halifax West High School	Class Room A225 tap	MUJ294	June 2, 2020	-	Passed	0.4600	Passed	
Halifax West High School	Gender Neutral Wash Room A226 tap 1	MUJ295	June 2, 2020	-	Passed	0.1900	Passed	
Halifax West High School	Gender Neutral Wash Room A226 tap 2	MUJ296	June 2, 2020	0.001	Passed	0.1500	Passed	
Halifax West High School	Staff Wash Room A230 tap	MUJ297	June 2, 2020	0.002	Passed	0.2300	Passed	
Halifax West High School	Girls Wash Room A234 tap 1	MUJ298	June 2, 2020	-	Passed	0.1300	Passed	
Halifax West High School	Girls Wash Room A234 tap 2	MUJ299	June 2, 2020	-	Passed	0.1300	Passed	
Halifax West High School	Girls Wash Room A234 tap 3	MUJ300	June 2, 2020	0.001	Passed	0.1300	Passed	
Halifax West High School	Janitors Closet tap by Room A234	MUJ302	June 2, 2020	0.001	Passed	0.0570	Passed	
Halifax West High School	Boys Wash Room A235 tap 1	MUJ303	June 2, 2020	0.001	Passed	0.0720	Passed	
Halifax West High School	Boys Wash Room A235 tap 2	MUJ304	June 2, 2020	-	Passed	0.2600	Passed	
Halifax West High School	Boys Wash Room A235 tap 3	MUJ305	June 2, 2020	-	Passed	0.2500	Passed	
Halifax West High School	Boys Wash Room A235 tap 4	MUJ306	June 2, 2020	-	Passed	0.2600	Passed	
Halifax West High School	Mechanical Room C135 tap	MUJ308	June 2, 2020	0.001	Passed	0.0710	Passed	
Halifax West High School	Boys Wash Room C161 tap 1	MUJ310	June 2, 2020	0.001	Passed	0.1800	Passed	
Halifax West High School	Boys Wash Room C161 tap 2	MUJ311	June 2, 2020	-	Passed	0.2200	Passed	
Halifax West High School	Boys Wash Room C161 tap 3	MUJ312	June 2, 2020	0.001	Passed	0.1700	Passed	
Halifax West High School	Staff Wash Room C160 tap	MUJ313	June 2, 2020	0.004	Passed	0.2200	Passed	
Halifax West High School	Girls Wash Room C162 tap 2	MUJ315	June 2, 2020	-	Passed	0.2300	Passed	
Halifax West High School	Girls Wash Room C162 tap 3	MUJ316	June 2, 2020	-	Passed	0.1800	Passed	
Halifax West High School	Girls Wash Room C172 tap 1	MUJ317	June 2, 2020	-	Passed	0.1700	Passed	
Halifax West High School	Girls Wash Room C172 tap 2	MUJ318	June 2, 2020	-	Passed	0.2200	Passed	
Halifax West High School	Girls Wash Room C172 tap 3	MUJ319	June 2, 2020	0.004	Passed	0.3700	Passed	
Halifax West High School	Staff Wash Room C170 tap	MUJ320	June 2, 2020	-	Passed	0.0470	Passed	
Halifax West High School	Boys Wash Room C171 tap 1	MUJ321	June 2, 2020	0.010	Exceeded	0.4700	Passed	Hand washing only
Halifax West High School	Boys Wash Room C171 tap 2	MUJ322	June 2, 2020	-	Passed	0.5000	Passed	
Halifax West High School	Boys Wash Room C171 tap 3	MUJ323	June 2, 2020	-	Passed	0.2100	Passed	
Halifax West High School	Gender Neutral Wash Room C152 tap	MUJ325	June 2, 2020	0.001	Passed	0.1800	Passed	
Halifax West High School	Janitors Closet tap by Room C152	MUJ326	June 2, 2020	-	Passed	0.0370	Passed	
Halifax West High School	Girls Wash Room A313 tap 1	MUJ327	June 2, 2020	0.003	Passed	0.2500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Halifax West High School	Girls Wash Room A313 tap 2	MUJ328	June 2, 2020	-	Passed	0.1700	Passed	
Halifax West High School	Girls Wash Room A313 tap 3	MUJ329	June 2, 2020	-	Passed	0.1400	Passed	
Halifax West High School	Gender Neutral Wash Room tap by Room A312	MUJ330	June 2, 2020	-	Passed	0.1800	Passed	
Halifax West High School	Boys Wash Room A312 tap 1	MUJ331	June 2, 2020	-	Passed	0.3500	Passed	
Halifax West High School	Boys Wash Room A312 tap 2	MUJ332	June 2, 2020	-	Passed	0.4200	Passed	
Halifax West High School	Boys Wash Room A312 tap 3	MUJ333	June 2, 2020	0.001	Passed	0.1900	Passed	
Halifax West High School	Chemistry Lab A333 tap 1	MUJ335	June 2, 2020	-	Passed	0.4000	Passed	
Halifax West High School	Chemistry Lab A333 tap 2	MUJ336	June 2, 2020	-	Passed	0.4500	Passed	
Halifax West High School	Chemistry Lab A333 tap 3	MUJ337	June 2, 2020	0.001	Passed	0.2500	Passed	
Halifax West High School	Chemistry Lab A333 tap 4	MUJ338	June 2, 2020	-	Passed	0.9900	Passed	
Halifax West High School	Chemistry Lab A333 tap 5	MUJ339	June 2, 2020	-	Passed	0.6300	Passed	
Halifax West High School	Chemistry Lab A333 tap 6	MUJ340	June 2, 2020	0.001	Passed	0.3800	Passed	
Halifax West High School	Chemistry Lab A333 tap 7	MUJ341	June 2, 2020	0.001	Passed	0.3900	Passed	
Halifax West High School	Chemistry Lab A333 tap 8	MUJ342	June 2, 2020	0.001	Passed	0.4300	Passed	
Halifax West High School	Chemistry Lab A333 tap 10	MUJ343	June 2, 2020	0.001	Passed	0.3800	Passed	
Halifax West High School	Chemistry Lab A329 tap 1	MUJ344	June 2, 2020	0.001	Passed	0.3400	Passed	
Halifax West High School	Chemistry Lab A329 tap 2	MUJ345	June 2, 2020	0.001	Passed	0.1700	Passed	
Halifax West High School	Chemistry Lab A329 tap 3	MUJ346	June 2, 2020	-	Passed	0.4300	Passed	
Halifax West High School	Chemistry Lab A329 tap 4	MUJ347	June 2, 2020	0.001	Passed	0.3400	Passed	
Halifax West High School	Chemistry Lab A329 tap 5	MUJ348	June 2, 2020	0.002	Passed	0.3200	Passed	
Halifax West High School	Chemistry Lab A329 tap 6	MUJ349	June 2, 2020	-	Passed	0.5600	Passed	
Halifax West High School	Chemistry Lab A329 tap 7	MUJ350	June 2, 2020	-	Passed	0.4900	Passed	
Halifax West High School	Chemistry Lab A329 tap 8	MUJ351	June 2, 2020	0.001	Passed	0.3900	Passed	
Halifax West High School	Chemistry Lab A329 tap 9	MUJ352	June 2, 2020	-	Passed	0.3000	Passed	
Halifax West High School	Boys Wash Room A326 tap 1	MUJ353	June 2, 2020	0.004	Passed	0.1400	Passed	
Halifax West High School	Boys Wash Room A326 tap 2	MUJ354	June 2, 2020	-	Passed	0.3100	Passed	
Halifax West High School	Boys Wash Room A326 tap 3	MUJ355	June 2, 2020	-	Passed	0.2000	Passed	
Halifax West High School	Janitors Closet A234 tap	MUJ356	June 2, 2020	0.001	Passed	0.0370	Passed	
Halifax West High School	Girls Wash Room A325 tap 1	MUJ357	June 2, 2020	-	Passed	0.1700	Passed	
Halifax West High School	Girls Wash Room A325 tap 2	MUJ358	June 2, 2020	-	Passed	0.1100	Passed	
Halifax West High School	Girls Wash Room A325 tap 3	MUJ363	June 2, 2020	0.003	Passed	0.1100	Passed	
Halifax West High School	Staff Wash Room A321 tap	MUJ365	June 2, 2020	-	Passed	0.0830	Passed	
Halifax West High School	Biology Lab A319 tap 1	MUJ366	June 2, 2020	0.001	Passed	0.4500	Passed	
Halifax West High School	Biology Lab A319 tap 2	MUJ367	June 2, 2020	-	Passed	0.9300	Passed	
Halifax West High School	Biology Lab A319 tap 3	MUJ368	June 2, 2020	0.002	Passed	0.3300	Passed	
Halifax West High School	Biology Lab A319 tap 4	MUJ369	June 2, 2020	0.001	Passed	0.1000	Passed	
Halifax West High School	Biology Lab A319 tap 5	MUJ370	June 2, 2020	-	Passed	0.8500	Passed	
Halifax West High School	Biology Lab A319 tap 6	MUJ371	June 2, 2020	-	Passed	0.6000	Passed	
Halifax West High School	Biology Lab A319 tap 7	MUJ372	June 2, 2020	-	Passed	0.2000	Passed	
Halifax West High School	Biology Lab A318 tap 1	MUJ388	June 2, 2020	0.003	Passed	0.4300	Passed	
Halifax West High School	Biology Lab A318 tap 2	MUJ389	June 2, 2020	0.001	Passed	0.5300	Passed	
Halifax West High School	Biology Lab A318 tap 3	MUJ390	June 2, 2020	0.001	Passed	0.4300	Passed	
Halifax West High School	Biology Lab A318 tap 4	MUJ391	June 2, 2020	-	Passed	0.8500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Halifax West High School	Biology Lab A318 tap 5	MUJ392	June 2, 2020	0.001	Passed	0.4100	Passed	
Halifax West High School	Class Room tap Room A317	MUJ393	June 2, 2020	-	Passed	0.1000	Passed	
Halifax West High School	Gender Neutral Wash Room A315 tap	MUJ394	June 2, 2020	-	Passed	0.0660	Passed	
Halifax West High School	Janitors Closet A311 tap	MUJ396	June 2, 2020	0.002	Passed	0.0800	Passed	
Halifax West High School	Chemistry Lab A333 tap 9	NAO728	July 3, 2020	-	Passed	0.5300	Passed	
Halifax West High School	Room A340 tap 5	VYN822	May 30, 2023	0.001	Passed	0.1900	Passed	Tap remediated
Halifax West High School	Fountain by Room C346	VYN823	May 30, 2023	0.003	Passed	0.1800	Passed	
Halifax West High School	Fountain by Room A311	VYN824	May 30, 2023	-	Passed	0.0450	Passed	
Halifax West High School	Class Room B329 tap 1	VYN825	May 30, 2023	-	Passed	0.0550	Passed	Tap remediated
Halifax West High School	Room C352 tap	VYN826	May 30, 2023	0.002	Passed	0.2600	Passed	Tap remediated
Halifax West High School	Fountain by Room A224	VYN827	May 30, 2023	-	Passed	0.0220	Passed	
Halifax West High School	Fountain outside Gym	VYN828	May 30, 2023	-	Passed	0.1000	Passed	
Halifax West High School	Fountain in Gym	VYN829	May 30, 2023	-	Passed	0.0930	Passed	
Halifax West High School	Girls Wash Room A234 tap 4	VYN830	May 30, 2023	-	Passed	0.0300	Passed	Tap remediated
Halifax West High School	Fountain by Room C240	VYN857	May 30, 2023	-	Passed	0.0350	Passed	
Halifax West High School	Fountain by Room C246	VYN858	May 30, 2023	-	Passed	0.1900	Passed	
Halifax West High School	Fountain by Room C226	VYN859	May 30, 2023	-	Passed	0.1100	Passed	
Halifax West High School	Fountain by Room B210	VYN860	May 30, 2023	0.002	Passed	0.0510	Passed	
Halifax West High School	Kitchen/Cafeteria B202 tap 1	VYN861	May 30, 2023	-	Passed	0.0750	Passed	
Halifax West High School	Kitchen/Cafeteria B202 tap 2	VYN862	May 30, 2023	-	Passed	0.2200	Passed	
Halifax West High School	Kitchen/Cafeteria B202 tap 3	VYN863	May 30, 2023	0.002	Passed	0.3100	Passed	
Halifax West High School	Fountain by Room C133	VYN864	May 30, 2023	-	Passed	0.0350	Passed	
Halifax West High School	Fountain by Room C126	VYN865	May 30, 2023	-	Passed	0.0830	Passed	
Halifax West High School	Girls Wash Room C162 tap 1	VYN866	May 30, 2023	-	Passed	0.0390	Passed	Tap remediated
Halifax West High School	Fountain by Room B315	VYN899	June 2, 2020	-	Passed	0.1000	Passed	
Halifax West High School	Fountain by Room B315	VYN899	May 30, 2023	-	Passed	0.1000	Passed	
Halifax West High School	Fountain by Room A325	VYN906	May 30, 2023	-	Passed	0.0280	Passed	
Halifax West High School	Fountain by Room B327	VYN908	May 30, 2023	-	Passed	0.0044	Passed	
Halifax West High School	Fountain by Room C171	VYN914	May 30, 2023	-	Passed	0.0620	Passed	
Halifax West High School	Fountain by Room C147	VYN915	May 30, 2023	-	Passed	0.1700	Passed	
Halifax West High School	Fountain by Student Gov. Room	VYN916	May 30, 2023	-	Passed	0.0300	Passed	
Halifax West High School	Student Services tap	VYN917	May 30, 2023	-	Passed	0.2100	Passed	
Halifax West High School	Mech Room tap by Room C322H	VYN918	May 30, 2023	0.002	Passed	0.2800	Passed	Tap remediated
Halifax West High School	Room A343 tap	VYN919	May 30, 2023	0.004	Passed	0.1700	Passed	Tap remediated
Halifax West High School	Modular Gender Neutral Wash Room tap	XAB525	September 14, 2023	-	Passed	0.2000	Passed	
Halifax West High School	Modular Wash Room tap 1 by Room 410	XAB513	September 14, 2023	-	Passed	0.1300	Passed	
Halifax West High School	Modular Wash Room tap 2 by Room 410	XAB514	September 14, 2023	-	Passed	0.1300	Passed	
Halifax West High School	Modular Wash Room tap 3 by Room 410	XAB515	September 14, 2023	-	Passed	0.1200	Passed	
Halifax West High School	Modular Wash Room tap 4 by Room 410	XAB524	September 14, 2023	-	Passed	0.1200	Passed	
Halifax West High School	Modular Wash Room tap 1 by Room 404	XAB510	September 14, 2023	-	Passed	0.1200	Passed	
Halifax West High School	Modular Wash Room tap 2 by Room 404	XAB511	September 14, 2023	-	Passed	0.1300	Passed	
Halifax West High School	Modular Wash Room tap 3 by Room 404	XAB512	September 14, 2023	-	Passed	0.1900	Passed	
Halifax West High School	Modular Staff Room Wash Room tap	XAB509	September 14, 2023	-	Passed	0.7300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Halifax West High School	Modular Fountain by Wash Rooms	XAB508	September 14, 2023	-	Passed	0.0085	Passed	
Halifax West High School	Modular Janitors Closet tap	XAB507	September 14, 2023	-	Passed	0.1400	Passed	
Halifax West High School	Modular Staff Room tap	XAB506	September 14, 2023	-	Passed	0.0790	Passed	
Hammonds Plains Consolidated School	Gender Neutral Wash Room 220 tap	MTV690	June 1, 2020	-	Passed	0.0850	Passed	
Hammonds Plains Consolidated School	Class Room 219 tap	MTV691	June 1, 2020	-	Passed	0.2700	Passed	
Hammonds Plains Consolidated School	Girls Wash Room 225 tap 1	MTV696	June 1, 2020	-	Passed	0.1300	Passed	
Hammonds Plains Consolidated School	Girls Wash Room 225 tap 2	MTV697	June 1, 2020	-	Passed	0.1500	Passed	
Hammonds Plains Consolidated School	Girls Wash Room 225 tap 3	MTV698	June 1, 2020	-	Passed	0.1100	Passed	
Hammonds Plains Consolidated School	Girls Wash Room 225 tap 4	MTV699	June 1, 2020	-	Passed	0.1300	Passed	
Hammonds Plains Consolidated School	Girls Wash Room 225 tap 5	MTV700	June 1, 2020	-	Passed	0.0850	Passed	
Hammonds Plains Consolidated School	Janitors Closet tap by Room 225	MTV701	June 1, 2020	-	Passed	0.0440	Passed	
Hammonds Plains Consolidated School	Boys Wash Room 228 tap 1	MTV703	June 1, 2020	0.003	Passed	0.2800	Passed	
Hammonds Plains Consolidated School	Boys Wash Room 228 tap 2	MTV704	June 1, 2020	0.002	Passed	0.2200	Passed	
Hammonds Plains Consolidated School	Boys Wash Room 228 tap 3	MTV705	June 1, 2020	-	Passed	0.2300	Passed	
Hammonds Plains Consolidated School	Staff Gender Neutral Wash Room 203C tap	MTV706	June 1, 2020	-	Passed	0.0210	Passed	
Hammonds Plains Consolidated School	Staff Gender Neutral Wash Room 203B tap	MTV707	June 1, 2020	-	Passed	0.0220	Passed	
Hammonds Plains Consolidated School	Class Room 210 tap	MTV724	June 1, 2020	0.003	Passed	0.1500	Passed	
Hammonds Plains Consolidated School	Staff Gender Neutral Wash Room 238 tap	MTV726	June 1, 2020	-	Passed	0.0110	Passed	
Hammonds Plains Consolidated School	Staff Gender Neutral Wash Room 237 tap	MTV727	June 1, 2020	-	Passed	0.0068	Passed	
Hammonds Plains Consolidated School	Gender Neutral Wash Room 242 tap	MTV728	June 1, 2020	-	Passed	0.2300	Passed	
Hammonds Plains Consolidated School	Gender Neutral Wash Room 245A tap	MTV730	June 1, 2020	-	Passed	0.0980	Passed	
Hammonds Plains Consolidated School	Gender Neutral Wash Room 246A tap	MTV731	June 1, 2020	0.002	Passed	0.2800	Passed	
Hammonds Plains Consolidated School	Class Room 247 tap	MTV733	June 1, 2020	-	Passed	0.3700	Passed	
Hammonds Plains Consolidated School	Class Room 211 tap	NLV788	August 26, 2020	0.000	Passed	0.0040	Passed	
Hammonds Plains Consolidated School	Class Room 245 tap	NLV789	August 26, 2020	0.000	Passed	0.0070	Passed	
Hammonds Plains Consolidated School	Class Room 246 tap	NLV790	August 26, 2020	0.000	Passed	0.0080	Passed	
Hammonds Plains Consolidated School	Staff Room 203 tap	VXD850	May 24, 2023	-	Passed	0.0170	Passed	
Hammonds Plains Consolidated School	Fountain by Room 204	VXD851	May 24, 2023	-	Passed	0.0130	Passed	
Hammonds Plains Consolidated School	Fountain by Room 269	VXD852	May 24, 2023	-	Passed	0.0170	Passed	
Hammonds Plains Consolidated School	Fountain by Room 225	VXD853	May 24, 2023	-	Passed	0.0100	Passed	
Hammonds Plains Consolidated School	Cafeteria/Kitchen single compartment sink tap	VXD854	May 24, 2023	0.001	Passed	0.0600	Passed	
Hammonds Plains Consolidated School	Cafeteria/Kitchen double compartment sink tap	VXD855	May 24, 2023	-	Passed	0.0150	Passed	
Hammonds Plains Consolidated School	Cafeteria/Kitchen hand washing sink tap	VXD856	May 24, 2023	-	Passed	0.0120	Passed	
Hammonds Plains Consolidated School	Class Room 209 tap	VXD857	May 24, 2023	-	Passed	0.0170	Passed	Tap remediated
Harbour View Elementary	Fountain by Room 213	XBV861	September 20, 2023	-	Passed	-	Passed	
Harbour View Elementary	Class Room 214 tap	XBV862	September 20, 2023	0.002	Passed	0.0720	Passed	Tap remediated
Harbour View Elementary	Janitors Closet tap by Room 214	XBV863	September 20, 2023	-	Passed	0.0087	Passed	Tap remediated
Harbour View Elementary	Upstairs Boys Wash Room tap 1	XBV806	September 20, 2023	0.001	Passed	0.0250	Passed	Tap remediated
Harbour View Elementary	Upstairs Boys Wash Room tap 2	XBV807	September 20, 2023	0.001	Passed	0.0490	Passed	Tap remediated
Harbour View Elementary	Upstairs Boys Wash Room tap 3	XBV808	September 20, 2023	0.002	Passed	0.0550	Passed	Tap remediated
Harbour View Elementary	Upstairs Boys Wash Room tap 4	XBV809	September 20, 2023	0.001	Passed	0.0550	Passed	Tap remediated
Harbour View Elementary	Upstairs Girls Wash Room tap 1	XBV865	September 20, 2023	0.001	Passed	0.0330	Passed	Tap remediated
Harbour View Elementary	Upstairs Girls Wash Room tap 2	XBV866	September 20, 2023	0.003	Passed	0.0310	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Harbour View Elementary	Upstairs Girls Wash Room tap 3	XBV867	September 20, 2023	0.001	Passed	0.0270	Passed	Tap remediated
Harbour View Elementary	Upstairs Girls Wash Room tap 4	XBV805	September 20, 2023	0.001	Passed	0.0220	Passed	Tap remediated
Harbour View Elementary	Fountain by Room 215	XBV859	September 20, 2023	0.001	Passed	0.0009	Passed	
Harbour View Elementary	Fountain by Room 204	XBV860	September 20, 2023	-	Passed	0.0009	Passed	
Harbour View Elementary	Janitors Closet tap by Room 204	MYY079	June 25, 2020	-	Passed	0.0190	Passed	
Harbour View Elementary	Fountain by Room 208	XBV864	September 20, 2023	-	Passed	0.0007	Passed	
Harbour View Elementary	Student Services Wash Room tap	XBV810	September 20, 2023	0.001	Passed	0.0150	Passed	Tap remediated
Harbour View Elementary	Wash Room tap in caretaker Room	MYY082	June 25, 2020	0.001	Passed	0.0300	Passed	
Harbour View Elementary	Boys Wash Room tap 1 by Room 115	XBV888	September 20, 2023	0.004	Passed	0.1200	Passed	Tap remediated
Harbour View Elementary	Boys Wash Room tap 2 by Room 115	XBV889	September 20, 2023	0.003	Passed	0.1100	Passed	Tap remediated
Harbour View Elementary	Boys Wash Room tap 3 by Room 115	XBV890	September 20, 2023	0.003	Passed	0.0680	Passed	Tap remediated
Harbour View Elementary	Boys Wash Room tap 4 by Room 115	XBV891	September 20, 2023	0.003	Passed	0.0530	Passed	Tap remediated
Harbour View Elementary	Learning Centre Wash Room tap	MYY104	June 25, 2020	0.009	Exceeded	0.3200	Passed	Hand washing only
Harbour View Elementary	Staff Wash Room by learning Centre	MYY105	June 25, 2020	-	Passed	0.0510	Passed	
Harbour View Elementary	Janitors Closet tap by Room 114	MYY106	June 25, 2020	0.001	Passed	0.0370	Passed	
Harbour View Elementary	Library Wash Room tap	XBV894	September 20, 2023	0.003	Passed	0.0260	Passed	Tap remediated
Harbour View Elementary	Staff Room Female Wash Room tap 1	XBV825	September 20, 2023	0.001	Passed	0.0250	Passed	Tap remediated
Harbour View Elementary	Staff Room Female Wash Room tap 2	MYY109	June 25, 2020	0.005	Passed	0.2700	Passed	
Harbour View Elementary	Staff Room 308 tap 1	XBV823	September 20, 2023	0.001	Passed	0.0270	Passed	Tap remediated
Harbour View Elementary	Staff Room 308 tap 2	XBV812	September 20, 2023	0.027	Exceeded	0.0570	Passed	Hand washing only
Harbour View Elementary	Staff Room Male Wash Room tap 1	XBV826	September 20, 2023	0.006	Exceeded	0.0530	Passed	Hand washing only
Harbour View Elementary	Staff Room Male Wash Room tap 2	XBV827	September 20, 2023	0.014	Exceeded	0.1000	Passed	Hand washing only
Harbour View Elementary	Staff Wash Room tap in Main Office	MYY114	June 25, 2020	0.003	Passed	0.0970	Passed	
Harbour View Elementary	Main Office Kitchen tap	XBV858	September 20, 2023	0.001	Passed	0.0420	Passed	
Harbour View Elementary	Staff Wash Room tap in Main Office	XBV824	September 20, 2023	0.004	Passed	0.0290	Passed	Tap remediated
Harbour View Elementary	Gym Office tap	XBV822	September 20, 2023	0.001	Passed	0.0230	Passed	Tap remediated
Harbour View Elementary	Fountain by Gym doors	XBV892	September 20, 2023	0.001	Passed	0.1200	Passed	
Harbour View Elementary	Boys Wash Room tap 1 by Gym doors	XBV893	September 20, 2023	0.005	Passed	0.0220	Passed	Tap remediated
Harbour View Elementary	Boys Wash Room tap 2 by Gym doors	XBV820	September 20, 2023	-	Passed	0.0210	Passed	Tap remediated
Harbour View Elementary	Boys Wash Room tap 3 by Gym doors	XBV821	September 20, 2023	-	Passed	0.0220	Passed	Tap remediated
Harbour View Elementary	Girls Wash Room tap 1 by Gym doors	XBV828	September 20, 2023	0.004	Passed	0.1100	Passed	Tap remediated
Harbour View Elementary	Girls Wash Room tap 2 by Gym doors	MYY123	June 25, 2020	0.003	Passed	0.1600	Passed	
Harbour View Elementary	Girls Wash Room tap 3 by Gym doors	XBV829	September 20, 2023	0.004	Passed	0.1000	Passed	Tap remediated
Harbour View Elementary	Janitors Closet in Supplies Room	MYY125	June 25, 2020	0.004	Passed	0.4000	Passed	
Harbour View Elementary	Fountain by Room 111	XBV886	September 20, 2023	-	Passed	-	Passed	
Harbour View Elementary	Janitors Closet tap in Boiler Room	XBV811	September 20, 2023	-	Passed	0.0240	Passed	Tap remediated
Harbour View Elementary	Fountain by Room 115	XBV887	September 20, 2023	-	Passed	0.0006	Passed	
Harbour View Elementary	Breakfast Room tap 1	XBV884	September 20, 2023	-	Passed	0.0300	Passed	
Harbour View Elementary	Breakfast Room tap 2	XBV885	September 20, 2023	-	Passed	0.0290	Passed	
Harold T. Barrett Junior High School	Staff Room Wash Room 1 tap	MTA011	May 28, 2020	0.001	Passed	0.0800	Passed	
Harold T. Barrett Junior High School	Staff Room Wash Room 2 tap	MTA012	May 28, 2020	0.001	Passed	0.0750	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 1 by Staff Room	MTA014	May 28, 2020	0.002	Passed	0.4100	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 2 by Staff Room	MTA015	May 28, 2020	0.001	Passed	0.1100	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Harold T. Barrett Junior High School	Girls Wash Room tap 1 by Gym	MTA017	May 28, 2020	0.002	Passed	1.4000	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 2 by Gym	MTA018	May 28, 2020	0.001	Passed	0.3300	Passed	
Harold T. Barrett Junior High School	Industrial arts Room tap by Elec. Room	MTA022	May 28, 2020	0.002	Passed	0.1500	Passed	
Harold T. Barrett Junior High School	Janitors Closet tap by Mech. Room	MTA025	May 28, 2020	-	Passed	0.0210	Passed	
Harold T. Barrett Junior High School	Class Room tap 2 Room 203	MTA028	May 28, 2020	0.001	Passed	0.4600	Passed	
Harold T. Barrett Junior High School	Class Room tap 3 Room 203	MTA029	May 28, 2020	0.003	Passed	0.7200	Passed	
Harold T. Barrett Junior High School	Janitors Closet tap by Room 205	MTA033	May 28, 2020	0.001	Passed	0.2700	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 1 by Room 205	MTA035	May 28, 2020	0.005	Passed	0.2400	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 2 by Room 205	MTA036	May 28, 2020	0.002	Passed	0.1900	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 1 by Office	MTA037	May 28, 2020	0.001	Passed	0.2800	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 2 by Office	MTA038	May 28, 2020	0.001	Passed	0.2300	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 3 by Office	MTA039	May 28, 2020	0.001	Passed	0.2000	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 2 by Office	MTA042	May 28, 2020	0.001	Passed	0.1900	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 3 by Office	MTA043	May 28, 2020	0.001	Passed	0.2000	Passed	
Harold T. Barrett Junior High School	Guidance Room Gender Neutral Wash Room tap	RSX384	January 28, 2022	-	Passed	0.0360	Passed	
Harold T. Barrett Junior High School	Gender Neutral Wash Room 104 tap	RSX385	January 28, 2022	-	Passed	0.1300	Passed	
Harold T. Barrett Junior High School	Class Room 203 tap 1	RSX386	January 28, 2022	-	Passed	0.4900	Passed	
Harold T. Barrett Junior High School	Class Room 203 tap 4	RSX387	January 28, 2022	0.001	Passed	0.1400	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 1 by Room 205	RSX388	January 28, 2022	-	Passed	0.0530	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 2 by Room 205	RSX389	January 28, 2022	-	Passed	0.0270	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 1 by Office	RSX391	January 28, 2022	-	Passed	0.0260	Passed	
Harold T. Barrett Junior High School	Staff Room tap	WDJ047	June 15, 2023	-	Passed	0.0180	Passed	
Harold T. Barrett Junior High School	Fountain by Staff Room	WDJ048	June 15, 2023	-	Passed	0.2000	Passed	
Harold T. Barrett Junior High School	Family Studies tap 1	WDJ049	June 15, 2023	-	Passed	0.0490	Passed	
Harold T. Barrett Junior High School	Family Studies tap 2	WDJ050	June 15, 2023	0.001	Passed	0.1400	Passed	
Harold T. Barrett Junior High School	Fountain by Office	WDJ051	June 15, 2023	-	Passed	0.0220	Passed	
Harold T. Barrett Junior High School	Fountain by Room 205	WDJ052	June 15, 2023	0.001	Passed	0.0812	Passed	
Harold T. Barrett Junior High School	Cafeteria Kitchen tap 1	WDJ053	June 15, 2023	-	Passed	0.0170	Passed	
Harold T. Barrett Junior High School	Cafeteria Kitchen tap 2	WDJ054	June 15, 2023	-	Passed	0.0150	Passed	
Harold T. Barrett Junior High School	Cafeteria Kitchen tap 3	WDJ055	June 15, 2023	-	Passed	0.0160	Passed	
Harrietsfield Elementary	Staff Wash Room tap	MOV557	May 6, 2020	0.004	Passed	0.1900	Passed	
Harrietsfield Elementary	Girls Wash Room tap 1	MOV559	May 6, 2020	0.005	Passed	0.0600	Passed	
Harrietsfield Elementary	Girls Wash Room tap 2	MOV560	May 6, 2020	0.004	Passed	0.1100	Passed	
Harrietsfield Elementary	Boys Wash Room tap 1	MOV563	May 6, 2020	0.002	Passed	0.4200	Passed	
Harrietsfield Elementary	Boys Wash Room tap 3	MOV564	May 6, 2020	0.002	Passed	0.3100	Passed	
Harrietsfield Elementary	Staff Wash Room tap	MOV649	May 6, 2020	0.003	Passed	0.1800	Passed	
Harrietsfield Elementary	Boys Wash Room tap 1	MOV653	May 6, 2020	0.003	Passed	0.3500	Passed	
Harrietsfield Elementary	Janitors Closet tap	MOV656	May 6, 2020	0.004	Passed	0.1800	Passed	
Harrietsfield Elementary	Boys Wash Room tap 2	MRV010	May 22, 2020	0.004	Passed	0.2600	Passed	
Harrietsfield Elementary	Girls Wash Room tap 3	RWE955	February 15, 2022	-	Passed	0.0570	Passed	
Harrietsfield Elementary	Girls Wash Room tap 4	RWE956	February 15, 2022	-	Passed	0.0430	Passed	
Harrietsfield Elementary	Storage Room 4	RWE957	February 15, 2022	-	Passed	0.0470	Passed	
Harrietsfield Elementary	Girls Wash Room tap 1	RWE958	February 15, 2022	-	Passed	0.0530	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Harrietsfield Elementary	Girls Wash Room tap 2	RWE959	February 15, 2022	-	Passed	0.0460	Passed	
Harrietsfield Elementary	Girls Wash Room tap 3	RWE960	February 15, 2022	-	Passed	0.0460	Passed	
Harrietsfield Elementary	Boys Wash Room tap 2	RWE961	February 15, 2022	0.001	Passed	0.1800	Passed	
Harrietsfield Elementary	Boys Wash Room tap 3	RWE962	February 15, 2022	0.002	Passed	0.2600	Passed	
Harrietsfield Elementary	1st Floor Fountain	VQL588	April 25, 2023	-	Passed	-	Passed	
Harrietsfield Elementary	2nd Floor Fountain	VQL591	April 25, 2023	-	Passed	-	Passed	
Harrietsfield Elementary	Staff Room tap	VQL593	April 25, 2023	-	Passed	0.1700	Passed	
Harry R. Hamilton Elementary	2nd Floor Girls Wash Room tap 1	SVW030	June 8, 2022	0.001	Passed	0.0500	Passed	
Harry R. Hamilton Elementary	2nd Floor Girls Wash Room tap 2	SVW031	June 8, 2022	-	Passed	0.1200	Passed	
Harry R. Hamilton Elementary	2nd Floor Girls Wash Room tap 3	SVW032	June 8, 2022	0.002	Passed	0.1600	Passed	
Harry R. Hamilton Elementary	2nd Floor Boys Wash Room tap 1	SVW033	June 8, 2022	0.002	Passed	0.0570	Passed	
Harry R. Hamilton Elementary	2nd Floor Boys Wash Room tap 2	SVW034	June 8, 2022	-	Passed	0.0550	Passed	
Harry R. Hamilton Elementary	2nd Floor Boys Wash Room tap 3	SVW035	June 8, 2022	-	Passed	0.0330	Passed	
Harry R. Hamilton Elementary	Fountain by 2nd Floor Wash Rooms	XJS462	October 24, 2023	-	Passed	0.0010	Passed	
Harry R. Hamilton Elementary	Class Room 212 tap	WCN518	June 13, 2023	-	Passed	0.0014	Passed	
Harry R. Hamilton Elementary	Janitors Closet tap by Room 212	MUU017	June 5, 2020	-	Passed	0.0210	Passed	
Harry R. Hamilton Elementary	Fountain by Room 207	WCN517	June 13, 2023	-	Passed	0.0012	Passed	
Harry R. Hamilton Elementary	Gym Office tap	SVW038	June 8, 2022	-	Passed	0.8900	Passed	
Harry R. Hamilton Elementary	1st Floor Girls Wash Room tap 1	SVW040	June 5, 2020	-	Passed	0.7000	Passed	
Harry R. Hamilton Elementary	1st Floor Girls Wash Room tap 2	SVW041	June 5, 2020	-	Passed	0.2000	Passed	Hand washing only
Harry R. Hamilton Elementary	1st Floor Girls Wash Room tap 3	SVW042	June 5, 2020	-	Passed	0.4600	Passed	
Harry R. Hamilton Elementary	1st Floor Boys Wash Room tap 1	SVW043	June 5, 2020	-	Passed	0.0680	Passed	
Harry R. Hamilton Elementary	1st Floor Boys Wash Room tap 2	SVW044	June 5, 2020	-	Passed	0.0950	Passed	
Harry R. Hamilton Elementary	1st Floor Boys Wash Room tap 3	SVW045	June 5, 2020	-	Passed	0.2100	Passed	
Harry R. Hamilton Elementary	Staff Room tap	WCN514	June 13, 2023	-	Passed	0.0150	Passed	
Harry R. Hamilton Elementary	Staff Room Wash Room tap	MUU025	June 5, 2020	-	Passed	0.0200	Passed	
Harry R. Hamilton Elementary	Staff Room Wash Room tap	MUU027	June 5, 2020	0.001	Passed	0.0330	Passed	
Harry R. Hamilton Elementary	Gender Neutral Wash Room tap inside Room 103	MUU028	June 5, 2020	0.001	Passed	0.0940	Passed	
Harry R. Hamilton Elementary	Gender Neutral Wash Room tap inside Room 104	MUU029	June 5, 2020	0.002	Passed	0.0730	Passed	
Harry R. Hamilton Elementary	Class Room 104 tap	MUU030	June 5, 2020	0.002	Passed	0.0970	Passed	
Harry R. Hamilton Elementary	Janitors Closet tap by Room 110	MUU031	June 5, 2020	0.004	Passed	0.1500	Passed	
Harry R. Hamilton Elementary	Fountain by Gym	WCN515	June 13, 2023	-	Passed	0.0014	Passed	
Harry R. Hamilton Elementary	Fountain by Boys Wash Room	WCN516	June 13, 2023	-	Passed	0.0010	Passed	
Harry R. Hamilton Elementary	Modular Staff Room tap	XDW956	September 29, 2023	-	Passed	0.0700	Passed	
Harry R. Hamilton Elementary	Modular Janitors Closet tap	XDW957	September 29, 2023	-	Passed	0.0540	Passed	
Harry R. Hamilton Elementary	Modular Change Room tap	XDW958	September 29, 2023	-	Passed	0.0750	Passed	
Harry R. Hamilton Elementary	Modular Classroom 306 tap	XDW959	September 29, 2023	-	Passed	0.0780	Passed	
Harry R. Hamilton Elementary	Modular Classroom 305 tap	XDW960	September 29, 2023	-	Passed	0.0810	Passed	
Harry R. Hamilton Elementary	Modular Classroom 304 tap	XDW961	September 29, 2023	-	Passed	0.0700	Passed	
Harry R. Hamilton Elementary	Fountain in Modular	XDW962	September 29, 2023	-	Passed	0.0110	Passed	
Harry R. Hamilton Elementary	Modular Boys Wash Room tap 1	XDW966	September 29, 2023	-	Passed	0.0790	Passed	
Harry R. Hamilton Elementary	Modular Boys Wash Room tap 2	XDW967	September 29, 2023	-	Passed	0.0800	Passed	
Harry R. Hamilton Elementary	Modular Boys Wash Room tap 3	XDW968	September 29, 2023	-	Passed	0.0800	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Harry R. Hamilton Elementary	Modular Classroom 303 tap	XDW969	September 29, 2023	-	Passed	0.0640	Passed	
Harry R. Hamilton Elementary	Modular Classroom 302 tap	XDW970	September 29, 2023	-	Passed	0.0670	Passed	
Harry R. Hamilton Elementary	Modular Classroom 301 tap	XDW971	September 29, 2023	-	Passed	0.0680	Passed	
Hawthorn Elementary	Class Room 26 tap	MYY206	June 25, 2020	0.002	Passed	0.7700	Passed	
Hawthorn Elementary	Class Room 21 tap	MYY207	June 25, 2020	0.003	Passed	0.2400	Passed	
Hawthorn Elementary	Fountain by Room 19	WIH401	July 7, 2023	-	Passed	0.1100	Passed	
Hawthorn Elementary	Boys Wash Room tap 1 by Room 20	MYY209	June 25, 2020	0.002	Passed	0.1000	Passed	
Hawthorn Elementary	Boys Wash Room tap 2 by Room 20	MYY210	June 25, 2020	0.004	Passed	0.2700	Passed	
Hawthorn Elementary	Boys Wash Room tap 3 by Room 20	WIH399	July 7, 2023	-	Passed	0.0250	Passed	Tap remediated
Hawthorn Elementary	Boys Wash Room tap 4 by Room 20	WIH400	July 7, 2023	-	Passed	0.0260	Passed	Tap remediated
Hawthorn Elementary	Janitors Closet tap by Gender Neutral Wash Room	MYY213	June 25, 2020	0.001	Passed	0.0950	Passed	
Hawthorn Elementary	Gender Neutral Wash Room tap	MYY214	June 25, 2020	0.001	Passed	0.0720	Passed	
Hawthorn Elementary	Girls Wash Room tap 1 by Room 28	WIH402	July 7, 2023	0.001	Passed	0.0430	Passed	Tap remediated
Hawthorn Elementary	Girls Wash Room tap 2 by Room 28	MYY216	June 25, 2020	0.005	Passed	0.2000	Passed	
Hawthorn Elementary	Girls Wash Room tap 3 by Room 28	WIH403	July 7, 2023	-	Passed	0.0280	Passed	Tap remediated
Hawthorn Elementary	Girls Wash Room tap 4 by Room 28	WIH404	July 7, 2023	0.001	Passed	0.0390	Passed	Tap remediated
Hawthorn Elementary	Class Room 15 tap	MYY219	June 25, 2020	0.002	Passed	0.1700	Passed	
Hawthorn Elementary	Staff Room Female Wash Room tap 1	MYY220	June 25, 2020	0.004	Passed	0.2600	Passed	
Hawthorn Elementary	Staff Room Female Wash Room tap 2	MYY221	June 25, 2020	0.001	Passed	0.0750	Passed	
Hawthorn Elementary	Staff Room Male Wash Room tap	WIH422	July 7, 2023	0.001	Passed	0.0590	Passed	Tap remediated
Hawthorn Elementary	Staff Room tap	WIH414	July 7, 2023	-	Passed	0.0078	Passed	
Hawthorn Elementary	Class Room 11 tap	MYY225	June 25, 2020	0.004	Passed	0.5100	Passed	
Hawthorn Elementary	Class Room 12 tap	WIH417	July 7, 2023	-	Passed	0.0110	Passed	Tap remediated
Hawthorn Elementary	Boys Wash Room tap 1 by Room 12	WIH418	July 7, 2023	-	Passed	0.0150	Passed	Tap remediated
Hawthorn Elementary	Boys Wash Room tap 2 by Room 12	WIH419	July 7, 2023	0.001	Passed	0.0250	Passed	Tap remediated
Hawthorn Elementary	Boys Wash Room tap 3 by Room 12	XDW460	September 28, 2023	0.005	Passed	0.1600	Passed	Tap remediated
Hawthorn Elementary	Janitors Closet tap by Room 12	MYY234	June 25, 2020	0.004	Passed	0.1200	Passed	
Hawthorn Elementary	Girls Wash Room tap 1 by Room 17	WIH410	July 7, 2023	0.004	Passed	0.0750	Passed	Tap remediated
Hawthorn Elementary	Girls Wash Room tap 2 by Room 17	WIH411	July 7, 2023	0.004	Passed	0.0950	Passed	Tap remediated
Hawthorn Elementary	Girls Wash Room tap 3 by Room 17	WIH412	July 7, 2023	0.001	Passed	0.0300	Passed	Tap remediated
Hawthorn Elementary	Girls Wash Room tap 4 by Room 17	WIH413	July 7, 2023	0.002	Passed	0.0350	Passed	Tap remediated
Hawthorn Elementary	Pre-Primary Room 7 tap	MYY239	June 25, 2020	0.004	Passed	0.4100	Passed	
Hawthorn Elementary	Staff Wash Room tap by Room 7	MYY240	June 25, 2020	0.003	Passed	0.3500	Passed	
Hawthorn Elementary	Girls Wash Room tap 1 by Staff Wash Room	WIH415	July 7, 2023	-	Passed	0.0110	Passed	Tap remediated
Hawthorn Elementary	Girls Wash Room tap 2 by Staff Wash Room	WIH416	July 7, 2023	-	Passed	0.0170	Passed	Tap remediated
Hawthorn Elementary	Girls Wash Room tap 3 by Staff Wash Room	MYY243	June 25, 2020	0.004	Passed	0.2400	Passed	
Hawthorn Elementary	Lab sink tap by Room 6	WIH408	July 7, 2023	-	Passed	0.0180	Passed	Tap remediated
Hawthorn Elementary	Boys Wash Room tap 1 near Room 2	WIH406	July 7, 2023	0.001	Passed	0.1000	Passed	Tap remediated
Hawthorn Elementary	Boys Wash Room tap 2 near Room 2	MYY247	June 25, 2020	0.004	Passed	0.1800	Passed	
Hawthorn Elementary	Boys Wash Room tap 3 near Room 6	MYY248	June 25, 2020	0.002	Passed	0.0560	Passed	
Hawthorn Elementary	Janitors Closet tap in Sink Room	MYY249	June 25, 2020	0.001	Passed	0.0550	Passed	
Hawthorn Elementary	Caretaker Room tap	WIH405	July 7, 2023	0.001	Passed	0.0970	Passed	
Hawthorn Elementary	Fountain by Boys Wash Room	WIH421	July 7, 2023	-	Passed	0.0018	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Hawthorn Elementary	Pre-Primary Room 3 tap	WIH409	July 7, 2023	-	Passed	0.0260	Passed	
Hawthorn Elementary	Fountain by Music Room	WIH407	July 7, 2023	-	Passed	0.0017	Passed	
Herring Cove Junior High School	Boys Wash Room tap 1 by Room 321	MQS625	May 19, 2020	0.003	Passed	0.2900	Passed	
Herring Cove Junior High School	Boys Wash Room tap 2 by Room 321	MQS626	May 19, 2020	0.001	Passed	0.2200	Passed	
Herring Cove Junior High School	Girls Wash Room tap 1 by Room 326	MQS628	May 19, 2020	0.003	Passed	0.0430	Passed	
Herring Cove Junior High School	Girls Wash Room tap 2 by Room 326	MQS629	May 19, 2020	0.001	Passed	0.0140	Passed	
Herring Cove Junior High School	Girls Wash Room tap 3 by Room 326	MQS630	May 19, 2020	0.001	Passed	0.0120	Passed	
Herring Cove Junior High School	Class Room 327 tap	MQS631	May 19, 2020	0.003	Passed	0.0500	Passed	
Herring Cove Junior High School	Class Room 328 tap	MQS632	May 19, 2020	-	Passed	0.0110	Passed	
Herring Cove Junior High School	Janitors Closet 224 tap	MQS640	May 19, 2020	0.021	Exceeded	0.1400	Passed	Hand washing only
Herring Cove Junior High School	Boys Wash Room tap 2 by Room 228	MQS642	May 19, 2020	0.001	Passed	0.0810	Passed	
Herring Cove Junior High School	Gender Neutral Wash Room 229 tap	MQS643	May 19, 2020	0.003	Passed	0.2200	Passed	
Herring Cove Junior High School	Girls Wash Room tap 1 by Room 232	MQS644	May 19, 2020	0.002	Passed	0.3200	Passed	
Herring Cove Junior High School	Girls Wash Room tap 2 by Room 232	MQS645	May 19, 2020	0.002	Passed	0.2300	Passed	
Herring Cove Junior High School	Class Room 214 tap	MQS647	May 19, 2020	0.001	Passed	0.1000	Passed	
Herring Cove Junior High School	Basement Boys Wash Room tap 2	MQS655	May 19, 2020	0.005	Passed	0.2700	Passed	
Herring Cove Junior High School	Janitors Closet 131 tap	MQS656	May 19, 2020	0.010	Exceeded	0.2200	Passed	Hand washing only
Herring Cove Junior High School	Basement Girls Wash Room tap 2	MQS710	May 19, 2020	0.001	Passed	0.2400	Passed	
Herring Cove Junior High School	Basement Girls Wash Room tap 3	MQS711	May 19, 2020	0.003	Passed	0.2000	Passed	
Herring Cove Junior High School	Class Room 115 tap	NNS692	September 3, 2020	0.001	Passed	0.0270	Passed	
Herring Cove Junior High School	Fountain by Room 224	VPX451	April 21, 2023	-	Passed	0.0120	Passed	
Herring Cove Junior High School	Boys Wash Room tap 1 by Room 228	VPX452	April 21, 2023	-	Passed	0.0110	Passed	Tap remediated
Herring Cove Junior High School	Staff Room 210 tap	VPX454	April 21, 2023	0.004	Passed	0.0660	Passed	
Herring Cove Junior High School	Photocopy Room tap	VPX455	April 21, 2023	0.007	Exceeded	0.0300	Passed	Hand washing only
Herring Cove Junior High School	Family Studies 114 tap 1	VPX456	April 21, 2023	0.001	Passed	0.4300	Passed	
Herring Cove Junior High School	Family Studies 114 tap 2	VPX457	April 21, 2023	0.001	Passed	0.3200	Passed	
Herring Cove Junior High School	Family Studies 114 tap 3	VPX458	April 21, 2023	0.001	Passed	0.2800	Passed	
Herring Cove Junior High School	Family Studies 114 tap 4	VPX459	April 21, 2023	0.001	Passed	0.1100	Passed	
Herring Cove Junior High School	Basement Boys Wash Room tap 1	VPX460	April 21, 2023	-	Passed	0.0290	Passed	Tap remediated
Herring Cove Junior High School	Basement Girls Wash Room tap 1	VPX461	April 21, 2023	-	Passed	0.1200	Passed	Tap remediated
Herring Cove Junior High School	Fountain by Room 131	VPX462	April 21, 2023	-	Passed	0.0008	Passed	
Herring Cove Junior High School	Class Room 117 tap	VPX463	April 21, 2023	0.002	Passed	0.0640	Passed	Tap remediated
Herring Cove Junior High School	Gym Kitchen 1 tap	VPX464	April 21, 2023	-	Passed	0.0450	Passed	
Herring Cove Junior High School	Gym Kitchen 2 tap	VPX465	April 21, 2023	-	Passed	0.0420	Passed	
Herring Cove Junior High School	Gym Kitchen Wash Sink tap	VPX466	April 21, 2023	-	Passed	0.0320	Passed	
Herring Cove Junior High School	Janitors Closet 324 tap	VPX467	April 21, 2023	-	Passed	0.0120	Passed	Tap remediated
Herring Cove Junior High School	Fountain by Room 324	VPX468	April 21, 2023	-	Passed	0.0008	Passed	
Herring Cove Junior High School	Class Room 326 tap	VPX469	April 21, 2023	-	Passed	0.0230	Passed	Tap remediated
Highland Park Junior High School	4th Floor Boys Wash Room tap 1	MSH477	May 26, 2020	0.002	Passed	0.0140	Passed	
Highland Park Junior High School	4th Floor Boys Wash Room tap 2	MSH478	May 26, 2020	0.001	Passed	0.0140	Passed	
Highland Park Junior High School	4th Floor Boys Wash Room tap 3	MSH479	May 26, 2020	0.001	Passed	0.0150	Passed	
Highland Park Junior High School	4th Floor Boys Wash Room tap 4	MSH480	May 26, 2020	0.002	Passed	0.0210	Passed	
Highland Park Junior High School	4th Floor Janitors Closet tap	MSH481	May 26, 2020	0.001	Passed	0.0120	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Highland Park Junior High School	4th Floor Girls Wash Room tap 2	MSH483	May 26, 2020	0.001	Passed	0.0410	Passed	
Highland Park Junior High School	4th Floor Girls Wash Room tap 3	MSH484	May 26, 2020	-	Passed	0.0280	Passed	
Highland Park Junior High School	4th Floor Girls Wash Room tap 4	MSH485	May 26, 2020	-	Passed	0.0270	Passed	
Highland Park Junior High School	Class Room 407 tap	MSH486	May 26, 2020	0.003	Passed	0.4400	Passed	
Highland Park Junior High School	Class Room 409 tap	MSH487	May 26, 2020	0.003	Passed	0.3300	Passed	
Highland Park Junior High School	Class Room 301 tap	MSH488	May 26, 2020	0.001	Passed	0.0910	Passed	
Highland Park Junior High School	Class Room 300 tap	MSH489	May 26, 2020	-	Passed	0.0540	Passed	
Highland Park Junior High School	Staff Room 204 Wash Room 1 tap	MSH491	May 26, 2020	-	Passed	0.0170	Passed	
Highland Park Junior High School	Principals Office 202 Wash Room tap	MSH494	May 26, 2020	-	Passed	0.0130	Passed	
Highland Park Junior High School	Gender Neutral Wash Room 200 tap	MSH495	May 26, 2020	-	Passed	0.0170	Passed	
Highland Park Junior High School	Class Room 203 tap	MSH496	May 26, 2020	0.001	Passed	0.0350	Passed	
Highland Park Junior High School	Caretakers Office 205 tap	MSH497	May 26, 2020	0.002	Passed	0.0089	Passed	
Highland Park Junior High School	Phys Ed Office tap	MSP301	May 27, 2020	0.002	Passed	0.0320	Passed	
Highland Park Junior High School	Boiler Room tap	MSP302	May 27, 2020	-	Passed	0.0190	Passed	
Highland Park Junior High School	4th Floor Girls Wash Room tap 1	NFE702	July 27, 2020	0.001	Passed	0.0390	Passed	
Highland Park Junior High School	Staff Wash 204 Was Room 2 tap	NFE719	July 27, 2020	-	Passed	0.0048	Passed	
Highland Park Junior High School	Fountain by Room 204	VVC451	May 12, 2023	-	Passed	0.0420	Passed	
Highland Park Junior High School	Teachers Room 204 tap	VVC452	May 12, 2023	-	Passed	0.0550	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 1	VVC453	May 12, 2023	-	Passed	0.0430	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 2	VVC454	May 12, 2023	-	Passed	0.1100	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 3	VVC455	May 12, 2023	-	Passed	0.0880	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 4	VVC456	May 12, 2023	-	Passed	0.0470	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 5	VVC457	May 12, 2023	-	Passed	0.0290	Passed	
Highland Park Junior High School	Staff Room 401 tap	VVC458	May 12, 2023	-	Passed	0.0350	Passed	
Highland Park Junior High School	Fountain by Gym	VVC459	May 12, 2023	-	Passed	0.0880	Passed	
Highland Park Junior High School	Fountain by Room 400	VVC460	May 12, 2023	-	Passed	0.0220	Passed	
Hillside Park Elementary	1st Floor Boys Wash Room tap 3	MPX261	May 13, 2020	0.002	Passed	0.0480	Passed	
Hillside Park Elementary	1st Floor Janitors Closet tap	MPX262	May 13, 2020	0.003	Passed	0.1100	Passed	
Hillside Park Elementary	Class Room 207 tap	MPX270	May 13, 2020	0.002	Passed	0.1300	Passed	
Hillside Park Elementary	Staff Room 203 Male Wash Room tap	MPX274	May 13, 2020	0.002	Passed	0.0500	Passed	
Hillside Park Elementary	2nd Floor Boys Wash Room tap	MPX279	May 13, 2020	0.003	Passed	0.2100	Passed	
Hillside Park Elementary	1st Floor Boys Wash Room tap 1	SCA135	March 14, 2022	-	Passed	0.0320	Passed	
Hillside Park Elementary	1st Floor Boys Wash Room tap 2	SCA136	March 14, 2022	0.001	Passed	0.0340	Passed	
Hillside Park Elementary	1st Floor Girls Wash Room tap 1	SCA137	March 14, 2022	0.001	Passed	0.0350	Passed	
Hillside Park Elementary	1st Floor Girls Wash Room tap 2	SCA138	March 14, 2022	0.001	Passed	0.0350	Passed	
Hillside Park Elementary	1st Floor Girls Wash Room tap 3	SCA139	March 14, 2022	0.001	Passed	0.0350	Passed	
Hillside Park Elementary	Class Room 108 tap	SCA140	March 14, 2022	0.001	Passed	0.0380	Passed	
Hillside Park Elementary	Class Room 110 tap	SCA141	March 14, 2022	0.001	Passed	0.0490	Passed	
Hillside Park Elementary	Class Room 206 tap	SCA142	March 14, 2022	0.001	Passed	0.0680	Passed	
Hillside Park Elementary	Staff Room 203 Female Wash Room tap	SCA143	March 14, 2022	-	Passed	0.0500	Passed	
Hillside Park Elementary	2nd Floor Music Room tap	SCA1447	March 14, 2022	0.004	Passed	0.1100	Passed	
Hillside Park Elementary	Gym Office Wash Room tap	SCA145	March 14, 2022	0.003	Passed	0.0830	Passed	
Hillside Park Elementary	2nd Floor Girls Wash Room tap	SCA147	March 14, 2022	0.003	Passed	0.0730	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Hillside Park Elementary	2nd Floor Janitors Closet tap	SCA148	March 14, 2022	0.003	Passed	0.0630	Passed	
Hillside Park Elementary	Fountain by 1st Floor Electrical Room	SCA150	March 14, 2022	0.008	Exceeded	0.0080	Passed	Fountain out of service. Other sources available.
Hillside Park Elementary	3rd Floor Girls Wash Room tap 1	SCH155	March 15, 2022	0.002	Passed	0.0590	Passed	
Hillside Park Elementary	3rd Floor Girls Wash Room tap 2	SCH186	March 15, 2022	0.001	Passed	0.0460	Passed	
Hillside Park Elementary	3rd Floor Girls Wash Room tap 3	SCH187	March 15, 2022	0.002	Passed	0.0390	Passed	
Hillside Park Elementary	3rd Floor Boys Wash Room tap 1	SCH188	March 15, 2022	0.001	Passed	0.0220	Passed	
Hillside Park Elementary	3rd Floor Boys Wash Room tap 2	SCH189	March 15, 2022	-	Passed	0.0220	Passed	
Hillside Park Elementary	3rd Floor Boys Wash Room tap 3	SCH190	March 15, 2022	0.001	Passed	0.0290	Passed	
Hillside Park Elementary	Fountain by Room 204	WCT726	June 14, 2023	-	Passed	0.0010	Passed	
Hillside Park Elementary	Staff Room 203 tap	WCT727	June 14, 2023	-	Passed	0.0230	Passed	
Hillside Park Elementary	Class Room 220 tap	WCT728	June 14, 2023	0.001	Passed	0.0360	Passed	Tap remediated
Hillside Park Elementary	Fountain by Room 220	WCT729	June 14, 2023	0.001	Passed	0.0059	Passed	
Hillside Park Elementary	2nd Floor Kitchen tap	WCT730	June 14, 2023	0.001	Passed	0.0320	Passed	
Hillside Park Elementary	Library Room 218 tap	WCT731	June 14, 2023	0.002	Passed	0.0340	Passed	Tap remediated
Hillside Park Elementary	Fountain by 3rd Floor Girls Wash Room	WCT732	June 14, 2023	0.002	Passed	0.0032	Passed	
Hillside Park Elementary	3rd Floor Janitors Closet tap	WCT733	June 14, 2023	-	Passed	0.0170	Passed	Tap remediated
Hillside Park Elementary	Learning Centre 109 tap	WCT734	June 14, 2023	0.001	Passed	0.0260	Passed	
Holland Road Elementary	Class Room 172 tap	MWI032	June 15, 2020	0.001	Passed	0.2500	Passed	
Holland Road Elementary	Class Room 171 tap	MWI033	June 15, 2020	0.001	Passed	0.0770	Passed	
Holland Road Elementary	Class Room 170 tap	MWI034	June 15, 2020	0.001	Passed	0.0700	Passed	
Holland Road Elementary	Primary Wash Room 169 tap	MWI035	June 15, 2020	-	Passed	0.0680	Passed	
Holland Road Elementary	Boys Wash Room 172 tap	MWI037	June 15, 2020	-	Passed	0.0760	Passed	
Holland Road Elementary	Girls Wash Room 173 tap 1	MWI038	June 15, 2020	0.004	Passed	0.0890	Passed	
Holland Road Elementary	Girls Wash Room 173 tap 2	MWI039	June 15, 2020	-	Passed	0.0660	Passed	
Holland Road Elementary	Class Room 123 tap	MWI040	June 15, 2020	0.001	Passed	0.0950	Passed	
Holland Road Elementary	Class Room 123 Wash Room tap	MWI041	June 15, 2020	0.001	Passed	0.1900	Passed	
Holland Road Elementary	Janitors Closet tap by Room 123	MWI042	June 15, 2020	0.002	Passed	0.1300	Passed	
Holland Road Elementary	Class Room 126 Wash Room tap	MWI043	June 15, 2020	0.001	Passed	0.1700	Passed	
Holland Road Elementary	Class Room 126 tap	MWI044	June 15, 2020	-	Passed	0.0340	Passed	
Holland Road Elementary	Class Room 122 tap	MWI045	June 15, 2020	0.003	Passed	0.2500	Passed	
Holland Road Elementary	Class Room 128 tap	MWI046	June 15, 2020	0.001	Passed	0.1700	Passed	
Holland Road Elementary	Music Room 130 tap	MWI047	June 15, 2020	0.003	Passed	0.0970	Passed	
Holland Road Elementary	Class Room 136 Wash Room tap	MWI048	June 15, 2020	0.001	Passed	0.1600	Passed	
Holland Road Elementary	Boys Wash Room tap 1 by Room 136	MWI049	June 15, 2020	-	Passed	0.0790	Passed	
Holland Road Elementary	Boys Wash Room tap 2 by Room 136	MWI050	June 15, 2020	0.001	Passed	0.0990	Passed	
Holland Road Elementary	Mechanical Room tap by Library	MWI051	June 15, 2020	0.002	Passed	0.1000	Passed	
Holland Road Elementary	Girls Wash Room tap 1 by Main Office	MWI053	June 15, 2020	-	Passed	0.0440	Passed	
Holland Road Elementary	Girls Wash Room tap 2 by Main Office	MWI054	June 15, 2020	0.002	Passed	0.0660	Passed	
Holland Road Elementary	Girls Wash Room tap 3 by Main Office	MWI055	June 15, 2020	0.001	Passed	0.0240	Passed	
Holland Road Elementary	Staff Room Wash Room 1 tap	MWI056	June 15, 2020	0.002	Passed	0.2200	Passed	
Holland Road Elementary	Staff Room Wash Room 2 tap	MWI057	June 15, 2020	-	Passed	0.2400	Passed	
Holland Road Elementary	Kitchen 145 tap	MWI059	June 15, 2020	0.005	Passed	0.1200	Passed	
Holland Road Elementary	Girls Locker Room tap by Room 149	MWI063	June 15, 2020	0.002	Passed	0.0850	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Holland Road Elementary	Fountain by Library	XJR681	October 24, 2023	-	Passed	0.0220	Passed	
Holland Road Elementary	Fountain by Room 170	XJR682	October 24, 2023	-	Passed	-	Passed	
Holland Road Elementary	Gym Office 149 Wash Room tap	SPH549	May 11, 2022	0.004	Passed	0.1300	Passed	
Holland Road Elementary	Staff Room tap	WDJ153	June 15, 2023	0.001	Passed	0.0240	Passed	
Holland Road Elementary	Boys Locker Room 172 tap	WDJ154	June 15, 2023	-	Passed	0.0510	Passed	Tap remediated
Holland Road Elementary	Fountain by Gym	WDJ156	June 15, 2023	-	Passed	0.0180	Passed	
Horizon Elementary	Janitors Closet tap inside Fan Room	MVY786	June 11, 2020	0.002	Passed	0.2100	Passed	
Horizon Elementary	2nd Floor Boys Wash Room tap 1 by Storage Room	WFH434	June 22, 2023	-	Passed	0.0075	Passed	Tap remediated
Horizon Elementary	2nd Floor Boys Wash Room tap 2 by Storage Room	MVY788	June 11, 2020	0.003	Passed	0.1300	Passed	
Horizon Elementary	2nd Floor Boys Wash Room tap 3 by Storage Room	WFH435	June 22, 2023	-	Passed	0.0086	Passed	Tap remediated
Horizon Elementary	2nd Floor Boys Wash Room tap 4 by Storage Room	WFH455	June 22, 2023	-	Passed	0.0087	Passed	Tap remediated
Horizon Elementary	Fountain by Boys Wash Room	WFH433	June 22, 2023	-	Passed	0.0010	Passed	
Horizon Elementary	Class Room 213 tap 1	MVY792	June 11, 2020	0.004	Passed	0.8900	Passed	
Horizon Elementary	Class Room 213 tap 2	WFH457	June 22, 2023	0.001	Passed	0.0094	Passed	Tap remediated
Horizon Elementary	Fountain by Girls Wash Room	WFH432	June 22, 2023	-	Passed	0.0350	Passed	
Horizon Elementary	2nd Floor Girls Wash Room tap 1 by Elevator	MVY795	June 11, 2020	0.004	Passed	0.0580	Passed	
Horizon Elementary	2nd Floor Girls Wash Room tap 2 by Elevator	WFH456	June 22, 2023	-	Passed	0.0120	Passed	Tap remediated
Horizon Elementary	2nd Floor Girls Wash Room tap 3 by Elevator	MVY797	June 11, 2020	0.002	Passed	0.1500	Passed	
Horizon Elementary	2nd Floor Girls Wash Room tap 4 by Elevator	MVY798	June 11, 2020	0.003	Passed	0.1000	Passed	
Horizon Elementary	2nd Floor Girls Wash Room tap 5 by Elevator	MVY799	June 11, 2020	0.000	Passed	0.0390	Passed	
Horizon Elementary	Class Room 1 tap	MVY800	June 11, 2020	0.002	Passed	0.3200	Passed	
Horizon Elementary	Fountain by Service Room	WFH226	June 22, 2023	-	Passed	0.0019	Passed	
Horizon Elementary	Boys Wash Room tap 1 in Rec Centre	WFH227	June 22, 2023	-	Passed	0.0750	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 2 in Rec Centre	MVY803	June 11, 2020	0.002	Passed	0.2200	Passed	
Horizon Elementary	Rec Centre Kitchen tap	WFH230	June 22, 2023	-	Passed	0.0400	Passed	
Horizon Elementary	Girls Wash Room tap 1 in Rec Centre	MVY805	June 11, 2020	-	Passed	0.1200	Passed	
Horizon Elementary	Girls Wash Room tap 2 in Rec Centre	MVY806	June 11, 2020	0.000	Passed	0.0300	Passed	
Horizon Elementary	Fountain in Dance Studio	WFH383	June 22, 2023	0.001	Passed	0.3100	Passed	
Horizon Elementary	Infant Room Bar Sink tap	MVY808	June 11, 2020	0.000	Passed	0.4700	Passed	
Horizon Elementary	Infant Room Kitchen Sink tap	WFH384	June 22, 2023	-	Passed	0.0160	Passed	
Horizon Elementary	Girls Locker Room tap 1 in Rec Centre	MVY810	June 11, 2020	0.001	Passed	0.3800	Passed	
Horizon Elementary	Girls Locker Room tap 2 in Rec Centre	WFH228	June 22, 2023	0.001	Passed	0.0100	Passed	Tap remediated
Horizon Elementary	Girls Locker Room tap 3 in Rec Centre	WFH229	June 22, 2023	-	Passed	0.0100	Passed	Tap remediated
Horizon Elementary	Fountain by Gym South Entrance	WFH388	June 22, 2023	-	Passed	0.0020	Passed	
Horizon Elementary	Gym Office (South) Wash Room tap	MVY814	June 11, 2020	0.005	Passed	0.1900	Passed	
Horizon Elementary	Boys Locker Room tap 1 in Rec Centre	WFH386	June 22, 2023	-	Passed	0.0090	Passed	Tap remediated
Horizon Elementary	Boys Locker Room tap 2 in Rec Centre	WFH387	June 22, 2023	-	Passed	0.0078	Passed	Tap remediated
Horizon Elementary	Boys Locker Room tap 3 in Rec Centre	MVY817	June 11, 2020	0.003	Passed	0.0490	Passed	
Horizon Elementary	Toddler Room tap	WFH224	June 22, 2023	-	Passed	0.0600	Passed	
Horizon Elementary	Toddler Room Gender Neutral Wash Room tap 1	WFH225	June 22, 2023	-	Passed	0.0660	Passed	Tap remediated
Horizon Elementary	Toddler Room Gender Neutral Wash Room tap 2	WFH226	June 22, 2023	0.001	Passed	0.0330	Passed	
Horizon Elementary	Boys Wash Room tap 1 by Girls Wash Room	WFH389	June 22, 2023	0.002	Passed	0.0220	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 2 by Girls Wash Room	WFH390	June 22, 2023	0.001	Passed	0.0150	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Horizon Elementary	Fountain by Gym and Boys Locker Room	WFH385	June 22, 2023	-	Passed	0.0012	Passed	
Horizon Elementary	Music Room 110 tap	WFH391	June 22, 2023	-	Passed	0.0140	Passed	Tap remediated
Horizon Elementary	Janitors Closet tap inside Mech Room	MVY825	June 11, 2020	-	Passed	0.0190	Passed	
Horizon Elementary	Fountain by Guidance Room	WFH252	June 22, 2023	-	Passed	0.0010	Passed	
Horizon Elementary	Class Room 104 tap	WFH426	June 22, 2023	-	Passed	0.0095	Passed	Tap remediated
Horizon Elementary	Class Room 102 tap	WFH258	June 22, 2023	-	Passed	0.0670	Passed	Tap remediated
Horizon Elementary	Room 103 Gender Neutral Wash Room tap	WFH257	June 22, 2023	-	Passed	0.0130	Passed	Tap remediated
Horizon Elementary	Class Room 105 Gender Neutral Wash Room tap	WFH256	June 22, 2023	-	Passed	0.0120	Passed	Tap remediated
Horizon Elementary	Class Room 105 tap	MVY831	June 11, 2020	0.002	Passed	0.4000	Passed	
Horizon Elementary	Girls Wash Room tap 1 by Library	WFH253	June 22, 2023	-	Passed	0.0130	Passed	Tap remediated
Horizon Elementary	Girls Wash Room tap 2 by Library	WFH254	June 22, 2023	-	Passed	0.0300	Passed	Tap remediated
Horizon Elementary	Girls Wash Room tap 3 by Library	WFH255	June 22, 2023	-	Passed	0.0320	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 1 by Mech Room	WFH392	June 22, 2023	-	Passed	0.0080	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 2 by Mech Room	WFH249	June 22, 2023	-	Passed	0.0076	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 3 by Mech Room	WFH250	June 22, 2023	-	Passed	0.0070	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 4 by Mech Room	WFH251	June 22, 2023	-	Passed	0.0059	Passed	Tap remediated
Horizon Elementary	Fountain by Cafeteria	WFH223	June 22, 2023	-	Passed	0.1000	Passed	
Horizon Elementary	Class Room 113 Wash Room tap	WFH429	June 22, 2023	-	Passed	0.0090	Passed	Tap remediated
Horizon Elementary	Class Room 113 tap	WFH428	June 22, 2023	-	Passed	0.0110	Passed	Tap remediated
Horizon Elementary	Class Room 115 Wash Room tap	MVY844	June 11, 2020	0.007	Exceeded	0.1000	Passed	Hand washing only
Horizon Elementary	Class Room 115 tap 1	MVY845	June 11, 2020	-	Passed	0.0670	Passed	
Horizon Elementary	Class Room 115 tap 2	MVY846	June 11, 2020	0.003	Passed	0.3500	Passed	
Horizon Elementary	Class Room 116 tap	WFH431	June 22, 2023	0.001	Passed	0.0300	Passed	Tap remediated
Horizon Elementary	Class Room 114 tap	MVY848	June 11, 2020	0.004	Passed	0.4300	Passed	
Horizon Elementary	Staff Room Kitchen tap	WFH427	June 22, 2023	-	Passed	0.0084	Passed	
Horizon Elementary	Staff Room Wash Room tap 1	MVY850	June 11, 2020	0.003	Passed	0.1300	Passed	
Horizon Elementary	Staff Room Wash Room tap 2	MVY851	June 11, 2020	0.002	Passed	0.0950	Passed	
Horizon Elementary	Cafeteria Double Sink tap	WFH221	June 22, 2023	0.001	Passed	0.0190	Passed	
Horizon Elementary	Cafeteria Hand Washing Sink tap	WFH222	June 22, 2023	0.008	Exceeded	0.0230	Passed	Hand washing only
Humber Park Elementary	Janitors Closet tap Room 33	XGE303	October 11, 2023	0.001	Passed	0.1300	Passed	Tap remediated
Humber Park Elementary	Girls Gym Change Room tap	XGE306	October 11, 2023	0.003	Passed	0.1500	Passed	Tap remediated
Humber Park Elementary	Boys Gym Change Room tap	XGE305	October 11, 2023	0.002	Passed	0.1900	Passed	Tap remediated
Humber Park Elementary	Fountain by Gym	XGE304	October 11, 2023	0.002	Passed	0.1700	Passed	
Humber Park Elementary	Boys Wash Room 8 tap 1	XGE308	October 11, 2023	-	Passed	0.0230	Passed	Tap remediated
Humber Park Elementary	Boys Wash Room 8 tap 2	XGE309	October 11, 2023	0.001	Passed	0.0450	Passed	Tap remediated
Humber Park Elementary	Boys Wash Room 8 tap 3	MXK123	June 18, 2020	0.004	Passed	0.0580	Passed	
Humber Park Elementary	Boys Wash Room 8 tap 4	MXK124	June 18, 2020	-	Passed	0.0260	Passed	
Humber Park Elementary	Janitors Closet 9 tap	MXK125	June 18, 2020	0.001	Passed	0.0100	Passed	
Humber Park Elementary	Fountain by Boys Wash Room / Room 8	XGE302	October 11, 2023	0.001	Passed	0.0340	Passed	
Humber Park Elementary	Fountain by Girls Wash Room / Room 7	MXK129	June 18, 2020	0.002	Passed	0.0360	Passed	
Humber Park Elementary	Girls Wash Room 7 tap 1	MXK130	June 18, 2020	0.003	Passed	0.0580	Passed	
Humber Park Elementary	Girls Wash Room 7 tap 2	MXK131	June 18, 2020	0.002	Passed	0.0350	Passed	
Humber Park Elementary	Girls Wash Room 7 tap 3	MXK132	June 18, 2020	0.001	Passed	0.0140	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Humber Park Elementary	Girls Wash Room 7 tap 4	MXK133	June 18, 2020	-	Passed	0.0110	Passed	
Humber Park Elementary	Staff Room Wash Room 1 tap	MXK134	June 18, 2020	0.001	Passed	0.0140	Passed	
Humber Park Elementary	Staff Room tap	XGE307	October 11, 2023	-	Passed	0.0089	Passed	
Humber Park Elementary	Staff Room Wash Room 2 tap	MXK136	June 18, 2020	0.002	Passed	0.2100	Passed	
Ian Forsyth Elementary	Janitors Closet 206 tap	MWI424	June 15, 2020	0.037	Exceeded	0.2200	Passed	Hand washing only
Ian Forsyth Elementary	Staff Room 204 Wash Room tap	XDW622	September 29, 2023	-	Passed	0.0014	Passed	Tap remediated
Ian Forsyth Elementary	VP Office 202 tap 1	XDW623	September 29, 2023	0.001	Passed	0.0340	Passed	Tap remediated
Ian Forsyth Elementary	VP Office 202 tap 2	XDW624	September 29, 2023	0.001	Passed	0.0310	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room 142 tap 1	XDW617	September 29, 2023	0.078	Exceeded	0.3700	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room 142 tap 2	XDW618	September 29, 2023	0.047	Exceeded	0.2200	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room 142 tap 3	XDW619	September 29, 2023	0.034	Exceeded	0.1500	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room 142 tap 4	XDW620	September 29, 2023	0.031	Exceeded	0.1300	Passed	Hand washing only
Ian Forsyth Elementary	Janitors Closet 141 tap	MWI432	June 15, 2020	0.002	Passed	0.1800	Passed	
Ian Forsyth Elementary	Boys Wash Room 139 tap 1	XDW616	September 29, 2023	-	Passed	0.0110	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room 139 tap 2	MWI435	June 15, 2020	0.001	Passed	0.0600	Passed	
Ian Forsyth Elementary	Boys Wash Room 139 tap 3	MWI436	June 15, 2020	0.002	Passed	0.0690	Passed	
Ian Forsyth Elementary	Boys Wash Room 139 tap 4	MWI437	June 15, 2020	0.003	Passed	0.1200	Passed	
Ian Forsyth Elementary	Class Room 129 tap	MWI438	June 15, 2020	0.004	Passed	0.5400	Passed	
Ian Forsyth Elementary	Staff Room 103 tap	XDW596	September 29, 2023	0.001	Passed	0.0040	Passed	Tap remediated
Ian Forsyth Elementary	Staff Room 103 Wash Room tap	XDW599	September 29, 2023	-	Passed	0.0073	Passed	Tap remediated
Ian Forsyth Elementary	Sick Room 104 tap	XDW597	September 29, 2023	-	Passed	0.0055	Passed	Tap remediated
Ian Forsyth Elementary	Gym Kitchen tap	XDW606	September 29, 2023	0.001	Passed	0.0150	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 1 by Room 111	XDW603	September 29, 2023	0.004	Passed	0.0630	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 2 by Room 111	XDW604	September 29, 2023	-	Passed	0.0090	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 3 by Room 111	XDW605	September 29, 2023	0.001	Passed	0.0160	Passed	Tap remediated
Ian Forsyth Elementary	Janitors Closet 108 tap	NDP124	July 16, 2020	0.041	Exceeded	0.2800	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room tap 1 by Room 106	XDW600	September 29, 2023	0.001	Passed	0.0330	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room tap 2 by Room 106	XDW601	September 29, 2023	0.001	Passed	0.0250	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room tap 3 by Room 106	XDW602	September 29, 2023	0.001	Passed	0.0360	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room tap 1 by Room 123	XDW609	September 29, 2023	0.015	Exceeded	0.0660	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room tap 2 by Room 123	XDW610	September 29, 2023	0.005	Exceeded	0.0290	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room tap 3 by Room 123	XDW611	September 29, 2023	0.003	Passed	0.0190	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room tap 4 by Room 123	XDW612	September 29, 2023	0.001	Passed	0.0120	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 1 by Room 125	XDW613	September 29, 2023	-	Passed	0.0043	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 2 by Room 125	XDW614	September 29, 2023	-	Passed	0.0049	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 3 by Room 125	XDW615	September 29, 2023	0.001	Passed	0.0096	Passed	Tap remediated
Ian Forsyth Elementary	Main Office tap	XDW595	September 29, 2023	0.004	Passed	0.1600	Passed	Tap remediated
Ian Forsyth Elementary	Main Office Wash Room tap	XDW594	September 29, 2023	0.002	Passed	0.0280	Passed	Tap remediated
Ian Forsyth Elementary	Janitors Closet 127 tap	NDP230	July 16, 2020	0.069	Exceeded	0.4300	Passed	Hand washing only
Ian Forsyth Elementary	Fountain on 2nd Floor	XDW621	September 29, 2023	0.001	Passed	0.0780	Passed	
Ian Forsyth Elementary	Fountain by Room 126	XDW607	September 29, 2023	0.001	Passed	0.1000	Passed	
Ian Forsyth Elementary	Fountain by Room 130	XDW608	September 29, 2023	0.002	Passed	0.5300	Passed	
Ian Forsyth Elementary	Fountain by Room 140	SHU484	April 7, 2022	0.002	Passed	0.0580	Passed	Fountain replaced

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ian Forsyth Elementary	Fountain by Room 105	XDW598	September 29, 2023	0.001	Passed	0.1500	Passed	
Inglis Street Elementary	Caretaker Room Wash Room 312 tap	MTA096	May 28, 2020	0.001	Passed	0.0950	Passed	
Inglis Street Elementary	YMCA Room Wash Room 311 tap	MTA097	May 28, 2020	-	Passed	0.0360	Passed	
Inglis Street Elementary	Janitors Closet 307 tap	MTA099	May 28, 2020	0.001	Passed	0.0740	Passed	
Inglis Street Elementary	Girls Wash Room 308 tap 1	MTA100	May 28, 2020	0.002	Passed	0.1600	Passed	
Inglis Street Elementary	Girls Wash Room 308 tap 2	MTA101	May 28, 2020	0.001	Passed	0.0730	Passed	
Inglis Street Elementary	Girls Wash Room 308 tap 3	MTA102	May 28, 2020	0.001	Passed	0.0400	Passed	
Inglis Street Elementary	Class Room 302 tap	MTA104	May 28, 2020	0.002	Passed	0.2000	Passed	
Inglis Street Elementary	Boys Wash Room 301 tap 1	MTA105	May 28, 2020	0.001	Passed	0.0470	Passed	
Inglis Street Elementary	Boys Wash Room 301 tap 2	MTA106	May 28, 2020	0.003	Passed	0.0780	Passed	
Inglis Street Elementary	Principals Office Wash Room 209 tap	MTA108	May 28, 2020	-	Passed	0.0220	Passed	
Inglis Street Elementary	Class Room Wash Room 206 tap	MTA111	May 28, 2020	-	Passed	0.0061	Passed	
Inglis Street Elementary	Girls Wash Room 205 tap 1	MTA112	May 28, 2020	-	Passed	0.0120	Passed	
Inglis Street Elementary	Girls Wash Room 205 tap 2	MTA113	May 28, 2020	-	Passed	0.0063	Passed	
Inglis Street Elementary	Girls Wash Room 205 tap 3	MTA114	May 28, 2020	-	Passed	0.0054	Passed	
Inglis Street Elementary	Janitors Closet 204 tap	MTA115	May 28, 2020	0.001	Passed	0.1500	Passed	
Inglis Street Elementary	Boys Wash Room 200 tap 1	MTA116	May 28, 2020	0.002	Passed	0.2100	Passed	
Inglis Street Elementary	Boys Wash Room 200 tap 2	MTA117	May 28, 2020	0.001	Passed	0.0130	Passed	
Inglis Street Elementary	Boys Wash Room 200 tap 3	MTA118	May 28, 2020	0.002	Passed	0.0410	Passed	
Inglis Street Elementary	Boys Wash Room 200 tap 4	MTA119	May 28, 2020	0.002	Passed	0.1300	Passed	
Inglis Street Elementary	Gym Office Wash Room tap	MTA121	May 28, 2020	0.002	Passed	0.1200	Passed	
Inglis Street Elementary	Basement Janitors Closet tap	MTA122	May 28, 2020	0.001	Passed	0.2600	Passed	
Inglis Street Elementary	Class Room tap Room 112	MTA123	May 28, 2020	-	Passed	0.0210	Passed	
Inglis Street Elementary	Gender Neutral Wash Room tap 1 by Room 325	MTA124	May 28, 2020	0.001	Passed	0.0240	Passed	
Inglis Street Elementary	Gender Neutral Wash Room tap 2 by Room 325	MTA125	May 28, 2020	-	Passed	0.0200	Passed	
Inglis Street Elementary	Basement Boiler Room tap	MUV553	June 8, 2020	0.002	Passed	0.1300	Passed	
Inglis Street Elementary	Basement Class Room	MUV554	June 8, 2020	0.001	Passed	0.0490	Passed	
Inglis Street Elementary	Class Room 305 tap	NLK012	August 24, 2020	0.000	Passed	0.0050	Passed	
Inglis Street Elementary	Fountain by Gym	VTZ933	May 9, 2023	-	Passed	0.1800	Passed	
Inglis Street Elementary	Fountain by Room 209	VTZ934	May 9, 2023	-	Passed	0.1100	Passed	
Inglis Street Elementary	Staff Room 208 tap	VTZ935	May 9, 2023	-	Passed	0.0710	Passed	
Inglis Street Elementary	Fountain by Room 311	VTZ936	May 9, 2023	-	Passed	0.1800	Passed	
Inglis Street Elementary	Boys Wash Room 301 tap 3	VTZ937	May 9, 2023	-	Passed	0.0980	Passed	Tap remediated
Inglis Street Elementary	Basement Fountain	VTZ938	May 9, 2023	0.001	Passed	0.0880	Passed	
Island View High School	Gender Neutral Wash Room 304H.1 tap	MYZ388	June 25, 2020	0.001	Passed	0.0700	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304G	MZD660	June 25, 2020	0.003	Passed	0.6300	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304F	WGQ675	June 27, 2023	-	Passed	0.1600	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room tap Room 304E	MZD662	June 25, 2020	0.001	Passed	0.1100	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304D	WGQ676	June 27, 2023	-	Passed	0.7800	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room tap Room 304C	WGQ677	June 27, 2023	0.001	Passed	0.2100	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room tap Room 304B	MZD665	June 25, 2020	0.001	Passed	0.1900	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304A	MZD666	June 25, 2020	0.004	Passed	0.3800	Passed	
Island View High School	Janitors Closet 208B.1 tap	MZD667	June 25, 2020	-	Passed	0.3800	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Island View High School	Class Room 327 tap 1	MZD668	June 25, 2020	-	Passed	0.1900	Passed	
Island View High School	Class Room 327 tap 2	WGQ678	June 23, 2023	-	Passed	0.5800	Passed	
Island View High School	Fountain by Room 317	WGQ670	June 27, 2023	-	Passed	1.3000	Passed	
Island View High School	Life Sciences Lab 315.1 tap 1	WGQ671	June 25, 2020	-	Passed	1.7000	Passed	
Island View High School	Life Sciences Lab 315.1 tap 2	MZD673	June 25, 2020	0.004	Passed	0.4400	Passed	
Island View High School	Life Sciences Lab 315.1 tap 3	MZD673	June 25, 2020	0.004	Passed	0.4400	Passed	
Island View High School	Life Sciences Lab 315.1 tap 4	MZD674	June 25, 2020	0.001	Passed	0.2800	Passed	
Island View High School	Life Sciences Lab 315.1 tap 5	MZD675	June 25, 2020	-	Passed	1.1000	Passed	
Island View High School	Life Sciences Lab 315.1 tap 6	WDQ672	June 27, 2023	-	Passed	0.9200	Passed	Tap remediated
Island View High School	Life Sciences Lab 315.1 tap 7	MZD677	June 25, 2020	-	Passed	0.1900	Passed	
Island View High School	Assistive Care Wash Room tap by Room 315	WGQ678	June 27, 2023	-	Passed	0.8300	Passed	Tap remediated
Island View High School	Class Room 311A tap	MZD679	June 25, 2020	0.002	Passed	0.4900	Passed	
Island View High School	Chemistry Lab 309 tap 1	MZD680	June 25, 2020	-	Passed	0.0340	Passed	
Island View High School	Chemistry Lab 309 tap 2	MZD681	June 25, 2020	0.001	Passed	0.0730	Passed	
Island View High School	Chemistry Lab 309 tap 3	WGQ674	June 27, 2023	0.001	Passed	0.6000	Passed	Laboratory or Hand washing only
Island View High School	Chemistry Lab 309 tap 4	MZD683	June 25, 2020	-	Passed	0.0660	Passed	
Island View High School	Chemistry Lab 309 tap 5	MZD684	June 25, 2020	0.001	Passed	0.0810	Passed	
Island View High School	Chemistry Lab 309 tap 6	MZD685	June 25, 2020	0.001	Passed	0.0570	Passed	
Island View High School	Chemistry Lab 309 tap 7	MZD686	June 25, 2020	-	Passed	0.4900	Passed	
Island View High School	Chemistry Lab 309 tap 8	MZD687	June 25, 2020	0.001	Passed	0.0300	Passed	
Island View High School	Chemistry Lab 309 tap 9	MZD688	June 25, 2020	0.001	Passed	0.4200	Passed	
Island View High School	Staff Room 305 tap 1	WGQ687	June 27, 2023	-	Passed	0.0560	Passed	
Island View High School	Staff Room 305 tap 2	WGQ688	June 25, 2020	-	Passed	0.7300	Passed	
Island View High School	Gender Neutral Wash Room 303 tap	MZD691	June 25, 2020	-	Passed	0.0720	Passed	
Island View High School	Gender Neutral Wash Room 206H tap 1	MZD692	June 25, 2020	0.003	Passed	0.6100	Passed	
Island View High School	Gender Neutral Wash Room 206G tap 1	MZD693	June 25, 2020	0.002	Passed	0.2600	Passed	
Island View High School	Gender Neutral Wash Room 206F tap 1	WGQ679	June 27, 2023	0.001	Passed	0.1100	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room 206E tap 1	MZD695	June 25, 2020	0.004	Passed	0.9300	Passed	
Island View High School	Gender Neutral Wash Room 206D tap 1	MZD696	June 25, 2020	0.004	Passed	0.3000	Passed	
Island View High School	Gender Neutral Wash Room 206C tap 1	MZD697	June 25, 2020	0.001	Passed	0.1200	Passed	
Island View High School	Gender Neutral Wash Room 206B tap 1	MZD698	June 25, 2020	0.001	Passed	0.1500	Passed	
Island View High School	Gender Neutral Wash Room 206A tap 1	MZD699	June 25, 2020	0.001	Passed	0.1400	Passed	
Island View High School	Janitors Closet 208B.1 tap	MZD700	June 25, 2020	-	Passed	0.0600	Passed	
Island View High School	Assistive Care Wash Room tap by Room 217	WGQ660	June 27, 2023	-	Passed	0.3200	Passed	
Island View High School	Class Room 225 tap 1	MZD701	June 25, 2020	-	Passed	0.1100	Passed	
Island View High School	Class Room 225 tap 2	MZD702	June 25, 2020	0.004	Passed	0.8400	Passed	
Island View High School	Class Room 227 tap 1	MZD703	June 25, 2020	-	Passed	0.2600	Passed	
Island View High School	Class Room 227 tap 2	MZD704	June 25, 2020	0.002	Passed	0.5700	Passed	
Island View High School	Class Room 213 tap	MZD705	June 25, 2020	0.001	Passed	0.2200	Passed	
Island View High School	Nutrition Lab 211 tap 1	WGQ661	June 27, 2023	-	Passed	0.3500	Passed	
Island View High School	Nutrition Lab 211 tap 2	WGQ662	June 27, 2023	-	Passed	0.7300	Passed	
Island View High School	Nutrition Lab 211 tap 3	WGQ663	June 27, 2023	-	Passed	0.6000	Passed	
Island View High School	Nutrition Lab 211 tap 4	WGQ664	June 27, 2023	-	Passed	0.1800	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Island View High School	Nutrition Lab 211 tap 5	WGQ665	June 27, 2023	-	Passed	0.2900	Passed	
Island View High School	Nutrition Lab 211 tap 6	WGQ666	June 27, 2023	0.001	Passed	0.2100	Passed	
Island View High School	Fountain by Room 211	WGQ667	June 27, 2023	-	Passed	0.7100	Passed	
Island View High School	Main Office Wash Room 1081 tap	MZD713	June 25, 2020	-	Passed	0.0600	Passed	
Island View High School	Gym Gender Neutral Wash Room 1 tap	WGQ668	June 27, 2023	-	Passed	0.3400	Passed	Tap remediated
Island View High School	Gym Gender Neutral Wash Room 2 tap	WGQ669	June 27, 2023	0.001	Passed	0.4200	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room 106J.1 tap	MZD716	June 26, 2020	-	Passed	0.0520	Passed	
Island View High School	Gender Neutral Wash Room tap 1 by Room 106F.1	MZD717	June 26, 2020	-	Passed	0.1200	Passed	
Island View High School	Gender Neutral Wash Room tap 2 by Room 106F.1	MZD718	June 26, 2020	0.001	Passed	0.2000	Passed	
Island View High School	Gender Neutral Wash Room 106B.1 tap	WGQ681	June 27, 2023	-	Passed	0.8300	Passed	Tap remediated
Island View High School	Janitors Closet 112A.1 tap	WGQ686	June 27, 2023	-	Passed	0.3700	Passed	Tap remediated
Island View High School	Kitchen 112 tap 1	WGQ683	June 27, 2023	-	Passed	0.0680	Passed	
Island View High School	Kitchen 112 tap 2	WGQ684	June 27, 2023	-	Passed	0.0860	Passed	
Island View High School	Kitchen 112 tap 3	WGQ685	June 27, 2023	-	Passed	0.3600	Passed	
Island View High School	Janitors Closet 114 tap	MZD724	June 26, 2020	0.001	Passed	0.2900	Passed	
Island View High School	Music Room 118 tap	MZD725	June 26, 2020	0.001	Passed	0.7100	Passed	
Island View High School	Art Room 117 tap 1	MZD726	June 26, 2020	-	Passed	0.2500	Passed	
Island View High School	Art Room 117 tap 2	MZD727	June 26, 2020	-	Passed	0.1600	Passed	
Island View High School	Media Room 111B.1 tap	MZD728	June 26, 2020	0.003	Passed	0.1300	Passed	
Island View High School	Fountain by Room 111	WGQ682	June 27, 2023	-	Passed	0.5400	Passed	
Island View High School	Production Room 107 tap	MZD730	June 26, 2020	0.001	Passed	0.5200	Passed	
Island View High School	Recycle Room 105 tap	MZD731	June 26, 2020	0.001	Passed	1.1000	Passed	
Island View High School	Science Lab 103 tap 1	MZD855	June 26, 2020	-	Passed	1.5000	Passed	
Island View High School	Science Lab 103 tap 2	MZD856	June 26, 2020	-	Passed	0.4100	Passed	
Island View High School	Science Lab 103 tap 3	MZD857	June 26, 2020	-	Passed	0.0570	Passed	
Island View High School	Science Lab 103 tap 4	NAM732	June 30, 2020	0.002	Passed	0.0240	Passed	
Island View High School	Science Lab 103 tap 5	WGQ680	June 27, 2023	-	Passed	0.1300	Passed	Laboratory or Hand washing only
Island View High School	Science Lab 103 tap 6	NAM734	June 30, 2020	0.002	Passed	0.0620	Passed	
Island View High School	Science Lab 103 tap 7	NAM735	June 30, 2020	0.002	Passed	0.1500	Passed	
J.L. Ilesley High School	3rd Floor Double Fountain 1	VPP510	April 20, 2023	-	Passed	0.1500	Passed	
J.L. Ilesley High School	3rd Floor Double Fountain 2	VPP511	April 20, 2023	-	Passed	0.1200	Passed	
J.L. Ilesley High School	3rd Floor Gender Neutral Wash Rooms tap 1	VPP512	April 20, 2023	-	Passed	0.7200	Passed	
J.L. Ilesley High School	3rd Floor Gender Neutral Wash Rooms tap 2	VPP513	April 20, 2023	-	Passed	0.2600	Passed	
J.L. Ilesley High School	3rd Floor Gender Neutral Wash Rooms tap 3	VPP514	April 20, 2023	-	Passed	0.2100	Passed	
J.L. Ilesley High School	3rd Floor Gender Neutral Wash Rooms tap 4	VPP515	April 20, 2023	0.001	Passed	0.8800	Passed	
J.L. Ilesley High School	3rd Floor Gender Neutral Wash Rooms tap 5	VPP516	April 20, 2023	-	Passed	0.3400	Passed	
J.L. Ilesley High School	3rd Floor Gender Neutral Wash Rooms tap 6	VPP517	April 20, 2023	-	Passed	0.3800	Passed	
J.L. Ilesley High School	3rd Floor Fountain by Gender Neutral Wash Rooms	VPP518	April 20, 2023	-	Passed	0.1000	Passed	
J.L. Ilesley High School	Classroom 339 tap 1	VPP519	April 20, 2023	-	Passed	0.5700	Passed	
J.L. Ilesley High School	Classroom 339 tap 2	VPP570	April 20, 2023	-	Passed	0.6800	Passed	
J.L. Ilesley High School	Classroom 339 tap 3	VPP571	April 20, 2023	-	Passed	0.6800	Passed	
J.L. Ilesley High School	Classroom 339 tap 4	VPP572	April 20, 2023	-	Passed	0.2100	Passed	
J.L. Ilesley High School	Classroom 339 tap 5	VPP574	April 20, 2023	-	Passed	0.6300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
J.L. Ilesley High School	Classroom 339A tap	VPP584	April 20, 2023	-	Passed	0.3100	Passed	
J.L. Ilesley High School	Chemistry Lab 337 tap 1	VPP587	April 20, 2023	-	Passed	0.4500	Passed	
J.L. Ilesley High School	Chemistry Lab 337 tap 2	VPP588	April 20, 2023	-	Passed	0.4500	Passed	
J.L. Ilesley High School	Chemistry Lab 337 tap 3	VPP589	April 20, 2023	-	Passed	1.3000	Passed	
J.L. Ilesley High School	Chemistry Lab 337 tap 4	VPP590	April 20, 2023	-	Passed	0.7300	Passed	
J.L. Ilesley High School	Chemistry Lab 337 tap 5	VPP591	April 20, 2023	-	Passed	0.4200	Passed	
J.L. Ilesley High School	Chemistry Lab 337A tap	VPP633	April 20, 2023	0.003	Passed	0.2400	Passed	
J.L. Ilesley High School	Staff Room 335	VPP634	April 20, 2023	-	Passed	0.5600	Passed	
J.L. Ilesley High School	Classroom 301 tap 1	VPP635	April 20, 2023	-	Passed	0.4100	Passed	
J.L. Ilesley High School	Classroom 301 tap 2	VPP636	April 20, 2023	-	Passed	0.4600	Passed	
J.L. Ilesley High School	Board Room 317 tap	VPP637	April 20, 2023	-	Passed	0.6800	Passed	
J.L. Ilesley High School	Classroom 319 tap	VPP638	April 20, 2023	-	Passed	0.4500	Passed	
J.L. Ilesley High School	Wash Room 319D	VPP639	April 20, 2023	-	Passed	0.4700	Passed	
J.L. Ilesley High School	Fan Room 319F	VPP640	April 20, 2023	-	Passed	0.2100	Passed	
J.L. Ilesley High School	2nd Floor Double Fountain 1	VPP641	April 20, 2023	-	Passed	0.3700	Passed	
J.L. Ilesley High School	2nd Floor Double Fountain 2	XKT672	October 27, 2023	-	Passed	0.0770	Passed	
J.L. Ilesley High School	2nd Floor Gender Neutral Wash Rooms tap 1	VPP650	April 20, 2023	-	Passed	0.3700	Passed	
J.L. Ilesley High School	2nd Floor Gender Neutral Wash Rooms tap 2	VPP651	April 20, 2023	-	Passed	0.4400	Passed	
J.L. Ilesley High School	2nd Floor Gender Neutral Wash Rooms tap 3	VPP652	April 20, 2023	-	Passed	0.2600	Passed	
J.L. Ilesley High School	2nd Floor Gender Neutral Wash Rooms tap 4	VPP653	April 20, 2023	-	Passed	0.3200	Passed	
J.L. Ilesley High School	2nd Floor Gender Neutral Wash Rooms tap 5	VPP654	April 20, 2023	-	Passed	0.2700	Passed	
J.L. Ilesley High School	2nd Floor Gender Neutral Wash Rooms tap 6	VPP655	April 20, 2023	-	Passed	0.3000	Passed	
J.L. Ilesley High School	2nd Floor Fountain by Gender Neutral Wash Rooms	VPP656	April 20, 2023	-	Passed	0.0840	Passed	
J.L. Ilesley High School	Music Storage Room 208C tap	VPP657	April 20, 2023	-	Passed	0.5700	Passed	
J.L. Ilesley High School	Classroom 230 tap 1	VPP658	April 20, 2023	-	Passed	0.4500	Passed	
J.L. Ilesley High School	Classroom 230 tap 2	VPP659	April 20, 2023	-	Passed	0.3300	Passed	
J.L. Ilesley High School	Fountain 1 by Room 234	VPP669	April 20, 2023	-	Passed	0.2000	Passed	
J.L. Ilesley High School	Fountain 2 by Room 234	VPP670	April 20, 2023	-	Passed	0.1700	Passed	
J.L. Ilesley High School	Classroom 238 tap	VPP671	April 20, 2023	-	Passed	0.3900	Passed	
J.L. Ilesley High School	Wash Room 236 tap	VPP672	April 20, 2023	-	Passed	0.3700	Passed	
J.L. Ilesley High School	Staff Room 240 tap	VPP673	April 20, 2023	-	Passed	0.1700	Passed	
J.L. Ilesley High School	Staff Room Wash Room 240B tap	VPP674	April 20, 2023	-	Passed	0.3000	Passed	
J.L. Ilesley High School	Staff Room Wash Room 240C tap	VPP675	April 20, 2023	-	Passed	0.2000	Passed	
J.L. Ilesley High School	Physics Lab 207 tap 1	VPP676	April 20, 2023	0.014	Exceeded	0.1100	Passed	Laboratory or Hand washing only
J.L. Ilesley High School	Physics Lab 207 tap 2	VPP677	April 20, 2023	0.007	Exceeded	0.0850	Passed	Laboratory or Hand washing only
J.L. Ilesley High School	1st Floor Double Fountain 1	VPP678	April 20, 2023	-	Passed	0.5600	Passed	
J.L. Ilesley High School	1st Floor Double Fountain 2	VPP702	April 20, 2023	-	Passed	0.4600	Passed	
J.L. Ilesley High School	1st Floor Gender Neutral Wash Rooms tap 1	XKT669	October 27, 2023	-	Passed	0.2400	Passed	
J.L. Ilesley High School	1st Floor Gender Neutral Wash Rooms tap 2	XKT670	October 27, 2023	-	Passed	0.2400	Passed	
J.L. Ilesley High School	1st Floor Gender Neutral Wash Rooms tap 3	XKT671	October 27, 2023	-	Passed	0.2400	Passed	
J.L. Ilesley High School	1st Floor Gender Neutral Wash Rooms tap 4	VPP703	April 20, 2023	-	Passed	0.2000	Passed	
J.L. Ilesley High School	1st Floor Gender Neutral Wash Rooms tap 5							Out-of-Service
J.L. Ilesley High School	1st Floor Gender Neutral Wash Rooms tap 6	VPP704	April 20, 2023	-	Passed	0.2300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
J.L. Ilesley High School	Wash Room 125 tap	VPP705	April 20, 2023	-	Passed	0.3300	Passed	
J.L. Ilesley High School	1st Floor Fountain by Gender Neutral Wash Rooms	VPP706	April 20, 2023	-	Passed	0.0710	Passed	
J.L. Ilesley High School	Nutrition Room 127 tap 1	VPP707	April 20, 2023	-	Passed	0.0910	Passed	
J.L. Ilesley High School	Nutrition Room 127 tap 2	VPP708	April 20, 2023	-	Passed	0.1600	Passed	
J.L. Ilesley High School	Nutrition Room 127 tap 3	VPP709	April 20, 2023	-	Passed	0.1600	Passed	
J.L. Ilesley High School	Nutrition Room 127 tap 4	VPP711	April 20, 2023	-	Passed	0.2100	Passed	
J.L. Ilesley High School	Nutrition Room 127 tap 5	VPP712	April 20, 2023	-	Passed	0.8500	Passed	
J.L. Ilesley High School	Science Room 135 tap 1	VPP735	April 20, 2023	-	Passed	0.2800	Passed	
J.L. Ilesley High School	Science Room 135 tap 2	VPP736	April 20, 2023	-	Passed	0.2500	Passed	
J.L. Ilesley High School	Science Room 135 tap 3	VPP737	April 20, 2023	-	Passed	0.5800	Passed	
J.L. Ilesley High School	Science Room 135 tap 4	VPP738	April 20, 2023	0.001	Passed	0.3800	Passed	
J.L. Ilesley High School	Science Room 135 tap 5	VPP739	April 20, 2023	-	Passed	0.9800	Passed	
J.L. Ilesley High School	Science Room 135 tap 6	VPP740	April 20, 2023	-	Passed	1.6000	Passed	
J.L. Ilesley High School	Room 126 tap 1	VPP741	April 20, 2023	-	Passed	0.4300	Passed	
J.L. Ilesley High School	Room 126 tap 2	VPP742	April 20, 2023	-	Passed	0.8700	Passed	
J.L. Ilesley High School	Wash Room 124 tap	VPP743	April 20, 2023	-	Passed	0.4200	Passed	
J.L. Ilesley High School	Fountain 1 by Room 122	VPP744	April 20, 2023	-	Passed	0.1800	Passed	
J.L. Ilesley High School	Fountain 2 by Room 122	VPP745	April 20, 2023	-	Passed	0.1500	Passed	
J.L. Ilesley High School	Wood Shop Room 105 tap	VPP812	April 20, 2023	-	Passed	0.3900	Passed	
J.L. Ilesley High School	Custodian Room 107 tap	VPP813	April 20, 2023	-	Passed	0.2000	Passed	
J.L. Ilesley High School	Skilled Trades Room 109 tap	VPP814	April 20, 2023	-	Passed	0.3500	Passed	
J.L. Ilesley High School	Cafeteria/Kitchen Room 115 tap 1	VPP815	April 20, 2023	-	Passed	0.2700	Passed	
J.L. Ilesley High School	Cafeteria/Kitchen Room 115 tap 2	VPP816	April 20, 2023	-	Passed	0.2700	Passed	
J.L. Ilesley High School	Cafeteria/Kitchen Room 115 tap 3	VPP817	April 20, 2023	-	Passed	0.2700	Passed	
J.L. Ilesley High School	Janitors Closet 115 tap	VPP818	April 30, 2023	-	Passed	0.1600	Passed	
J.L. Ilesley High School	Cafeteria Storage Room 113 tap	VPP819	April 30, 2023	-	Passed	0.1300	Passed	
J.L. Ilesley High School	Main Office Kitchen Room 201G tap	VPP820	April 20, 2023	-	Passed	0.2900	Passed	
J.L. Ilesley High School	Main Office Wash Room 201D tap	VPP824	April 20, 2023	-	Passed	0.4000	Passed	
J.L. Ilesley High School	Gym Locker Room Wash Room 1 tap	XKT673	October 27, 2023	0.001	Passed	0.5300	Passed	
J.L. Ilesley High School	Gym Locker Room Wash Room 2 tap	VPP826	April 20, 2023	-	Passed	0.4400	Passed	
John MacNeil Elementary	Staff Room Wash Room 1 tap	MYA977	June 22, 2020	0.002	Passed	0.0170	Passed	
John MacNeil Elementary	Staff Room Wash Room 2 tap	MYA978	June 22, 2020	-	Passed	0.0240	Passed	
John MacNeil Elementary	Learning Centre 1 Wash Room tap	XAB698	September 14, 2023	0.001	Passed	0.0300	Passed	
John MacNeil Elementary	Fountain by Room 1	XAB697	September 14, 2023	-	Passed	0.0027	Passed	
John MacNeil Elementary	Boys Wash Room tap 1 by Resource Centre	XAB689	September 14, 2023	0.002	Passed	0.0610	Passed	Tap remediated
John MacNeil Elementary	Boys Wash Room tap 2 by Resource Centre	XAB690	September 14, 2023	-	Passed	0.0270	Passed	Tap remediated
John MacNeil Elementary	Janitors Closet tap by resource Room	MYA983	June 22, 2020	-	Passed	0.0150	Passed	
John MacNeil Elementary	Girls Wash Room tap 1 by resource Room	MYA984	June 22, 2020	0.002	Passed	0.1900	Passed	
John MacNeil Elementary	Girls Wash Room tap 2 by resource Room	MYA985	June 22, 2020	-	Passed	0.1100	Passed	
John MacNeil Elementary	Girls Wash Room tap 3 by resource Room	MYA986	June 22, 2020	0.004	Passed	0.1100	Passed	
John MacNeil Elementary	Girls Wash Room tap 1	XAB694	September 14, 2023	-	Passed	0.0220	Passed	Tap remediated
John MacNeil Elementary	Girls Wash Room tap 2	XAB695	September 14, 2023	-	Passed	0.0210	Passed	Tap remediated
John MacNeil Elementary	Girls Wash Room tap 3	MYA989	June 22, 2020	0.002	Passed	0.0290	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
John MacNeil Elementary	Girls Wash Room tap 4	MYA990	June 22, 2020	0.001	Passed	0.0230	Passed	
John MacNeil Elementary	Staff Room Kitchen tap	XAB696	September 14, 2023	-	Passed	0.0180	Passed	
John MacNeil Elementary	Boys Wash Room tap 1	XAB692	September 14, 2023	0.001	Passed	0.0190	Passed	
John MacNeil Elementary	Boys Wash Room tap 2	XAB693	September 14, 2023	-	Passed	0.0189	Passed	
John MacNeil Elementary	Staff Room Wash Room 1 tap	MYA977	June 22, 2020	0.002	Passed	0.0170	Passed	
John MacNeil Elementary	Staff Room Wash Room 2 tap	MYA978	June 22, 2020	-	Passed	0.0240	Passed	
John MacNeil Elementary	Fountain by Office	XAB701	September 14, 2023	-	Passed	0.0470	Passed	
John MacNeil Elementary	Fountain by Gym	XAB700	September 14, 2023	-	Passed	0.0009	Passed	
John MacNeil Elementary	Cafeteria/Kitchen by Gym	XAB691	September 14, 2023	0.001	Passed	0.0260	Passed	
John Martin Junior High School	Boys Wash Room tap 2 by Resource Room	MYA982	June 22, 2020	0.010	Exceeded	0.1200	Passed	Hand washing only
John Martin Junior High School	Janitors Closet tap by Resource Room	MYA983	June 22, 2020	-	Passed	0.0150	Passed	
John Martin Junior High School	Girls Wash Room tap 1 by Resource Room	MYA984	June 22, 2020	0.002	Passed	0.1900	Passed	
John Martin Junior High School	Girls Wash Room tap 2 by Resource Room	MYA985	June 22, 2020	-	Passed	0.1100	Passed	
John Martin Junior High School	Girls Wash Room tap 3 by Resource Room	MYA986	June 22, 2020	0.004	Passed	0.1100	Passed	
John Martin Junior High School	Fountain by Gym							Out-of-Service
John Martin Junior High School	Girls Wash Room tap 1 by Gym	MYA987	June 22, 2020	0.120	Exceeded	0.6800	Passed	Hand washing only
John Martin Junior High School	Girls Wash Room tap 2 by Gym	MYA988	June 22, 2020	0.020	Exceeded	0.2200	Passed	Hand washing only
John Martin Junior High School	Girls Wash Room tap 3 by Gym	MYA989	June 22, 2020	0.002	Passed	0.0290	Passed	
John Martin Junior High School	Girls Wash Room tap 4 by Gym	MYA990	June 22, 2020	0.001	Passed	0.0230	Passed	
John Martin Junior High School	Boys Wash Room tap 1 by Gym	MYA991	June 22, 2020	0.110	Exceeded	2.9000	Exceeded	Hand washing only
John Martin Junior High School	Boys Wash Room tap 2 by Gym	MYA992	June 22, 2020	0.005	Exceeded	0.1000	Passed	Hand washing only
John Martin Junior High School	Boys Wash Room tap 3 by Gym	MYA993	June 22, 2020	0.002	Passed	0.0330	Passed	
John Martin Junior High School	Cafeteria/Kitchen tap in Gym	MYA994	June 22, 2020	0.110	Exceeded	0.7700	Passed	Hand washing only
John Martin Junior High School	Boys Wash Room tap 3 by Staff Wash Room	WHU642	June 5, 2023	0.003	Passed	0.0980	Passed	Tap remediated
John Martin Junior High School	Staff Wash Room by Caretaker Room	WHX400	June 6, 2023	0.001	Passed	0.0200	Passed	Tap remediated
John Martin Junior High School	Janitors Closet inside caretaker Room	MYR810	June 24, 2020	0.001	Passed	0.0140	Passed	
John Martin Junior High School	Gender Neutral Wash Room by Girls Wash Room	WHU639	June 5, 2023	-	Passed	0.0160	Passed	Tap remediated
John Martin Junior High School	Girls Wash Room tap 1 by Gender Neutral Wash Room	WHU636	June 5, 2023	0.007	Exceeded	0.1200	Passed	Hand washing only
John Martin Junior High School	Girls Wash Room tap 2 by Gender Neutral Wash Room	WHU637	June 5, 2023	0.006	Exceeded	0.1200	Passed	Hand washing only
John Martin Junior High School	Girls Wash Room tap 3 by Gender Neutral Wash Room	WHU638	June 5, 2023	0.007	Exceeded	0.1700	Passed	Hand washing only
John Martin Junior High School	Kitchen/Cafeteria tap 1	WHX603	July 6, 2023	-	Passed	0.0360	Passed	
John Martin Junior High School	Kitchen/Cafeteria tap 2	WHX604	July 6, 2023	0.001	Passed	0.0047	Passed	
John Martin Junior High School	Staff Wash Room tap by Caretaker Supplies Room	WHX401	June 6, 2023	-	Passed	0.0190	Passed	Tap remediated
John Martin Junior High School	Fountain by back Gym doors	MYR822	June 24, 2020	0.003	Passed	1.7000	Passed	Out-of-Service
John Martin Junior High School	Staff Wash Room tap in Teachers Wash Room	WHX605	July 6, 2023	0.001	Passed	0.0130	Passed	Tap remediated
John Martin Junior High School	Janitors Supplies Room tap	MYR824	June 24, 2020	0.001	Passed	0.0230	Passed	
John Martin Junior High School	Gym Office Wash Room tap	WHX606	July 6, 2023	-	Passed	0.0220	Passed	Tap remediated
John Martin Junior High School	Girls Wash Room tap 1 in Gym	WHX406	July 6, 2023	0.001	Passed	0.0110	Passed	Tap remediated
John Martin Junior High School	Girls Wash Room tap 2 in Gym	WHX407	July 6, 2023	-	Passed	0.0093	Passed	Tap remediated
John Martin Junior High School	Girls Wash Room tap 3 in Gym	WHX408	July 6, 2023	-	Passed	0.0120	Passed	Tap remediated
John Martin Junior High School	Girls Wash Room tap 4 in Gym	WHX409	July 6, 2023	-	Passed	0.0120	Passed	Tap remediated
John Martin Junior High School	Boys Wash Room tap 1 in Gym	WHX560	July 6, 2023	-	Passed	0.0035	Passed	Tap remediated
John Martin Junior High School	Boys Wash Room tap 2 in Gym	MYR831	June 24, 2020	-	Passed	0.0058	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
John Martin Junior High School	Boys Wash Room tap 3 in Gym	WHX561	July 6, 2023	-	Passed	0.0045	Passed	Tap remediated
John Martin Junior High School	Boys Wash Room tap 4 in Gym	WHX562	July 6, 2023	-	Passed	0.0041	Passed	Tap remediated
John Martin Junior High School	Staff Shower Room tap in Gym	WHX405	July 6, 2023	0.010	Exceeded	0.0870	Passed	Hand washing only
John Martin Junior High School	Janitors Closet tap by Boiler Room	MYR835	June 24, 2020	0.002	Passed	0.0390	Passed	
John Martin Junior High School	Tech Ed Room Janitors Closet tap	WHX404	July 6, 2023	-	Passed	0.0400	Passed	Tap remediated
John Martin Junior High School	Tech Ed Room Gender Neutral Wash Room tap	WHX403	July 6, 2023	0.001	Passed	0.0320	Passed	Tap remediated
John Martin Junior High School	Office Staff Wash Room tap	WHX563	July 6, 2023	-	Passed	0.0270	Passed	Tap remediated
John Martin Junior High School	Science Lab 1 tap 1	MYR847	June 24, 2020	0.160	Exceeded	0.1800	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 1 tap 3	MYR848	June 24, 2020	0.200	Exceeded	2.3000	Exceeded	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 1 tap 4	MYR849	June 24, 2020	0.360	Exceeded	0.8100	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 1 tap 5	MYR850	June 24, 2020	0.140	Exceeded	2.0000	Exceeded	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 1 tap 6	MYR851	June 24, 2020	1.000	Exceeded	3.2000	Exceeded	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 2 tap 1	MYR856	June 24, 2020	0.340	Exceeded	2.1000	Exceeded	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 2 tap 2	MYR857	June 24, 2020	1.500	Exceeded	0.5500	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 2 tap 3	MYR858	June 24, 2020	0.440	Exceeded	0.2800	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 2 tap 4	MYR859	June 24, 2020	0.750	Exceeded	0.5700	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 2 tap 5	MYR860	June 24, 2020	1.100	Exceeded	1.8000	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 2 tap 6	MYR861	June 24, 2020	0.140	Exceeded	1.3000	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 3 tap 1	MYR862	June 24, 2020	0.580	Exceeded	0.8400	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 3 tap 2	MYR863	June 24, 2020	1.200	Exceeded	0.4300	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 3 tap 3	MYR864	June 24, 2020	0.650	Exceeded	0.1800	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 3 tap 4	MYR865	June 24, 2020	3.400	Exceeded	0.6700	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 3 tap 5	MYR866	June 24, 2020	3.500	Exceeded	0.4700	Passed	Laboratory or Hand washing only
John Martin Junior High School	Science Lab 3 tap 6	MYR867	June 24, 2020	3.900	Exceeded	1.6000	Passed	Laboratory or Hand washing only
John Martin Junior High School	Lab sink in science Lab tap 3	MYR868	June 24, 2020	3.400	Exceeded	0.9100	Passed	Out-of-Service
John Martin Junior High School	Handwashing sink in science Lab	MYR869	June 24, 2020	0.039	Exceeded	0.5800	Passed	Out-of-Service
John Martin Junior High School	Science Lab 1 tap 2	NAI288	June 29, 2020	0.380	Exceeded	1.2000	Passed	Laboratory or Hand washing only
John Martin Junior High School	Fountain by Room 213	WHX402	July 6, 2023	-	Passed	0.0025	Passed	
John Martin Junior High School	Fountain by caretaker supplies Room	WHU635	June 5, 2023	-	Passed	0.0005	Passed	
John Martin Junior High School	Breakfast Room tap	WHU623	June 5, 2023	0.000	Passed	0.0028	Passed	
John Martin Junior High School	Family Studies hand washing sink tap	WHX566	July 6, 2023	0.001	Passed	0.0520	Passed	
John Martin Junior High School	Family Studies Room tap 1	WHX567	July 6, 2023	-	Passed	0.0160	Passed	
John Martin Junior High School	Family Studies Room tap 2	WHX568	July 6, 2023	0.001	Passed	0.0360	Passed	
John Martin Junior High School	Family Studies Room tap 3	WHX569	July 6, 2023	-	Passed	0.0220	Passed	
John Martin Junior High School	Family Studies Room tap 4	WHX570	July 6, 2023	-	Passed	0.0250	Passed	
John Martin Junior High School	Family Studies Room tap 5	WHX602	July 6, 2023	-	Passed	0.0240	Passed	
John Martin Junior High School	Games Room tap	WHX565	July 6, 2023	0.001	Passed	0.1230	Passed	
John Martin Junior High School	Fountain by Room 203	WHU624	June 5, 2023	-	Passed	0.0009	Passed	
John W. MacLeod Elementary	Wash Room 9 tap	MNX928	May 1, 2020	-	Passed	0.0079	Passed	
John W. MacLeod Elementary	Wash Room 8 tap	MNX929	May 1, 2020	0.004	Passed	0.0630	Passed	
John W. MacLeod Elementary	Wash Room 22 tap 1	MNY246	May 1, 2020	0.002	Passed	0.2200	Passed	
John W. MacLeod Elementary	Wash Room 22 tap 2	MNY247	May 1, 2020	0.001	Passed	0.0980	Passed	
John W. MacLeod Elementary	Wash Room 22 tap 3	MNY248	May 1, 2020	0.004	Passed	0.2700	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
John W. MacLeod Elementary	Boys Wash Room 27 tap 1	MNY251	May 1, 2020	0.001	Passed	0.1100	Passed	
John W. MacLeod Elementary	Boys Wash Room 27 tap 2	MNY252	May 1, 2020	-	Passed	0.0950	Passed	
John W. MacLeod Elementary	Boys Wash Room 27 tap 3	MNY253	May 1, 2020	-	Passed	0.0670	Passed	
John W. MacLeod Elementary	Boys Wash Room 27 tap 4	MNY254	May 1, 2020	-	Passed	0.0680	Passed	
John W. MacLeod Elementary	Girls Wash Room 29 tap 1	MNY255	May 1, 2020	0.002	Passed	0.0290	Passed	
John W. MacLeod Elementary	Girls Wash Room 29 tap 2	MNY256	May 1, 2020	0.001	Passed	0.0230	Passed	
John W. MacLeod Elementary	Girls Wash Room 29 tap 3	MNY257	May 1, 2020	-	Passed	0.0150	Passed	
John W. MacLeod Elementary	Girls Wash Room 29 tap 4	MNY258	May 1, 2020	0.001	Passed	0.0190	Passed	
John W. MacLeod Elementary	Art Class Room 32 tap	MNY259	May 1, 2020	0.002	Passed	0.1200	Passed	
John W. MacLeod Elementary	Room 38 tap	MNY260	May 1, 2020	0.001	Passed	0.1100	Passed	
John W. MacLeod Elementary	Janitors Closet Room 4 tap 1	MNY261	May 1, 2020	0.001	Passed	0.1100	Passed	
John W. MacLeod Elementary	Janitors Closet Room 4 tap 2	MNY262	May 1, 2020	0.001	Passed	0.1200	Passed	
John W. MacLeod Elementary	Class Room 34 tap	MSP473	May 27, 2020	0.001	Passed	0.0170	Passed	
John W. MacLeod Elementary	Staff Room 10 tap	VPX395	April 21, 2023	0.001	Passed	0.0560	Passed	
John W. MacLeod Elementary	Fountain by Room 3	VPX396	April 21, 2023	-	Passed	-	Passed	
John W. MacLeod Elementary	Fountain by Room 18	VPX397	April 21, 2023	-	Passed	0.0670	Passed	
John W. MacLeod Elementary	Fountain by Room 22	VPX398	April 21, 2023	-	Passed	0.0007	Passed	
John W. MacLeod Elementary	Room 13 tap	VPX399	April 21, 2023	-	Passed	0.0088	Passed	Tap remediated
John W. MacLeod Elementary	Fountain by Room 35	VPX400	April 21, 2023	-	Passed	-	Passed	
John W. MacLeod Elementary	Wash Room 22 tap 4	VPX401	April 21, 2023	0.001	Passed	0.1100	Passed	Tap remediated
Joseph Giles Elementary	Boys Wash Room tap 1 by Room 11	MVV982	June 11, 2020	0.004	Passed	0.1400	Passed	
Joseph Giles Elementary	Boys Wash Room tap 2 by Room 11	MVV983	June 11, 2020	0.004	Passed	0.1300	Passed	
Joseph Giles Elementary	Boys Wash Room tap 3 by Room 11	MVV984	June 11, 2020	0.002	Passed	0.1800	Passed	
Joseph Giles Elementary	Class Room 3 tap	MVV985	June 11, 2020	0.004	Passed	0.1100	Passed	
Joseph Giles Elementary	Class Room 3 Wash Room tap	MVV986	June 11, 2020	0.001	Passed	0.0360	Passed	
Joseph Giles Elementary	Fountain by Teachers Room	XDF339	September 27, 2023	-	Passed	0.0310	Passed	
Joseph Giles Elementary	Teacher Lounge Wash Room tap	MVV988	June 11, 2020	0.001	Passed	0.0260	Passed	
Joseph Giles Elementary	Teachers Lounge tap	XDF340	September 27, 2023	-	Passed	0.0059	Passed	
Joseph Giles Elementary	Janitors Closet tap by Girls Wash Room	MVV990	June 11, 2020	-	Passed	0.0380	Passed	
Joseph Giles Elementary	Girls Wash Room tap 1 by Teachers Lounge	MVV991	June 11, 2020	0.003	Passed	0.1800	Passed	
Joseph Giles Elementary	Girls Wash Room tap 2 by Teachers Lounge	MVV992	June 11, 2020	0.003	Passed	0.1800	Passed	
Joseph Giles Elementary	Girls Wash Room tap 3 by Teachers Lounge	MVV993	June 11, 2020	0.003	Passed	0.1500	Passed	
Joseph Giles Elementary	Class Room 19 tap	XDF344	September 27, 2023	0.002	Passed	0.1300	Passed	Tap remediated
Joseph Giles Elementary	Wash Room tap in Boys Locker Room	XDF342	September 27, 2023	-	Passed	0.0290	Passed	Tap remediated
Joseph Giles Elementary	Janitors Closet tap in Boys Locker Room	MVV996	June 11, 2020	0.004	Passed	0.1100	Passed	
Joseph Giles Elementary	Wash Room tap in Girls Locker Room	MVV998	June 11, 2020	0.002	Passed	0.2500	Passed	
Joseph Giles Elementary	Fountain by Office	XDF343	September 27, 2023	-	Passed	0.0360	Passed	
Joseph Giles Elementary	Fountain by Boys Locker Room	XDF341	September 27, 2023	-	Passed	0.3400	Passed	
Joseph Howe Elementary	2nd Floor Boys Wash Room tap 1	MTP738	May 29, 2020	0.001	Passed	0.0640	Passed	
Joseph Howe Elementary	2nd Floor Boys Wash Room tap 2	MTP739	May 29, 2020	0.001	Passed	0.0380	Passed	
Joseph Howe Elementary	2nd Floor Boys Wash Room tap 3	MTP740	May 29, 2020	-	Passed	0.0280	Passed	
Joseph Howe Elementary	2nd Floor Janitors Closet tap	MTP741	May 29, 2020	-	Passed	0.0088	Passed	
Joseph Howe Elementary	2nd Floor Girls Wash Room tap 1	MTP743	May 29, 2020	-	Passed	0.0100	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Joseph Howe Elementary	2nd Floor Girls Wash Room tap 2	MTP744	May 29, 2020	-	Passed	0.0140	Passed	
Joseph Howe Elementary	2nd Floor Girls Wash Room tap 3	MTP745	May 29, 2020	-	Passed	0.0130	Passed	
Joseph Howe Elementary	2nd Floor Girls Wash Room tap 4	MTP746	May 29, 2020	-	Passed	0.0190	Passed	
Joseph Howe Elementary	2nd Floor Girls Wash Room tap 5	MTP747	May 29, 2020	-	Passed	0.0210	Passed	
Joseph Howe Elementary	2nd Floor Staff Room Wash Room 1 tap	MTP757	May 29, 2020	-	Passed	0.0031	Passed	
Joseph Howe Elementary	2nd Floor Staff Room Wash Room 2 tap	MTP758	May 29, 2020	-	Passed	0.0039	Passed	
Joseph Howe Elementary	1st Floor Boys Wash Room tap 1	MTP760	May 29, 2020	-	Passed	0.0110	Passed	
Joseph Howe Elementary	1st Floor Boys Wash Room tap 2	MTP761	May 29, 2020	-	Passed	0.0180	Passed	
Joseph Howe Elementary	1st Floor Boys Wash Room tap 3	MTP762	May 29, 2020	0.001	Passed	0.0430	Passed	
Joseph Howe Elementary	1st Floor Boys Wash Room tap 4	MTP763	May 29, 2020	0.001	Passed	0.0600	Passed	
Joseph Howe Elementary	1st Floor Janitors Closet tap	MTP764	May 29, 2020	0.009	Exceeded	0.5600	Passed	Hand washing only
Joseph Howe Elementary	1st Floor Girls Wash Room tap 1	MTP766	May 29, 2020	-	Passed	0.0130	Passed	
Joseph Howe Elementary	1st Floor Girls Wash Room tap 2	MTP770	May 29, 2020	0.004	Passed	0.1800	Passed	
Joseph Howe Elementary	1st Floor Girls Wash Room tap 3	MTP771	May 29, 2020	-	Passed	0.0140	Passed	
Joseph Howe Elementary	1st Floor Girls Wash Room tap 4	MTP772	May 29, 2020	0.001	Passed	0.0690	Passed	
Joseph Howe Elementary	Gender Neutral Wash Room tap	MTP774	May 29, 2020	-	Passed	0.0480	Passed	
Joseph Howe Elementary	Boys Wash Room tap 2 Basement by Gym	MTP781	May 29, 2020	0.003	Passed	0.0910	Passed	
Joseph Howe Elementary	Basement Janitors Closet tap	MTP783	May 29, 2020	-	Passed	0.0490	Passed	
Joseph Howe Elementary	Caretakers Room tap by Room 138	MTP784	May 29, 2020	0.002	Passed	0.0510	Passed	
Joseph Howe Elementary	Girls Wash Room 138 tap 1	MTP785	May 29, 2020	-	Passed	0.0190	Passed	
Joseph Howe Elementary	Girls Wash Room 138 tap 2	MTP786	May 29, 2020	0.001	Passed	0.0260	Passed	
Joseph Howe Elementary	Gender Neutral Gym Wash Room tap 1	MTP788	May 29, 2020	0.002	Passed	0.0770	Passed	
Joseph Howe Elementary	Gender Neutral Gym Wash Room tap 2	MTP789	May 29, 2020	-	Passed	0.0140	Passed	
Joseph Howe Elementary	Gender Neutral Gym Wash Room tap 3	MTP790	May 29, 2020	-	Passed	0.0120	Passed	
Joseph Howe Elementary	Gender Neutral Gym Wash Room tap 4	MTP793	May 29, 2020	-	Passed	0.0110	Passed	
Joseph Howe Elementary	Boys Wash Room tap 1 Basement by Gym	VVK879	May 16, 2023	-	Passed	0.0700	Passed	Tap remediated
Joseph Howe Elementary	Basement Fountain by Gym	VVK880	May 16, 2023	-	Passed	0.0033	Passed	
Joseph Howe Elementary	1st Floor Fountain by Janitors Closet	VVK881	May 16, 2023	-	Passed	0.0037	Passed	
Joseph Howe Elementary	1st Floor Class Room Wash Room tap	VVK882	May 16, 2023	-	Passed	0.0320	Passed	Tap remediated
Joseph Howe Elementary	Basement Breakfast Club Room tap	VVK883	May 29, 2020	-	Passed	0.0670	Passed	
Joseph Howe Elementary	Staff Room Kitchen tap	VVK884	May 16, 2023	-	Passed	0.0045	Passed	
Joseph Howe Elementary	2nd Floor Fountain by Girls Wash Room	VVK885	May 16, 2023	-	Passed	0.0150	Passed	
Joseph Howe Elementary	Pre Primary 2nd Floor Fountain	VVK886	May 16, 2023	-	Passed	0.0011	Passed	
Joseph Howe Elementary	2nd Floor Pre primary Laundry/Wash Room tap 1	VVK887	May 16, 2023	-	Passed	0.0100	Passed	
Joseph Howe Elementary	2nd Floor Pre primary Laundry/Wash Room tap 2	VVK888	May 16, 2023	-	Passed	0.0870	Passed	
Joseph Howe Elementary	2nd Floor Pre Primary Laundry/Wash Room tap 3	VVK889	May 16, 2023	-	Passed	0.0780	Passed	
Kingswood Elementary	Janitors Closet 233 tap	MUU155	June 5, 2020	-	Passed	0.0380	Passed	
Kingswood Elementary	Gender Neutral Wash Room 232 tap	MUU160	June 5, 2020	0.001	Passed	0.0600	Passed	
Kingswood Elementary	Boys Wash Room tap 1 by Room 225	MUU161	June 5, 2020	0.002	Passed	0.0500	Passed	
Kingswood Elementary	Boys Wash Room tap 2 by Room 225	MUU162	June 5, 2020	0.003	Passed	0.0910	Passed	
Kingswood Elementary	Girls Wash Room tap 1 by Room 224	MUU163	June 5, 2020	0.001	Passed	0.1900	Passed	
Kingswood Elementary	Girls Wash Room tap 2 by Room 224	MUU164	June 5, 2020	0.002	Passed	0.1900	Passed	
Kingswood Elementary	Gender Neutral Wash Room 224 tap	MUU165	June 5, 2020	-	Passed	0.0077	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Kingswood Elementary	Laundry Tub Room 240 tap	MUU167	June 5, 2020	-	Passed	0.0380	Passed	
Kingswood Elementary	Gender Neutral Wash Room 20 tap	MUU168	June 5, 2020	0.004	Passed	0.1300	Passed	
Kingswood Elementary	Class Room 210 tap	MUU169	June 5, 2020	-	Passed	0.0350	Passed	
Kingswood Elementary	Class Room 112 tap	MUU170	June 5, 2020	0.001	Passed	0.5000	Passed	
Kingswood Elementary	Class Room 113 tap	MUU171	June 5, 2020	-	Passed	0.3900	Passed	
Kingswood Elementary	Class Room 117 tap	MUU173	June 5, 2020	-	Passed	0.3900	Passed	
Kingswood Elementary	Class Room 118 tap	MUU174	June 5, 2020	-	Passed	0.5000	Passed	
Kingswood Elementary	Class Room 120 tap	MUU175	June 5, 2020	-	Passed	0.4700	Passed	
Kingswood Elementary	Class Room 119 tap	MUU176	June 5, 2020	-	Passed	0.3600	Passed	
Kingswood Elementary	Class Room 116 tap	MUU177	June 5, 2020	0.002	Passed	0.6800	Passed	
Kingswood Elementary	Class Room 115 tap 1	MUU178	June 5, 2020	-	Passed	0.0680	Passed	
Kingswood Elementary	Class Room 115 tap 2	MUU179	June 5, 2020	-	Passed	0.5600	Passed	
Kingswood Elementary	Gender Neutral Wash Room 114 tap	MUU180	June 5, 2020	0.002	Passed	0.0600	Passed	
Kingswood Elementary	Gender Neutral Wash Room 165 tap	MUU185	June 5, 2020	0.001	Passed	0.0660	Passed	
Kingswood Elementary	Class Room 167 tap	MUU187	June 5, 2020	-	Passed	0.0300	Passed	
Kingswood Elementary	Class Room 110 tap	MUU188	June 5, 2020	-	Passed	0.0410	Passed	
Kingswood Elementary	Main Office Staff Wash Room 180 tap	MUU189	June 5, 2020	-	Passed	0.0380	Passed	
Kingswood Elementary	Library Kitchen 107 tap	MUU190	June 5, 2020	0.001	Passed	0.1100	Passed	
Kingswood Elementary	Boys Wash Room tap 1 by Room 106	MUU191	June 5, 2020	0.003	Passed	0.3100	Passed	
Kingswood Elementary	Girls Wash Room tap 1 by Room 183	MUU193	June 5, 2020	0.001	Passed	0.0340	Passed	
Kingswood Elementary	Girls Wash Room tap 2 by Room 183	MUU194	June 5, 2020	0.003	Passed	0.1100	Passed	
Kingswood Elementary	Class Room 102 tap	MUU195	June 5, 2020	-	Passed	0.2500	Passed	
Kingswood Elementary	Gender Neutral Wash Room 187 tap	MUU196	June 5, 2020	-	Passed	0.0870	Passed	
Kingswood Elementary	Gender Neutral Wash Room 124 tap	MUU197	June 5, 2020	0.001	Passed	0.0360	Passed	
Kingswood Elementary	Class Room 101 tap	MUU198	June 5, 2020	-	Passed	0.0430	Passed	
Kingswood Elementary	Class Room 103 tap	MUU199	June 5, 2020	-	Passed	0.2400	Passed	
Kingswood Elementary	Gender Neutral Wash Room 121 tap	MUU200	June 5, 2020	-	Passed	0.0390	Passed	
Kingswood Elementary	Class Room 104 tap	MUU202	June 5, 2020	-	Passed	0.0590	Passed	
Kingswood Elementary	Music Room 105 tap	MUU204	June 5, 2020	0.004	Passed	0.0640	Passed	
Kingswood Elementary	Laundry Tub 138 tap	MUU205	June 5, 2020	0.001	Passed	0.0980	Passed	
Kingswood Elementary	Janitors Closet 142 tap	MUU214	June 5, 2020	-	Passed	0.0310	Passed	
Kingswood Elementary	Boys Change Room 144 tap	MUU216	June 5, 2020	0.001	Passed	0.1600	Passed	
Kingswood Elementary	Girls Change Room 150 tap	MUU217	June 5, 2020	0.002	Passed	0.0740	Passed	
Kingswood Elementary	Gym Office Wash Room 146 tap	MUU218	June 5, 2020	0.001	Passed	0.0850	Passed	
Kingswood Elementary	Cafeteria/Kitchen Handwashing tap	VXQ494	May 25, 2023	0.001	Passed	0.3200	Passed	
Kingswood Elementary	Cafeteria/Kitchen Triple Compartment Sink tap 1	VXQ495	May 25, 2023	-	Passed	0.0800	Passed	
Kingswood Elementary	Cafeteria/Kitchen Triple Compartment Sink tap 2	VXQ496	May 25, 2023	-	Passed	0.0570	Passed	
Kingswood Elementary	Cafeteria/Kitchen Single Compartment Sink tap	VXQ497	May 25, 2023	0.001	Passed	0.0970	Passed	
Kingswood Elementary	Cafeteria/Stage Kitchen tap 1	VXQ498	May 25, 2023	-	Passed	0.0320	Passed	
Kingswood Elementary	Cafeteria/Stage Kitchen tap 2	VXQ499	May 25, 2023	-	Passed	0.0450	Passed	
Kingswood Elementary	Boys Wash Room tap 2 by Room 106	VXQ500	May 25, 2023	-	Passed	0.0680	Passed	Tap remediated
Kingswood Elementary	Fountain by Room 104	VXQ501	May 25, 2023	-	Passed	0.0540	Passed	
Kingswood Elementary	Boys Wash Room tap 1 by Room 114	VXQ502	May 25, 2023	-	Passed	0.0290	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Kingswood Elementary	Boys Wash Room tap 2 by Room 114	VXQ503	May 25, 2023	-	Passed	0.0940	Passed	Tap remediated
Kingswood Elementary	Girls Wash Room tap 1 by Room 167	VXQ504	May 25, 2023	-	Passed	0.0290	Passed	Tap remediated
Kingswood Elementary	Girls Wash Room tap 2 by Room 167	VXQ505	May 25, 2023	-	Passed	0.0280	Passed	Tap remediated
Kingswood Elementary	Fountain by Room 184	VXQ506	May 25, 2023	-	Passed	0.1600	Passed	
Kingswood Elementary	Gender Neutral Wash Room 166 tap	VXQ507	May 25, 2023	0.002	Passed	0.2300	Passed	Tap remediated
Kingswood Elementary	Fountain in Gym by Room 144	VXQ508	May 25, 2023	-	Passed	0.2400	Passed	
Kingswood Elementary	Fountain by Room 204	VXQ509	May 25, 2023	-	Passed	0.0650	Passed	
Kingswood Elementary	Boys Wash Room tap 1 by Room 232	VXQ510	May 25, 2023	-	Passed	0.0220	Passed	Tap remediated
Kingswood Elementary	Boys Wash Room tap 2 by Room 232	VXQ511	May 25, 2023	-	Passed	0.1200	Passed	Tap remediated
Kingswood Elementary	Girls Wash Room tap 1 by Room 233	VXQ512	May 25, 2023	-	Passed	0.1200	Passed	Tap remediated
Kingswood Elementary	Girls Wash Room tap 2 by Room 233	VXQ513	May 25, 2023	-	Passed	0.0820	Passed	Tap remediated
Kingswood Elementary	Fountain by Room 242	VXQ514	May 25, 2023	-	Passed	0.1000	Passed	
Kingswood Elementary	Gender Neutral Wash Room 186 tap	VXQ515	May 25, 2023	-	Passed	0.0940	Passed	Tap remediated
LeMarchant-St. Thomas Elementary	Class Room tap Room 306	MUW210	June 8, 2020	-	Passed	0.4600	Passed	
LeMarchant-St. Thomas Elementary	Class Room tap Room 308	MUW211	June 8, 2020	0.001	Passed	0.0820	Passed	
LeMarchant-St. Thomas Elementary	Assist Care Wash Room tap	MUW212	June 8, 2020	-	Passed	0.1800	Passed	
LeMarchant-St. Thomas Elementary	Class Room tap Room 314	MUW213	June 8, 2020	0.001	Passed	0.1500	Passed	
LeMarchant-St. Thomas Elementary	Class Room tap Room 316	MUW214	June 8, 2020	0.001	Passed	0.1600	Passed	
LeMarchant-St. Thomas Elementary	Class Room tap Room 318	MUW215	June 8, 2020	-	Passed	0.2800	Passed	
LeMarchant-St. Thomas Elementary	Class Room tap Room 322	MUW216	June 8, 2020	0.001	Passed	0.0700	Passed	
LeMarchant-St. Thomas Elementary	Class Room tap Room 326	MUW217	June 8, 2020	0.002	Passed	0.1800	Passed	
LeMarchant-St. Thomas Elementary	Class Room tap Room 325	MUW218	June 8, 2020	-	Passed	0.2100	Passed	
LeMarchant-St. Thomas Elementary	Class Room tap Room 323	MUW219	June 8, 2020	-	Passed	0.2300	Passed	
LeMarchant-St. Thomas Elementary	3rd Floor Wash Room sink tap 1	MUW220	June 8, 2020	0.002	Passed	0.6300	Passed	
LeMarchant-St. Thomas Elementary	3rd Floor Wash Room sink tap 2	MUW221	June 8, 2020	0.005	Passed	0.6000	Passed	
LeMarchant-St. Thomas Elementary	3rd Floor Wash Room sink tap 3	NAM731	June 30, 2020	0.001	Passed	0.5000	Passed	
LeMarchant-St. Thomas Elementary	3rd Floor Wash Room sink tap 4	MUW223	June 8, 2020	0.002	Passed	0.6200	Passed	
LeMarchant-St. Thomas Elementary	Janitors Closet tap by Room 301	MUW226	June 8, 2020	-	Passed	0.4700	Passed	
LeMarchant-St. Thomas Elementary	Class Room tap Room 301	MUW227	June 8, 2020	-	Passed	0.1000	Passed	
LeMarchant-St. Thomas Elementary	Class Room 302 tap	MUW228	June 8, 2020	-	Passed	0.0380	Passed	
LeMarchant-St. Thomas Elementary	Class Room 206 tap 1	MUW229	June 8, 2020	-	Passed	0.2300	Passed	
LeMarchant-St. Thomas Elementary	Class Room 206 tap 2	MUW230	June 8, 2020	0.001	Passed	0.5600	Passed	
LeMarchant-St. Thomas Elementary	Class Room 216 tap	MUW233	June 8, 2020	-	Passed	0.3400	Passed	
LeMarchant-St. Thomas Elementary	Class Room 218 tap	NAM730	June 30, 2020	-	Passed	0.0820	Passed	
LeMarchant-St. Thomas Elementary	Class Room 220 tap	MUW237	June 8, 2020	-	Passed	0.3900	Passed	
LeMarchant-St. Thomas Elementary	Class Room 222 tap	MUW238	June 8, 2020	-	Passed	0.5200	Passed	
LeMarchant-St. Thomas Elementary	Class Room 226 tap	MUW239	June 8, 2020	0.004	Passed	0.2700	Passed	
LeMarchant-St. Thomas Elementary	Class Room 225 tap	MUW240	June 8, 2020	-	Passed	0.2700	Passed	
LeMarchant-St. Thomas Elementary	Class Room 221 tap	MUW241	June 8, 2020	-	Passed	0.1600	Passed	
LeMarchant-St. Thomas Elementary	Class Room 213 tap	MUW242	June 8, 2020	-	Passed	0.3000	Passed	
LeMarchant-St. Thomas Elementary	2nd Floor Wash Room tap 1	NAM729	June 30, 2020	-	Passed	0.4200	Passed	
LeMarchant-St. Thomas Elementary	2nd Floor Wash Room tap 2	MUW244	June 8, 2020	0.002	Passed	0.7000	Passed	
LeMarchant-St. Thomas Elementary	2nd Floor Wash Room tap 3	MUW245	June 8, 2020	0.002	Passed	0.6600	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
LeMarchant-St. Thomas Elementary	2nd Floor Wash Room tap 4	MUW246	June 8, 2020	0.001	Passed	0.6300	Passed	
LeMarchant-St. Thomas Elementary	Janitors Closet 209 tap	MUW247	June 8, 2020	-	Passed	0.3400	Passed	
LeMarchant-St. Thomas Elementary	Class Room 202 tap	MUW248	June 8, 2020	-	Passed	0.1900	Passed	
LeMarchant-St. Thomas Elementary	Class Room 204 tap	MUW249	June 8, 2020	-	Passed	0.6800	Passed	
LeMarchant-St. Thomas Elementary	Main Office 102 Wash Room tap	MUW250	June 8, 2020	-	Passed	0.4900	Passed	
LeMarchant-St. Thomas Elementary	Room 114 Kitchen sink tap	MUW254	June 8, 2020	0.001	Passed	0.9500	Passed	
LeMarchant-St. Thomas Elementary	Gender Neutral Wash Room 116 tap	MUW255	June 8, 2020	-	Passed	0.2500	Passed	
LeMarchant-St. Thomas Elementary	Room 116 Kitchen sink tap	MUW256	June 8, 2020	-	Passed	0.2200	Passed	
LeMarchant-St. Thomas Elementary	Class Room 122 Gender Neutral Wash Room tap	MUW257	June 8, 2020	0.001	Passed	0.4900	Passed	
LeMarchant-St. Thomas Elementary	Class Room 122 tap	MUW258	June 8, 2020	0.001	Passed	0.3900	Passed	
LeMarchant-St. Thomas Elementary	Class Room 124 tap	MUW259	June 8, 2020	-	Passed	0.6500	Passed	
LeMarchant-St. Thomas Elementary	Class Room 124 Gender Neutral Wash Room tap	MUW260	June 8, 2020	-	Passed	0.3500	Passed	
LeMarchant-St. Thomas Elementary	Class Room 126 Gender Neutral Wash Room tap	MUW261	June 8, 2020	-	Passed	0.4800	Passed	
LeMarchant-St. Thomas Elementary	Class Room 126 tap	MUW262	June 8, 2020	-	Passed	0.3600	Passed	
LeMarchant-St. Thomas Elementary	Class Room 125 tap	MUW263	June 8, 2020	-	Passed	0.2700	Passed	
LeMarchant-St. Thomas Elementary	Class Room 125 Gender Neutral Wash Room tap	MUW264	June 8, 2020	-	Passed	0.4700	Passed	
LeMarchant-St. Thomas Elementary	Janitors Closet 121 tap	MUW265	June 8, 2020	-	Passed	0.2000	Passed	
LeMarchant-St. Thomas Elementary	Gym Gender Neutral Wash Room 119B tap	MUW266	June 8, 2020	-	Passed	0.1600	Passed	
LeMarchant-St. Thomas Elementary	Gym Staff Wash Room tap	MUW267	June 8, 2020	-	Passed	1.2000	Passed	
LeMarchant-St. Thomas Elementary	Main Floor Gender Neutral Wash Room tap 1	MUW268	June 8, 2020	0.003	Passed	0.6000	Passed	
LeMarchant-St. Thomas Elementary	Main Floor Gender Neutral Wash Room tap 2	MUW269	June 8, 2020	0.001	Passed	0.6100	Passed	
LeMarchant-St. Thomas Elementary	Main Floor Gender Neutral Wash Room tap 4	MUW271	June 8, 2020	0.001	Passed	0.6700	Passed	
LeMarchant-St. Thomas Elementary	Stage tap 1	MUW272	June 8, 2020	-	Passed	0.1500	Passed	
LeMarchant-St. Thomas Elementary	Stage tap 2	MUW273	June 8, 2020	-	Passed	0.0560	Passed	
LeMarchant-St. Thomas Elementary	Music Room tap	MUW274	June 8, 2020	-	Passed	1.1000	Passed	
LeMarchant-St. Thomas Elementary	Room 109 Laundry tub tap	MUW275	June 8, 2020	-	Passed	0.4200	Passed	
LeMarchant-St. Thomas Elementary	Class Room 129 tap	MUW276	June 8, 2020	-	Passed	0.1200	Passed	
LeMarchant-St. Thomas Elementary	Cafeteria/Kitchen Janitors Closet tap	MUW279	June 8, 2020	0.001	Passed	0.6900	Passed	
LeMarchant-St. Thomas Elementary	Laundry tub tap in Boiler Room (outside)	MUW281	June 8, 2020	0.001	Passed	0.6600	Passed	
LeMarchant-St. Thomas Elementary	Main Floor Gender Neutral Wash Room tap 3	NAM727	June 30, 2020	-	Passed	0.4600	Passed	
LeMarchant-St. Thomas Elementary	Gender Neutral Wash Room 114 tap	NAM728	June 30, 2020	0.001	Passed	0.0940	Passed	
LeMarchant-St. Thomas Elementary	Cafeteria/Kitchen double compartment tap	VUA194	May 9, 2023	-	Passed	0.0300	Passed	
LeMarchant-St. Thomas Elementary	Cafeteria/Kitchen hand washing tap	VUA195	May 9, 2023	-	Passed	0.5300	Passed	
LeMarchant-St. Thomas Elementary	Cafeteria/Kitchen single compartment tap	VUA196	May 9, 2023	-	Passed	0.0330	Passed	
LeMarchant-St. Thomas Elementary	Fountain 1 by Room 110	VUA197	May 9, 2023	-	Passed	0.0340	Passed	
LeMarchant-St. Thomas Elementary	Fountain 2 by Room 114	VUA198	May 9, 2023	-	Passed	0.0300	Passed	
LeMarchant-St. Thomas Elementary	Fountain 1 by Room 206	VUA199	May 9, 2023	-	Passed	0.0570	Passed	
LeMarchant-St. Thomas Elementary	Fountain 2 by Room 206	VUA200	May 9, 2023	-	Passed	0.0640	Passed	
LeMarchant-St. Thomas Elementary	Staff Room 216	VUA201	May 9, 2023	-	Passed	0.1000	Passed	
LeMarchant-St. Thomas Elementary	Fountain 1 by Room 218	VUA202	May 9, 2023	-	Passed	0.0320	Passed	
LeMarchant-St. Thomas Elementary	Fountain 2 by Room 218	VUA203	May 9, 2023	-	Passed	0.0270	Passed	
LeMarchant-St. Thomas Elementary	Fountain by 3rd Floor Wash Rooms	VUA204	May 9, 2023	-	Passed	0.0210	Passed	
LeMarchant-St. Thomas Elementary	Fountain by 3rd Floor Janitors Closet	VUA205	June 8, 2020	-	Passed	0.0230	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Leslie Thomas Junior High School	3rd Floor Boys Wash Room tap 1	MOP577	May 5, 2020	0.003	Passed	0.1100	Passed	
Leslie Thomas Junior High School	3rd Floor Boys Wash Room tap 2	MOP578	May 5, 2020	0.003	Passed	0.0930	Passed	
Leslie Thomas Junior High School	3rd Floor Girls Wash Room tap 1	MOP579	May 5, 2020	0.004	Passed	0.0900	Passed	
Leslie Thomas Junior High School	3rd Floor Girls Wash Room tap 2	MOP580	May 5, 2020	0.002	Passed	0.0810	Passed	
Leslie Thomas Junior High School	Class Room 308 Wash Room 1 tap	MOP584	May 5, 2020	0.003	Passed	0.0780	Passed	
Leslie Thomas Junior High School	Class Room 308 Wash Room 2 tap	MOP585	May 5, 2020	0.002	Passed	0.0700	Passed	
Leslie Thomas Junior High School	Janitors Closet 3D tap	MOP586	May 5, 2020	0.002	Passed	0.0670	Passed	
Leslie Thomas Junior High School	2nd Floor Girls Wash Room tap 2	MOP590	May 5, 2020	0.002	Passed	0.0860	Passed	
Leslie Thomas Junior High School	Janitors Closet 2A tap	MOP592	May 5, 2020	0.001	Passed	0.0500	Passed	
Leslie Thomas Junior High School	Class Room 113 tap	MOP595	May 5, 2020	0.002	Passed	0.2600	Passed	
Leslie Thomas Junior High School	Class Room 111 tap 1	MOP596	May 5, 2020	0.001	Passed	0.3800	Passed	
Leslie Thomas Junior High School	Class Room 110 tap	MOP598	May 5, 2020	0.002	Passed	0.8000	Passed	
Leslie Thomas Junior High School	Class Room 109 tap	MOP600	May 5, 2020	0.002	Passed	0.0760	Passed	
Leslie Thomas Junior High School	Janitors Closet 1B tap	MOP605	May 5, 2020	0.003	Passed	0.0730	Passed	
Leslie Thomas Junior High School	1st Floor Girls Wash Room tap 2	MOP608	May 5, 2020	0.001	Passed	0.0760	Passed	
Leslie Thomas Junior High School	1st Floor Girls Wash Room tap 3	MOP609	May 5, 2020	0.002	Passed	0.0820	Passed	
Leslie Thomas Junior High School	1st Floor Boys Wash Room tap 1	SBZ983	March 14, 2022	0.003	Passed	0.0780	Passed	
Leslie Thomas Junior High School	1st Floor Boys Wash Room tap 2	SBZ984	March 14, 2022	0.002	Passed	0.0630	Passed	
Leslie Thomas Junior High School	1st Floor Girls Wash Room tap 1	SBZ985	March 14, 2022	-	Passed	0.0550	Passed	
Leslie Thomas Junior High School	Class Room 106 tap	SBZ986	March 14, 2022	0.004	Passed	0.1900	Passed	
Leslie Thomas Junior High School	Class Room 107 tap	SBZ987	March 14, 2022	0.003	Passed	0.1000	Passed	
Leslie Thomas Junior High School	Class Room 108 tap							Out-of-Service
Leslie Thomas Junior High School	Class Room 111 tap 2	SBZ989	March 12, 2022	0.001	Passed	0.0990	Passed	
Leslie Thomas Junior High School	Main Office Wash Room tap	SBZ990	March 14, 2022	-	Passed	0.0230	Passed	
Leslie Thomas Junior High School	2nd Floor Girls Wash Room tap 1	SBZ994	March 14, 2022	-	Passed	0.0640	Passed	
Leslie Thomas Junior High School	2nd Floor Boys Wash Room tap 1	SBZ995	March 14, 2022	0.001	Passed	0.0550	Passed	
Leslie Thomas Junior High School	2nd Floor Boys Wash Room tap 2	SBZ996	March 14, 2022	0.001	Passed	0.0540	Passed	
Leslie Thomas Junior High School	Class Room 308 tap	SBZ997	March 14, 2022	0.001	Passed	0.0780	Passed	
Leslie Thomas Junior High School	3rd Floor Girls Wash Room tap 3	SBZ998	March 14, 2022	0.001	Passed	0.0560	Passed	
Leslie Thomas Junior High School	Fountain by Room 2A	WCN447	June 13, 2023	-	Passed	0.0600	Passed	
Leslie Thomas Junior High School	2nd Floor Café tap	WCN448	June 13, 2023	-	Passed	0.0640	Passed	
Leslie Thomas Junior High School	Fountain by Room 3D	WCN449	June 13, 2023	-	Passed	0.0620	Passed	
Leslie Thomas Junior High School	Fountain by Room 1B	WCN450	June 13, 2023	-	Passed	0.0680	Passed	
Lockview High School	Class Room A108 tap	NBQ671	July 8, 2020	0.007	Exceeded	1.8000	Passed	Hand washing only
Lockview High School	Class Room A112 tap 1	NBQ672	July 8, 2020	0.003	Passed	0.9500	Passed	
Lockview High School	Class Room A112 tap 2	NBQ673	July 8, 2020	0.013	Exceeded	0.0470	Passed	Hand washing only
Lockview High School	Staff Wash Room C105 tap	NBQ674	July 8, 2020	0.016	Exceeded	0.1000	Passed	Hand washing only
Lockview High School	Staff Wash Room C106 tap	NBQ675	July 8, 2020	0.005	Passed	0.0720	Passed	
Lockview High School	Staff Room tap by Room C106	WGS839	June 29, 2023	-	Passed	0.0700	Passed	
Lockview High School	Library Support Room C117 tap	WGS444	June 30, 2023	0.002	Passed	0.0460	Passed	Tap remediated
Lockview High School	Library Support Wash Room C117B tap	WGS840	June 29, 2023	-	Passed	0.0530	Passed	Tap remediated
Lockview High School	Male Wash Room tap 1 by section A	WGS451	June 30, 2023	0.006	Exceeded	0.1300	Passed	Hand washing only
Lockview High School	Male Wash Room tap 2 by section A	WGS452	June 30, 2023	0.009	Exceeded	0.1200	Passed	Hand washing only

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Lockview High School	Male Wash Room tap 3 by section A	WGS453	June 30, 2023	0.010	Exceeded	0.1400	Passed	Hand washing only
Lockview High School	Male Wash Room tap 4 by section A	WGS454	June 30, 2023	0.008	Exceeded	0.1200	Passed	Hand washing only
Lockview High School	Science Lab B101 tap 1	NBQ683	July 8, 2020	0.001	Passed	0.7100	Passed	
Lockview High School	Science Lab B101 tap 2	NBQ684	July 8, 2020	0.008	Exceeded	0.9200	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B101 tap 3	NBQ685	July 8, 2020	0.005	Exceeded	1.3000	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B101 tap 4	NBQ686	July 8, 2020	0.005	Passed	0.7600	Passed	
Lockview High School	Science Lab B101 tap 5	NBQ687	July 8, 2020	0.001	Passed	1.7000	Passed	
Lockview High School	Science Lab B101 tap 6	NBQ688	July 8, 2020	0.001	Passed	1.4000	Passed	
Lockview High School	Science Lab B101 tap 7	NBQ689	July 8, 2020	0.001	Passed	1.1000	Passed	
Lockview High School	Science Lab B101 tap 8	NBQ690	July 8, 2020	0.001	Passed	1.0000	Passed	
Lockview High School	Science Lab B101 tap 9	NBQ691	July 8, 2020	0.007	Exceeded	0.7400	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B101 tap 10	NBQ692	July 8, 2020	0.018	Exceeded	1.1000	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B101 tap 11	NBQ693	July 8, 2020	0.004	Passed	0.8900	Passed	
Lockview High School	Science Lab B101 tap 12	WGS834	June 29, 2023	-	Passed	0.2700	Passed	Laboratory or Hand washing only
Lockview High School	Science Lab B101 tap 13	NBQ695	July 8, 2020	0.004	Passed	1.2000	Passed	
Lockview High School	Science Lab B101 tap 14	NBQ696	July 8, 2020	0.002	Passed	1.6000	Passed	
Lockview High School	Science Lab B101 tap 15	NBQ697	July 8, 2020	0.007	Exceeded	0.4000	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B101 tap 16	NBQ698	July 8, 2020	0.004	Passed	0.9600	Passed	
Lockview High School	Science Lab B101 tap 17	NBQ699	July 8, 2020	0.011	Exceeded	0.8700	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B101 tap 18	NBQ700	July 8, 2020	0.081	Exceeded	0.9300	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 1	NBQ701	July 8, 2020	0.006	Exceeded	1.5000	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 2	NBQ702	July 8, 2020	0.005	Exceeded	0.7900	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 3	NBQ703	July 8, 2020	0.009	Exceeded	0.5800	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 4	NBQ704	July 8, 2020	0.004	Passed	1.6000	Passed	
Lockview High School	Science Lab B102 tap 5	NBQ705	July 8, 2020	0.006	Exceeded	0.7700	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 6	NBQ706	July 8, 2020	0.001	Passed	1.7000	Passed	
Lockview High School	Science Lab B102 tap 7	NBQ707	July 8, 2020	0.008	Exceeded	0.6500	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 8	NBQ708	July 8, 2020	0.014	Exceeded	0.6800	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 9	NBQ709	July 8, 2020	0.006	Exceeded	0.2700	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 10	NBQ710	July 8, 2020	0.009	Exceeded	1.3000	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 11	NBQ711	July 8, 2020	0.008	Exceeded	0.2000	Passed	Laboratory or hand washing only
Lockview High School	Science Lab B102 tap 12	NBQ712	July 8, 2020	0.002	Passed	1.2000	Passed	
Lockview High School	Science Lab B102 tap 13	NBQ713	July 8, 2020	0.004	Passed	0.8200	Passed	
Lockview High School	Science Lab B102 tap 14	NBQ714	July 8, 2020	0.003	Passed	1.8000	Passed	
Lockview High School	Science Lab B102 tap 15	NBQ715	July 8, 2020	0.003	Passed	0.5600	Passed	
Lockview High School	Science Lab B102 tap 16	NBQ716	July 8, 2020	0.002	Passed	1.6000	Passed	
Lockview High School	Science Lab B102 tap 17	NBQ717	July 8, 2020	0.001	Passed	0.6400	Passed	
Lockview High School	Science Lab B102 tap 18	NBQ718	July 8, 2020	0.005	Passed	1.6000	Passed	
Lockview High School	Integrated Science Lab Room B104 tap 1	NBQ719	July 8, 2020	0.400	Exceeded	0.4200	Passed	Laboratory or hand washing only
Lockview High School	Integrated Science Lab Room B104 tap 2	WGS835	June 29, 2023	-	Passed	0.1700	Passed	Tap remediated
Lockview High School	Integrated Science Lab Room B104 tap 3	NBQ721	July 8, 2020	0.009	Exceeded	0.6000	Passed	Laboratory or hand washing only
Lockview High School	Integrated Science Lab Room B104 tap 4	NBQ722	July 8, 2020	0.017	Exceeded	0.0530	Passed	Laboratory or hand washing only
Lockview High School	Integrated Science Lab Room B104 tap 5	NBQ723	July 8, 2020	0.014	Exceeded	0.0570	Passed	Laboratory or hand washing only

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Lockview High School	Biology Lab B105 tap 1	NBQ724	July 8, 2020	0.013	Exceeded	0.1400	Passed	Laboratory or hand washing only
Lockview High School	Biology Lab B105 tap 2	NBQ725	July 8, 2020	0.081	Exceeded	0.2600	Passed	Laboratory or hand washing only
Lockview High School	Biology Lab B105 tap 3	NBQ726	July 8, 2020	0.021	Exceeded	0.0890	Passed	Laboratory or hand washing only
Lockview High School	Biology Lab B105 tap 4	NBQ727	July 8, 2020	0.015	Exceeded	0.2000	Passed	Laboratory or hand washing only
Lockview High School	Biology Lab Prep Room B107 tap	NBQ728	July 8, 2020	0.030	Exceeded	0.1300	Passed	Laboratory or hand washing only
Lockview High School	Biology Lab B106 tap 1	NBQ729	July 8, 2020	0.016	Exceeded	0.3600	Passed	Laboratory or hand washing only
Lockview High School	Biology Lab B106 tap 2	NBQ730	July 8, 2020	0.017	Exceeded	0.1200	Passed	Laboratory or hand washing only
Lockview High School	Biology Lab B106 tap 3	NBQ731	July 8, 2020	0.033	Exceeded	0.3800	Passed	Laboratory or hand washing only
Lockview High School	Biology Lab B106 tap 4	NBQ732	July 8, 2020	0.012	Exceeded	0.2200	Passed	Laboratory or hand washing only
Lockview High School	Integrated Science Lab Room B109 tap 1	NBQ733	July 8, 2020	0.010	Exceeded	0.0790	Passed	Laboratory or hand washing only
Lockview High School	Integrated Science Lab Room B109 tap 2	NBQ734	July 8, 2020	0.016	Exceeded	0.1700	Passed	Laboratory or hand washing only
Lockview High School	Integrated Science Lab Room B109 tap 3	NBQ735	July 8, 2020	0.044	Exceeded	0.0570	Passed	Laboratory or hand washing only
Lockview High School	Integrated Science Lab Room B109 tap 4	NBQ736	July 8, 2020	0.017	Exceeded	0.1300	Passed	Laboratory or hand washing only
Lockview High School	Integrated Science Lab Room B109 tap 5	NBQ737	July 8, 2020	0.039	Exceeded	0.4500	Passed	Laboratory or hand washing only
Lockview High School	Physics Lab B110 tap 1	WGQ836	June 29, 2023	-	Passed	0.1300	Passed	Laboratory or hand washing only
Lockview High School	Physics Lab B110 tap 2	NBQ739	July 8, 2020	0.005	Passed	0.4100	Passed	
Lockview High School	Physics Lab Prep Room B112 tap	WGQ837	June 29, 2023	0.003	Passed	0.0970	Passed	Laboratory or hand washing only
Lockview High School	Physics Lab B111 tap 1	NBQ741	July 8, 2020	0.049	Exceeded	0.8200	Passed	Laboratory or hand washing only
Lockview High School	Physics Lab B111 tap 2	NBQ742	July 8, 2020	0.006	Exceeded	0.0730	Passed	Laboratory or hand washing only
Lockview High School	Janitors Closet C137 tap	NBQ743	July 8, 2020	0.006	Exceeded	0.0970	Passed	Hand washing only
Lockview High School	Female Wash Room by Room B113 tap 1	NBQ744	July 8, 2020	0.004	Passed	0.0950	Passed	
Lockview High School	Female Wash Room by Room B113 tap 2	NBQ745	July 8, 2020	0.002	Passed	0.0830	Passed	
Lockview High School	Female Wash Room by Room B113 tap 3	NBQ746	July 8, 2020	0.001	Passed	0.0670	Passed	
Lockview High School	Female Wash Room by Room B113 tap 4	WGQ838	June 29, 2023	-	Passed	0.0740	Passed	Tap remediated
Lockview High School	Class Room Wash Room D109B tap	WGS455	June 30, 2023	-	Passed	0.0380	Passed	Tap remediated
Lockview High School	Class Room D109 tap	NBQ749	July 8, 2020	0.002	Passed	0.1600	Passed	
Lockview High School	Class Room D103 tap 1	WGS458	June 30, 2023	-	Passed	0.0520	Passed	Tap remediated
Lockview High School	Class Room D103 tap 2	WGS459	June 30, 2023	-	Passed	0.0430	Passed	Tap remediated
Lockview High School	Class Room Wash Room D106B tap	WGS457	June 30, 2023	-	Passed	0.0640	Passed	Tap remediated
Lockview High School	Fountain by Room B113	WGQ833	June 29, 2023	-	Passed	0.1400	Passed	
Lockview High School	Health Room C122 tap	WGQ832	June 29, 2023	-	Passed	0.0410	Passed	Tap remediated
Lockview High School	Office Wash Room D128 tap	NCK026	July 13, 2020	-	Passed	0.0760	Passed	
Lockview High School	Office D125 tap	WGS456	June 30, 2023	-	Passed	0.0470	Passed	
Lockview High School	Office Wash Room D116 tap	WGS443	June 30, 2023	-	Passed	0.0680	Passed	Tap remediated
Lockview High School	Office Wash Room D115 tap	NCK029	July 13, 2020	0.002	Passed	0.2500	Passed	
Lockview High School	Production Room F131 tap 1	WGQ830	June 29, 2023	-	Passed	0.0400	Passed	
Lockview High School	Production Room F131 tap 2	WGQ831	June 29, 2023	0.001	Passed	0.1500	Passed	Tap remediated
Lockview High School	Fountain by Room F127	WGQ820	June 29, 2023	-	Passed	0.1300	Passed	
Lockview High School	Girls Wash Room tap 1 by Room F127	WGQ826	June 29, 2023	0.005	Exceeded	0.1500	Passed	Hand washing only
Lockview High School	Girls Wash Room tap 2 by Room F127	WGQ827	June 29, 2023	0.005	Passed	0.1600	Passed	Tap remediated
Lockview High School	Girls Wash Room tap 3 by Room F127	WGQ828	June 29, 2023	0.005	Passed	0.1600	Passed	Tap remediated
Lockview High School	Girls Wash Room tap 4 by Room F127	WGQ829	June 29, 2023	0.005	Exceeded	0.1600	Passed	Hand washing only
Lockview High School	Gender Neutral Wash Room F127 tap	NCK057	July 13, 2020	0.001	Passed	0.0660	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Lockview High School	Kitchen F102 tap 1	WGQ816	June 29, 2023	-	Passed	0.0410	Passed	
Lockview High School	Kitchen F102 tap 2	WGQ817	June 29, 2023	-	Passed	0.0440	Passed	Tap remediated
Lockview High School	Kitchen F102 tap 3	WGQ818	June 29, 2023	-	Passed	0.0360	Passed	
Lockview High School	Kitchen F102 tap 4	WGQ819	June 29, 2023	-	Passed	0.0470	Passed	
Lockview High School	Music Room tap Room F122	NCK062	July 13, 2020	0.002	Passed	0.8100	Passed	
Lockview High School	Janitors Closet tap Room F117	NCK063	July 13, 2020	0.002	Passed	0.0600	Passed	
Lockview High School	Janitors Closet tap Room F121	NCK064	July 13, 2020	0.002	Passed	0.0810	Passed	
Lockview High School	Janitors Closet tap Room F121	NCK095	July 13, 2020	0.098	Exceeded	0.2000	Passed	Hand washing only
Lockview High School	Art Room F110 tap 1	NCK101	July 13, 2020	0.013	Exceeded	0.2400	Passed	Hand washing only
Lockview High School	Art Room F110 tap 2	NCK102	July 13, 2020	0.025	Exceeded	0.2400	Passed	Hand washing only
Lockview High School	Art Room F109 tap 1	NCK103	July 13, 2020	0.010	Exceeded	0.1600	Passed	Hand washing only
Lockview High School	Art Room F109 tap 2	NCK104	July 13, 2020	0.075	Exceeded	0.7600	Passed	Hand washing only
Lockview High School	Fountain by Gym	WGQ815	June 29, 2023	-	Passed	0.2200	Passed	
Lockview High School	Female Wash Room tap 1 F Pod	NCK191	July 13, 2020	0.003	Passed	0.0710	Passed	
Lockview High School	Female Wash Room tap 2 F Pod	NCK192	July 13, 2020	0.007	Exceeded	0.1100	Passed	Hand washing only
Lockview High School	Female Wash Room tap 3 F Pod	NCK193	July 13, 2020	0.002	Passed	0.0780	Passed	
Lockview High School	Male Wash Room tap 1 F Pod	NCK194	July 13, 2020	0.002	Passed	0.0680	Passed	
Lockview High School	Male Wash Room tap 2 F Pod	NCK195	July 13, 2020	0.007	Exceeded	0.0660	Passed	Hand washing only
Lockview High School	Male Wash Room tap 3 F Pod	NCK196	July 13, 2020	0.003	Passed	0.0630	Passed	
Lockview High School	Fountain by Room F101	WGQ814	June 29, 2023	-	Passed	0.3400	Passed	
Lockview High School	Student Council Room F101 tap	WGS450	June 30, 2023	-	Passed	0.0570	Passed	Tap remediated
Lockview High School	Boys Locker Room E115 tap 1	NCK199	July 13, 2020	0.002	Passed	0.1300	Passed	
Lockview High School	Boys Locker Room E115 tap 2	NCK246	July 13, 2020	0.003	Passed	0.1500	Passed	
Lockview High School	Boys Locker Room E114 tap	WGS464	June 30, 2023	0.001	Passed	0.1600	Passed	Tap remediated
Lockview High School	Girls Locker Room E110 tap 1	WGS461	June 30, 2023	0.001	Passed	0.1000	Passed	Tap remediated
Lockview High School	Girls Locker Room E110 tap 2	WGS462	June 30, 2023	0.001	Passed	0.1100	Passed	Tap remediated
Lockview High School	Girls Locker Room E111 tap 1	NCK250	July 13, 2020	0.002	Passed	0.1100	Passed	
Lockview High School	Girls Locker Room E111 tap 2	WGS463	June 30, 2023	0.001	Passed	0.0950	Passed	Tap remediated
Lockview High School	Multipurpose Room Wash Room E109 tap 1	NCK252	July 13, 2020	0.003	Passed	0.3600	Passed	
Lockview High School	Multipurpose Room Wash Room E109 tap 2	WGS460	June 30, 2023	-	Passed	0.0240	Passed	Tap remediated
Lockview High School	Tech Ed Room C214 tap 1	NCK254	July 13, 2020	0.007	Exceeded	0.9200	Passed	Hand washing only
Lockview High School	Tech Ed Room C214 tap 2	NCK255	July 13, 2020	0.026	Exceeded	0.2300	Passed	Hand washing only
Lockview High School	Class Room C216 tap	WGS445	June 30, 2023	-	Passed	0.0840	Passed	Tap remediated
Lockview High School	Class Room A209 tap 1	NCK329	July 13, 2020	0.005	Passed	1.2000	Passed	
Lockview High School	Class Room A209 tap 2	NCK330	July 13, 2020	0.039	Exceeded	0.2200	Passed	Hand washing only
Lockview High School	Class Room A205 tap 1	NCK331	July 13, 2020	0.022	Exceeded	0.1100	Passed	Hand washing only
Lockview High School	Class Room A205 tap 2	NCK332	July 13, 2020	0.005	Passed	1.2000	Passed	
Lockview High School	Class Room B202 tap 1	NCK333	July 13, 2020	0.013	Exceeded	0.3100	Passed	Hand washing only
Lockview High School	Class Room B202 tap 2	NCK334	July 13, 2020	0.001	Passed	1.0000	Passed	
Lockview High School	Class Room B207 tap 1	NCK335	July 13, 2020	0.026	Exceeded	0.2800	Passed	Hand washing only
Lockview High School	Class Room B207 tap 2	NCK336	July 13, 2020	0.071	Exceeded	0.0840	Passed	Hand washing only
Lockview High School	Janitors Closet B214 tap	NCK337	July 13, 2020	0.002	Passed	0.1900	Passed	
Lockview High School	Gender Neutral Wash Room C219 tap	WGQ847	June 29, 2023	0.002	Passed	0.0510	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Lockview High School	Gender Neutral Wash Room C202 tap	WGQ846	June 29, 2023	-	Passed	0.0660	Passed	Tap remediated
Lockview High School	Male Wash Room by Room C202 tap 1	WGQ841	June 29, 2023	0.003	Passed	0.1700	Passed	Tap remediated
Lockview High School	Male Wash Room by Room C202 tap 2	WGQ842	June 29, 2023	0.003	Passed	0.1400	Passed	Tap remediated
Lockview High School	Male Wash Room by Room C202 tap 3	WGQ843	June 29, 2023	0.002	Passed	0.1200	Passed	Tap remediated
Lockview High School	Male Wash Room by Room C202 tap 4	WGQ844	June 29, 2023	0.001	Passed	0.0920	Passed	Tap remediated
Lockview High School	Male Wash Room by Room C202 tap 5	WGQ845	June 29, 2023	0.001	Passed	0.0870	Passed	Tap remediated
Lockview High School	Female Wash Room by Room C202 tap 1	NCK345	July 13, 2020	0.004	Passed	0.1200	Passed	
Lockview High School	Female Wash Room by Room C202 tap 2	NCK346	July 13, 2020	0.003	Passed	0.1000	Passed	
Lockview High School	Female Wash Room by Room C202 tap 3	WGS446	June 30, 2023	0.003	Passed	0.1300	Passed	Tap remediated
Lockview High School	Female Wash Room by Room C202 tap 4	WGS447	June 30, 2023	0.003	Passed	0.1300	Passed	Tap remediated
Lockview High School	Female Wash Room by Room C202 tap 5	NCK366	July 13, 2020	0.004	Passed	0.0670	Passed	
Lockview High School	Female Wash Room by Room C202 tap 6	NCK367	July 13, 2020	0.003	Passed	0.0810	Passed	
Lockview High School	Class Room D207 tap 1	WGS448	June 30, 2023	-	Passed	0.1000	Passed	Tap remediated
Lockview High School	Class Room D207 tap 2	WGS449	June 30, 2023	-	Passed	0.1300	Passed	Tap remediated
Lockview High School	Class Room D203 tap 1							Out-of-Service
Lockview High School	Class Room D203 tap 2	NCK370	July 13, 2020	0.008	Exceeded	1.7000	Passed	Hand washing only
Lockview High School	Home Ec. F113 tap 1	WGQ821	June 29, 2023	-	Passed	0.0160	Passed	
Lockview High School	Home Ec. F113 tap 2	WGQ822	June 29, 2023	0.001	Passed	0.0140	Passed	
Lockview High School	Home Ec. F113 tap 3	WGQ823	June 29, 2023	-	Passed	0.0160	Passed	
Lockview High School	Home Ec. F113 tap 4	WGQ824	June 29, 2023	-	Passed	0.0150	Passed	
Lockview High School	Home Ec. Prep Room F111 tap	WGQ825	June 29, 2023	-	Passed	0.0170	Passed	
Lockview High School	Fountain by Room B101	SHS323	April 5, 2022	-	Passed	0.1400	Passed	
Lockview High School	Fountain by Room C216	SHS324	April 5, 2022	-	Passed	0.1500	Passed	
Lockview High School	Fountain by Room B201	SHS325	April 5, 2022	-	Passed	0.0910	Passed	
Madeline Symonds Middle School	Class Room 1095 tap	NAO960	July 3, 2020	-	Passed	0.3300	Passed	
Madeline Symonds Middle School	Class Room 1091 tap 1	NAO961	July 3, 2020	-	Passed	0.5000	Passed	
Madeline Symonds Middle School	Class Room 1091 tap 2	NAO962	July 3, 2020	0.001	Passed	0.2000	Passed	
Madeline Symonds Middle School	Science Lab 1086 tap 1	NAO963	July 3, 2020	0.002	Passed	0.3000	Passed	
Madeline Symonds Middle School	Science Lab 1086 tap 2	NAO964	July 3, 2020	-	Passed	0.6000	Passed	
Madeline Symonds Middle School	Science Lab 1086 tap 3	NAO965	July 3, 2020	-	Passed	0.6600	Passed	
Madeline Symonds Middle School	Science Lab 1086 tap 4	NAO966	July 3, 2020	-	Passed	0.9600	Passed	
Madeline Symonds Middle School	Science Lab 1086 tap 5	NAO967	July 3, 2020	-	Passed	0.5200	Passed	
Madeline Symonds Middle School	Science Lab 1086 tap 6	NAO968	July 3, 2020	0.002	Passed	0.8000	Passed	
Madeline Symonds Middle School	Science Lab 1085 tap 1	NAO969	July 3, 2020	-	Passed	0.7700	Passed	
Madeline Symonds Middle School	Science Lab 1085 tap 2	NAO970	July 3, 2020	0.001	Passed	0.1900	Passed	
Madeline Symonds Middle School	Science Lab 1085 tap 3	NAO971	July 3, 2020	0.001	Passed	0.7400	Passed	
Madeline Symonds Middle School	Science Lab 1085 tap 4	NAO972	July 3, 2020	0.001	Passed	0.3500	Passed	
Madeline Symonds Middle School	Science Lab 1085 tap 5	NAO973	July 3, 2020	-	Passed	0.5700	Passed	
Madeline Symonds Middle School	Science Lab 1085 tap 6	NAO974	July 3, 2020	0.002	Passed	0.6300	Passed	
Madeline Symonds Middle School	Learning Centre Wash Room 1081 tap	NAO975	July 3, 2020	0.004	Passed	0.3000	Passed	
Madeline Symonds Middle School	Class Room 1076 tap	NAO977	July 3, 2020	-	Passed	0.4000	Passed	
Madeline Symonds Middle School	Class Room 1072 tap 1	NAO978	July 3, 2020	-	Passed	0.8500	Passed	
Madeline Symonds Middle School	Class Room 1072 tap 2	NAO979	July 3, 2020	-	Passed	0.2900	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Madeline Symonds Middle School	Janitors Closet 1100 tap	NAO980	July 3, 2020	0.001	Passed	0.0760	Passed	
Madeline Symonds Middle School	Gender Neutral Wash Room 1101 tap	NAO982	July 3, 2020	0.001	Passed	0.1100	Passed	
Madeline Symonds Middle School	Boys Wash Room tap 1 by Room 1095	NAO983	July 3, 2020	0.001	Passed	0.1200	Passed	
Madeline Symonds Middle School	Boys Wash Room tap 2 by Room 1095	NAO984	July 3, 2020	0.001	Passed	0.1500	Passed	
Madeline Symonds Middle School	Boys Wash Room tap 3 by Room 1095	NAO985	July 3, 2020	0.001	Passed	0.1600	Passed	
Madeline Symonds Middle School	Boys Wash Room tap 4 by Room 1095	NAO986	July 3, 2020	0.001	Passed	0.2400	Passed	
Madeline Symonds Middle School	Art Room 1061 tap	NAO988	July 3, 2020	0.002	Passed	0.1000	Passed	
Madeline Symonds Middle School	Girls Locker Room 1043 tap 1	NAO989	July 3, 2020	0.001	Passed	0.2100	Passed	
Madeline Symonds Middle School	Girls Locker Room 1043 tap 2	NAO990	July 3, 2020	0.001	Passed	0.1900	Passed	
Madeline Symonds Middle School	Gym Office Wash Room 1046 tap	NAO991	July 3, 2020	-	Passed	0.3200	Passed	
Madeline Symonds Middle School	Gym Office Wash Room 1048 tap	NAO992	July 3, 2020	-	Passed	0.3100	Passed	
Madeline Symonds Middle School	Male Locker Room 1050 tap 1	NAO993	July 3, 2020	0.001	Passed	0.4300	Passed	
Madeline Symonds Middle School	Male Locker Room 1050 tap 2	NAO994	July 3, 2020	0.001	Passed	0.4200	Passed	
Madeline Symonds Middle School	Female Wash Room 1036 tap	NAO995	July 3, 2020	0.002	Passed	0.0850	Passed	
Madeline Symonds Middle School	Janitors Closet 1035 tap	NAO996	July 3, 2020	0.001	Passed	0.0370	Passed	
Madeline Symonds Middle School	Male Wash Room 1037 tap	NAO997	July 3, 2020	0.001	Passed	0.1600	Passed	
Madeline Symonds Middle School	Office Wash Room 1035 tap	NAP002	July 3, 2020	-	Passed	0.0690	Passed	
Madeline Symonds Middle School	Class Room 2065 tap	NAP003	July 3, 2020	-	Passed	0.2500	Passed	
Madeline Symonds Middle School	Class Room 2061 tap 2	NAP005	July 3, 2020	0.001	Passed	0.8100	Passed	
Madeline Symonds Middle School	Class Room 2058 tap	NAP006	July 3, 2020	-	Passed	0.6300	Passed	
Madeline Symonds Middle School	Class Room 2053 tap 1	NAP007	July 3, 2020	0.004	Passed	0.6800	Passed	
Madeline Symonds Middle School	Class Room 2053 tap 2	NAP008	July 3, 2020	-	Passed	0.1500	Passed	
Madeline Symonds Middle School	Class Room 2050 tap	NAP009	July 3, 2020	-	Passed	0.2400	Passed	
Madeline Symonds Middle School	Class Room 2046 tap 1	NAP010	July 3, 2020	0.001	Passed	0.5300	Passed	
Madeline Symonds Middle School	Class Room 2046 tap 2	NAP011	July 3, 2020	0.002	Passed	0.2700	Passed	
Madeline Symonds Middle School	Female Wash Room tap 1 by Room 2046	NAP012	July 3, 2020	0.001	Passed	0.4400	Passed	
Madeline Symonds Middle School	Female Wash Room tap 2 by Room 2046	NAP013	July 3, 2020	-	Passed	0.1900	Passed	
Madeline Symonds Middle School	Female Wash Room tap 3 by Room 2046	NAP014	July 3, 2020	0.001	Passed	0.2100	Passed	
Madeline Symonds Middle School	Female Wash Room tap 4 by Room 2046	NAP015	July 3, 2020	0.001	Passed	0.2600	Passed	
Madeline Symonds Middle School	Janitors Closet 2071 tap	NAP016	July 3, 2020	0.001	Passed	0.0690	Passed	
Madeline Symonds Middle School	Gender Neutral Wash Room 2072 tap	NAP017	July 3, 2020	0.001	Passed	0.1000	Passed	
Madeline Symonds Middle School	Male Wash Room tap 1 by Room 2072	NAP018	July 3, 2020	0.001	Passed	0.1900	Passed	
Madeline Symonds Middle School	Male Wash Room tap 2 by Room 2072	NAP019	July 3, 2020	0.001	Passed	0.1500	Passed	
Madeline Symonds Middle School	Male Wash Room tap 3 by Room 2072	NAP020	July 3, 2020	0.001	Passed	0.1600	Passed	
Madeline Symonds Middle School	Janitors Closet tap Room 2036	NAP022	July 3, 2020	0.003	Passed	0.1700	Passed	
Madeline Symonds Middle School	Tech Ed Room 2039 tap	NAP023	July 3, 2020	-	Passed	0.3900	Passed	
Madeline Symonds Middle School	Staff Room Wash Room 2026 tap	NAP024	July 3, 2020	-	Passed	0.2100	Passed	
Madeline Symonds Middle School	Staff Room Wash Room 2027 tap	NAP025	July 3, 2020	0.001	Passed	0.2200	Passed	
Madeline Symonds Middle School	Fountain by Room 2037	XKK148	October 26, 2023	-	Passed	0.1900	Passed	
Madeline Symonds Middle School	Class Room 2061 tap 1	NXX287	October 15, 2020	-	Passed	0.1900	Passed	
Madeline Symonds Middle School	Fountain by Room 2038	VXD780	May 24, 2023	-	Passed	0.1500	Passed	
Madeline Symonds Middle School	Staff Room 2025 Kitchen tap	VXD781	May 24, 2023	-	Passed	0.0170	Passed	
Madeline Symonds Middle School	Fountain by Room 1104	VXD886	May 24, 2023	-	Passed	0.0530	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Madeline Symonds Middle School	Fountain by Room 1101	VXD887	May 24, 2023	-	Passed	0.0720	Passed	
Madeline Symonds Middle School	Fountain by Room 1056	VXD888	May 24, 2023	0.001	Passed	0.0650	Passed	
Madeline Symonds Middle School	Family Studies 1029 tap 1	VXD889	May 24, 2023	-	Passed	0.0210	Passed	
Madeline Symonds Middle School	Family Studies 1029 tap 2	VXD890	May 24, 2023	-	Passed	0.0220	Passed	
Madeline Symonds Middle School	Family Studies 1029 tap 3	VXD891	May 24, 2023	-	Passed	0.0180	Passed	
Madeline Symonds Middle School	Family Studies 1029 tap 4	VXD892	May 24, 2023	-	Passed	0.0190	Passed	
Madeline Symonds Middle School	Learning Centre 1079 tap	VXD893	May 24, 2023	-	Passed	0.1400	Passed	
Madeline Symonds Middle School	Fountain by Room 2072	VXD894	May 24, 2023	-	Passed	0.0850	Passed	
Madeline Symonds Middle School	Male Wash Room tap 4 by Room 2072	VXD895	May 24, 2023	-	Passed	0.0700	Passed	Tap remediated
Marine Drive Academy	Wash Room 319 tap	QWP094	September 24, 2021	0.002	Passed	0.2900	Passed	
Marine Drive Academy	Science Lab Room 317 tap 1	QWP093	September 24, 2021	0.002	Passed	0.4100	Passed	
Marine Drive Academy	Science Lab Room 317 tap 2	QWP096	September 24, 2021	0.001	Passed	0.1800	Passed	
Marine Drive Academy	Science Lab Room 317 tap 3	QWP092	September 24, 2021	0.001	Passed	0.1500	Passed	
Marine Drive Academy	Science Lab Room 317A tap	QWP095	September 24, 2021	0.001	Passed	0.3400	Passed	
Marine Drive Academy	Art Room 316 tap	QWP097	September 24, 2021	-	Passed	0.3700	Passed	
Marine Drive Academy	Gender Neutral Wash Room 313 tap 1	QWP071	September 24, 2021	0.003	Passed	0.4400	Passed	
Marine Drive Academy	Gender Neutral Wash Room 313 tap 2	QWP084	September 24, 2021	0.002	Passed	0.4100	Passed	
Marine Drive Academy	Food Lab Room 310 tap 1	XGX674	October 13, 2023	0.001	Passed	0.5600	Passed	
Marine Drive Academy	Food Lab Room 310 tap 2	XGX675	October 13, 2023	0.001	Passed	0.4500	Passed	
Marine Drive Academy	Food Lab Room 310 tap 3	XGX676	October 13, 2023	0.001	Passed	0.4300	Passed	
Marine Drive Academy	Food Lab Room 310 tap 4	XGX677	October 13, 2023	0.001	Passed	0.3900	Passed	
Marine Drive Academy	Food Lab Room 310 tap 5	XGX678	October 13, 2023	0.001	Passed	0.4100	Passed	
Marine Drive Academy	Food Lab Room 310 tap 6	XGX679	October 13, 2023	0.002	Passed	0.4500	Passed	
Marine Drive Academy	Class Room 307 tap	QWP078	September 24, 2021	0.001	Passed	0.3000	Passed	
Marine Drive Academy	Class Room 306 tap	QWP100	September 24, 2021	0.001	Passed	0.2000	Passed	
Marine Drive Academy	Mechanical Room 305 tap	QWP085	September 24, 2021	-	Passed	0.2800	Passed	
Marine Drive Academy	3rd Floor Hallway tap	XGX680	October 13, 2023	-	Passed	0.4500	Passed	
Marine Drive Academy	3rd Floor Fountain	XGX673	October 13, 2023	0.001	Passed	0.4800	Passed	
Marine Drive Academy	Gym Room 201 tap 1	QWP061	September 24, 2021	0.004	Passed	0.4200	Passed	
Marine Drive Academy	Gym Room 201 tap 2	RMM546	December 1, 2021	0.002	Passed	0.3200	Passed	
Marine Drive Academy	Music Room 202 tap	QWP067	September 24, 2021	0.001	Passed	0.4300	Passed	
Marine Drive Academy	Music Room 202 LT tap	QWP103	September 24, 2021	-	Passed	0.3800	Passed	
Marine Drive Academy	Cafeteria Room 206 tap 1	XGX666	October 13, 2023	0.001	Passed	0.5800	Passed	
Marine Drive Academy	Cafeteria Room 206 tap 2	XGX668	October 13, 2023	0.001	Passed	0.6300	Passed	
Marine Drive Academy	Cafeteria Room 206 tap 3	XGX669	October 13, 2023	0.001	Passed	0.5700	Passed	
Marine Drive Academy	Gender Neutral Wash Room 207 tap	QWP066	September 24, 2021	0.001	Passed	0.2000	Passed	
Marine Drive Academy	Gender Neutral Wash Room 213-1 tap	QWP104	September 24, 2021	0.003	Passed	0.4600	Passed	
Marine Drive Academy	Gender Neutral Wash Room 213-2 tap	QWP101	September 24, 2021	0.002	Passed	0.4400	Passed	
Marine Drive Academy	Class Room 220 Wash Room tap	QWP108	September 24, 2021	-	Passed	0.2400	Passed	
Marine Drive Academy	Class Room 220 tap	QWP109	September 24, 2021	-	Passed	0.2100	Passed	
Marine Drive Academy	Class Room 221 Wash Room tap	QWP070	September 24, 2021	0.001	Passed	0.3000	Passed	
Marine Drive Academy	Class Room 221 tap	QWP107	September 24, 2021	-	Passed	0.3700	Passed	
Marine Drive Academy	Staff Room 223 tap	XGX672	October 13, 2023	-	Passed	0.7500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Marine Drive Academy	Staff Room 223 Wash Room tap	QWP069	September 24, 2021	-	Passed	0.2600	Passed	
Marine Drive Academy	Wash Room 224 tap	QWP110	September 24, 2021	0.001	Passed	0.3200	Passed	
Marine Drive Academy	Class Room 225 tap	QWP091	September 24, 2021	-	Passed	0.6500	Passed	
Marine Drive Academy	Class Room 226 tap	QWP068	September 24, 2021	0.001	Passed	0.3800	Passed	
Marine Drive Academy	2nd Floor Fountain by Gym	XGX671	October 13, 2023	0.001	Passed	1.3000	Passed	
Marine Drive Academy	2nd Floor Fountain by Room 216	XGX670	October 13, 2023	0.001	Passed	1.1000	Passed	
Marine Drive Academy	Water Room tap	QWP088	September 24, 2021	0.002	Passed	0.0980	Passed	
Marine Drive Academy	Boiler Room tap	QWP072	September 24, 2021	-	Passed	0.2900	Passed	
Marine Drive Academy	Custodian Room 103 tap	QWP089	September 24, 2021	0.002	Passed	0.2800	Passed	
Marine Drive Academy	Recycle Room 104 tap 1	QWP073	September 24, 2021	-	Passed	0.1400	Passed	
Marine Drive Academy	Recycle Room 104 tap 2	QWP080	September 24, 2021	-	Passed	0.1500	Passed	
Marine Drive Academy	Gender Neutral Wash Room 111 tap 1	QWP077	September 24, 2021	0.004	Passed	0.5000	Passed	
Marine Drive Academy	Gender Neutral Wash Room 111 tap 2	RMM545	December 1, 2021	-	Passed	-	Passed	
Marine Drive Academy	Class Room 118	QWP076	September 24, 2021	-	Passed	0.3800	Passed	
Marine Drive Academy	1st Floor Fountain	XGX681	October 13, 2023	-	Passed	0.8000	Passed	
Marine Drive Academy	1st Floor Hallway tap	XGX682	October 13, 2023	-	Passed	0.4600	Passed	
Marine Drive Academy	Wood Shop 114 tap	QWP111	September 24, 2021	-	Passed	0.2200	Passed	
Michael Wallace Elementary	Gender Neutral Wash Room 29B tap by Gym	WGQ739	June 30, 2023	0.001	Passed	0.0220	Passed	Tap remediated
Michael Wallace Elementary	Caretakers Office 22 tap	MXV212	June 18, 2020	0.001	Passed	0.0460	Passed	
Michael Wallace Elementary	Girls Wash Room 19 tap 1	MXV213	June 18, 2020	0.001	Passed	0.0590	Passed	
Michael Wallace Elementary	Girls Wash Room 19 tap 2	MXV214	June 18, 2020	0.001	Passed	0.0320	Passed	
Michael Wallace Elementary	Girls Wash Room 19 tap 3	MXV215	June 18, 2020	-	Passed	0.0160	Passed	
Michael Wallace Elementary	Boys Wash Room 23 tap 1	MXV216	June 18, 2020	0.001	Passed	0.2200	Passed	
Michael Wallace Elementary	Boys Wash Room tap 2	MXV217	June 18, 2020	0.001	Passed	0.0380	Passed	
Michael Wallace Elementary	Boys Wash Room tap 3	MXV218	June 18, 2020	0.001	Passed	0.0190	Passed	
Michael Wallace Elementary	2nd Floor Gender Neutral Wash Room 2A tap	WGQ737	June 30, 2023	-	Passed	0.0160	Passed	Tap remediated
Michael Wallace Elementary	Staff Room 2 tap	WGQ740	June 30, 2023	-	Passed	0.0071	Passed	Tap remediated
Michael Wallace Elementary	Boys Wash Room 11 tap 1	MXV221	June 18, 2020	0.001	Passed	0.0660	Passed	
Michael Wallace Elementary	Boys Wash Room 11 tap 2	MXV222	June 18, 2020	-	Passed	0.0160	Passed	
Michael Wallace Elementary	Boys Wash Room 11 tap 3	MXV223	June 18, 2020	-	Passed	0.0100	Passed	
Michael Wallace Elementary	Boys Wash Room 11 tap 4	MXV224	June 18, 2020	-	Passed	0.0100	Passed	
Michael Wallace Elementary	Boys Wash Room 11 tap 5	MXV225	June 18, 2020	0.001	Passed	0.0880	Passed	
Michael Wallace Elementary	Girls Wash Room 10 tap 1	WGQ743	June 30, 2023	-	Passed	0.0090	Passed	Tap remediated
Michael Wallace Elementary	Girls Wash Room 10 tap 2	MXV227	June 18, 2020	0.002	Passed	0.0380	Passed	
Michael Wallace Elementary	Girls Wash Room 10 tap 3	MXV228	June 18, 2020	0.001	Passed	0.0130	Passed	
Michael Wallace Elementary	Girls Wash Room 10 tap 4	WGQ744	June 30, 2023	-	Passed	0.0110	Passed	Tap remediated
Michael Wallace Elementary	Girls Wash Room 10 tap 5	MXV230	June 18, 2020	0.002	Passed	0.0300	Passed	
Michael Wallace Elementary	Main Office 5 Gender Neutral Wash Room tap	WGQ741	June 30, 2023	-	Passed	0.0110	Passed	Tap remediated
Michael Wallace Elementary	Fountain by Room 26	WGQ736	June 30, 2023	-	Passed	0.0410	Passed	
Michael Wallace Elementary	Fountain by 2nd Floor Wash Rooms	WGQ738	June 30, 2023	0.003	Passed	0.0540	Passed	
Michael Wallace Elementary	Fountain by Room 2	WGQ742	June 30, 2023	-	Passed	0.0230	Passed	
Millwood Elementary	Girls Wash Room tap 1 by Fan Room	MSZ955	May 28, 2020	-	Passed	0.0440	Passed	
Millwood Elementary	Girls Wash Room tap 2 by Fan Room	MSZ956	May 28, 2020	-	Passed	0.0320	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Millwood Elementary	Girls Wash Room tap 3 by Fan Room	MSZ957	May 28, 2020	-	Passed	0.0500	Passed	
Millwood Elementary	Boys Wash Room tap 1 by Fan Room	MSZ958	May 28, 2020	-	Passed	0.0071	Passed	
Millwood Elementary	Boys Wash Room tap 2 by Fan Room	MSZ959	May 28, 2020	-	Passed	0.0062	Passed	
Millwood Elementary	Boys Wash Room tap 3 by Fan Room	MSZ960	May 28, 2020	-	Passed	0.0065	Passed	
Millwood Elementary	Janitors Closet tap by Room 202	MSZ961	May 28, 2020	-	Passed	0.0056	Passed	
Millwood Elementary	Girls Wash Room tap 1 by Elevator	MSZ963	May 28, 2020	-	Passed	0.0070	Passed	
Millwood Elementary	Girls Wash Room tap 2 by Elevator	MSZ964	May 28, 2020	-	Passed	0.0091	Passed	
Millwood Elementary	Girls Wash Room tap 3 by Elevator	MSZ965	May 28, 2020	-	Passed	0.0072	Passed	
Millwood Elementary	Boys Wash Room tap 1 by Elevator	MSZ966	May 28, 2020	-	Passed	0.0076	Passed	
Millwood Elementary	Boys Wash Room tap 2 by Elevator	MSZ967	May 28, 2020	-	Passed	0.0064	Passed	
Millwood Elementary	Boys Wash Room tap 3 by Elevator	MSZ968	May 28, 2020	-	Passed	0.0055	Passed	
Millwood Elementary	Caretaker Room tap by Electrical Room	MSZ969	May 28, 2020	-	Passed	0.0032	Passed	
Millwood Elementary	Class Room 135 tap	MSZ971	May 28, 2020	-	Passed	0.0071	Passed	
Millwood Elementary	Class Room 135 Gender Neutral Wash Room tap	MSZ972	May 28, 2020	-	Passed	0.0060	Passed	
Millwood Elementary	Class Room 132 Gender Neutral Wash Room tap	MSZ973	May 28, 2020	0.001	Passed	0.0570	Passed	
Millwood Elementary	Class Room 132 tap	MSZ974	May 28, 2020	-	Passed	0.0065	Passed	
Millwood Elementary	Class Room 128 tap	MSZ975	May 28, 2020	-	Passed	0.0067	Passed	
Millwood Elementary	Class Room 127 tap	MSZ976	May 28, 2020	-	Passed	0.0067	Passed	
Millwood Elementary	Class Room 123 tap	MSZ977	May 28, 2020	-	Passed	0.0059	Passed	
Millwood Elementary	Class Room 123 Wash Room tap	MSZ978	May 28, 2020	0.001	Passed	0.0940	Passed	
Millwood Elementary	Class Room 122 tap	MSZ979	May 28, 2020	-	Passed	0.0098	Passed	
Millwood Elementary	Class Room tap by Room 122	MSZ980	May 28, 2020	0.001	Passed	0.0076	Passed	
Millwood Elementary	Staff Room Wash Room 1 tap	MSZ982	May 28, 2020	-	Passed	0.0075	Passed	
Millwood Elementary	Staff Room Wash Room 2 tap	MSZ983	May 28, 2020	-	Passed	0.0064	Passed	
Millwood Elementary	Girls Locker Room tap	MSZ985	May 28, 2020	0.004	Passed	0.2600	Passed	
Millwood Elementary	Gym Office Wash Room tap	MSZ986	May 28, 2020	0.001	Passed	0.0220	Passed	
Millwood Elementary	Main Office tap	WCT718	June 14, 2023	-	Passed	0.0150	Passed	
Millwood Elementary	Fountain by Room 135	WCT719	June 14, 2023	-	Passed	0.0640	Passed	
Millwood Elementary	Staff Room 111 tap	WCT720	June 14, 2023	-	Passed	0.0120	Passed	
Millwood Elementary	Fountain by Room 202	WCT721	June 14, 2023	-	Passed	0.0240	Passed	
Millwood Elementary	Boys Locker Room tap	WCT722	June 14, 2023	0.002	Passed	0.0630	Passed	Tap remediated
Millwood Elementary	Kitchen by Main Office tap	WCT723	June 14, 2023	-	Passed	0.0280	Passed	
Millwood High School	Janitors Closet tap Room 241	MTN671	May 29, 2020	0.001	Passed	0.0250	Passed	
Millwood High School	Boys Wash Room tap 1 Room 204	MTN672	May 29, 2020	0.001	Passed	0.0200	Passed	
Millwood High School	Boys Wash Room tap 2 Room 204	MTN673	May 29, 2020	0.001	Passed	0.0250	Passed	
Millwood High School	Boys Wash Room tap 3 Room 204	MTN674	May 29, 2020	0.001	Passed	0.0260	Passed	
Millwood High School	Boys Wash Room tap 4 Room 204	MTN675	May 29, 2020	0.004	Passed	0.0330	Passed	
Millwood High School	Boys Wash Room tap 5 Room 204	MTN676	May 29, 2020	-	Passed	0.0800	Passed	
Millwood High School	Boys Wash Room tap 6 Room 204	MTN677	May 29, 2020	0.001	Passed	0.0190	Passed	
Millwood High School	Girls Wash Room tap 1 Room 205	WDJ126	June 20, 2023	0.001	Passed	0.0800	Passed	Tap remediated
Millwood High School	Girls Wash Room tap 2 Room 205	MTN679	May 29, 2020	0.002	Passed	0.1000	Passed	
Millwood High School	Girls Wash Room tap 3 Room 205	MTN680	May 29, 2020	0.001	Passed	0.1100	Passed	
Millwood High School	Girls Wash Room tap 4 Room 205	MTN681	May 29, 2020	-	Passed	0.0790	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Millwood High School	Girls Wash Room tap 5 Room 205	MTN682	May 29, 2020	0.005	Passed	0.2000	Passed	
Millwood High School	Girls Wash Room tap 6 Room 205	MTN683	May 29, 2020	0.003	Passed	0.0400	Passed	
Millwood High School	Fountain by Room 206	WDJ127	June 20, 2023	-	Passed	0.0860	Passed	
Millwood High School	Gender Neutral Wash Room by Room 202	WDJ128	June 20, 2023	0.001	Passed	0.4300	Passed	Tap remediated
Millwood High School	Gender Neutral Wash Room tap Room 202	MTN685	May 29, 2020	0.003	Passed	0.5800	Passed	
Millwood High School	Class Room tap Room 202	MTN686	May 29, 2020	0.002	Passed	0.0520	Passed	
Millwood High School	Class Room tap Room 240	MTN687	May 29, 2020	0.001	Passed	0.0280	Passed	
Millwood High School	Physics Lab tap 1 Room 226	MTN689	May 29, 2020	0.003	Passed	0.1800	Passed	
Millwood High School	Physics Lab tap 2 Room 226	MTN690	May 29, 2020	0.020	Exceeded	1.1000	Passed	Laboratory or Hand washing only
Millwood High School	Physics Lab Storage tap Room 231	MTN691	May 29, 2020	0.004	Passed	0.0570	Passed	
Millwood High School	Class Room tap Room 229	WDJ129	June 20, 2023	0.001	Passed	0.3500	Passed	Tap remediated
Millwood High School	Art Room tap 1 Room 223	MTN692	May 29, 2020	-	Passed	0.1200	Passed	
Millwood High School	Art Room tap 2 Room 223	MTN693	May 29, 2020	0.001	Passed	0.0500	Passed	
Millwood High School	Science Room tap 1 Room 222	MTN694	May 29, 2020	0.012	Exceeded	0.2200	Passed	Laboratory or Hand washing only
Millwood High School	Science Room tap 2 Room 222	MTN695	May 29, 2020	0.001	Passed	0.0510	Passed	
Millwood High School	Chemistry Lab tap 1 Room 220	MTN696	May 29, 2020	0.001	Passed	0.0310	Passed	
Millwood High School	Chemistry Lab tap 2 Room 220	MTN697	May 29, 2020	0.002	Passed	0.0630	Passed	
Millwood High School	Chemistry Lab tap 3 Room 220	MTN698	May 29, 2020	0.001	Passed	0.0330	Passed	
Millwood High School	Chemistry Lab tap 4 Room 220	MTN699	May 29, 2020	-	Passed	0.0120	Passed	
Millwood High School	Chemistry Lab tap 5 Room 220	MTN700	May 29, 2020	0.001	Passed	0.0490	Passed	
Millwood High School	Science Room tap 1 Room 215	MTN704	May 29, 2020	0.010	Exceeded	0.4500	Passed	Laboratory or Hand washing only
Millwood High School	Science Room tap 2 Room 215	MTN705	May 29, 2020	0.002	Passed	0.8400	Passed	
Millwood High School	Science Room tap 3 Room 215	MTN706	May 29, 2020	0.006	Exceeded	1.0000	Passed	Laboratory or Hand washing only
Millwood High School	Science Room tap 1 Room 216	MTN707	May 29, 2020	0.006	Exceeded	0.3100	Passed	Laboratory or Hand washing only
Millwood High School	Main Office Gender Neutral Wash Room tap 1	WDJ123	June 20, 2023	-	Passed	0.0600	Passed	Tap remediated
Millwood High School	Main Office Gender Neutral Wash Room tap 2	MTN710	May 29, 2020	-	Passed	0.0310	Passed	
Millwood High School	Main Office Gender Neutral Wash Room tap 3	MTN711	May 29, 2020	0.004	Passed	0.0380	Passed	
Millwood High School	Class Room tap Room 109	MTN712	May 29, 2020	0.002	Passed	0.0500	Passed	
Millwood High School	Cafeteria Kitchen triple compartment sink tap	MTN714	May 29, 2020	0.001	Passed	0.0440	Passed	
Millwood High School	Girls Wash Room tap 1 Room 120	WDJ120	June 20, 2023	-	Passed	0.0950	Passed	Tap remediated
Millwood High School	Girls Wash Room tap 2 Room 120	MTN717	May 29, 2020	0.003	Passed	0.0540	Passed	
Millwood High School	Girls Wash Room tap 3 Room 120	MTN718	May 29, 2020	0.001	Passed	0.0570	Passed	
Millwood High School	Girls Wash Room tap 4 Room 120	MTN719	May 29, 2020	0.002	Passed	0.0540	Passed	
Millwood High School	Girls Wash Room tap 5 Room 120	WDJ121	June 20, 2023	-	Passed	0.0990	Passed	Tap remediated
Millwood High School	Girls Wash Room tap 6 Room 120	MTN721	May 29, 2020	0.001	Passed	0.0260	Passed	
Millwood High School	Boys Wash Room tap 1 Room 119	MTN722	May 29, 2020	0.003	Passed	0.0970	Passed	
Millwood High School	Boys Wash Room tap 2 Room 119	MTN723	May 29, 2020	-	Passed	0.0240	Passed	
Millwood High School	Boys Wash Room tap 3 Room 119	MTN728	May 29, 2020	0.002	Passed	0.0800	Passed	
Millwood High School	Janitors Closet tap Room 123	MTN729	May 29, 2020	-	Passed	0.0190	Passed	
Millwood High School	Girls Locker Room tap 1 Room 150	MTN731	May 29, 2020	0.001	Passed	0.0330	Passed	
Millwood High School	Girls Locker Room tap 2 Room 150	MTN732	May 29, 2020	0.001	Passed	0.0350	Passed	
Millwood High School	Girls Locker Room tap 3 Room 150	MTN733	May 29, 2020	0.001	Passed	0.0400	Passed	
Millwood High School	Gym Office Wash Room tap Room 151	MTN735	May 29, 2020	0.002	Passed	0.0970	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Millwood High School	Gender Neutral Wash Room tap Room 152	MTN736	May 29, 2020	0.002	Passed	0.0360	Passed	
Millwood High School	Boys Locker Room tap 1 Room 153	MTN737	May 29, 2020	-	Passed	0.0390	Passed	
Millwood High School	Boys Locker Room tap 2 Room 153	MTN738	May 29, 2020	-	Passed	0.0410	Passed	
Millwood High School	Fountain by Girls Wash Room	WDJ122	June 20, 2023	-	Passed	0.0580	Passed	
Millwood High School	Laundry tub tap Room 129	WDJ124	June 20, 2023	0.001	Passed	0.0670	Passed	
Millwood High School	Kitchen sink tap Room 117	WDJ125	June 20, 2023	-	Passed	0.0350	Passed	Tap remediated
Millwood High School	Modular Staff Room tap	WDJ130	June 20, 2023	-	Passed	0.1900	Passed	
Millwood High School	Fountain in Modular	WDJ131	June 20, 2023	-	Passed	0.0640	Passed	
Millwood High School	Modular Staff Wash Room tap	WDJ132	June 20, 2023	-	Passed	0.2000	Passed	
Millwood High School	Modular Girls wash Room tap 1	WDJ133	June 20, 2023	-	Passed	0.2000	Passed	
Millwood High School	Modular Girls wash Room tap 2	WDJ134	June 20, 2023	-	Passed	0.2000	Passed	
Millwood High School	Modular Girls wash Room tap 3	WDJ135	June 20, 2023	-	Passed	0.1800	Passed	
Millwood High School	Modular Girls wash Room tap 4	WDJ136	June 20, 2023	-	Passed	0.1800	Passed	
Millwood High School	Modular Boys wash Room tap 1	WDJ137	June 20, 2023	-	Passed	0.1800	Passed	
Millwood High School	Modular Boys wash Room tap 2	WDJ138	June 20, 2023	-	Passed	0.1800	Passed	
Millwood High School	Modular Boys wash Room tap 3	WDJ139	June 20, 2023	-	Passed	0.1800	Passed	
Millwood High School	Modular Janitors Closet	WDJ140	June 20, 2023	-	Passed	0.2100	Passed	
Mount Edward Elementary	Staff Room tap	WIH370	July 7, 2023	-	Passed	0.0099	Passed	
Mount Edward Elementary	Staff Room Wash Room tap	MUW071	June 8, 2020	0.003	Passed	0.0400	Passed	
Mount Edward Elementary	Class Room 8 tap	MUW072	June 8, 2020	0.003	Passed	0.2300	Passed	
Mount Edward Elementary	Boys Wash Room tap 1 by Gym	WIH366	July 7, 2023	-	Passed	0.0210	Passed	Tap remediated
Mount Edward Elementary	Boys Wash Room tap 2 by Gym	MUW075	June 8, 2020	0.002	Passed	0.0840	Passed	
Mount Edward Elementary	Boys Wash Room tap 3 by Gym	MUW076	June 8, 2020	0.003	Passed	0.0570	Passed	
Mount Edward Elementary	Gender Neutral Wash Room tap by Gym	WIH368	July 7, 2023	-	Passed	0.0200	Passed	Tap remediated
Mount Edward Elementary	Janitors Closet tap by Girls Wash Room	MUW078	June 8, 2020	0.002	Passed	0.5400	Passed	
Mount Edward Elementary	Girls Wash Room tap 1 by Janitors Closet	MUW079	June 8, 2020	0.002	Passed	0.2500	Passed	
Mount Edward Elementary	Girls Wash Room tap 2 by Janitors Closet	WIH367	July 7, 2023	-	Passed	0.0130	Passed	Tap remediated
Mount Edward Elementary	Girls Wash Room tap 3 by Janitors Closet	MUW087	June 8, 2020	0.001	Passed	0.0840	Passed	
Mount Edward Elementary	Fountain by Staff Room	XLP247	October 31, 2023	0.001	Passed	0.0690	Passed	
Mount Edward Elementary	Girls Wash Room tap 1 by Office	WIH376	July 7, 2023	-	Passed	0.0120	Passed	Tap remediated
Mount Edward Elementary	Girls Wash Room tap 2 by Office	MUW090	June 8, 2020	0.002	Passed	0.2300	Passed	
Mount Edward Elementary	Boys Wash Room tap 1 by Office	WIH374	July 7, 2023	0.004	Passed	0.0210	Passed	Tap remediated
Mount Edward Elementary	Boys Wash Room tap 2 by Office	MUW092	June 8, 2020	0.005	Passed	0.3300	Passed	
Mount Edward Elementary	Boys Wash Room tap 3 by Office	WIH375	July 7, 2023	0.001	Passed	0.0240	Passed	Tap remediated
Mount Edward Elementary	Fountain by Janitors Closet	WIH373	July 7, 2023	-	Passed	0.0370	Passed	
Mount Edward Elementary	Janitors Closet tap by Main Office	MUW095	June 8, 2020	0.001	Passed	0.0560	Passed	
Mount Edward Elementary	Office tap	WIH371	July 7, 2023	-	Passed	0.0200	Passed	
Mount Edward Elementary	Principal's Office Wash Room tap	WIH372	July 7, 2023	-	Passed	0.0180	Passed	Tap remediated
Mount Edward Elementary	Canteen tap in Gym	XLP246	October 31, 2023	0.001	Passed	0.0190	Passed	
Mount Edward Elementary	Fountain by Room 3	WIH365	July 7, 2023	0.001	Passed	0.6900	Passed	
Musquodoboit Rural High School	General Science 2205 tap 1	MVW073	June 11, 2020	-	Passed	0.0400	Passed	
Musquodoboit Rural High School	General Science 2205 tap 2	MVW074	June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	General Science 2205 tap 3	MVW075	June 11, 2020	0.002	Passed	0.0480	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Musquodoboit Rural High School	General Science 2205 tap 4	MVW076	June 11, 2020	0.001	Passed	0.0410	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 2701 tap	MVW077	June 11, 2020	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 1 by Room 2103	MVW079	June 11, 2020	0.001	Passed	0.1100	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 2 by Room 2103	MVW080	June 11, 2020	0.001	Passed	0.1700	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 3 by Room 2103	MVW081	June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Janitors Closet 2103 tap	MVW082	June 11, 2020	0.001	Passed	0.1100	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 1 by Room 2309	MVW085	June 11, 2020	0.002	Passed	0.1300	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 2 by Room 2309	MVW086	June 11, 2020	0.001	Passed	0.1300	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 3 by Room 2309	MVW087	June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Physics Lab 2309 tap 1	MVW088	June 11, 2020	-	Passed	0.2000	Passed	
Musquodoboit Rural High School	Physics Lab 2309 tap 2	MVW089	June 11, 2020	0.002	Passed	0.0300	Passed	
Musquodoboit Rural High School	Physics Lab 2309 tap 3	MVW090	June 11, 2020	0.002	Passed	0.2400	Passed	
Musquodoboit Rural High School	General Science Lab 2303 tap 1	MVW091	June 11, 2020	0.001	Passed	0.1300	Passed	
Musquodoboit Rural High School	General Science Lab 2303 tap 2	MVW092	June 11, 2020	-	Passed	0.1500	Passed	
Musquodoboit Rural High School	General Science Lab 2303 tap 3	MVW093	June 11, 2020	0.001	Passed	0.0540	Passed	
Musquodoboit Rural High School	General Science Lab 2303 tap 4	MVW094	June 11, 2020	0.001	Passed	0.0790	Passed	
Musquodoboit Rural High School	General Science Lab 2303 tap 5	MVW095	June 11, 2020	-	Passed	0.0980	Passed	
Musquodoboit Rural High School	Chemistry Lab 2301 tap 1	MVW096	June 11, 2020	0.005	Exceeded	0.0990	Passed	Laboratory or Hand washing only
Musquodoboit Rural High School	Chemistry Lab 2301 tap 2	MVW097	June 11, 2020	0.014	Exceeded	0.1800	Passed	Laboratory or Hand washing only
Musquodoboit Rural High School	Chemistry Lab 2301 tap 3	MVW098	June 11, 2020	0.001	Passed	0.2500	Passed	
Musquodoboit Rural High School	Chemistry Lab 2301 tap 4	MVW099	June 11, 2020	0.003	Passed	0.0560	Passed	
Musquodoboit Rural High School	Chemistry Lab 2301 tap 5	MVW100	June 11, 2020	0.006	Exceeded	0.1300	Passed	Laboratory or Hand washing only
Musquodoboit Rural High School	Chemistry Lab 2301 tap 6	MVW101	June 11, 2020	-	Passed	0.0320	Passed	
Musquodoboit Rural High School	Chemistry Lab 2301 tap 7	MVW102	June 11, 2020	-	Passed	0.3500	Passed	
Musquodoboit Rural High School	Chemistry Lab 2301 tap 8	MVW103	June 11, 2020	-	Passed	0.1800	Passed	
Musquodoboit Rural High School	Chemistry Lab 2301 tap 9	MVW104	June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Chemistry Lab 2301 tap 10	MVW107	June 11, 2020	0.001	Passed	0.0960	Passed	
Musquodoboit Rural High School	Family Studies 2206 tap 1	WEQ067	June 21, 2023	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Family Studies 2206 tap 2	WEQ068	June 21, 2023	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Family Studies 2206 tap 3	WEQ069	June 21, 2023	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Family Studies 2206 tap 4	WEQ070	June 21, 2023	0.001	Passed	0.0960	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 2100 tap 1	MVW112	June 11, 2020	0.003	Passed	0.1700	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 2100 tap 2	MVW113	June 11, 2020	0.004	Passed	0.2000	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 2100 tap 3	MVW114	June 11, 2020	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Janitors Closet 2112 tap	MVW115	June 11, 2020	0.002	Passed	0.1400	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 2111 tap 1	MVW116	June 11, 2020	0.002	Passed	0.1400	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 2111 tap 2	MVW119	June 11, 2020	0.002	Passed	0.1400	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 2111 tap 3	WEQ071	June 21, 2023	-	Passed	0.2100	Passed	Tap remediated
Musquodoboit Rural High School	Learning Centre Wash Room tap	MVW121	June 11, 2020	0.001	Passed	0.0590	Passed	
Musquodoboit Rural High School	Music Room 1426 tap	MVW122	June 11, 2020	0.003	Passed	0.4800	Passed	
Musquodoboit Rural High School	Cafeteria 1422 tap 1	WEQ052	June 21, 2023	0.002	Passed	0.2300	Passed	
Musquodoboit Rural High School	Cafeteria 1422 tap 2	WEQ053	June 21, 2023	-	Passed	0.1700	Passed	
Musquodoboit Rural High School	Cafeteria 1422 tap 3	WEQ054	June 21, 2023	-	Passed	0.1800	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Musquodoboit Rural High School	Cafeteria 1422 tap 4	WEQ055	June 21, 2023	-	Passed	0.1700	Passed	
Musquodoboit Rural High School	Cafeteria 1422 tap 3	WEQ056	June 21, 2023	-	Passed	0.2100	Passed	
Musquodoboit Rural High School	Male Locker Room 1413 tap	MVW128	June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Female Locker Room 1415 tap	MVW129	June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Male Wash Room 1123 tap 1	MVW132	June 11, 2020	0.003	Passed	0.2200	Passed	
Musquodoboit Rural High School	Male Wash Room 1123 tap 2	MVW133	June 11, 2020	0.002	Passed	0.1300	Passed	
Musquodoboit Rural High School	Male Wash Room 1123 tap 3	MVW134	June 11, 2020	0.002	Passed	0.1700	Passed	
Musquodoboit Rural High School	Janitors Closet 1125 tap	MVW135	June 11, 2020	0.005	Exceeded	0.1400	Passed	Hand washing only
Musquodoboit Rural High School	Female Wash Room 1124 tap 1	MVW136	June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Female Wash Room 1124 tap 2	MVW137	June 11, 2020	0.001	Passed	0.1100	Passed	
Musquodoboit Rural High School	Female Wash Room 1124 tap 3	MVW138	June 11, 2020	0.002	Passed	0.1600	Passed	
Musquodoboit Rural High School	Tech Ed 1303 tap	MVW139	June 11, 2020	0.001	Passed	0.1400	Passed	
Musquodoboit Rural High School	Art Room 1305 tap	MVW140	June 11, 2020	0.001	Passed	0.2100	Passed	
Musquodoboit Rural High School	Class Room 1301 tap 1	MVW141	June 11, 2020	-	Passed	0.2100	Passed	
Musquodoboit Rural High School	Class Room 1301 tap 2	MVW142	June 11, 2020	0.001	Passed	0.1600	Passed	
Musquodoboit Rural High School	Staff Room 112 tap 1	WEQ060	June 21, 2023	0.001	Passed	0.0980	Passed	
Musquodoboit Rural High School	Staff Room 112 tap 2	WEQ061	June 21, 2023	0.001	Passed	0.1300	Passed	
Musquodoboit Rural High School	Staff Room 112 tap 3	WEQ064	June 21, 2023	0.002	Passed	0.1500	Passed	
Musquodoboit Rural High School	Admin Wash Room 1104 tap	MVW146	June 11, 2020	0.001	Passed	0.1400	Passed	
Musquodoboit Rural High School	Seminar Room 1127 tap	WEQ065	June 21, 2023	0.001	Passed	0.1300	Passed	Tap remediated
Musquodoboit Rural High School	Staff Wash Room tap	MVW182	June 11, 2020	0.001	Passed	0.1400	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 1201 tap 1	MVW183	June 11, 2020	0.001	Passed	0.1300	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 1201 tap 2	MVW184	June 11, 2020	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 1201 tap 3	MVW185	June 11, 2020	0.001	Passed	0.1100	Passed	
Musquodoboit Rural High School	Janitors Closet 1203 tap	MVW186	June 11, 2020	0.004	Passed	0.5300	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room 1202 tap 1	MVW187	June 11, 2020	0.004	Passed	0.4200	Passed	
Musquodoboit Rural High School	Fountain by Room 2701	WEQ072	June 21, 2023	-	Passed	0.0580	Passed	
Musquodoboit Rural High School	Fountain by 2nd Floor Wash Rooms	WEQ066	June 21, 2023	-	Passed	0.0058	Passed	
Musquodoboit Rural High School	Fountain by 1st Floor Wash Rooms	WEQ057	June 21, 2023	-	Passed	0.0480	Passed	
Musquodoboit Rural High School	Fountain by Room 1127	WEQ059	June 21, 2023	-	Passed	0.0049	Passed	
Musquodoboit Rural High School	Fountain by Gym	WEQ058	June 21, 2023	0.001	Passed	0.2000	Passed	
Musquodoboit Valley Education Centre	Kitchen 173 tap 1	WEQ038	June 21, 2023	0.001	Passed	0.2600	Passed	
Musquodoboit Valley Education Centre	Kitchen 173 tap 2	WEQ039	June 21, 2023	0.002	Passed	0.2900	Passed	
Musquodoboit Valley Education Centre	Kitchen 173 tap 3	WEQ040	June 21, 2023	-	Passed	0.2700	Passed	
Musquodoboit Valley Education Centre	Fountain by Room 173	WEQ041	June 21, 2023	-	Passed	0.1400	Passed	
Musquodoboit Valley Education Centre	Girls Wash Room tap 1 Room 171	MVV866	June 11, 2020	-	Passed	0.5300	Passed	
Musquodoboit Valley Education Centre	Girls Wash Room tap 2 Room 171	MVV867	June 11, 2020	0.001	Passed	0.7700	Passed	
Musquodoboit Valley Education Centre	Girls Wash Room tap 3 Room 171	MVV868	June 11, 2020	0.001	Passed	0.6400	Passed	
Musquodoboit Valley Education Centre	Girls Wash Room tap 4 Room 171	WEQ043	June 21, 2023	-	Passed	0.2000	Passed	Tap remediated
Musquodoboit Valley Education Centre	Boys Wash Room tap 1 Room 170	MVV870	June 11, 2020	0.001	Passed	0.6000	Passed	
Musquodoboit Valley Education Centre	Boys Wash Room tap 2 Room 170	MVV871	June 11, 2020	0.001	Passed	0.5100	Passed	
Musquodoboit Valley Education Centre	Boys Wash Room tap 3 Room 170	MVV873	June 11, 2020	0.001	Passed	0.6800	Passed	
Musquodoboit Valley Education Centre	Fountain by Room 170	WEQ042	June 21, 2023	-	Passed	0.1000	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Musquodoboit Valley Education Centre	Boys Change Room 185 tap 1	MVV875	June 11, 2020	0.002	Passed	0.6900	Passed	
Musquodoboit Valley Education Centre	Boys Change Room 185 tap 2	MVV876	June 11, 2020	0.001	Passed	0.7400	Passed	
Musquodoboit Valley Education Centre	Gym Office Wash Room tap Room 187	MVV877	June 11, 2020	0.002	Passed	0.6600	Passed	
Musquodoboit Valley Education Centre	Art/Music Room tap	WEQ044	June 21, 2023	0.001	Passed	0.2100	Passed	Tap remediated
Musquodoboit Valley Education Centre	Admin Office Wash Room tap	WEQ037	June 21, 2023	-	Passed	0.1500	Passed	Tap remediated
Musquodoboit Valley Education Centre	Gender Neutral Wash Room tap by Office	MVV882	June 11, 2020	0.002	Passed	0.6900	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room 140 tap 1	MVV883	June 11, 2020	0.001	Passed	0.4100	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room 140 tap 2	MVV884	June 11, 2020	0.001	Passed	0.4900	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room 140 tap 3	MVV885	June 11, 2020	0.002	Passed	0.9200	Passed	
Musquodoboit Valley Education Centre	Fountain by Room 140	WEQ045	June 21, 2023	-	Passed	0.0150	Passed	
Musquodoboit Valley Education Centre	Class Room 142 tap	MVV887	June 11, 2020	0.001	Passed	0.3800	Passed	
Musquodoboit Valley Education Centre	Class Room 153 tap	MVV888	June 11, 2020	0.002	Passed	0.9700	Passed	
Musquodoboit Valley Education Centre	Class Room 155 tap	MVV889	June 11, 2020	0.001	Passed	0.7700	Passed	
Musquodoboit Valley Education Centre	Class Room 156 tap	MVV890	June 11, 2020	0.002	Passed	0.8400	Passed	
Musquodoboit Valley Education Centre	Fountain by Room 156	WEQ046	June 21, 2023	-	Passed	0.0320	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room 141 tap 1	MVV892	June 11, 2020	0.002	Passed	0.4800	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room 141 tap 2	MVV915	June 11, 2020	0.001	Passed	0.6500	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room 141 tap 3	MVV916	June 11, 2020	0.001	Passed	0.7200	Passed	
Musquodoboit Valley Education Centre	Janitors Closet tap by Room 141	MVV917	June 11, 2020	0.001	Passed	0.2200	Passed	
Musquodoboit Valley Education Centre	Staff Room Wash Room 1 tap	MVV918	June 11, 2020	-	Passed	0.1500	Passed	
Musquodoboit Valley Education Centre	Staff Room Wash Room 2 tap	MVV919	June 11, 2020	0.005	Passed	0.4300	Passed	
Musquodoboit Valley Education Centre	Staff Room Kitchen tap	MVV920	June 11, 2020	0.001	Passed	0.2700	Passed	
Musquodoboit Valley Education Centre	Girls Change Room 189 tap 1	SCD285	March 15, 2022	0.001	Passed	0.8400	Passed	
Musquodoboit Valley Education Centre	Girls Change Room 189 tap 2	SCD286	March 15, 2022	0.002	Passed	0.6000	Passed	
Nelson Whynder Elementary	Fountain by Room 108	XDK399	September 29, 2023	-	Passed	0.0760	Passed	
Nelson Whynder Elementary	Staff Room 110 tap	XDH400	September 28, 2023	-	Passed	0.1200	Passed	
Nelson Whynder Elementary	Staff Room 110 Wash Room tap	XDH401	September 28, 2023	-	Passed	0.0640	Passed	
Nelson Whynder Elementary	Staff Wash Room 112 tap	MXU466	June 18, 2020	0.001	Passed	0.1700	Passed	
Nelson Whynder Elementary	Janitors Closet 113 tap	MXU467	June 18, 2020	0.001	Passed	0.1600	Passed	
Nelson Whynder Elementary	Dentist Room tap 1	XDH402	September 28, 2023	-	Passed	0.0540	Passed	
Nelson Whynder Elementary	Dentist Room tap 2	XDH403	September 28, 2023	-	Passed	0.0490	Passed	
Nelson Whynder Elementary	Dentist Room tap 3	XDH404	September 28, 2023	-	Passed	0.0700	Passed	
Nelson Whynder Elementary	Janitors Closet tap by Room 113	MXU471	June 18, 2020	-	Passed	1.0000	Passed	
Nelson Whynder Elementary	Class Room 132 tap	NAI070	June 29, 2020	0.001	Passed	0.5000	Passed	
Nelson Whynder Elementary	Class Room 132 Wash Room tap	NAI071	June 29, 2020	0.001	Passed	0.5500	Passed	
Nelson Whynder Elementary	Class Room 136 Wash Room tap	NAI072	June 29, 2020	0.003	Passed	0.8600	Passed	
Nelson Whynder Elementary	Class Room 136 tap	NAI073	June 29, 2020	0.002	Passed	0.2900	Passed	
Nelson Whynder Elementary	Fountain by Room 138	XJW855	September 28, 2023	-	Passed	0.0640	Passed	
Nelson Whynder Elementary	Boys Wash Room 138 tap 1	NAI074	June 29, 2020	0.001	Passed	0.3100	Passed	
Nelson Whynder Elementary	Boys Wash Room 138 tap 2	NAI075	June 29, 2020	0.001	Passed	0.0920	Passed	
Nelson Whynder Elementary	Boys Wash Room 138 tap 3	NMD527	August 27, 2020	0.000	Passed	0.0160	Passed	
Nelson Whynder Elementary	Caretakers Office / Janitors Closet tap	NAI079	June 29, 2020	0.003	Passed	0.4700	Passed	
Nelson Whynder Elementary	Girls Wash Room 140 tap 1	NAI085	June 29, 2020	0.001	Passed	0.0920	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Nelson Whynder Elementary	Girls Wash Room 140 tap 2	NAI086	June 29, 2020	0.001	Passed	0.1500	Passed	
Nelson Whynder Elementary	Girls Wash Room 140 tap 3	NAI087	June 29, 2020	-	Passed	0.2300	Passed	
Nelson Whynder Elementary	Class Room 150 tap	NAI088	June 29, 2020	0.005	Passed	0.9000	Passed	
Nelson Whynder Elementary	Class Room tap left of Room 149	QWQ917	October 8, 2021	-	Passed	0.0044	Passed	
Nelson Whynder Elementary	Class Room tap Room 149	QWQ918	October 8, 2021	-	Passed	-	Passed	
Nelson Whynder Elementary	Class Room 148 tap	NAI102	June 29, 2020	0.002	Passed	0.3400	Passed	
Nelson Whynder Elementary	Fountain by Gym	XDK406	September 29, 2023	-	Passed	-	Passed	
Nelson Whynder Elementary	Girls Locker Room tap	NAI090	June 29, 2020	0.004	Passed	0.1900	Passed	
Nelson Whynder Elementary	Gym Office Wash Room tap	NAI091	June 29, 2020	0.004	Passed	0.2900	Passed	
Nelson Whynder Elementary	Boys Locker Room tap	XDK407	September 29, 2023	-	Passed	0.0670	Passed	Tap remediated
Nelson Whynder Elementary	Class Room 137 tap	XDK405	September 29, 2023	-	Passed	0.0440	Passed	Tap remediated
Nelson Whynder Elementary	Class Room 134 tap	NAI104	June 29, 2020	0.001	Passed	1.7000	Passed	
Nelson Whynder Elementary	Class Room 131 tap	NAI105	June 29, 2020	0.003	Passed	0.8400	Passed	
Nelson Whynder Elementary	Learning Centre 129 tap	XDK415	September 29, 2023	-	Passed	0.0470	Passed	
Nelson Whynder Elementary	Learning Centre 129 Wash Room tap	NAI108	June 29, 2020	0.001	Passed	0.1800	Passed	
Nelson Whynder Elementary	Gender Neutral Wash Room 1 tap (by Learning Centre)	XDK408	September 29, 2023	0.001	Passed	0.0710	Passed	Tap remediated
Nelson Whynder Elementary	Gender Neutral Wash Room 2 tap (by Learning Centre)	XDK409	September 29, 2023	0.001	Passed	0.2000	Passed	Tap remediated
Nelson Whynder Elementary	Wash Room 105 tap	QWQ916	October 18, 2021	0.002	Passed	0.2800	Passed	
Nelson Whynder Elementary	Cafe/Kitchen tap 1 (by Gym)	XDK411	September 29, 2023	-	Passed	0.0530	Passed	
Nelson Whynder Elementary	Cafe/Kitchen tap 2 (by Gym)	XDK412	September 29, 2023	-	Passed	0.0580	Passed	
Nelson Whynder Elementary	Cafe/Kitchen tap 3 (by Gym)	XDK413	September 29, 2023	0.005	Passed	0.0740	Passed	
Nelson Whynder Elementary	Cafe/Kitchen tap 4 (by Gym)	XDK414	September 29, 2023	0.001	Passed	0.0550	Passed	Tap remediated
Ocean View Elementary	2nd Floor Boys Wash Room tap 1 by Room 212	WEQ079	June 21, 2023	0.001	Passed	0.3100	Passed	Tap remediated
Ocean View Elementary	2nd Floor Boys Wash Room tap 2 by Room 212	MYA660	June 22, 2020	0.002	Passed	0.4700	Passed	
Ocean View Elementary	2nd Floor Boys Wash Room tap 3 by Room 212	MYA661	June 22, 2020	0.001	Passed	0.2400	Passed	
Ocean View Elementary	Janitors Closet tap by Room 212	MYA662	June 22, 2020	0.001	Passed	0.4200	Passed	
Ocean View Elementary	2nd Floor Girls Wash Room tap 1 by Room 212	WEQ076	June 21, 2023	0.002	Passed	0.0450	Passed	Tap remediated
Ocean View Elementary	2nd Floor Girls Wash Room tap 2 by Room 212	WEQ077	June 21, 2023	0.003	Passed	0.0480	Passed	Tap remediated
Ocean View Elementary	2nd Floor Girls Wash Room tap 3 by Room 212	WEQ078	June 21, 2023	0.010	Exceeded	0.1200	Passed	Hand washing only
Ocean View Elementary	Art Room tap 1	WEQ093	June 21, 2023	0.001	Passed	0.0310	Passed	Tap remediated
Ocean View Elementary	Art Room tap 2	WEQ094	June 21, 2023	-	Passed	0.0220	Passed	Tap remediated
Ocean View Elementary	2nd Floor Girls Wash Room tap 1 by Room 203	WEQ081	June 21, 2023	0.017	Exceeded	0.4200	Passed	Hand washing only
Ocean View Elementary	2nd Floor Girls Wash Room tap 2 by Room 203	WEQ082	June 21, 2023	0.006	Exceeded	0.2400	Passed	Hand washing only
Ocean View Elementary	2nd Floor Girls Wash Room tap 3 by Room 203	WEQ083	June 21, 2023	0.003	Passed	0.1100	Passed	Tap remediated
Ocean View Elementary	Janitors Closet tap by Room 203	MYA673	June 22, 2020	0.002	Passed	0.2900	Passed	
Ocean View Elementary	2nd Floor Boys Wash Room tap 1 by Room 203	MYA674	June 22, 2020	0.001	Passed	0.2300	Passed	
Ocean View Elementary	2nd Floor Boys Wash Room tap 2 by Room 203	MYA675	June 22, 2020	0.001	Passed	0.2000	Passed	
Ocean View Elementary	2nd Floor Boys Wash Room tap 3 by Room 203	MYA676	June 22, 2020	0.001	Passed	0.2600	Passed	
Ocean View Elementary	Gym Office tap	WEQ084	June 21, 2023	0.003	Passed	0.1200	Passed	Tap remediated
Ocean View Elementary	Gender Neutral Wash Room tap near Gym	MYA678	June 22, 2020	0.003	Passed	0.1100	Passed	
Ocean View Elementary	Learning Centre Wash Room tap	MYA679	June 22, 2020	0.002	Passed	0.0790	Passed	
Ocean View Elementary	Kitchen by Room 101 tap 1	MYA681	June 22, 2020	0.002	Passed	0.1100	Passed	
Ocean View Elementary	Kitchen by Room 101 tap 2	MYA682	June 22, 2020	0.001	Passed	0.1200	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ocean View Elementary	Class Room 103 Wash Room tap	MYA684	June 22, 2020	0.001	Passed	0.0900	Passed	
Ocean View Elementary	Class Room 103 tap	MYA685	June 22, 2020	0.001	Passed	0.0670	Passed	
Ocean View Elementary	Class Room 105 Wash Room tap	MYA686	June 22, 2020	0.001	Passed	0.0670	Passed	
Ocean View Elementary	Class Room 105 tap	MYA687	June 22, 2020	0.003	Passed	0.0660	Passed	
Ocean View Elementary	Class Room 107 Wash Room tap	MYA688	June 22, 2020	0.001	Passed	0.0500	Passed	
Ocean View Elementary	Class Room 107 tap	MYA689	June 22, 2020	0.001	Passed	0.0590	Passed	
Ocean View Elementary	1st Floor Boys Wash Room tap 1	MYA690	June 22, 2020	0.002	Passed	0.2300	Passed	
Ocean View Elementary	1st Floor Boys Wash Room tap 2	MYA703	June 22, 2020	0.002	Passed	0.1300	Passed	
Ocean View Elementary	1st Floor Boys Wash Room tap 3	MYA704	June 22, 2020	0.001	Passed	0.0510	Passed	
Ocean View Elementary	1st Floor Boys Wash Room tap 4	MYA705	June 22, 2020	0.001	Passed	0.0660	Passed	
Ocean View Elementary	1st Floor Boys Wash Room tap 5	MYA706	June 22, 2020	0.001	Passed	0.0570	Passed	
Ocean View Elementary	Janitors Closet tap by 1st Floor Wash Rooms	MYA707	June 22, 2020	-	Passed	0.0150	Passed	
Ocean View Elementary	1st Floor Girls Wash Room tap 1	WEQ091	June 21, 2023	0.001	Passed	0.0630	Passed	Tap remediated
Ocean View Elementary	1st Floor Girls Wash Room tap 2	WEQ092	June 21, 2023	0.001	Passed	0.0310	Passed	Tap remediated
Ocean View Elementary	1st Floor Girls Wash Room tap 3	MYA711	June 22, 2020	0.004	Passed	0.0480	Passed	
Ocean View Elementary	1st Floor Girls Wash Room tap 4	MYA712	June 22, 2020	0.002	Passed	0.0300	Passed	
Ocean View Elementary	1st Floor Girls Wash Room tap 5	MYA714	June 22, 2020	0.002	Passed	0.0140	Passed	
Ocean View Elementary	Staff Room tap	WEQ085	June 21, 2023	-	Passed	0.0240	Passed	
Ocean View Elementary	Staff Room Wash Room 1 tap	MYA716	June 22, 2020	0.002	Passed	0.0920	Passed	
Ocean View Elementary	Staff Room Wash Room 2 tap	MYA717	June 22, 2020	0.001	Passed	0.0550	Passed	
Ocean View Elementary	Sick Room tap	WEQ086	June 21, 2023	-	Passed	0.0260	Passed	
Ocean View Elementary	Class Room 112 Wash Room tap	WEQ088	June 21, 2023	-	Passed	0.0210	Passed	Tap remediated
Ocean View Elementary	Class Room tap Room 112	MYA720	June 22, 2020	-	Passed	0.0800	Passed	
Ocean View Elementary	Class Room 110 Wash Room tap	MYA721	June 22, 2020	0.001	Passed	0.1000	Passed	
Ocean View Elementary	Class Room tap Room 110	MYA722	June 22, 2020	0.002	Passed	0.2100	Passed	
Ocean View Elementary	Fountain by Room 103	WEQ089	June 21, 2023	0.002	Passed	0.0009	Passed	
Ocean View Elementary	Fountain by Room 110	WEQ087	June 21, 2023	-	Passed	0.0006	Passed	
Ocean View Elementary	Fountain by Room 203	WEQ080	June 21, 2023	-	Passed	0.0012	Passed	
Ocean View Elementary	Fountain by Room 212	WEQ075	June 21, 2023	-	Passed	0.0006	Passed	
Ocean View Elementary	Fountain by 1st Floor Wash Rooms	WEQ090	June 21, 2023	-	Passed	-	Passed	
O'Connell Drive Elementary	Library Wash Room 191 tap	MXK240	June 18, 2020	0.001	Passed	0.0920	Passed	
O'Connell Drive Elementary	Janitors Closet 181 tap	MXK241	June 18, 2020	0.001	Passed	0.0840	Passed	
O'Connell Drive Elementary	Class Room Wash Room 175 tap	MXK242	June 18, 2020	0.003	Passed	0.1800	Passed	
O'Connell Drive Elementary	Class Room 177A tap	MXK243	June 18, 2020	0.002	Passed	0.0870	Passed	
O'Connell Drive Elementary	Class Room Wash Room 174 tap	MXK245	June 18, 2020	0.001	Passed	0.1000	Passed	
O'Connell Drive Elementary	Boys Wash Room 166 tap 1	MXK246	June 18, 2020	0.001	Passed	0.0390	Passed	
O'Connell Drive Elementary	Boys Wash Room 166 tap 2	MXK247	June 18, 2020	-	Passed	0.0170	Passed	
O'Connell Drive Elementary	Girls Wash Room 167 tap 1	MXK248	June 18, 2020	-	Passed	0.0210	Passed	
O'Connell Drive Elementary	Girls Wash Room 167 tap 2	MXK249	June 18, 2020	-	Passed	0.0200	Passed	
O'Connell Drive Elementary	Fountain by Library	WGN187	June 28, 2023	-	Passed	0.3900	Passed	
O'Connell Drive Elementary	Cafe/Kitchen tap 1 (by door)	WGN189	June 28, 2023	-	Passed	0.0660	Passed	
O'Connell Drive Elementary	Cafe/Kitchen tap 2	WGN190	June 28, 2023	-	Passed	0.0520	Passed	
O'Connell Drive Elementary	Cafe/Kitchen tap 3	WGN191	June 28, 2023	-	Passed	0.0430	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
O'Connell Drive Elementary	Boys Locker Room Wash Room 156 tap	MXK253	June 18, 2020	0.001	Passed	0.0470	Passed	
O'Connell Drive Elementary	Girls Lockers Room Wash Room 159 tap	MXK254	June 18, 2020	0.002	Passed	0.1700	Passed	
O'Connell Drive Elementary	Gym Office 161 Wash Room tap	MXK255	June 18, 2020	0.001	Passed	0.0530	Passed	
O'Connell Drive Elementary	Music Room 149 tap	MXK256	June 18, 2020	-	Passed	0.0290	Passed	
O'Connell Drive Elementary	Class Room 140 tap	MXK257	June 18, 2020	0.004	Passed	0.2700	Passed	
O'Connell Drive Elementary	Girls Wash Room 137 tap 1	MXK259	June 18, 2020	0.001	Passed	0.1800	Passed	
O'Connell Drive Elementary	Girls Wash Room 137 tap 2	MXK260	June 18, 2020	-	Passed	0.0910	Passed	
O'Connell Drive Elementary	Girls Wash Room 137 tap 3	MXK261	June 18, 2020	-	Passed	0.0710	Passed	
O'Connell Drive Elementary	Boys Wash Room 135 tap 1	MXK262	June 18, 2020	0.001	Passed	0.1700	Passed	
O'Connell Drive Elementary	Boys Wash Room 135 tap 2	MXK263	June 18, 2020	-	Passed	0.0810	Passed	
O'Connell Drive Elementary	Boys Wash Room 135 tap 3	MXK264	June 18, 2020	-	Passed	0.0590	Passed	
O'Connell Drive Elementary	Janitors Closet 126 tap	MXK266	June 18, 2020	0.001	Passed	0.1700	Passed	
O'Connell Drive Elementary	Staff Room 115A Kitchen tap	WGN182	June 28, 2023	-	Passed	0.0420	Passed	
O'Connell Drive Elementary	Main Office Wash Room 114 tap	MXK268	June 18, 2020	-	Passed	0.0230	Passed	
O'Connell Drive Elementary	Main Office Wash Room 113 tap	MXK269	June 18, 2020	0.001	Passed	0.0280	Passed	
O'Connell Drive Elementary	Main Office Wash Room 111	MXK584	June 18, 2020	0.002	Passed	0.0480	Passed	
O'Connell Drive Elementary	Fountain by Boys Wash Room 135	WGN185	June 28, 2023	-	Passed	0.5000	Passed	
O'Connell Drive Elementary	Class Room 139 Wash Room tap	ROM521	January 12, 2022	0.004	Passed	0.3700	Passed	
O'Connell Drive Elementary	Class Room 173 tap	WGN188	June 28, 2023	-	Passed	0.0880	Passed	Tap remediated
Oldfield Consolidated School	Teachers Room 16 tap	MWG681	June 12, 2020	-	Passed	0.0026	Passed	
Oldfield Consolidated School	Staff Wash Room tap Room 14	MWG682	June 12, 2020	-	Passed	0.0024	Passed	
Oldfield Consolidated School	Girls Wash Room tap 1 Room 12	MWG683	June 12, 2020	-	Passed	0.0045	Passed	
Oldfield Consolidated School	Girls Wash Room tap 2 Room 12	MWG684	June 12, 2020	-	Passed	0.0027	Passed	
Oldfield Consolidated School	Girls Wash Room tap 3 Room 12	MWG685	June 12, 2020	-	Passed	0.0031	Passed	
Oldfield Consolidated School	Girls Wash Room tap 4 Room 12	MWG686	June 12, 2020	-	Passed	0.0026	Passed	
Oldfield Consolidated School	Janitors Closet tap Room 10	MWG687	June 12, 2020	0.002	Passed	0.0041	Passed	
Oldfield Consolidated School	Boys Wash Room tap 1 Room 8	MWG688	June 12, 2020	-	Passed	0.0034	Passed	
Oldfield Consolidated School	Boys Wash Room tap 2 Room 8	MWG689	June 12, 2020	-	Passed	0.0050	Passed	
Oldfield Consolidated School	Boys Wash Room tap 3 Room 8	MWG690	June 12, 2020	0.001	Passed	0.0078	Passed	
Oldfield Consolidated School	Learning Centre tap Room 6	MWG691	June 12, 2020	-	Passed	0.0026	Passed	
Oxford School	3rd Floor Girls Wash Room tap 1 (East)	MSZ272	May 28, 2020	0.002	Passed	0.4200	Passed	
Oxford School	3rd Floor Girls Wash Room tap 2 (East)	MSZ273	May 28, 2020	0.004	Passed	0.2800	Passed	
Oxford School	3rd Floor Staff Wash Room tap	MSZ274	May 28, 2020	0.001	Passed	0.0220	Passed	
Oxford School	3rd Floor Boys Wash Room tap 1 (East)	MSZ277	May 28, 2020	0.002	Passed	0.0690	Passed	
Oxford School	3rd Floor Boys Wash Room tap 2 (East)	MSZ278	May 28, 2020	0.004	Passed	0.2000	Passed	
Oxford School	Janitors Closet tap by Room 305	MSZ279	May 28, 2020	0.001	Passed	0.0560	Passed	
Oxford School	3rd Floor Boys Wash Room tap 1 (West)	MSZ281	May 28, 2020	-	Passed	0.0430	Passed	
Oxford School	3rd Floor Boys Wash Room tap 2 (West)	MSZ296	May 28, 2020	0.001	Passed	0.0560	Passed	
Oxford School	3rd Floor Boys Wash Room tap 3 (West)	MSZ297	May 28, 2020	0.001	Passed	0.0480	Passed	
Oxford School	3rd Floor Girls Wash Room tap 1 (West)	MSZ299	May 28, 2020	0.002	Passed	0.0460	Passed	
Oxford School	3rd Floor Girls Wash Room tap 2 (West)	MSZ300	May 28, 2020	-	Passed	0.0470	Passed	
Oxford School	3rd Floor Girls Wash Room tap 3 (West)	MSZ301	May 28, 2020	0.002	Passed	0.1500	Passed	
Oxford School	Class Room Wash Room tap Room 314	MSZ302	May 28, 2020	-	Passed	0.0660	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Oxford School	2nd Floor Boys Wash Room tap 2 (East)	MSZ304	May 28, 2020	-	Passed	0.0032	Passed	
Oxford School	Janitors Closet tap by Room 206	MSZ310	May 28, 2020	0.002	Passed	0.0270	Passed	
Oxford School	2nd Floor Girls Wash Room tap 1 (East)	MSZ312	May 28, 2020	0.001	Passed	0.1500	Passed	
Oxford School	2nd Floor Girls Wash Room tap 2 (East)	MSZ313	May 28, 2020	0.001	Passed	0.1600	Passed	
Oxford School	2nd Floor Janitors Closet tap by Room 206	MSZ314	May 28, 2020	0.050	Exceeded	1.4000	Passed	Hand washing only
Oxford School	2nd Floor Staff Wash Room tap 1 by Room 210	MSZ315	May 28, 2020	0.001	Passed	0.1400	Passed	
Oxford School	2nd Floor Staff Wash Room tap 2 by Room 210	MSZ316	May 28, 2020	0.002	Passed	0.4400	Passed	
Oxford School	2nd Floor Staff Wash Room tap 3 by Room 210	MSZ317	May 28, 2020	0.004	Passed	0.3400	Passed	
Oxford School	2nd Floor Boys Wash Room tap 1 by Room 217	MSZ318	May 28, 2020	0.001	Passed	0.0690	Passed	
Oxford School	2nd Floor Boys Wash Room tap 2 by Room 217	MSZ319	May 28, 2020	0.001	Passed	0.0610	Passed	
Oxford School	2nd Floor Boys Wash Room tap 3 by Room 217	MSZ320	May 28, 2020	-	Passed	0.0490	Passed	
Oxford School	Janitors Closet tap by Room 217	MSZ321	May 28, 2020	-	Passed	0.0520	Passed	
Oxford School	Girls Wash Room tap 1 by Room 215	MSZ323	May 28, 2020	-	Passed	0.0410	Passed	
Oxford School	Girls Wash Room tap 2 by Room 215	MSZ324	May 28, 2020	0.002	Passed	0.1000	Passed	
Oxford School	Girls Wash Room tap 3 by Room 215	MSZ325	May 28, 2020	0.001	Passed	0.1200	Passed	
Oxford School	Gym Girls Locker Room tap	MSZ329	May 28, 2020	0.001	Passed	0.2300	Passed	
Oxford School	Basement Boiler Room tap	MSZ330	May 28, 2020	0.001	Passed	0.5600	Passed	
Oxford School	1st Floor Boys Wash Room tap 1 by Room 104	MSZ331	May 28, 2020	0.004	Passed	0.8000	Passed	
Oxford School	1st Floor Boys Wash Room tap 2 by Room 104	MSZ332	May 28, 2020	-	Passed	0.0590	Passed	
Oxford School	Staff Room 109 Wash Room tap	MSZ334	May 28, 2020	-	Passed	0.0220	Passed	
Oxford School	Boys Wash Room tap 1 by Room 111	MSZ335	May 28, 2020	0.001	Passed	0.0900	Passed	
Oxford School	Boys Wash Room tap 2 by Room 111	MSZ336	May 28, 2020	0.001	Passed	0.1100	Passed	
Oxford School	Boys Wash Room tap 3 by Room 111	MSZ337	May 28, 2020	0.001	Passed	0.0640	Passed	
Oxford School	1st Floor Janitors Closet tap by Room 111	MSZ338	May 28, 2020	0.001	Passed	0.0790	Passed	
Oxford School	1st Floor Girls Wash Room tap 1 by Room 111	MSZ340	May 28, 2020	0.003	Passed	0.2600	Passed	
Oxford School	1st Floor Girls Wash Room tap 2 by Room 111	MSZ341	May 28, 2020	0.001	Passed	0.1200	Passed	
Oxford School	1st Floor Girls Wash Room tap 3 by Room 111	MSZ342	May 28, 2020	0.001	Passed	0.0480	Passed	
Oxford School	Gym Boys Locker Room tap	MSZ344	May 28, 2020	0.001	Passed	0.2700	Passed	
Oxford School	Fountain by Room 317	WGM891	June 28, 2023	-	Passed	0.0350	Passed	
Oxford School	Fountain by Room 303	VVK662	May 16, 2023	-	Passed	0.0120	Passed	
Oxford School	Fountain by Room 206	VVK663	May 16, 2023	-	Passed	0.0020	Passed	
Oxford School	Family Studies tap 1 Room 204	VVK664	May 16, 2023	0.001	Passed	0.0220	Passed	
Oxford School	Family Studies tap 2 Room 204	VVK665	May 16, 2023	-	Passed	0.0160	Passed	
Oxford School	Family Studies tap 3 Room 204	VVK666	May 16, 2023	-	Passed	0.0170	Passed	
Oxford School	Family Studies tap 4 Room 204	VVK667	May 16, 2023	-	Passed	0.0150	Passed	
Oxford School	Fountain by Room 217	VVK668	May 16, 2023	-	Passed	0.0007	Passed	
Oxford School	Staff Room tap Room 312	VVK669	May 16, 2023	0.001	Passed	0.1800	Passed	
Oxford School	3rd Floor Staff Wash Room 2 tap	VVK670	May 16, 2023	-	Passed	0.0054	Passed	Tap remediated
Oxford School	Art Room tap Room 202	VVK671	May 16, 2023	-	Passed	0.0160	Passed	Tap remediated
Oxford School	2nd Floor Boys Wash Room tap 1 (East)	VVK672	May 16, 2023	-	Passed	0.0066	Passed	Tap remediated
Oxford School	Staff Room 109 tap	VVK673	May 16, 2023	-	Passed	0.0190	Passed	
Oxford School	1st Floor Office tap	VVK674	May 16, 2023	-	Passed	0.0190	Passed	
Oxford School	Gym Kitchen tap	VVK675	May 16, 2023	-	Passed	0.1100	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Oxford School	Fountain by Gym	VVK676	May 16, 2023	-	Passed	0.0011	Passed	
Oxford School	Fountain by Room 111	VVK677	May 16, 2023	-	Passed	0.0008	Passed	
Oyster Pond Academy	Class Room 2201 tap 1	NAH599	June 29, 2020	0.002	Passed	0.2100	Passed	
Oyster Pond Academy	Class Room 2201 tap 2	NAH600	June 29, 2020	0.004	Passed	0.6400	Passed	
Oyster Pond Academy	Staff Wash Room 2106 tap	NAH601	June 29, 2020	0.004	Passed	0.8600	Passed	
Oyster Pond Academy	Food Lab 2203 tap 1	XGU479	October 12, 2023	0.001	Passed	0.4600	Passed	
Oyster Pond Academy	Food Lab 2203 tap 2	XGU480	October 12, 2023	0.001	Passed	0.3900	Passed	
Oyster Pond Academy	Food Lab 2203 tap 3	XGU481	October 12, 2023	0.001	Passed	0.4200	Passed	
Oyster Pond Academy	Food Lab 2203 tap 4	XGU482	October 12, 2023	0.002	Passed	0.4300	Passed	
Oyster Pond Academy	Class Room 2209 tap 1	XGU479	June 29, 2020	0.001	Passed	0.3900	Passed	
Oyster Pond Academy	Class Room 2209 tap 2	RWQ470	February 16, 2022	0.002	Passed	0.5400	Passed	
Oyster Pond Academy	Class Room 2209 tap 3	XGU480	June 29, 2020	0.003	Passed	1.5000	Passed	
Oyster Pond Academy	Class Room 2209 tap 4	NAH628	June 29, 2020	0.002	Passed	1.1000	Passed	
Oyster Pond Academy	Class Room 2209 tap 5	NAH629	June 29, 2020	0.003	Passed	0.4300	Passed	
Oyster Pond Academy	Class Room Wash Room 2303 tap	RWQ430	February 16, 2022	0.001	Passed	0.5100	Passed	
Oyster Pond Academy	Girls Wash Room tap 1 by Room 2104	RWQ431	February 16, 2022	0.006	Exceeded	1.0000	Passed	Hand washing only
Oyster Pond Academy	Girls Wash Room tap 2 by Room 2104	RWQ432	February 16, 2022	0.006	Exceeded	0.8000	Passed	Hand washing only
Oyster Pond Academy	Girls Wash Room tap 3 by Room 2104	RWQ433	February 16, 2022	0.003	Passed	0.8200	Passed	
Oyster Pond Academy	Janitors Closet 2104 tap	RWQ434	February 16, 2022	0.068	Exceeded	1.7000	Passed	Hand washing only
Oyster Pond Academy	Boys Wash Room tap 1 by Room 2104	RWQ435	February 16, 2022	0.004	Passed	0.7800	Passed	
Oyster Pond Academy	Boys Wash Room tap 2 by Room 2104	RWQ436	February 16, 2022	0.004	Passed	0.6300	Passed	
Oyster Pond Academy	Boys Wash Room tap 3 by Room 2104	RWQ437	February 16, 2022	0.004	Passed	0.6400	Passed	
Oyster Pond Academy	Boys Wash Room tap 1 by Room 2114	XGU648	October 12, 2023	0.010	Exceeded	1.6000	Passed	Hand washing only
Oyster Pond Academy	Boys Wash Room tap 2 by Room 2114	XGU477	October 12, 2023	0.010	Exceeded	1.5000	Passed	Hand washing only
Oyster Pond Academy	Boys Wash Room tap 3 by Room 2114	XGU478	October 12, 2023	0.025	Exceeded	1.9000	Passed	Hand washing only
Oyster Pond Academy	Janitors Closet 2114 tap	XGU635	October 12, 2023	0.040	Exceeded	1.0000	Passed	Hand washing only
Oyster Pond Academy	Girls Wash Room tap 1 by Room 2114	XGU637	October 12, 2023	0.021	Exceeded	2.4000	Exceeded	Hand washing only
Oyster Pond Academy	Girls Wash Room tap 2 by Room 2114	XGU638	October 12, 2023	0.020	Exceeded	2.6000	Exceeded	Hand washing only
Oyster Pond Academy	Girls Wash Room tap 3 by Room 2114	XGU640	October 12, 2023	0.018	Exceeded	2.5000	Exceeded	Hand washing only
Oyster Pond Academy	Staff Wash Room 2111 tap	RWQ469	February 16, 2022	0.001	Passed	0.3800	Passed	
Oyster Pond Academy	Recycle Room 1422 tap	NAH641	June 29, 2020	-	Passed	0.5700	Passed	
Oyster Pond Academy	Kitchen 1420 single compartment sink 1 tap	XGU743	October 12, 2023	0.001	Passed	0.6100	Passed	
Oyster Pond Academy	Kitchen 1420 single compartment sink 2 tap	XGU745	October 12, 2023	0.002	Passed	0.5600	Passed	
Oyster Pond Academy	Kitchen 1420 triple compartment sink tap	XGU747	October 12, 2023	0.001	Passed	0.6800	Passed	
Oyster Pond Academy	Janitors Closet 1421 tap	XGU748	October 12, 2023	0.005	Passed	0.5700	Passed	Tap remediated
Oyster Pond Academy	Laundry Tub Room 1424 tap	XGU740	October 12, 2023	0.017	Exceeded	2.4000	Exceeded	Hand washing only
Oyster Pond Academy	Class Room 1307 tap	RWQ476	February 16, 2022	0.001	Passed	0.4400	Passed	
Oyster Pond Academy	Class Room 1309 tap	RWQ477	February 16, 2022	0.001	Passed	0.7200	Passed	
Oyster Pond Academy	Class Room 1313 tap	RWQ478	February 16, 2022	0.003	Passed	0.9400	Passed	
Oyster Pond Academy	Class Room 1310 tap	XGU485	October 12, 2023	0.001	Passed	0.6900	Passed	
Oyster Pond Academy	Gender Neutral Wash Room 1303 tap	NAH650	June 29, 2020	0.002	Passed	0.3600	Passed	
Oyster Pond Academy	Class Room 1301 tap	NAH651	June 29, 2020	0.001	Passed	1.9000	Passed	
Oyster Pond Academy	Class Room 1314 tap	XGU485	October 12, 2023	0.001	Passed	0.7500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Oyster Pond Academy	Class Room 1308 tap	NAH683	June 29, 2020	0.003	Passed	1.1000	Passed	
Oyster Pond Academy	Class Room Wash Room 1306 tap	NAH684	June 29, 2020	0.002	Passed	0.7200	Passed	
Oyster Pond Academy	Class Room Wash Room 1305 tap	NAH685	June 29, 2020	0.003	Passed	0.9500	Passed	
Oyster Pond Academy	Class Room 1302 tap	NAH686	June 29, 2020	0.003	Passed	0.9400	Passed	
Oyster Pond Academy	Girls Wash Room 1135 tap 1	XGE441	October 12, 2023	0.008	Exceeded	1.6000	Passed	Hand washing only
Oyster Pond Academy	Girls Wash Room 1135 tap 2	XGE726	October 12, 2023	0.008	Exceeded	1.6000	Passed	Hand washing only
Oyster Pond Academy	Girls Wash Room 1135 tap 3	RWQ482	February 16, 2022	0.004	Passed	0.9600	Passed	
Oyster Pond Academy	Janitors Closet 1133 tap	RWQ483	February 16, 2022	0.002	Passed	0.3500	Passed	
Oyster Pond Academy	Boys Wash Room 1134 tap 1	XGE728	October 12, 2023	0.009	Exceeded	1.4000	Passed	Hand washing only
Oyster Pond Academy	Boys Wash Room 1134 tap 2	XGE729	October 12, 2023	0.019	Exceeded	1.6000	Passed	Hand washing only
Oyster Pond Academy	Boys Wash Room 1134 tap 3	XGE731	October 12, 2023	0.015	Exceeded	1.6000	Passed	Hand washing only
Oyster Pond Academy	Staff Wash Room 1132 tap	RWQ487	February 16, 2022	0.002	Passed	0.4100	Passed	
Oyster Pond Academy	Staff Wash Room 1109 tap	RWQ488	February 16, 2022	0.002	Passed	0.8100	Passed	
Oyster Pond Academy	Staff Room 1113 tap	XGU483	October 12, 2023	0.001	Passed	0.5300	Passed	
Oyster Pond Academy	Staff Wash Room 1115 tap	RWQ490	February 16, 2022	0.001	Passed	0.4600	Passed	
Oyster Pond Academy	Staff Wash Room 1114 tap	RWQ491	February 16, 2022	0.001	Passed	0.4700	Passed	
Oyster Pond Academy	Class Room 1122 tap	RWQ492	February 16, 2022	0.004	Passed	1.0000	Passed	
Oyster Pond Academy	Wood Shop 1201 Laundry Tub tap	XGU484	October 12, 2023	0.005	Exceeded	0.4200	Passed	Hand washing only
Oyster Pond Academy	Girls Wash Room 1127 tap 1	XGU432	October 12, 2023	0.007	Exceeded	0.9600	Passed	Hand washing only
Oyster Pond Academy	Girls Wash Room 1127 tap 2	XGU433	October 12, 2023	0.018	Exceeded	1.1000	Passed	Hand washing only
Oyster Pond Academy	Girls Wash Room 1127 tap 3	XGU434	October 12, 2023	0.010	Exceeded	0.9200	Passed	Hand washing only
Oyster Pond Academy	Janitors Closet 1125 tap	RWQ514	February 16, 2022	0.003	Passed	0.3900	Passed	
Oyster Pond Academy	Boys Wash Room 1126 tap 1	XGU435	October 12, 2023	0.024	Exceeded	3.3000	Exceeded	Hand washing only
Oyster Pond Academy	Boys Wash Room 1126 tap 2	XGU436	October 12, 2023	0.011	Exceeded	3.4000	Exceeded	Hand washing only
Oyster Pond Academy	Boys Wash Room 1126 tap 3	XGU437	October 12, 2023	0.019	Exceeded	3.8000	Exceeded	Hand washing only
Oyster Pond Academy	Class Room Wash Room 1205 tap	NAH732	June 29, 2020	0.004	Passed	1.6000	Passed	
Oyster Pond Academy	Class Room 1203 tap	NAH733	June 29, 2020	0.004	Passed	1.5000	Passed	
Oyster Pond Academy	Boys Locker Room 1413 tap 1	XGU620	October 12, 2023	0.140	Exceeded	3.1000	Exceeded	Hand washing only
Oyster Pond Academy	Boys Locker Room 1413 tap 2	XGU622	October 12, 2023	0.060	Exceeded	3.7000	Exceeded	Hand washing only
Oyster Pond Academy	Girls Locker Room 1410 tap 1	XGU785	October 12, 2023	0.025	Exceeded	2.0000	Exceeded	Hand washing only
Oyster Pond Academy	Girls Locker Room 1410 tap 2	XGU615	October 12, 2023	0.032	Exceeded	2.0000	Exceeded	Hand washing only
Oyster Pond Academy	Class Room Wash Room 1404 tap	RWQ522	February 16, 2022	0.003	Passed	0.3800	Passed	
Oyster Pond Academy	Class Room 1129 tap	NAH715	June 29, 2020	0.003	Passed	1.1000	Passed	
Oyster Pond Academy	Fountain by Room 1133	XGU440	October 12, 2023	-	Passed	1.4000	Passed	
Oyster Pond Academy	Fountain by Room 1125	XGU439	October 12, 2023	-	Passed	2.3000	Exceeded	
Oyster Pond Academy	Fountain by Room 2104	XGU632	October 12, 2023	-	Passed	1.5000	Passed	
Oyster Pond Academy	Fountain by Room 2114	XGU633	October 12, 2023	-	Passed	1.1000	Passed	
Oyster Pond Academy	Fountain by Gym Entrance	XGU438	October 12, 2023	-	Passed	0.5600	Passed	
Park West School	Main Office Wash Room 1090 tap	MQJ269	May 15, 2020	-	Passed	0.0340	Passed	
Park West School	Kitchen 1080 hand sink tap	WAT163	June 6, 2023	-	Passed	0.0110	Passed	
Park West School	Kitchen 1080 MKE sink tap	WAT164	June 6, 2023	-	Passed	0.0065	Passed	
Park West School	Kitchen 1080 hand dish sink tap	WAT165	June 6, 2023	-	Passed	0.0310	Passed	
Park West School	Girls Wash Room 1067 tap	MQJ273	May 15, 2020	0.003	Passed	0.3300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Park West School	Boys Wash Room 1068 tap	MQJ274	May 15, 2020	-	Passed	0.0910	Passed	
Park West School	Class Room 1069 tap 1	MQJ275	May 15, 2020	-	Passed	0.1100	Passed	
Park West School	Class Room 1069 tap 2	MQJ276	May 15, 2020	-	Passed	0.0760	Passed	
Park West School	Music Room 1070 tap	MQJ277	May 15, 2020	-	Passed	0.0780	Passed	
Park West School	Library Work Room 1041 tap	MQJ278	May 15, 2020	-	Passed	0.3400	Passed	
Park West School	Class Room 1014 tap	MQJ279	May 15, 2020	-	Passed	0.2400	Passed	
Park West School	Class Room 1013 tap	MQJ280	May 15, 2020	-	Passed	0.0420	Passed	
Park West School	Class Room 1016 tap	MQJ281	May 15, 2020	-	Passed	0.1800	Passed	
Park West School	Class Room 1012 tap	MQJ282	May 15, 2020	-	Passed	0.1900	Passed	
Park West School	Class Room 1011 tap	MQJ283	May 15, 2020	-	Passed	0.1100	Passed	
Park West School	Girls Wash Room 1048 tap 1	MQJ285	May 15, 2020	-	Passed	0.1600	Passed	
Park West School	Girls Wash Room 1048 tap 2	MQJ286	May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Girls Wash Room 1048 tap 3	MQJ287	May 15, 2020	-	Passed	0.1300	Passed	
Park West School	Girls Wash Room 1048 tap 4	MQJ288	May 15, 2020	-	Passed	0.1300	Passed	
Park West School	Fountain by Room 1048	WAT166	June 6, 2023	-	Passed	0.0130	Passed	
Park West School	Gender Neutral Wash Room 1047 tap	MQJ291	May 15, 2020	-	Passed	0.1400	Passed	
Park West School	Janitors Closet 1046 tap	MQJ292	May 15, 2020	-	Passed	0.5500	Passed	
Park West School	Class Room 1027 tap	MQJ293	May 15, 2020	-	Passed	0.0440	Passed	
Park West School	Class Room 1026 tap	MQJ294	May 15, 2020	-	Passed	0.2400	Passed	
Park West School	Class Room 1025 tap	MQJ295	May 15, 2020	-	Passed	0.1900	Passed	
Park West School	Class Room 1021 tap	MQJ296	May 15, 2020	-	Passed	0.1600	Passed	
Park West School	Gender Neutral Wash Room 1029 tap	MQJ297	May 15, 2020	-	Passed	0.2000	Passed	
Park West School	Class Room 1034 tap	MQJ298	May 15, 2020	-	Passed	0.2200	Passed	
Park West School	Class Room 1033 tap	NES598	July 24, 2020	-	Passed	0.2100	Passed	
Park West School	Gender Neutral Wash Room 1036 tap	MQJ300	May 15, 2020	-	Passed	0.2400	Passed	
Park West School	Class Room 1032 tap	MQJ304	May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Class Room 1031 tap	MQJ305	May 15, 2020	-	Passed	0.2000	Passed	
Park West School	Boys Wash Room 1043 tap 1	MQJ306	May 15, 2020	-	Passed	0.2500	Passed	
Park West School	Boys Wash Room 1043 tap 2	MQJ307	May 15, 2020	-	Passed	0.1600	Passed	
Park West School	Boys Wash Room 1043 tap 3	MQJ308	May 15, 2020	0.002	Passed	0.1900	Passed	
Park West School	Boys Wash Room 1043 tap 4	MQJ309	May 15, 2020	-	Passed	0.1500	Passed	
Park West School	Fountain by Gym	WGM997	June 28, 2023	-	Passed	0.0340	Passed	
Park West School	Gym Office 1054 Wash Room tap	MQJ311	May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Boys Locker Room 1058 tap 1	MQJ312	May 15, 2020	-	Passed	0.0860	Passed	
Park West School	Boys Locker Room 1058 tap 2	MQJ313	May 15, 2020	-	Passed	0.2300	Passed	
Park West School	Girls Locker Room 1059 tap 1	MQJ318	May 15, 2020	-	Passed	0.2000	Passed	
Park West School	Girls Locker Room 1059 tap 2	MQJ319	May 15, 2020	-	Passed	0.1800	Passed	
Park West School	Class Room 2026 tap	MQJ320	May 15, 2020	-	Passed	0.1500	Passed	
Park West School	Class Room 2027 tap	MQJ321	May 15, 2020	-	Passed	0.2400	Passed	
Park West School	Class Room 2028 tap 1	MQJ322	May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Class Room 2028 tap 2	MQJ323	May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Class Room 2029 tap 1	MQJ324	May 15, 2020	-	Passed	0.7700	Passed	
Park West School	Class Room 2029 tap 2	MQJ325	May 15, 2020	-	Passed	0.2300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Park West School	Class Room 2029 tap 3	MQJ326	May 15, 2020	-	Passed	0.1000	Passed	
Park West School	Class Room 2036 tap 1	MQJ327	May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Class Room 2036 tap 2	MQJ328	May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Class Room 2037 tap	MQJ329	May 15, 2020	-	Passed	0.0940	Passed	
Park West School	Class Room 2038 tap	MQJ330	May 15, 2020	-	Passed	0.2300	Passed	
Park West School	Class Room tap 1 Room 2039	MQJ331	May 15, 2020	0.002	Passed	0.3400	Passed	
Park West School	Janitors Closet tap Room 2064	MQJ333	May 15, 2020	-	Passed	0.2200	Passed	
Park West School	Gender Neutral Wash Room tap Room 2065	MQJ334	May 15, 2020	-	Passed	0.0290	Passed	
Park West School	Class Room 2046 tap	MQJ337	May 15, 2020	-	Passed	0.2100	Passed	
Park West School	Class Room 2047 tap	MQJ338	May 15, 2020	-	Passed	0.2100	Passed	
Park West School	Class Room 2048 tap	MQJ339	May 15, 2020	-	Passed	0.3400	Passed	
Park West School	Class Room 2049 tap	MQJ340	May 15, 2020	-	Passed	0.2200	Passed	
Park West School	Staff Room Wash Room 2074 tap	MQJ341	May 15, 2020	0.003	Passed	0.0580	Passed	
Park West School	Staff Room Wash Room 2073 tap	MQJ343	May 15, 2020	-	Passed	0.1600	Passed	
Park West School	Class Room 2071 tap	MQJ344	May 15, 2020	-	Passed	0.0690	Passed	
Park West School	Girls Wash Room 2056 tap 1	MQJ345	May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Girls Wash Room 2056 tap 2	MQJ346	May 15, 2020	-	Passed	0.2000	Passed	
Park West School	Girls Wash Room 2056 tap 3	MQJ347	May 15, 2020	0.001	Passed	0.1800	Passed	
Park West School	Girls Wash Room 2056 tap 4	MQJ348	May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Girls Wash Room 2056 tap 5	MQJ349	May 15, 2020	-	Passed	0.1500	Passed	
Park West School	Girls Wash Room 2056 tap 6	MQJ350	May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Boys Wash Room 2055 tap 1	MQJ351	May 15, 2020	-	Passed	0.1000	Passed	
Park West School	Boys Wash Room 2055 tap 2	MQJ352	May 15, 2020	0.001	Passed	0.1200	Passed	
Park West School	Boys Wash Room 2055 tap 3	MQJ353	May 15, 2020	-	Passed	0.1100	Passed	
Park West School	Boys Wash Room 2055 tap 4	MQJ354	May 15, 2020	-	Passed	0.0980	Passed	
Park West School	Class Room tap 2 Room 2039	NES599	July 24, 2020	-	Passed	0.1100	Passed	
Park West School	Fountain by Room 2026	WAT085	June 6, 2023	-	Passed	0.0560	Passed	
Park West School	Fountain by Room 2065	WAT167	June 6, 2023	-	Passed	0.0110	Passed	
Park West School	Staff Room 2075 tap	WAT168	June 6, 2023	-	Passed	0.0150	Passed	
Park West School	Food Lab 2012 tap 1	WAT169	June 6, 2023	-	Passed	0.0210	Passed	
Park West School	Food Lab 2012 tap 2	WAT170	June 6, 2023	-	Passed	0.0160	Passed	
Park West School	Food Lab 2012 tap 3	WAT171	June 6, 2023	-	Passed	0.0170	Passed	
Park West School	Food Lab 2012 tap 4	WAT084	June 6, 2023	-	Passed	0.0160	Passed	
Park West School	Modular Girls Wash Room tap 1	WAT086	June 6, 2023	0.001	Passed	0.0360	Passed	
Park West School	Modular Girls Wash Room tap 2	WAT087	June 6, 2023	-	Passed	0.0590	Passed	
Park West School	Modular Girls Wash Room tap 3	WAT088	June 6, 2023	-	Passed	0.0280	Passed	
Park West School	Modular Girls Wash Room tap 4	WAT089	June 6, 2023	-	Passed	0.0200	Passed	
Park West School	Modular Boys Wash Room tap 1	WAT090	June 6, 2023	-	Passed	0.0570	Passed	
Park West School	Modular Boys Wash Room tap 2	WAT091	June 6, 2023	-	Passed	0.0430	Passed	
Park West School	Modular Boys Wash Room tap 3	WAT092	June 6, 2023	-	Passed	0.0310	Passed	
Park West School	Modular Boys Wash Room tap 4	WAT093	June 6, 2023	-	Passed	0.0250	Passed	
Park West School	Modular Staff Wash Room	WAT175	June 6, 2023	-	Passed	0.0180	Passed	
Park West School	Modular Kitchen tap	WAT176	June 6, 2023	-	Passed	0.0055	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Park West School	Fountain in Modular	WGM998	June 28, 2023	-	Passed	0.0600	Passed	
Porters Lake Elementary	Main Office Wash Room 169 tap	MXS508	June 18, 2020	0.003	Passed	0.2500	Passed	
Porters Lake Elementary	Class Room 164 tap	MXS510	June 18, 2020	0.001	Passed	0.3000	Passed	
Porters Lake Elementary	Class Room Wash Room 163 tap	MXS511	June 18, 2020	0.001	Passed	0.2000	Passed	
Porters Lake Elementary	Class Room Wash Room 162 tap	MXS512	June 18, 2020	0.001	Passed	0.2500	Passed	
Porters Lake Elementary	Class Room 161 tap	MXS513	June 18, 2020	0.003	Passed	0.3200	Passed	
Porters Lake Elementary	Class Room 160 tap	MXS514	June 18, 2020	0.003	Passed	0.5300	Passed	
Porters Lake Elementary	Class Room 158 tap	MXS515	June 18, 2020	0.001	Passed	0.0850	Passed	
Porters Lake Elementary	Class Room 155 tap	MXS516	June 18, 2020	0.005	Passed	0.0990	Passed	
Porters Lake Elementary	Class Room 153 tap	MXS517	June 18, 2020	0.002	Passed	0.1600	Passed	
Porters Lake Elementary	Class Room 152 tap	MXS520	June 18, 2020	0.002	Passed	0.3300	Passed	
Porters Lake Elementary	Class Room 150 tap	MXS521	June 18, 2020	0.004	Passed	0.2900	Passed	
Porters Lake Elementary	Janitors Closet 147 tap	MXS522	June 18, 2020	0.001	Passed	0.1100	Passed	
Porters Lake Elementary	Arts/Stage Class Room 178 tap 1	MXS523	June 18, 2020	0.001	Passed	0.0530	Passed	
Porters Lake Elementary	Arts/Stage Class Room 178 tap 2	MXS524	June 18, 2020	-	Passed	0.0530	Passed	
Porters Lake Elementary	Girls Wash Room tap 1 by Room 145	MXS525	June 18, 2020	0.003	Passed	0.2300	Passed	
Porters Lake Elementary	Boys Wash Room tap 1 by Room 146	MXS528	June 18, 2020	0.004	Passed	0.1600	Passed	
Porters Lake Elementary	Boys Wash Room tap 2 by Room 146	MXS529	June 18, 2020	0.003	Passed	0.1200	Passed	
Porters Lake Elementary	Boys Wash Room tap 3 by Room 146	MXS530	June 18, 2020	0.002	Passed	0.1100	Passed	
Porters Lake Elementary	Janitors Closet 142 tap	MXS531	June 18, 2020	0.003	Passed	0.1200	Passed	
Porters Lake Elementary	Janitors Closet 138 tap	MXS532	June 18, 2020	0.004	Passed	0.2500	Passed	
Porters Lake Elementary	Gym Office Wash Room 161 tap	MXS533	June 18, 2020	0.003	Passed	0.2000	Passed	
Porters Lake Elementary	Recycle Room 192 tap 1	MXS544	June 18, 2020	0.004	Passed	0.1200	Passed	
Porters Lake Elementary	Recycle Room 192 tap 2 (Handwashing)	MXS545	June 18, 2020	0.001	Passed	0.0450	Passed	
Porters Lake Elementary	Boys Wash Room tap 1 by Library	MXS547	June 18, 2020	0.004	Passed	0.2300	Passed	
Porters Lake Elementary	Boys Wash Room tap 2 by Library	MXS548	June 18, 2020	0.004	Passed	0.1600	Passed	
Porters Lake Elementary	Janitors Closet tap by Boys Wash Room	MXS550	June 18, 2020	0.002	Passed	0.1200	Passed	
Porters Lake Elementary	Staff Room 129 tap	WGQ479	June 18, 2020	-	Passed	0.1600	Passed	
Porters Lake Elementary	Staff Room Wash Room 125 tap	MXS559	June 18, 2020	0.002	Passed	0.1900	Passed	
Porters Lake Elementary	Staff Room Wash Room 126 tap	MXS560	June 18, 2020	0.001	Passed	0.1700	Passed	
Porters Lake Elementary	Class Room 108 tap	MXS562	June 18, 2020	0.001	Passed	0.1200	Passed	
Porters Lake Elementary	Library 106 tap	WGQ486	June 27, 2023	-	Passed	0.0790	Passed	
Porters Lake Elementary	Fountain by Room 168	WGQ477	June 27, 2023	-	Passed	0.0160	Passed	
Porters Lake Elementary	Fountain by Room 192	WGQ481	June 27, 2023	-	Passed	0.0130	Passed	
Porters Lake Elementary	Fountain between Wash Rooms	WGQ478	June 27, 2023	-	Passed	0.0330	Passed	
Porters Lake Elementary	Kitchen tap 1 (Hand Wash Sink tap by door)	WGQ482	June 27, 2023	0.001	Passed	0.1000	Passed	
Porters Lake Elementary	Kitchen tap 2 (Big Sink)	WGQ483	June 27, 2023	0.001	Passed	0.1100	Passed	
Porters Lake Elementary	Kitchen tap 3	WGQ484	June 27, 2023	-	Passed	0.0840	Passed	
Porters Lake Elementary	Kitchen tap 4	WGQ485	June 27, 2023	-	Passed	0.0800	Passed	
Porters Lake Elementary	Girls Wash Room tap 2 by Room 145	RPM522	January 12, 2022	0.002	Passed	0.1300	Passed	
Porters Lake Elementary	Girls Wash Room tap 3 by Room 145	RPM523	January 12, 2022	0.005	Passed	0.2100	Passed	
Porters Lake Elementary	Boys Locker Room tap 1	RPM524	January 12, 2022	0.001	Passed	0.1000	Passed	
Porters Lake Elementary	Boys Locker Room tap 2	RPM525	January 12, 2022	0.001	Passed	0.0880	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Porters Lake Elementary	Girls Locker Room tap 1	RPM526	January 12, 2022	0.001	Passed	0.1200	Passed	
Porters Lake Elementary	Girls Locker Room tap 2	RPM527	January 12, 2022	0.002	Passed	0.1500	Passed	
Porters Lake Elementary	Boys Wash Room tap 3 by Library	RPM529	January 12, 2022	0.001	Passed	0.1400	Passed	
Porters Lake Elementary	Girls Wash Room tap 2 by Seminar Room	RPM530	January 12, 2022	0.001	Passed	0.1200	Passed	
Porters Lake Elementary	Girls Wash Room tap 3 by Seminar Room	RPM531	January 12, 2022	0.003	Passed	0.1700	Passed	
Porters Lake Elementary	Girls Wash Room tap 4 by Seminar Room	RPM532	January 12, 2022	0.003	Passed	0.0950	Passed	
Porters Lake Elementary	Gender Neutral Wash Room 109 tap	WGQ480	June 27, 2023	0.002	Passed	0.2600	Passed	Tap remediated
Porters Lake Elementary	Girls Wash Room tap 1 by Seminar Room	SJE291	April 12, 2022	-	Passed	0.0410	Passed	
Portland Estates Elementary	Gym Locker Room Wash Room tap Room 1077	NCB105	July 9, 2020	-	Passed	1.4000	Passed	
Portland Estates Elementary	Gym Office Wash Room tap Room 1073	NCB106	July 9, 2020	0.001	Passed	0.3100	Passed	
Portland Estates Elementary	Kitchen tap 1 Room 1066	XKA269	October 25, 2023	0.001	Passed	0.1300	Passed	
Portland Estates Elementary	Kitchen tap 2 Room 1066	XKA270	October 25, 2023	-	Passed	0.0250	Passed	
Portland Estates Elementary	Kitchen tap 3 Room 1066	XKA271	October 25, 2023	-	Passed	0.0560	Passed	
Portland Estates Elementary	Kitchen tap 4 Room 1066	XKA272	October 25, 2023	-	Passed	0.0200	Passed	
Portland Estates Elementary	Janitors Closet tap Room 1059	NCB111	July 9, 2020	-	Passed	0.0570	Passed	
Portland Estates Elementary	Music Room tap Room 1062	NCB112	July 9, 2020	-	Passed	1.5000	Passed	
Portland Estates Elementary	Art Room tap 1 Room 1063	NCB113	July 9, 2020	0.001	Passed	0.9500	Passed	
Portland Estates Elementary	Art Room tap 2 Room 1063	NCB114	July 9, 2020	0.001	Passed	0.2500	Passed	
Portland Estates Elementary	Recycle Room tap Room 1055	NCB115	July 9, 2020	0.002	Passed	0.1800	Passed	
Portland Estates Elementary	Class Room tap Room 1036	NCB116	July 9, 2020	-	Passed	0.7500	Passed	
Portland Estates Elementary	Class Room tap Room 1037	NCB117	July 9, 2020	0.002	Passed	0.2900	Passed	
Portland Estates Elementary	Gender Neutral Wash Room tap Room 1041	NCB118	July 9, 2020	0.001	Passed	0.7100	Passed	
Portland Estates Elementary	Class Room tap Room 1038	NCB119	July 9, 2020	-	Passed	0.3900	Passed	
Portland Estates Elementary	Class Room tap Room 1039	NCB120	July 9, 2020	0.001	Passed	0.3000	Passed	
Portland Estates Elementary	Office health Room tap Room 1021	NCB121	July 9, 2020	0.001	Passed	0.2200	Passed	
Portland Estates Elementary	Office Wash Room tap Room 1018	NCB122	July 9, 2020	0.002	Passed	0.1900	Passed	
Portland Estates Elementary	Fountain by Room 1025	XKA276	October 25, 2023	-	Passed	0.0290	Passed	
Portland Estates Elementary	Female Wash Room 1050 tap 1	NCB124	July 9, 2020	0.001	Passed	0.2400	Passed	
Portland Estates Elementary	Female Wash Room 1050 tap 2	NCB126	July 9, 2020	0.001	Passed	0.3400	Passed	
Portland Estates Elementary	Female Wash Room 1050 tap 3	NCB127	July 9, 2020	0.001	Passed	0.2800	Passed	
Portland Estates Elementary	Male Wash Room 1049 tap 1	NCB128	July 9, 2020	-	Passed	0.2500	Passed	
Portland Estates Elementary	Male Wash Room 1049 tap 2	NCB129	July 9, 2020	0.001	Passed	0.4300	Passed	
Portland Estates Elementary	Male Wash Room 1049 tap 3	NCB130	July 9, 2020	0.001	Passed	0.3800	Passed	
Portland Estates Elementary	Fountain by Room 1049	XKA275	October 25, 2023	-	Passed	0.0330	Passed	
Portland Estates Elementary	Lab Storage Room 1047 tap	NCB132	July 9, 2020	0.001	Passed	0.2900	Passed	
Portland Estates Elementary	Female Wash Room tap 1 Room 1046	NCB133	July 9, 2020	0.001	Passed	0.1200	Passed	
Portland Estates Elementary	Female Wash Room tap 2 Room 1046	XKA274	October 25, 2023	-	Passed	0.0400	Passed	Tap remediated
Portland Estates Elementary	Male Wash Room tap 1 Room 1045	NCB135	July 9, 2020	0.001	Passed	0.1400	Passed	
Portland Estates Elementary	Male Wash Room tap 2 Room 1045	NCB136	July 9, 2020	0.002	Passed	0.1900	Passed	
Portland Estates Elementary	Fountain by Room 1045	XKA273	October 25, 2023	-	Passed	0.0230	Passed	
Portland Estates Elementary	Class Room tap Room 2030	NCB138	July 9, 2020	-	Passed	0.2600	Passed	
Portland Estates Elementary	Class Room tap Room 2031	NCB140	July 9, 2020	0.001	Passed	0.2600	Passed	
Portland Estates Elementary	Class Room tap Room 2032	NCB142	July 9, 2020	-	Passed	0.4100	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Portland Estates Elementary	Class Room tap Room 2033	NCB144	July 9, 2020	-	Passed	0.4400	Passed	
Portland Estates Elementary	Class Room tap Room 2017	NCB146	July 9, 2020	0.001	Passed	0.2200	Passed	
Portland Estates Elementary	Class Room tap Room 2018	NCB148	July 9, 2020	0.001	Passed	0.5700	Passed	
Portland Estates Elementary	Class Room tap Room 2019	XKA280	October 25, 2023	-	Passed	0.1200	Passed	Tap remediated
Portland Estates Elementary	Class Room tap Room 2020	NCB150	July 9, 2020	-	Passed	0.5400	Passed	
Portland Estates Elementary	Staff Room Wash Room tap Room 2009	NCB151	July 9, 2020	0.003	Passed	0.4500	Passed	
Portland Estates Elementary	Staff Room Wash Room tap Room 2008	NCB152	July 9, 2020	0.002	Passed	0.3500	Passed	
Portland Estates Elementary	Staff Room 2007 tap	XKA279	October 25, 2023	-	Passed	0.0240	Passed	
Portland Estates Elementary	Male Wash Room tap 1 Room 2026	NCB154	July 9, 2020	0.001	Passed	0.3100	Passed	
Portland Estates Elementary	Male Wash Room tap 2 Room 2026	NCB155	July 9, 2020	0.001	Passed	0.2900	Passed	
Portland Estates Elementary	Male Wash Room tap 3 Room 2026	NCB156	July 9, 2020	0.001	Passed	0.2400	Passed	
Portland Estates Elementary	Fountain right of Room 2026	NCB157	July 9, 2020	-	Passed	0.2300	Passed	
Portland Estates Elementary	Fountain by Room 2017	XKA277	October 25, 2023	-	Passed	0.0230	Passed	
Portland Estates Elementary	Female Wash Room tap 1 Room 2025	XKA278	October 25, 2023	-	Passed	0.1000	Passed	Tap remediated
Portland Estates Elementary	Female Wash Room tap 2 Room 2025	NCB160	July 9, 2020	0.001	Passed	0.3600	Passed	
Portland Estates Elementary	Female Wash Room tap 3 Room 2025	NCB162	July 9, 2020	0.003	Passed	0.3200	Passed	
Prospect Road Elementary	Staff Room 113 Wash Room tap	RUZ936	February 7, 2022	0.002	Passed	1.5000	Passed	
Prospect Road Elementary	Girls Wash Room tap 1 near Room 110	RUZ938	February 7, 2022	0.003	Passed	1.2000	Passed	
Prospect Road Elementary	Girls Wash Room tap 2 near Room 110	RUZ939	February 7, 2022	0.003	Passed	1.4000	Passed	
Prospect Road Elementary	Girls Wash Room tap 3 near Room 110	RUZ940	February 7, 2022	0.004	Passed	1.4000	Passed	
Prospect Road Elementary	Janitors Closet tap near Room 110	RUZ941	February 7, 2022	0.002	Passed	0.6800	Passed	
Prospect Road Elementary	Fountain by Room 110	XKT544	October 27, 2023	0.003	Passed	0.0110	Passed	Out-of-Service
Prospect Road Elementary	Boys Wash Room tap 1 near Room 110	RUZ942	February 7, 2022	0.002	Passed	1.2000	Passed	
Prospect Road Elementary	Boys Wash Room tap 2 near Room 110	RUZ943	February 7, 2022	0.001	Passed	1.1000	Passed	
Prospect Road Elementary	Boys Wash Room tap 3 near Room 110	RUZ944	February 7, 2022	0.001	Passed	0.9500	Passed	
Prospect Road Elementary	Class Room tap Room 108	RVA531	February 7, 2022	0.001	Passed	1.6000	Passed	
Prospect Road Elementary	Staff Wash Room tap by Janitors Closet	RVA532	February 7, 2022	0.001	Passed	0.6900	Passed	
Prospect Road Elementary	Mechanical Room tap	RVA533	February 7, 2022	0.001	Passed	0.7700	Passed	
Prospect Road Elementary	Girls Wash Room tap 1	RVA534	February 7, 2022	0.005	Passed	1.7000	Passed	
Prospect Road Elementary	Girls Wash Room tap 2	RVA535	February 7, 2022	0.004	Passed	0.9400	Passed	
Prospect Road Elementary	Girls Wash Room tap 3	RVA936	February 7, 2022	0.003	Passed	0.8300	Passed	
Prospect Road Elementary	Girls Wash Room tap 4	TBH343	June 30, 2022	0.001	Passed	0.9900	Passed	
Prospect Road Elementary	Boys Wash Room tap 1	VXD836	May 24, 2023	0.004	Passed	1.3000	Passed	Tap remediated
Prospect Road Elementary	Boys Wash Room tap 2	VXD837	May 24, 2023	0.005	Passed	1.1000	Passed	
Prospect Road Elementary	Boys Wash Room tap 3	RVA540	February 7, 2022	0.001	Passed	1.0000	Passed	
Prospect Road Elementary	Boys Wash Room tap 4	XKT546	October 27, 2023	0.003	Passed	1.1000	Passed	Tap remediated
Prospect Road Elementary	Fountain by Gym	XKT545	October 27, 2023	0.009	Exceeded	0.0930	Passed	Out-of-Service
Prospect Road Elementary	Staff Room 113 tap	VXD834	May 24, 2023	0.002	Passed	1.8000	Passed	
Prospect Road Elementary	Teachers Lounge Room 123A tap	VXD835	May 24, 2023	0.003	Passed	0.9400	Passed	Tap remediated
Ridgecliff Middle School	Fountain by Room 1104	VQU582	April 26, 2023	-	Passed	0.0250	Passed	
Ridgecliff Middle School	Male Wash Room tap 1 by Room 1103	NAM796	July 2, 2020	0.002	Passed	0.1900	Passed	
Ridgecliff Middle School	Male Wash Room tap2 by Room 1103	NAM797	July 2, 2020	0.002	Passed	0.2200	Passed	
Ridgecliff Middle School	Male Wash Room tap 3 by Room 1103	NAM798	July 2, 2020	0.001	Passed	0.2200	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ridgecliff Middle School	Male Wash Room tap 4 by Room 1103	NAM799	July 2, 2020	-	Passed	0.2100	Passed	
Ridgecliff Middle School	Gender Neutral Wash Room 1101 tap	NAM788	July 2, 2020	0.001	Passed	0.1900	Passed	
Ridgecliff Middle School	Fountain by Room 1100	VQU583	April 26, 2023	0.001	Passed	0.0500	Passed	
Ridgecliff Middle School	Janitors Closet 1100 tap	NAM786	July 2, 2020	0.002	Passed	0.2000	Passed	
Ridgecliff Middle School	Class Room 1095 tap	NAM767	July 2, 2020	-	Passed	0.2600	Passed	
Ridgecliff Middle School	Class Room 1092 tap 1	NAM768	July 2, 2020	0.003	Passed	0.6400	Passed	
Ridgecliff Middle School	Class Room 1092 tap 2	NAM769	July 2, 2020	0.001	Passed	0.3400	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 1	NAM770	July 2, 2020	0.002	Passed	1.1000	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 2	NAM771	July 2, 2020	0.003	Passed	0.3100	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 3	NAM772	July 2, 2020	0.001	Passed	1.0000	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 4	NAM773	July 2, 2020	0.004	Passed	0.8900	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 5	NAM774	July 2, 2020	0.002	Passed	0.5500	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 1	NAM775	July 2, 2020	0.003	Passed	0.7100	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 2	NAM776	July 2, 2020	0.004	Passed	0.5800	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 3	NAM777	July 2, 2020	0.005	Passed	0.6800	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 4	NAM778	July 2, 2020	0.003	Passed	0.3300	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 5	NAM779	July 2, 2020	0.003	Passed	0.2200	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 6	NAM780	July 2, 2020	0.003	Passed	0.1700	Passed	
Ridgecliff Middle School	Learning Centre Room 1081 Wash Room tap	VQU580	April 26, 2023	-	Passed	0.1400	Passed	
Ridgecliff Middle School	Learning Centre Room 1079 tap	VQU581	April 26, 2023	-	Passed	0.2100	Passed	
Ridgecliff Middle School	Class Room 1076 tap	NAM783	July 2, 2020	0.001	Passed	0.3200	Passed	
Ridgecliff Middle School	Girls Wash Room tap 1 by Room 1072	NAM792	July 2, 2020	0.001	Passed	0.4400	Passed	
Ridgecliff Middle School	Girls Wash Room tap 2 by Room 1072	NAM793	July 2, 2020	0.002	Passed	0.3500	Passed	
Ridgecliff Middle School	Girls Wash Room tap 4 by Room 1072	NAM795	July 2, 2020	0.004	Passed	0.3500	Passed	
Ridgecliff Middle School	Class Room 1072 tap 1	NAM784	July 2, 2020	0.001	Passed	0.3800	Passed	
Ridgecliff Middle School	Class Room 1072 tap 2	NAM785	July 2, 2020	0.001	Passed	0.3000	Passed	
Ridgecliff Middle School	Music Room 1064 tap	NAM789	July 2, 2020	0.002	Passed	1.5000	Passed	
Ridgecliff Middle School	Art Room 1061 tap	NAM790	July 2, 2020	-	Passed	0.7000	Passed	
Ridgecliff Middle School	Boys Wash Room 1050 tap 1	NAM815	July 2, 2020	0.001	Passed	0.5200	Passed	
Ridgecliff Middle School	Gym Office Wash Room 1048 tap	NAM814	July 2, 2020	-	Passed	0.5000	Passed	
Ridgecliff Middle School	Gym Office Wash Room 1046 tap	NAM813	July 2, 2020	-	Passed	0.4400	Passed	
Ridgecliff Middle School	Female Wash Room 1043 tap 1	NAM811	July 2, 2020	0.002	Passed	0.5100	Passed	
Ridgecliff Middle School	Female Wash Room 1043 tap 2	NAM812	July 2, 2020	0.001	Passed	0.2500	Passed	
Ridgecliff Middle School	Mech Room 1039 tap	NAM807	July 2, 2020	0.001	Passed	0.3200	Passed	
Ridgecliff Middle School	Gender Neutral Wash Room 1037 tap	NAM818	July 2, 2020	0.001	Passed	0.1500	Passed	
Ridgecliff Middle School	Janitors Closet 1035 tap	NAM806	July 2, 2020	0.003	Passed	0.2000	Passed	
Ridgecliff Middle School	Office Room 1025 Wash Room tap	NAM801	July 2, 2020	0.001	Passed	0.2200	Passed	
Ridgecliff Middle School	Class Room 2065 tap	NAM819	July 2, 2020	-	Passed	0.5600	Passed	
Ridgecliff Middle School	Class Room 2061 tap 2	NAM821	July 2, 2020	0.002	Passed	0.3600	Passed	
Ridgecliff Middle School	Class Room 2058 tap	NAM822	July 2, 2020	0.001	Passed	0.7700	Passed	
Ridgecliff Middle School	Class Room 2053 tap 1	NAM823	July 2, 2020	0.001	Passed	0.8700	Passed	
Ridgecliff Middle School	Class Room 2053 tap 2	NAM824	July 2, 2020	0.001	Passed	0.3100	Passed	
Ridgecliff Middle School	Class Room 2050 tap	NAM825	July 2, 2020	0.001	Passed	0.4500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ridgecliff Middle School	Class Room 2046 tap 1	NAM826	July 2, 2020	-	Passed	0.8400	Passed	
Ridgecliff Middle School	Class Room 2046 tap 2	NAM827	July 2, 2020	0.001	Passed	0.4800	Passed	
Ridgecliff Middle School	Gender Neutral Wash Room 2072 tap	NAM828	July 2, 2020	0.002	Passed	0.2900	Passed	
Ridgecliff Middle School	Janitors Closet tap by Room 2072	NAM830	July 2, 2020	0.005	Passed	0.3900	Passed	
Ridgecliff Middle School	Girls Wash Room tap 1 by Room 2046	NAM831	July 2, 2020	-	Passed	0.2800	Passed	
Ridgecliff Middle School	Girls Wash Room tap 2 by Room 2046	NAM832	July 2, 2020	0.001	Passed	0.3300	Passed	
Ridgecliff Middle School	Girls Wash Room tap 3 by Room 2046	NAM833	July 2, 2020	0.001	Passed	0.3500	Passed	
Ridgecliff Middle School	Girls Wash Room tap 4 by Room 2046	NAM834	July 2, 2020	0.001	Passed	0.1800	Passed	
Ridgecliff Middle School	Library Room 2021 tap	NAM835	July 2, 2020	0.001	Passed	0.2200	Passed	
Ridgecliff Middle School	Janitors Closet 2036 tap	NAM837	July 2, 2020	0.002	Passed	0.1600	Passed	
Ridgecliff Middle School	Staff Room 2025 Wash Room 1 tap	NAM838	July 2, 2020	-	Passed	0.2000	Passed	
Ridgecliff Middle School	Staff Room 2025 Wash Room 2 tap	NAM839	July 2, 2020	0.001	Passed	0.1800	Passed	
Ridgecliff Middle School	Tech Ed 2034 tap	NAM842	July 2, 2020	0.001	Passed	0.2600	Passed	
Ridgecliff Middle School	Sick Room 1026 tap	VQU584	April 26, 2023	-	Passed	0.0570	Passed	
Ridgecliff Middle School	Family Studies Room 1029 tap 1	VQU585	April 26, 2023	-	Passed	0.0200	Passed	
Ridgecliff Middle School	Family Studies Room 1029 tap 2	VQU585	April 26, 2023	-	Passed	0.0180	Passed	
Ridgecliff Middle School	Family Studies Room 1029 tap 3	VQU585	April 26, 2023	-	Passed	0.0110	Passed	
Ridgecliff Middle School	Family Studies Room 1029 tap 4	VQU585	April 26, 2023	-	Passed	0.0130	Passed	
Ridgecliff Middle School	Kitchen Room 1056 tap 1	VQU589	April 26, 2023	0.001	Passed	0.3400	Passed	Tap remediated
Ridgecliff Middle School	Kitchen Room 1056 tap 2	VQU607	April 26, 2023	0.001	Passed	0.2800	Passed	
Ridgecliff Middle School	Kitchen Room 1056 tap 3	VQU608	April 26, 2023	-	Passed	0.3500	Passed	
Ridgecliff Middle School	Girls Wash Room tap 3 by Room 1072	VQU609	April 26, 2023	-	Passed	0.1300	Passed	Tap remediated
Ridgecliff Middle School	Boys Wash Room 1050 tap 2	VQU610	April 26, 2023	-	Passed	0.3200	Passed	Tap remediated
Ridgecliff Middle School	Fountain by Room 2072	VQU611	April 26, 2023	-	Passed	0.0200	Passed	
Ridgecliff Middle School	Staff Room 2025 tap	VQU612	April 26, 2023	-	Passed	0.0180	Passed	
Ridgecliff Middle School	Class Room 2061 tap 1	VQU613	April 26, 2023	-	Passed	0.0310	Passed	Tap remediated
Ridgecliff Middle School	Fountain by Room 1056	VXQ777	May 25, 2023	-	Passed	0.0190	Passed	
Ridgecliff Middle School	Fountain by Room 2036	VXQ778	May 25, 2023	-	Passed	0.1600	Passed	
Robert K. Turner Elementary	Boys Wash Room tap 1 by Room 204	XCW900	September 21, 2023	0.002	Passed	0.0048	Passed	Tap remediated
Robert K. Turner Elementary	Boys Wash Room tap 2 by Room 204	XCW901	September 21, 2023	0.001	Passed	0.0050	Passed	Tap remediated
Robert K. Turner Elementary	Boys Wash Room tap 3 by Room 204	NMD779	August 27, 2020	0.001	Passed	0.0120	Passed	
Robert K. Turner Elementary	Boys Wash Room tap 4 by Room 204	NMD780	August 27, 2020	0.002	Passed	0.0070	Passed	
Robert K. Turner Elementary	Girls Wash Room tap 1 by Room 205	MUV985	June 8, 2020	0.004	Passed	0.0099	Passed	
Robert K. Turner Elementary	Girls Wash Room tap 2 by Room 205	MUV986	June 8, 2020	0.004	Passed	0.0120	Passed	
Robert K. Turner Elementary	Girls Wash Room tap 3 by Room 205	XCW902	September 21, 2023	-	Passed	0.0047	Passed	Tap remediated
Robert K. Turner Elementary	Girls Wash Room tap 4 by Room 205	XCW903	September 21, 2023	0.001	Passed	0.0063	Passed	Tap remediated
Robert K. Turner Elementary	Fountain by Room 207	XCW904	September 21, 2023	-	Passed	0.0089	Passed	
Robert K. Turner Elementary	Janitors Closet tap by Fountain by Room 207	MUV993	June 8, 2020	-	Passed	0.0087	Passed	
Robert K. Turner Elementary	Boys Wash Room tap 1 by Library	XCW892	September 21, 2023	-	Passed	0.0046	Passed	Tap remediated
Robert K. Turner Elementary	Boys Wash Room tap 2 by Library	XCW893	September 21, 2023	0.002	Passed	0.0048	Passed	Tap remediated
Robert K. Turner Elementary	Boys Wash Room tap 3 by Library	XCW894	September 21, 2023	0.002	Passed	0.0059	Passed	Tap remediated
Robert K. Turner Elementary	Girls Wash Room tap 1 by Library	XCW896	September 21, 2023	0.002	Passed	0.0043	Passed	Tap remediated
Robert K. Turner Elementary	Girls Wash Room tap 2 by Library	MUV999	June 8, 2020	0.004	Passed	0.0180	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Robert K. Turner Elementary	Girls Wash Room tap 3 by Library	XCW895	September 21, 2023	0.001	Passed	0.0082	Passed	Tap remediated
Robert K. Turner Elementary	Kitchen tap by Room 121	XCW905	September 21, 2023	0.001	Passed	0.0240	Passed	Tap remediated
Robert K. Turner Elementary	Fountain by Room 102	XCW898	September 21, 2023	-	Passed	0.0110	Passed	
Robert K. Turner Elementary	Janitors Closet tap by Fountain by Room 102	MUW002	June 8, 2020	0.003	Passed	0.1100	Passed	
Robert K. Turner Elementary	Gender Neutral Wash Room 105 tap	MUW010	June 8, 2020	0.002	Passed	0.2000	Passed	
Robert K. Turner Elementary	Gender Neutral Wash Room 104 tap	XCW897	September 21, 2023	-	Passed	0.0099	Passed	Tap remediated
Robert K. Turner Elementary	Staff Room tap	XCW890	September 21, 2023	-	Passed	0.0032	Passed	
Robert K. Turner Elementary	Fountain by Staff Room	XCW891	September 21, 2023	0.002	Passed	0.0820	Passed	
Robert K. Turner Elementary	Gender Neutral Staff Wash Room 1 tap	XCW899	September 21, 2023	0.001	Passed	0.0050	Passed	Tap remediated
Robert K. Turner Elementary	Gender Neutral Staff Wash Room 2 tap	MUW014	June 8, 2020	0.004	Passed	0.0110	Passed	
Rockingham Elementary	Class Room tap Room 55	MUD710	June 2, 2020	0.002	Passed	0.6800	Passed	
Rockingham Elementary	Class Room tap Room 26	MUD721	June 2, 2020	0.005	Passed	0.1800	Passed	
Rockingham Elementary	Girls Wash Room tap 2 Room 29	MUD724	June 2, 2020	0.005	Passed	0.0630	Passed	
Rockingham Elementary	Staff Wash Room inside Room 33	MUD727	June 2, 2020	0.001	Passed	0.0270	Passed	
Rockingham Elementary	Staff Wash Room inside Room 33	MUD728	June 2, 2020	0.002	Passed	0.2400	Passed	
Rockingham Elementary	Boys Wash Room tap 1 Room 40	MUD739	June 2, 2020	0.001	Passed	0.4800	Passed	
Rockingham Elementary	Boys Wash Room tap 2 Room 40	MUD740	June 2, 2020	0.001	Passed	0.0900	Passed	
Rockingham Elementary	Janitors Closet tap Room 43	MUD741	June 2, 2020	-	Passed	0.0930	Passed	
Rockingham Elementary	Girls Wash Room tap 1 Room 11	SOZ883	May 11, 2022	-	Passed	0.0300	Passed	
Rockingham Elementary	Girls Wash Room tap 2 Room 11	MUD749	June 2, 2020	0.004	Passed	0.2200	Passed	
Rockingham Elementary	Girls Wash Room tap 3 Room 11	MUD750	June 2, 2020	-	Passed	0.0140	Passed	
Rockingham Elementary	Girls Wash Room tap 4 Room 11	MUD751	June 2, 2020	0.002	Passed	0.2900	Passed	
Rockingham Elementary	Janitors Closet tap by Room 12	MUD767	June 2, 2020	0.001	Passed	0.0500	Passed	
Rockingham Elementary	Boys Wash Room tap 1 Room 12	MUD768	June 2, 2020	0.002	Passed	0.0670	Passed	
Rockingham Elementary	Boys Wash Room tap 2 Room 12	MUD769	June 2, 2020	0.002	Passed	0.0270	Passed	
Rockingham Elementary	Boys Wash Room tap 3 Room 12	MUD770	June 2, 2020	0.003	Passed	0.0380	Passed	
Rockingham Elementary	Boys Wash Room tap 4 Room 12	MUD771	June 2, 2020	0.001	Passed	0.0290	Passed	
Rockingham Elementary	Girls Wash Room tap 1 Room 48	SOY813	May 11, 2022	0.001	Passed	0.1300	Passed	
Rockingham Elementary	Girls Wash Room tap 2 Room 48	MUD714	June 2, 2020	0.004	Passed	0.1700	Passed	
Rockingham Elementary	Boys Wash Room tap 1 Room 57	SOZ807	May 11, 2022	0.001	Passed	0.0820	Passed	
Rockingham Elementary	Boys Wash Room tap 2 Room 57	SOZ808	May 11, 2022	0.001	Passed	0.0390	Passed	
Rockingham Elementary	Janitors Closet tap Room 58	SOZ809	May 11, 2022	-	Passed	0.0130	Passed	
Rockingham Elementary	Girls Wash Room tap 1 Room 56	SOZ810	May 11, 2022	0.001	Passed	0.0600	Passed	
Rockingham Elementary	Girls Wash Room tap 2 Room 56	SOZ811	May 11, 2022	0.002	Passed	0.0780	Passed	
Rockingham Elementary	Boys Wash Room tap 1 Room 47	XKJ951	October 26, 2023	0.002	Passed	0.0200	Passed	Tap remediated
Rockingham Elementary	Boys Wash Room tap 2 Room 47	SOZ815	May 11, 2022	0.001	Passed	0.0720	Passed	
Rockingham Elementary	Girls Wash Room tap 1 Room 29	SOZ816	May 11, 2022	0.001	Passed	0.0500	Passed	
Rockingham Elementary	Boys Wash Room tap 1 Room 30	SOZ817	May 11, 2022	-	Passed	0.0210	Passed	
Rockingham Elementary	Boys Wash Room tap 2 Room 30	SOZ818	May 11, 2022	-	Passed	0.0200	Passed	
Rockingham Elementary	Class Room tap Room 36	SOZ820	May 11, 2022	0.003	Passed	0.2600	Passed	
Rockingham Elementary	Girls Wash Room tap 1 Room 39	SOZ821	May 11, 2022	0.001	Passed	0.0410	Passed	
Rockingham Elementary	Girls Wash Room tap 2 Room 39	SOZ822	May 11, 2022	0.002	Passed	0.0640	Passed	
Rockingham Elementary	Fountain by Room 11	VVU987	May 17, 2023	-	Passed	0.0770	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Rockingham Elementary	Basin tap Room 10	VVU988	May 17, 2023	0.002	Passed	0.1000	Passed	
Rockingham Elementary	Basin tap Room 6	VVU989	May 17, 2023	-	Passed	0.0610	Passed	
Rockingham Elementary	Fountain by Room 39	VVU990	May 17, 2023	0.001	Passed	0.0770	Passed	
Rockingham Elementary	Staff Room Kitchen tap Room 33	VVU991	May 17, 2023	-	Passed	0.0120	Passed	
Rockingham Elementary	Fountain by Room 29	VVU992	May 17, 2023	0.001	Passed	0.0330	Passed	
Rockingham Elementary	Fountain by Room 50	VVU993	May 17, 2023	-	Passed	0.0960	Passed	
Rockingham Elementary	Fountain by Room 53	VVU994	May 17, 2023	-	Passed	0.0720	Passed	
Rockingham Elementary	Lavatory Sink tap Room 53	VVU995	May 17, 2023	-	Passed	0.0750	Passed	
Rockingham Elementary	Cafeteria/Kitchen handwashing tap	VVU997	May 17, 2023	-	Passed	0.0760	Passed	
Rockingham Elementary	Cafeteria/Kitchen double compartment sink tap	VVU998	May 17, 2023	-	Passed	0.0086	Passed	
Rockingham Elementary	Fountain by Room 22	VVU999	May 17, 2023	0.001	Passed	0.1200	Passed	
Rockingham Elementary	Janitors Closet tap by Room 33	VVV000	May 17, 2023	-	Passed	0.0079	Passed	Tap remediated
Rockingstone Heights School	Boys Wash Room tap 1 by Room 302	MUQ711	June 4, 2020	0.001	Passed	0.1500	Passed	
Rockingstone Heights School	Janitors Closet tap by Boys Wash Room	MUQ714	June 4, 2020	0.001	Passed	0.0510	Passed	
Rockingstone Heights School	Staff Wash Room by Girls Wash Room	MUQ716	June 4, 2020	0.001	Passed	0.0500	Passed	
Rockingstone Heights School	Girls Wash Room tap 2 by Room 309	MUQ718	June 4, 2020	0.002	Passed	0.0240	Passed	
Rockingstone Heights School	Girls Wash Room tap 3 by Room 309	MUQ719	June 4, 2020	0.003	Passed	0.0340	Passed	
Rockingstone Heights School	Boys Wash Room tap 1 by Room 202	MUQ721	June 4, 2020	0.002	Passed	0.0720	Passed	
Rockingstone Heights School	Boys Wash Room tap 2 by Room 202	MUQ722	June 4, 2020	0.003	Passed	0.0680	Passed	
Rockingstone Heights School	Boys Wash Room tap 3 by Room 202	MUQ723	June 4, 2020	0.003	Passed	0.0430	Passed	
Rockingstone Heights School	Girls Wash Room tap 2 by Room 203	MUQ727	June 4, 2020	0.002	Passed	0.0120	Passed	
Rockingstone Heights School	Gender Neutral Wash Room tap by Girls Wash Room	MUQ729	June 4, 2020	-	Passed	0.0045	Passed	
Rockingstone Heights School	Boys Wash Room tap 1 by caretaker Room	MUQ733	June 4, 2020	0.002	Passed	0.0630	Passed	
Rockingstone Heights School	Boys Wash Room tap 2 by caretaker Room	MUQ734	June 4, 2020	0.004	Passed	0.0650	Passed	
Rockingstone Heights School	Janitors Closet tap	MUQ736	June 4, 2020	-	Passed	0.0210	Passed	
Rockingstone Heights School	Staff Gender Neutral Wash Room tap by Girls Wash Room	MUQ738	June 4, 2020	0.001	Passed	0.0150	Passed	
Rockingstone Heights School	Girls Wash Room tap 1 by Staff Wash Room	MUQ739	June 4, 2020	0.001	Passed	0.1400	Passed	
Rockingstone Heights School	Class Room tap Room 102	MUQ750	June 4, 2020	-	Passed	0.3300	Passed	
Rockingstone Heights School	Class Room tap Room 103	MUQ751	June 4, 2020	-	Passed	0.3100	Passed	
Rockingstone Heights School	Class Room tap Room 105	MUQ752	June 4, 2020	0.001	Passed	0.2900	Passed	
Rockingstone Heights School	Gender Neutral Wash Room tap 1 by Room 203	NAK426	July 2, 2020	0.002	Passed	0.0400	Passed	
Rockingstone Heights School	Art Room tap 1 Room 100	VQU385	April 26, 2023	0.001	Passed	0.0910	Passed	Tap remediated
Rockingstone Heights School	Art Room tap 2 Room 100	VQU386	April 26, 2023	0.001	Passed	0.0650	Passed	Tap remediated
Rockingstone Heights School	Main Office Staff Wash Room tap	VQU387	April 26, 2023	0.001	Passed	0.0770	Passed	Tap remediated
Rockingstone Heights School	Gym Office Wash Room tap by Boys Wash Room	VQU388	April 26, 2023	0.009	Exceeded	0.0610	Passed	Hand washing only
Rockingstone Heights School	Gym Office Wash Room tap by Girls Wash Room	VQU389	April 26, 2023	0.006	Exceeded	0.0150	Passed	Hand washing only
Rockingstone Heights School	Girls Wash Room tap 2 by Staff Wash Room	VQU390	April 26, 2023	-	Passed	0.0042	Passed	Tap remediated
Rockingstone Heights School	Girls Wash Room tap 3 by Staff Wash Room	VQU391	April 26, 2023	-	Passed	0.0100	Passed	Tap remediated
Rockingstone Heights School	Boys Wash Room tap 3 by caretaker Room	VQU392	April 26, 2023	0.001	Passed	0.0590	Passed	Tap remediated
Rockingstone Heights School	Staff Male Wash Room tap in Staff Room	VQU393	April 26, 2023	-	Passed	0.0046	Passed	Tap remediated
Rockingstone Heights School	Staff Female Wash Room tap in Staff Room	VQU394	April 26, 2023	0.001	Passed	0.0150	Passed	Tap remediated
Rockingstone Heights School	Girls Wash Room tap 3 by Room 203	VQU411	April 26, 2023	-	Passed	0.0098	Passed	Tap remediated
Rockingstone Heights School	Janitors Closet tap by Boys Wash Room	VQU412	April 26, 2023	-	Passed	0.0044	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Rockingstone Heights School	Girls Wash Room tap 1 by Room 309	VQU413	April 26, 2023	-	Passed	0.0110	Passed	Tap remediated
Rockingstone Heights School	Boys Wash Room tap 2 by Room 302	VQU414	April 26, 2023	0.001	Passed	0.0700	Passed	Tap remediated
Rockingstone Heights School	Boys Wash Room tap 3 by Room 302	VQU415	April 26, 2023	0.001	Passed	0.0740	Passed	Tap remediated
Rockingstone Heights School	Kitchen sink tap 1 Room 300	VQU416	April 26, 2023	-	Passed	0.1600	Passed	
Rockingstone Heights School	Kitchen sink tap 2 Room 300	VQU417	April 26, 2023	-	Passed	0.1400	Passed	
Rockingstone Heights School	Kitchen sink tap 3 Room 300	VQU418	April 26, 2023	-	Passed	0.1200	Passed	
Rockingstone Heights School	Kitchen sink tap 4 Room 300	VQU419	April 26, 2023	-	Passed	0.0210	Passed	
Rockingstone Heights School	Fountain by Room 303	VQU420	April 26, 2023	-	Passed	0.0120	Passed	
Rockingstone Heights School	Fountain by Room 203	VQU431	April 26, 2023	-	Passed	0.0130	Passed	
Rockingstone Heights School	Staff Room Kitchen tap	VQU432	April 26, 2023	-	Passed	0.0250	Passed	
Rockingstone Heights School	Gym Cafeteria Kitchen tap	VQU433	April 26, 2023	-	Passed	0.0550	Passed	
Rockingstone Heights School	Gym Cafeteria tap	VQU434	April 26, 2023	-	Passed	0.1200	Passed	
Rockingstone Heights School	Youth Health Centre tap	VQU435	April 26, 2023	0.003	Passed	0.0150	Passed	
Rockingstone Heights School	Fountain by Room 103	VQU436	April 26, 2023	-	Passed	0.0260	Passed	
Rocky Lake Elementary	Staff Wash Room tap by Room 303	MSA062	May 25, 2020	0.001	Passed	0.0330	Passed	
Rocky Lake Elementary	Janitors Closet tap by Room 303	MSA063	May 25, 2020	-	Passed	0.0270	Passed	
Rocky Lake Elementary	Fountain by Room 303	VZI884	May 31, 2023	-	Passed	0.0260	Passed	
Rocky Lake Elementary	Girls Wash Room 305 tap 1	VZI885	May 31, 2023	-	Passed	0.0290	Passed	Tap remediated
Rocky Lake Elementary	Girls Wash Room 305 tap 2	MSA066	May 25, 2020	0.002	Passed	0.1500	Passed	
Rocky Lake Elementary	Girls Wash Room 305 tap 3	MSA067	May 25, 2020	0.001	Passed	0.0830	Passed	
Rocky Lake Elementary	Girls Wash Room 305 tap 4	MSA068	May 25, 2020	0.001	Passed	0.0370	Passed	
Rocky Lake Elementary	Girls Wash Room 305 tap 5	MSA069	May 25, 2020	0.001	Passed	0.0340	Passed	
Rocky Lake Elementary	Boys Wash Room 203 tap 1	VZI892	May 31, 2023	-	Passed	0.0210	Passed	Tap remediated
Rocky Lake Elementary	Boys Wash Room 203 tap 2	MSA076	May 25, 2020	0.001	Passed	0.0380	Passed	
Rocky Lake Elementary	Boys Wash Room 203 tap 3	MSA077	May 25, 2020	-	Passed	0.0220	Passed	
Rocky Lake Elementary	Boys Wash Room 203 tap 4	MSA078	May 25, 2020	0.002	Passed	0.0210	Passed	
Rocky Lake Elementary	Fountain by Room 203	VZI891	May 31, 2023	0.001	Passed	0.0290	Passed	
Rocky Lake Elementary	Staff Wash Room tap by Room 203	MSA079	May 25, 2020	0.002	Passed	0.0340	Passed	
Rocky Lake Elementary	Janitors Closet tap by Room 203	MSA080	May 25, 2020	-	Passed	0.0200	Passed	
Rocky Lake Elementary	Girls Wash Room 205 tap 1	VZI893	May 31, 2023	0.001	Passed	0.0230	Passed	Tap remediated
Rocky Lake Elementary	Girls Wash Room 205 tap 2	MSA083	May 25, 2020	0.005	Passed	0.0350	Passed	
Rocky Lake Elementary	Girls Wash Room 205 tap 3	MSA084	May 25, 2020	-	Passed	0.0250	Passed	
Rocky Lake Elementary	Girls Wash Room 205 tap 4	MSA085	May 25, 2020	-	Passed	0.0230	Passed	
Rocky Lake Elementary	Girls Wash Room 205 tap 5	MSA086	May 25, 2020	0.001	Passed	0.0240	Passed	
Rocky Lake Elementary	Class Room 206 tap	MSA087	May 25, 2020	0.001	Passed	0.0240	Passed	
Rocky Lake Elementary	Gender Neutral Wash Room tap by Elevator	MSA088	May 25, 2020	-	Passed	0.0180	Passed	
Rocky Lake Elementary	Kitchen triple compartment sink tap 1	MSA090	May 25, 2020	0.001	Passed	0.2000	Passed	Out-of-Service
Rocky Lake Elementary	Kitchen triple compartment sink tap 2	MSA091	May 25, 2020	0.003	Passed	0.2700	Passed	Out-of-Service
Rocky Lake Elementary	Kitchen triple compartment sink tap 3	MSA092	May 25, 2020	0.001	Passed	0.1500	Passed	Out-of-Service
Rocky Lake Elementary	Girls Wash Room 5 tap 1	MSA094	May 25, 2020	0.002	Passed	0.1100	Passed	
Rocky Lake Elementary	Girls Wash Room 5 tap 2	MSA095	May 25, 2020	0.002	Passed	0.1100	Passed	
Rocky Lake Elementary	Wash Room tap in Office by exit	MSA097	May 25, 2020	0.004	Passed	0.0400	Passed	
Rocky Lake Elementary	Boiler Room tap	MSQ477	May 27, 2020	0.000	Passed	0.0240	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Rocky Lake Elementary	Cafeteria laundry tap	VZI874	May 31, 2023	0.001	Passed	0.1500	Passed	
Rocky Lake Elementary	Fountain in Main Lobby	VZI875	May 31, 2023	-	Passed	0.0220	Passed	
Rocky Lake Elementary	Caretaker Room 105 tap	VZI876	May 31, 2023	-	Passed	0.0170	Passed	
Rocky Lake Elementary	Boys Wash Room tap 1 in Basement	VZI877	May 31, 2023	-	Passed	0.0150	Passed	
Rocky Lake Elementary	Boys Wash Room tap 2 in Basement	MSA107	May 25, 2020	0.001	Passed	0.0300	Passed	
Rocky Lake Elementary	Fountain in Makerspace	VZI878	May 31, 2023	0.001	Passed	0.0760	Passed	
Rocky Lake Elementary	Laundry Tub in Makerspace tap	VZI879	May 31, 2023	-	Passed	0.0160	Passed	
Rocky Lake Elementary	Wash Room off Girls Wash Room 5 tap	VZI880	May 31, 2023	0.001	Passed	0.0250	Passed	Tap remediated
Rocky Lake Elementary	Laboratory 100 tap 1	XJR841	October 24, 2023	0.002	Passed	0.0300	Passed	Tap remediated
Rocky Lake Elementary	Laboratory 100 tap 2	XJR842	October 24, 2023	0.003	Passed	0.0290	Passed	Tap remediated
Rocky Lake Elementary	Laboratory 102 tap 1	VZI883	May 31, 2023	0.003	Passed	0.0350	Passed	Tap remediated
Rocky Lake Elementary	Laboratory 102 tap 2	MSA102	May 25, 2020	0.003	Passed	0.0570	Passed	
Rocky Lake Elementary	Staff Room 103 Wash Room tap	MSA104	May 25, 2020	-	Passed	0.0200	Passed	
Rocky Lake Elementary	Staff Room 103 tap	MSA105	May 25, 2020	-	Passed	0.0200	Passed	
Rocky Lake Elementary	Lounge Kitchen sink tap	VZI886	May 31, 2023	0.002	Passed	0.0390	Passed	
Rocky Lake Elementary	Kitchen tap 1	VZI887	May 31, 2023	-	Passed	0.0220	Passed	
Rocky Lake Elementary	Kitchen tap 2	VZI888	May 31, 2023	-	Passed	0.0230	Passed	
Rocky Lake Elementary	Kitchen tap 3	VZI889	May 31, 2023	-	Passed	0.0190	Passed	
Rocky Lake Elementary	Kitchen tap 4	VZI890	May 31, 2023	-	Passed	0.0180	Passed	
Rocky Lake Junior High School	Gender Neutral Wash Room 329 tap	MSG715	May 26, 2020	0.001	Passed	0.0330	Passed	
Rocky Lake Junior High School	3rd Floor Boys Wash Room tap 1	MSG717	May 26, 2020	0.002	Passed	0.0460	Passed	
Rocky Lake Junior High School	3rd Floor Boys Wash Room tap 2	MSG718	May 26, 2020	0.001	Passed	0.0120	Passed	
Rocky Lake Junior High School	3rd Floor Boys Wash Room tap 3	MSG719	May 26, 2020	0.001	Passed	0.0100	Passed	
Rocky Lake Junior High School	Janitors Closet tap by 3rd Floor Wash Rooms	MSG720	May 26, 2020	0.001	Passed	0.0130	Passed	
Rocky Lake Junior High School	3rd Floor Girls Wash Room tap 1	MSG722	May 26, 2020	0.002	Passed	0.0670	Passed	
Rocky Lake Junior High School	3rd Floor Girls Wash Room tap 2	MSG723	May 26, 2020	0.001	Passed	0.0140	Passed	
Rocky Lake Junior High School	3rd Floor Girls Wash Room tap 3	MSG724	May 26, 2020	0.001	Passed	0.0300	Passed	
Rocky Lake Junior High School	3rd Floor Girls Wash Room tap 4	MSG725	May 26, 2020	0.004	Passed	0.0270	Passed	
Rocky Lake Junior High School	Staff Room Mens Wash Room tap	MSG727	May 26, 2020	-	Passed	0.0075	Passed	
Rocky Lake Junior High School	Staff Room Female Wash Room tap 2	MSG729	May 26, 2020	0.003	Passed	0.0180	Passed	
Rocky Lake Junior High School	Learning Centre Wash Room 219B tap	MSG730	May 26, 2020	-	Passed	0.0079	Passed	
Rocky Lake Junior High School	Biology Room 205 tap 1	MSG731	May 26, 2020	-	Passed	0.2000	Passed	
Rocky Lake Junior High School	Biology Room 205 tap 2	MSG732	May 26, 2020	-	Passed	0.1900	Passed	
Rocky Lake Junior High School	Biology Room 205 tap 3	MSG733	May 26, 2020	-	Passed	0.1800	Passed	
Rocky Lake Junior High School	Biology Room 205 tap 4	MSG734	May 26, 2020	0.001	Passed	0.1500	Passed	
Rocky Lake Junior High School	Biology Room 205 tap 5	MSG735	May 26, 2020	0.001	Passed	0.1100	Passed	
Rocky Lake Junior High School	Biology Room 205 tap 6	MSG736	May 26, 2020	-	Passed	0.9100	Passed	
Rocky Lake Junior High School	Class Room 205 tap	MSG737	May 26, 2020	-	Passed	1.1000	Passed	
Rocky Lake Junior High School	Chemistry Lab 203 tap 1	MSG738	May 26, 2020	0.058	Exceeded	0.1500	Passed	Laboratory or Hand washing only
Rocky Lake Junior High School	Chemistry Lab 203 tap 2	MSG739	May 26, 2020	0.008	Exceeded	0.1800	Passed	Laboratory or Hand washing only
Rocky Lake Junior High School	Chemistry Lab 203 tap 3	MSG740	May 26, 2020	0.063	Exceeded	0.3300	Passed	Laboratory or Hand washing only
Rocky Lake Junior High School	Chemistry Lab 203 tap 4	MSG741	May 26, 2020	0.023	Exceeded	0.4500	Passed	Laboratory or Hand washing only
Rocky Lake Junior High School	Chemistry Lab 204 Prep Room tap	MSG742	May 26, 2020	0.110	Exceeded	0.8600	Passed	Laboratory or Hand washing only

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Rocky Lake Junior High School	Janitors Closet tap by Room 203	MSG743	May 26, 2020	0.001	Passed	0.0700	Passed	
Rocky Lake Junior High School	Chemistry Lab 202 tap 1	MSG744	May 26, 2020	0.011	Exceeded	0.0710	Passed	Laboratory or Hand washing only
Rocky Lake Junior High School	Chemistry Lab 202 tap 2	MSG745	May 26, 2020	0.007	Exceeded	0.0970	Passed	Laboratory or Hand washing only
Rocky Lake Junior High School	Chemistry Lab 201 tap 1	MSG746	May 26, 2020	0.120	Exceeded	0.8700	Passed	Laboratory or Hand washing only
Rocky Lake Junior High School	Chemistry Lab 201 tap 2	MSG747	May 26, 2020	0.004	Passed	0.0550	Passed	Laboratory or Hand washing only
Rocky Lake Junior High School	Chemistry Lab 201 tap 3	MSG748	May 26, 2020	0.004	Passed	0.1300	Passed	
Rocky Lake Junior High School	Chemistry Lab 201 tap 4	MSG749	May 26, 2020	0.004	Passed	0.0530	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 1 connected to Gym	MSG750	May 26, 2020	0.002	Passed	0.0960	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 2 connected to Gym	MSG751	May 26, 2020	0.001	Passed	0.0510	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 3 connected to Gym	MSG752	May 26, 2020	0.003	Passed	0.1900	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 3 connected to Gym	MSG756	May 26, 2020	0.002	Passed	0.0096	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 4 connected to Gym	MSG757	May 26, 2020	0.001	Passed	0.0069	Passed	
Rocky Lake Junior High School	Main Office Staff Wash Room tap	MSG760	May 26, 2020	0.001	Passed	0.0300	Passed	
Rocky Lake Junior High School	Vice Principal Room tap	MSG761	May 26, 2020	0.003	Passed	0.0560	Passed	
Rocky Lake Junior High School	1st Floor Girls Wash Room tap 2	MSG770	May 26, 2020	0.001	Passed	0.0160	Passed	
Rocky Lake Junior High School	1st Floor Girls Wash Room tap 3	MSG771	May 26, 2020	0.001	Passed	0.0110	Passed	
Rocky Lake Junior High School	1st Floor Girls Wash Room tap 4	MSG772	May 26, 2020	0.001	Passed	0.0110	Passed	
Rocky Lake Junior High School	Gender Neutral Wash Room tap by 1st Floor Wash Rooms	MSG773	May 26, 2020	0.001	Passed	0.3100	Passed	
Rocky Lake Junior High School	Janitors Closet tap by Room 103	MTA205	May 28, 2020	0.001	Passed	0.0340	Passed	
Rocky Lake Junior High School	1st Floor Boys Wash Room tap 1	MTA206	May 28, 2020	-	Passed	0.0200	Passed	
Rocky Lake Junior High School	1st Floor Boys Wash Room tap 3	MTA208	May 28, 2020	0.001	Passed	0.0170	Passed	
Rocky Lake Junior High School	Class Room 103 tap	MTA209	May 28, 2020	-	Passed	0.0110	Passed	
Rocky Lake Junior High School	Boiler Room tap	MTA210	May 28, 2020	-	Passed	0.0200	Passed	
Rocky Lake Junior High School	Class Room 104 tap	MTA214	May 28, 2020	-	Passed	0.9000	Passed	
Rocky Lake Junior High School	Staff Photocopy Room tap	SCH350	March 15, 2022	-	Passed	0.0160	Passed	
Rocky Lake Junior High School	1st Floor Girls Wash Room tap 1	VXI855	May 31, 2023	-	Passed	0.0130	Passed	
Rocky Lake Junior High School	Room 105 triple compartment sink tap 2	VZI854	May 31, 2023	-	Passed	0.1500	Passed	
Rocky Lake Junior High School	1st Floor Boys Wash Room tap 2	VZI856	May 31, 2023	0.001	Passed	0.0540	Passed	
Rocky Lake Junior High School	Gym Physical Education Office 1 tap	VZI857	May 31, 2023	0.003	Passed	0.1300	Passed	
Rocky Lake Junior High School	Gym Physical Education Office 2 tap	VZI858	May 31, 2023	-	Passed	0.0350	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 1 connected to Gym	VZI859	May 31, 2023	-	Passed	0.0059	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 2 connected to Gym	VZI860	May 31, 2023	-	Passed	0.0150	Passed	
Rocky Lake Junior High School	Fountain by Cafeteria	VZI860	May 31, 2023	0.001	Passed	0.0540	Passed	
Rocky Lake Junior High School	Sick Room tap by Room 329	VZI862	May 31, 2023	-	Passed	0.0086	Passed	
Rocky Lake Junior High School	Cafeteria Janitors Closet tap	VZI863	May 31, 2023	0.001	Passed	0.2700	Passed	
Rocky Lake Junior High School	Cafeteria hand washing sink tap	VZI864	May 31, 2023	0.001	Passed	0.0560	Passed	
Rocky Lake Junior High School	Cafeteria triple sink tap 1	VZI865	May 31, 2023	-	Passed	0.0230	Passed	
Rocky Lake Junior High School	Cafeteria triple sink tap 2	VZI866	May 31, 2023	-	Passed	0.0330	Passed	
Rocky Lake Junior High School	Cafeteria bar sink tap	VZI867	May 31, 2023	-	Passed	0.0160	Passed	
Rocky Lake Junior High School	Fountain by 3rd Floor Wash Rooms	VZI868	May 31, 2023	-	Passed	0.0260	Passed	
Rocky Lake Junior High School	Learning Centre 301 tap	vzi869	May 31, 2023	-	Passed	0.0100	Passed	
Rocky Lake Junior High School	Fountain by Gym Wash Rooms	VZI870	May 31, 2023	-	Passed	0.0360	Passed	
Rocky Lake Junior High School	Staff Room tap	VZI871	May 31, 2023	-	Passed	0.0110	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Rocky Lake Junior High School	Staff Room Female Wash Room tap 1	VZI872	May 31, 2023	0.001	Passed	0.0180	Passed	Tap remediated
Rocky Lake Junior High School	Room 105 triple compartment sink tap 1	VZI873	May 31, 2023	-	Passed	0.1400	Passed	
Ross Road School	Staff Room 111 Wash Room tap	MXZ638	June 22, 2020	-	Passed	0.0260	Passed	
Ross Road School	Girls Wash Room tap 1 by Room 104	MXZ639	June 22, 2020	0.003	Passed	0.1200	Passed	
Ross Road School	Girls Wash Room tap 2 by Room 104	MXZ640	June 22, 2020	0.001	Passed	0.0280	Passed	
Ross Road School	Boys Wash Room tap 1 by Room 104	XGE228	October 11, 2023	-	Passed	0.0310	Passed	Tap remediated
Ross Road School	Boys Wash Room tap 2 by Room 104	MXZ642	June 22, 2020	0.004	Passed	0.2400	Passed	
Ross Road School	Gender Neutral Wash Room tap by Room 107	MXZ643	June 22, 2020	0.003	Passed	0.1800	Passed	
Ross Road School	Janitors Closet tap by Room 108	MXZ644	June 22, 2020	0.001	Passed	0.2000	Passed	
Ross Road School	Girls Wash Room tap 1 by Room 120	MXZ645	June 22, 2020	0.003	Passed	0.2200	Passed	
Ross Road School	Girls Wash Room tap 2 by Room 120	MXZ646	June 22, 2020	0.002	Passed	0.2100	Passed	
Ross Road School	Girls Wash Room tap 3 by Room 120	MXZ647	June 22, 2020	0.003	Passed	0.2000	Passed	
Ross Road School	Janitors Closet tap by Boys Wash Room	MXZ648	June 22, 2020	0.001	Passed	0.0260	Passed	
Ross Road School	Boys Wash Room tap 1 near Room 120	MXZ649	June 22, 2020	0.001	Passed	0.2400	Passed	
Ross Road School	Boys Wash Room tap 2 near Room 120	MXZ650	June 22, 2020	0.003	Passed	0.1800	Passed	
Ross Road School	Boys Wash Room tap 3 near Room 120	MXZ651	June 22, 2020	0.001	Passed	0.0470	Passed	
Ross Road School	Family Studies 120 tap 1	XGE229	October 11, 2023	-	Passed	0.0160	Passed	
Ross Road School	Family Studies 120 tap 2	XGE230	October 11, 2023	0.001	Passed	0.0310	Passed	
Ross Road School	Family Studies 120 tap 3	XGE231	October 11, 2023	0.001	Passed	0.0260	Passed	
Ross Road School	Family Studies 120 tap 4	XGE232	October 11, 2023	-	Passed	0.0290	Passed	
Ross Road School	Family Studies 120 tap 5	XGE234	October 11, 2023	0.001	Passed	0.0290	Passed	
Ross Road School	Janitors Closet 135 tap	MXZ659	June 22, 2020	0.001	Passed	0.0560	Passed	
Ross Road School	Tech Ed. Room tap	MXZ661	June 22, 2020	0.001	Passed	0.3300	Passed	
Ross Road School	Gym Office 138 tap	XGE236	October 11, 2023	-	Passed	0.1200	Passed	Tap remediated
Ross Road School	Boys Locker Room 140 tap	XGE237	October 11, 2023	-	Passed	0.0730	Passed	Tap remediated
Ross Road School	Girls Locker Room 141 tap	MXZ664	June 22, 2020	0.001	Passed	0.9300	Passed	
Ross Road School	Gym Office 139 tap	MXZ665	June 22, 2020	0.001	Passed	0.1200	Passed	
Ross Road School	Class Room 134 tap	MXZ666	June 22, 2020	0.001	Passed	0.1400	Passed	
Ross Road School	Class Room 133 tap	MXZ667	June 22, 2020	0.002	Passed	0.1300	Passed	
Ross Road School	Cafeteria/Kitchen tap 1	XGE223	October 11, 2023	0.001	Passed	0.0850	Passed	
Ross Road School	Cafeteria/Kitchen tap 2	XGE224	October 11, 2023	0.002	Passed	0.0980	Passed	
Ross Road School	Cafeteria/Kitchen tap 3	XGE225	October 11, 2023	0.001	Passed	0.0830	Passed	
Ross Road School	Cafeteria/Kitchen tap 4	XGE226	October 11, 2023	-	Passed	0.0740	Passed	
Ross Road School	Staff Room 216 tap	XGE240	October 11, 2023	-	Passed	0.0130	Passed	
Ross Road School	Gender Neutral Wash Room 217 tap	MXZ673	June 22, 2020	0.002	Passed	0.0870	Passed	
Ross Road School	Girls Wash Room tap 1 by Room 217	MXZ674	June 22, 2020	0.004	Passed	0.1800	Passed	
Ross Road School	Girls Wash Room tap 2 by Room 217	XGE241	October 11, 2023	-	Passed	0.0110	Passed	Tap remediated
Ross Road School	Girls Wash Room tap 3 by Room 217	XGE242	October 11, 2023	-	Passed	0.0120	Passed	Tap remediated
Ross Road School	Janitors Closet 214 tap	MXZ677	June 22, 2020	0.001	Passed	0.0500	Passed	
Ross Road School	Fountain by Room 214	XGE239	October 11, 2023	-	Passed	0.0970	Passed	
Ross Road School	Boys Wash Room tap 1 by Room 214	XGE243	October 11, 2023	-	Passed	0.0140	Passed	Tap remediated
Ross Road School	Boys Wash Room tap 2 by Room 214	XGE233	October 11, 2023	-	Passed	0.0120	Passed	Tap remediated
Ross Road School	Boys Wash Room tap 3 by Room 214	MXZ681	June 22, 2020	0.005	Passed	0.1500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ross Road School	Fountain by Boiler Room	XGE238	October 11, 2023	-	Passed	0.0019	Passed	
Ross Road School	Fountain in Gym	XGE235	October 11, 2023	-	Passed	0.0025	Passed	
Ross Road School	Fountain by Room 104	XGE227	October 11, 2023	-	Passed	0.0660	Passed	
Sackville Heights Elementary	Boys Locker Room tap in Gym	MYH123	June 23, 2020	-	Passed	0.0240	Passed	
Sackville Heights Elementary	Girls Locker Room tap in Gym	MYH124	June 23, 2020	0.001	Passed	0.4200	Passed	
Sackville Heights Elementary	Gym Office Wash Room tap	MYH125	June 23, 2020	-	Passed	0.0470	Passed	
Sackville Heights Elementary	Janitors Closet tap Room 1059	MYH129	June 23, 2020	-	Passed	0.0400	Passed	
Sackville Heights Elementary	Music Room tap by Room 1059	MYH130	June 23, 2020	-	Passed	0.1600	Passed	
Sackville Heights Elementary	Art Room tap Room 1063	MYH131	June 23, 2020	-	Passed	0.3900	Passed	
Sackville Heights Elementary	Recycle Room tap Room 1055	MYH132	June 23, 2020	-	Passed	0.0600	Passed	
Sackville Heights Elementary	Class Room tap Room 1036	MYH133	June 23, 2020	-	Passed	0.6100	Passed	
Sackville Heights Elementary	Class Room tap Room 1037	MYH134	June 23, 2020	0.001	Passed	0.1200	Passed	
Sackville Heights Elementary	Class Room tap Room 1038	MYH135	June 23, 2020	0.001	Passed	0.1400	Passed	
Sackville Heights Elementary	Class Room tap Room 1039	MYH136	June 23, 2020	0.001	Passed	0.2100	Passed	
Sackville Heights Elementary	Gender Neutral Wash Room tap Room 1041	MYH137	June 23, 2020	0.001	Passed	0.1600	Passed	
Sackville Heights Elementary	Class Room tap Room 1025	MYH138	June 23, 2020	0.001	Passed	0.1100	Passed	
Sackville Heights Elementary	Class Room tap Room 1026	MYH139	June 23, 2020	-	Passed	0.0520	Passed	
Sackville Heights Elementary	Gender Neutral Wash Room tap Room 1031	MYH140	June 23, 2020	0.001	Passed	0.0890	Passed	
Sackville Heights Elementary	Class Room tap Room 1027	MYH141	June 23, 2020	-	Passed	0.0420	Passed	
Sackville Heights Elementary	Class Room tap Room 1028	MYH142	June 23, 2020	-	Passed	0.0640	Passed	
Sackville Heights Elementary	Gender Neutral Wash Room tap Room 1022	MYH143	June 23, 2020	-	Passed	0.0440	Passed	
Sackville Heights Elementary	Main Office Wash Room tap Room 1018	MYH145	June 23, 2020	-	Passed	0.0410	Passed	
Sackville Heights Elementary	Girls Wash Room tap 1 Room 1050	MYH147	June 23, 2020	0.001	Passed	0.3200	Passed	
Sackville Heights Elementary	Girls Wash Room tap 2 Room 1050	MYH148	June 23, 2020	0.002	Passed	0.1800	Passed	
Sackville Heights Elementary	Girls Wash Room tap 3 Room 1050	MYH149	June 23, 2020	0.002	Passed	0.1700	Passed	
Sackville Heights Elementary	Boys Wash Room tap 1 Room 1049	MYH150	June 23, 2020	0.001	Passed	0.1300	Passed	
Sackville Heights Elementary	Boys Wash Room tap 3 Room 1049	MYH152	June 23, 2020	0.001	Passed	0.1700	Passed	
Sackville Heights Elementary	Library Storage Room tap Room 1047	MYH154	June 23, 2020	0.004	Passed	0.2400	Passed	
Sackville Heights Elementary	Girls Wash Room tap 1 Room 1046	MYH155	June 23, 2020	0.002	Passed	0.2000	Passed	
Sackville Heights Elementary	Girls Wash Room tap 2 Room 1046	MYH156	June 23, 2020	0.001	Passed	0.1500	Passed	
Sackville Heights Elementary	Boys Wash Room tap 1 Room 1045	MYH157	June 23, 2020	0.002	Passed	0.1800	Passed	
Sackville Heights Elementary	Boys Wash Room tap 2 Room 1045	MYH158	June 23, 2020	0.003	Passed	0.3200	Passed	
Sackville Heights Elementary	Class Room tap Room 2030	MYH160	June 23, 2020	-	Passed	0.3600	Passed	
Sackville Heights Elementary	Class Room tap Room 2031	MYH161	June 23, 2020	-	Passed	0.2400	Passed	
Sackville Heights Elementary	Class Room tap Room 2032	MYH162	June 23, 2020	-	Passed	0.2400	Passed	
Sackville Heights Elementary	Class Room tap Room 2033	MYH163	June 23, 2020	0.001	Passed	0.8300	Passed	
Sackville Heights Elementary	Class Room tap Room 2017	MYH164	June 23, 2020	0.001	Passed	0.0850	Passed	
Sackville Heights Elementary	Class Room tap Room 2018	MYH165	June 23, 2020	0.001	Passed	0.2100	Passed	
Sackville Heights Elementary	Class Room tap Room 2019	MYH166	June 23, 2020	0.001	Passed	0.1200	Passed	
Sackville Heights Elementary	Class Room tap Room 2020	MYH167	June 23, 2020	0.001	Passed	0.1300	Passed	
Sackville Heights Elementary	Staff Room Wash Room 1 tap Room 2009	MYH168	June 23, 2020	0.001	Passed	0.0820	Passed	
Sackville Heights Elementary	Staff Room Wash Room 2 tap Room 2008	MYH169	June 23, 2020	-	Passed	0.0510	Passed	
Sackville Heights Elementary	Janitors Closet tap Room 2040	MYH171	June 23, 2020	-	Passed	0.0740	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Sackville Heights Elementary	Girls Wash Room tap 1 Room 2025	MYH173	June 23, 2020	0.001	Passed	0.2000	Passed	
Sackville Heights Elementary	Girls Wash Room tap 2 Room 2025	MYH174	June 23, 2020	0.001	Passed	0.1800	Passed	
Sackville Heights Elementary	Girls Wash Room tap 3 Room 2025	MYH175	June 23, 2020	0.002	Passed	0.2000	Passed	
Sackville Heights Elementary	Boys Wash Room tap 1 Room 2026	MYH176	June 23, 2020	0.001	Passed	0.1300	Passed	
Sackville Heights Elementary	Boys Wash Room tap 2 Room 2026	MYH177	June 23, 2020	0.002	Passed	0.2100	Passed	
Sackville Heights Elementary	Boys Wash Room tap 3 Room 2026	MYH178	June 23, 2020	0.001	Passed	0.0810	Passed	
Sackville Heights Elementary	Boys Wash Room tap 2 Room 1049	NXK291	October 15, 2020	-	Passed	0.0640	Passed	Tap remediated
Sackville Heights Elementary	Fountain by Room 1050	XJR937	October 24, 2023	-	Passed	0.002	Passed	
Sackville Heights Elementary	Kitchen/Cafeteria 1066 tap 1	WCT664	June 14, 2023	-	Passed	0.0870	Passed	Tap remediated
Sackville Heights Elementary	Kitchen/Cafeteria 1066 tap 2	WCT665	June 14, 2023	-	Passed	0.0230	Passed	
Sackville Heights Elementary	Kitchen/Cafeteria 1066 tap 3	WCT666	June 14, 2023	-	Passed	0.0160	Passed	
Sackville Heights Elementary	Fountain by Room 1045	WCT667	June 14, 2023	-	Passed	0.0280	Passed	
Sackville Heights Elementary	Fountain by Room 1049	WCT668	June 14, 2023	-	Passed	0.0014	Passed	
Sackville Heights Elementary	Main Office Sick Room 1021 tap	WCT669	June 14, 2023	-	Passed	0.0330	Passed	
Sackville Heights Elementary	Fountain by Room 2026	WCT670	June 14, 2023	-	Passed	0.0009	Passed	
Sackville Heights Elementary	Staff Room 2007 tap	WCT671	June 14, 2023	-	Passed	0.0340	Passed	
Sackville Heights Elementary	Fountain by Room 2017	WCT672	June 14, 2023	-	Passed	0.0016	Passed	
Sackville Heights Elementary	Modular 1 Janitors Closet	WCT673	June 14, 2023	-	Passed	0.0019	Passed	
Sackville Heights Elementary	Fountain in Modular 1	WCT674	June 14, 2023	-	Passed	0.0640	Passed	
Sackville Heights Elementary	Modular 1 Girls Wash Room tap 1	WCT675	June 14, 2023	-	Passed	0.0340	Passed	
Sackville Heights Elementary	Modular 1 Girls Wash Room tap 2	WCT676	June 14, 2023	-	Passed	0.0270	Passed	
Sackville Heights Elementary	Modular 1 Girls Wash Room tap 3	WCT677	June 14, 2023	-	Passed	0.0240	Passed	
Sackville Heights Elementary	Modular 1 Boys Wash Room tap 1	WCT678	June 14, 2023	-	Passed	0.0300	Passed	
Sackville Heights Elementary	Modular 1 Boys Wash Room tap 2	WCT679	June 14, 2023	-	Passed	0.0260	Passed	
Sackville Heights Elementary	Modular 1 Staff Wash Room tap 1	WCT680	June 14, 2023	-	Passed	0.0300	Passed	
Sackville Heights Elementary	Modular 1 Staff Wash Room tap 2	WCT681	June 14, 2023	-	Passed	0.3900	Passed	
Sackville Heights Elementary	Modular 2 Janitors Closet tap	WCT682	June 14, 2023	-	Passed	0.1400	Passed	
Sackville Heights Elementary	Fountain in Modular 2	WCT684	June 14, 2023	-	Passed	0.0750	Passed	
Sackville Heights Elementary	Modular 2 Girls Wash Room tap 1	WCT685	June 14, 2023	-	Passed	0.0600	Passed	
Sackville Heights Elementary	Modular 2 Girls Wash Room tap 2	WCT686	June 14, 2023	-	Passed	0.0560	Passed	
Sackville Heights Elementary	Modular 2 Girls Wash Room tap 3	WCT687	June 14, 2023	-	Passed	0.0570	Passed	
Sackville Heights Elementary	Modular 2 Boys Wash Room tap 1	WCT688	June 14, 2023	-	Passed	0.0520	Passed	
Sackville Heights Elementary	Modular 2 Boys Wash Room tap 2	WCT689	June 14, 2023	-	Passed	0.0510	Passed	
Sackville Heights Elementary	Modular 2 Staff Wash Room tap	WCT690	June 14, 2023	-	Passed	0.0440	Passed	
Sackville Heights Junior High School	Art Room tap 1 Room 235	MTV819	June 1, 2020	0.001	Passed	0.3200	Passed	
Sackville Heights Junior High School	Art Room tap 2 Room 235	MTV820	June 1, 2020	0.001	Passed	0.2400	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 2 by Room 230	MTV822	June 1, 2020	0.003	Passed	0.5000	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 3 by Room 230	MTV823	June 1, 2020	-	Passed	0.1600	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 4 by Room 230	MTV824	June 1, 2020	-	Passed	0.1300	Passed	
Sackville Heights Junior High School	Janitors Closet tap by Girls Wash Room	MTV825	June 1, 2020	-	Passed	0.0430	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 1 by Telecom 3	MTV827	June 1, 2020	-	Passed	0.2900	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 2 by Telecom 3	MTV833	June 1, 2020	0.001	Passed	0.2100	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 3 by Telecom 3	MTV834	June 1, 2020	-	Passed	0.2300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Sackville Heights Junior High School	Boys Wash Room tap 4 by Telecom 3	MTV835	June 1, 2020	-	Passed	0.1800	Passed	
Sackville Heights Junior High School	Science Room tap 1 by Boys Wash Room	MTV836	June 1, 2020	0.001	Passed	0.1300	Passed	
Sackville Heights Junior High School	Science Room tap 2 by Boys Wash Room	MTV837	June 1, 2020	0.001	Passed	0.2000	Passed	
Sackville Heights Junior High School	Gender Neutral Wash Room tap Room 214C	MTV842	June 1, 2020	-	Passed	0.2200	Passed	
Sackville Heights Junior High School	Gender Neutral Wash Room tap Room 216	MTV859	June 1, 2020	-	Passed	0.0390	Passed	
Sackville Heights Junior High School	Class Room tap Room 214C	MTV860	June 1, 2020	-	Passed	0.1300	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 2 by Room 207A	MTV862	June 1, 2020	0.004	Passed	0.2700	Passed	
Sackville Heights Junior High School	Janitors Closet tap between Wash Rooms	MTV864	June 1, 2020	0.001	Passed	0.0590	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 1 by Room 203	MTV865	June 1, 2020	-	Passed	0.1400	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 2 by Room 203	MTV866	June 1, 2020	-	Passed	0.0810	Passed	
Sackville Heights Junior High School	Music Room tap Room 161	MTV872	June 1, 2020	-	Passed	0.4400	Passed	
Sackville Heights Junior High School	Janitors Closet tap Room 154	MTV873	June 1, 2020	-	Passed	0.2100	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 1 by Room 151	MTV875	June 1, 2020	0.004	Passed	0.1600	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 2 by Room 151	MTV876	June 1, 2020	-	Passed	0.2300	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 3 by Room 151	MTV877	June 1, 2020	-	Passed	0.1600	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 4 by Room 151	MTV878	June 1, 2020	-	Passed	0.1400	Passed	
Sackville Heights Junior High School	Staff Wash Room tap in Girls Wash Room 139	MTV886	June 1, 2020	-	Passed	0.0590	Passed	
Sackville Heights Junior High School	Janitors Closet 135 tap	MTV888	June 1, 2020	-	Passed	0.0230	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 1 by Room 135	MTV889	June 1, 2020	0.001	Passed	0.1600	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 2 by Room 135	MTV890	June 1, 2020	-	Passed	0.2200	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 3 by Room 135	MTV891	June 1, 2020	-	Passed	0.1500	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 4 by Room 135	MTV892	June 1, 2020	0.001	Passed	0.2400	Passed	
Sackville Heights Junior High School	Gender Neutral Wash Room tap Room 131B	MTV893	June 1, 2020	-	Passed	0.3600	Passed	
Sackville Heights Junior High School	Learning Centre 132B Gender Neutral Wash Room tap	MTV895	June 1, 2020	-	Passed	0.2700	Passed	
Sackville Heights Junior High School	Main Office Gender Neutral Wash Room 121 tap	MTV910	June 1, 2020	-	Passed	0.2100	Passed	
Sackville Heights Junior High School	Main Office Gender Neutral Wash Room 122 tap	MTV911	June 1, 2020	-	Passed	0.2700	Passed	
Sackville Heights Junior High School	Wood Shop 111 tap	MTV912	June 1, 2020	0.001	Passed	0.2900	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 1 by Wood Shop	MTV913	June 1, 2020	-	Passed	0.1000	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 2 by Wood Shop	MTV914	June 1, 2020	-	Passed	0.0810	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 3 by Wood Shop	MTV915	June 1, 2020	0.002	Passed	0.0830	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 4 by Wood Shop	MTV916	June 1, 2020	0.001	Passed	0.0930	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 5 by Wood Shop	MTV917	June 1, 2020	-	Passed	0.0760	Passed	
Sackville Heights Junior High School	Janitors Closet 107 tap	MUD544	June 2, 2020	0.001	Passed	0.0560	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 1 by Room 103	MUD545	June 2, 2020	-	Passed	0.1900	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 2 by Room 103	MUD546	June 2, 2020	0.002	Passed	0.2100	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 3 by Room 103	MUD547	June 2, 2020	-	Passed	0.1700	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 4 by Room 103	MUD548	June 2, 2020	-	Passed	0.1700	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 5 by Room 103	MUD549	June 2, 2020	-	Passed	0.1200	Passed	
Sackville Heights Junior High School	Girls Locker Room tap 1 in Gym	MUD550	June 2, 2020	0.001	Passed	0.2200	Passed	
Sackville Heights Junior High School	Girls Locker Room tap 2 in Gym	MUD551	June 2, 2020	0.001	Passed	0.4500	Passed	
Sackville Heights Junior High School	Boys Locker Room tap 1 in Gym	MUD552	June 2, 2020	0.001	Passed	0.1500	Passed	
Sackville Heights Junior High School	Boys Locker Room tap 2 in Gym	MUD553	June 2, 2020	-	Passed	0.1200	Passed	
Sackville Heights Junior High School	Gym Office Wash Room 170A tap	MUD554	June 2, 2020	-	Passed	0.4000	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Sackville Heights Junior High School	Fountain by Room 135	WCT691	June 14, 2023	-	Passed	0.0015	Passed	
Sackville Heights Junior High School	Class Room 141 tap	WCT692	June 14, 2023	-	Passed	0.0160	Passed	Tap remediated
Sackville Heights Junior High School	Fountain by Gym	WCT693	June 14, 2023	-	Passed	0.0490	Passed	
Sackville Heights Junior High School	Fountain by Room 103	WCT694	June 14, 2023	-	Passed	0.0120	Passed	
Sackville Heights Junior High School	Cafeteria single compartment sink tap	WCT695	June 14, 2023	-	Passed	0.1300	Passed	
Sackville Heights Junior High School	Cafeteria double compartment sink tap	WCT696	June 14, 2023	-	Passed	0.1500	Passed	
Sackville Heights Junior High School	Cafeteria hand wash sink tap	WCT697	June 14, 2023	-	Passed	0.1100	Passed	
Sackville Heights Junior High School	Learning Centre 132B tap	WCT698	June 14, 2023	-	Passed	0.0072	Passed	
Sackville Heights Junior High School	Family Studies tap 1 Room 222	WCT699	June 14, 2023	-	Passed	0.0300	Passed	
Sackville Heights Junior High School	Family Studies tap 2 Room 222	WCT700	June 14, 2023	-	Passed	0.0180	Passed	
Sackville Heights Junior High School	Room 243 laundry tub tap	WCT708	June 14, 2023	-	Passed	0.0120	Passed	
Sackville Heights Junior High School	Family Studies tap 3 Room 222	WCT701	June 14, 2023	-	Passed	0.0076	Passed	
Sackville Heights Junior High School	Family Studies tap 4 Room 222	WCT702	June 14, 2023	-	Passed	0.0061	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 1 by Room 230	WCT703	June 14, 2023	-	Passed	0.1800	Passed	Tap remediated
Sackville Heights Junior High School	Fountain By Room 230	WCT704	June 14, 2023	-	Passed	0.0240	Passed	
Sackville Heights Junior High School	Fountain by Room 207A	WCT705	June 14, 2023	-	Passed	0.1600	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 1 by Room 207A	WCT706	June 14, 2023	-	Passed	0.0670	Passed	Tap remediated
Sackville Heights Junior High School	Room 248 laundry tub tap	WCT707	June 14, 2023	0.001	Passed	0.0510	Passed	
Sackville High School	Chemistry Lab tap 1 Room 304	MSP782	May 27, 2020	0.006	Exceeded	0.7400	Passed	Laboratory or Hand washing only
Sackville High School	Chemistry Lab tap 2 Room 304	MSP783	May 27, 2020	0.009	Exceeded	0.6800	Passed	Laboratory or Hand washing only
Sackville High School	Chemistry Lab tap 3 Room 304	MSP784	May 27, 2020	0.005	Exceeded	0.6700	Passed	Laboratory or Hand washing only
Sackville High School	Chemistry Lab tap 4 Room 304	MSP785	May 27, 2020	0.007	Exceeded	0.7000	Passed	Laboratory or Hand washing only
Sackville High School	Chemistry Lab tap 5 Room 304	MSP786	May 27, 2020	0.004	Passed	0.6100	Passed	
Sackville High School	Chemistry Storage Room tap Room 305	MSP787	May 27, 2020	0.008	Exceeded	0.2200	Passed	Laboratory or Hand washing only
Sackville High School	Chemistry Storage Room tap Room 306	MSP788	May 27, 2020	0.006	Exceeded	0.1700	Passed	Laboratory or Hand washing only
Sackville High School	Chemistry Lab tap 1 Room 307	MSP789	May 27, 2020	0.013	Exceeded	1.1000	Passed	Laboratory or Hand washing only
Sackville High School	Chemistry Lab tap 2 Room 307	MSP790	May 27, 2020	0.026	Exceeded	0.4900	Passed	Laboratory or Hand washing only
Sackville High School	Chemistry Lab tap 3 Room 307	MSP791	May 27, 2020	0.005	Passed	0.8900	Passed	
Sackville High School	Chemistry Lab tap 4 Room 307	MSP870	May 27, 2020	0.006	Exceeded	0.7300	Passed	Laboratory or Hand washing only
Sackville High School	Chemistry Lab tap 5 Room 307	MSP871	May 27, 2020	0.004	Passed	0.2300	Passed	
Sackville High School	Physics Lab tap 1 Room 309	MSP872	May 27, 2020	0.007	Exceeded	1.4000	Passed	Laboratory or Hand washing only
Sackville High School	Physics Lab tap 2 Room 309	MSP873	May 27, 2020	0.045	Exceeded	0.8600	Passed	Laboratory or Hand washing only
Sackville High School	Class Room 312 tap 2	MSP877	June 13, 2023	0.005	Passed	0.5800	Passed	
Sackville High School	Class Room 313 tap 1	MSP879	May 27, 2020	0.003	Passed	0.2600	Passed	
Sackville High School	Class Room tap Room 321	MSP881	May 27, 2020	0.004	Passed	0.8600	Passed	
Sackville High School	Health Centre 325 tap	XJR452	October 24, 2023	-	Passed	0.0130	Passed	Tap remediated
Sackville High School	Gender Neutral Wash Room tap 1 by Room 325	MSP884	May 27, 2020	0.002	Passed	0.2800	Passed	
Sackville High School	Gender Neutral Wash Room tap 2 by Room 325	MSP885	May 27, 2020	0.002	Passed	0.3600	Passed	
Sackville High School	Gender Neutral Wash Room tap 3 by Room 325	MSP886	May 27, 2020	0.002	Passed	0.1300	Passed	
Sackville High School	Gender Neutral Wash Room tap 4 by Room 325	MSP887	May 27, 2020	0.001	Passed	0.0690	Passed	
Sackville High School	Electrical Room tap Room 326	MSP888	May 27, 2020	0.001	Passed	0.0450	Passed	
Sackville High School	Mens Staff Wash Room tap	MSP890	May 27, 2020	0.002	Passed	0.0820	Passed	
Sackville High School	Womens Staff Wash Room tap	MSP891	May 27, 2020	0.002	Passed	0.0660	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Sackville High School	Class Room tap 1 Room 238	MSP892	May 27, 2020	0.004	Passed	0.4000	Passed	
Sackville High School	Class Room tap 2 Room 238	MSP893	May 27, 2020	0.002	Passed	0.1700	Passed	
Sackville High School	Class Room Wash Room 1 tap Room 238	MSP894	May 27, 2020	0.002	Passed	0.2200	Passed	
Sackville High School	Class Room Wash Room 2 tap Room 238	MSP895	May 27, 2020	0.001	Passed	0.1500	Passed	
Sackville High School	2nd Floor Girls Wash Room tap 1	MSP898	May 27, 2020	0.001	Passed	0.0470	Passed	
Sackville High School	2nd Floor Girls Wash Room tap 2	MSP899	May 27, 2020	-	Passed	0.0310	Passed	
Sackville High School	2nd Floor Girls Wash Room tap 3	MSP915	May 27, 2020	-	Passed	0.0230	Passed	
Sackville High School	2nd Floor Girls Wash Room tap 4	MSP916	May 27, 2020	-	Passed	0.0170	Passed	
Sackville High School	Janitors Closet tap between Wash Rooms	MSP917	May 27, 2020	0.001	Passed	0.0380	Passed	
Sackville High School	2nd Floor Boys Wash Room tap 1	MSP919	May 27, 2020	0.001	Passed	0.0650	Passed	
Sackville High School	2nd Floor Boys Wash Room tap 2	MSP920	May 27, 2020	-	Passed	0.0150	Passed	
Sackville High School	2nd Floor Boys Wash Room tap 3	MSP921	May 27, 2020	0.001	Passed	0.0120	Passed	
Sackville High School	2nd Floor Boys Wash Room tap 4	MSP922	May 27, 2020	-	Passed	0.0120	Passed	
Sackville High School	Boiler Room tap	MSP924	May 27, 2020	-	Passed	0.0044	Passed	
Sackville High School	Boys Locker Room tap	MSP934	May 27, 2020	0.002	Passed	0.0960	Passed	
Sackville High School	Girls Locker Room tap	MSP935	May 27, 2020	0.003	Passed	0.1400	Passed	
Sackville High School	3rd Floor Janitors Closet	MSQ363	May 27, 2020	0.003	Passed	0.2900	Passed	
Sackville High School	Gender Neutral Wash Room tap 1 by stairs	MSQ365	May 27, 2020	0.002	Passed	0.3500	Passed	
Sackville High School	Gender Neutral Wash Room tap 2 by stairs	MSQ366	May 27, 2020	0.001	Passed	0.0520	Passed	
Sackville High School	Gender Neutral Wash Room tap 3 by stairs	MSQ367	May 27, 2020	0.002	Passed	0.1500	Passed	
Sackville High School	Gender Neutral Wash Room tap 4 by stairs	MSQ368	May 27, 2020	0.002	Passed	0.1000	Passed	
Sackville High School	Gym Office 1 tap	MSQ372	May 27, 2020	0.001	Passed	0.2500	Passed	
Sackville High School	Gym Office 2 tap	MSQ373	May 27, 2020	0.003	Passed	1.6000	Passed	
Sackville High School	Staff Room tap	MSQ375	June 13, 2023	0.002	Passed	0.1600	Passed	
Sackville High School	Boys Wash Room tap 2 by Cafeteria	MTN372	May 29, 2020	0.001	Passed	0.0120	Passed	
Sackville High School	Boys Wash Room tap 3 by Cafeteria	MTN373	May 29, 2020	0.001	Passed	0.0066	Passed	
Sackville High School	Boys Wash Room tap 4 by Cafeteria	MTN374	May 29, 2020	0.001	Passed	0.0700	Passed	Hand washing only
Sackville High School	Wood Shop tap	MTN432	May 29, 2020	0.002	Passed	0.1400	Passed	
Sackville High School	Gender Neutral Wash Room tap by Art Room	MTN433	May 29, 2020	0.001	Passed	0.1400	Passed	
Sackville High School	Art Room sink tap 1	XJS451	October 24, 2023	-	Passed	0.0120	Passed	Tap remediated
Sackville High School	Art Room sink tap 2	MTN435	May 29, 2020	0.002	Passed	0.2100	Passed	
Sackville High School	Art Room tap Room 129	MTN448	May 29, 2020	0.005	Passed	0.2100	Passed	
Sackville High School	Electronic Room by Cafeteria	MTN449	May 29, 2020	0.005	Passed	0.1100	Passed	
Sackville High School	Janitors Closet tap by Cafeteria	MTN454	May 29, 2020	0.001	Passed	0.0590	Passed	
Sackville High School	Staff Room tap	NJH104	June 13, 2023	0.004	Passed	0.0460	Passed	
Sackville High School	Class Room 310 tap	SCH573	March 15, 2022	0.001	Passed	0.0590	Passed	
Sackville High School	Class Room 312 tap 1	SCH575	March 15, 2022	0.001	Passed	0.0330	Passed	
Sackville High School	Class Room 312 tap 3	SCH576	March 15, 2022	-	Passed	0.0240	Passed	
Sackville High School	Girls Wash Room tap 1 by Cafeteria	WCN232	June 13, 2023	-	Passed	0.0066	Passed	Tap remediated
Sackville High School	Girls Wash Room tap 2 by Cafeteria	XJS450	October 24, 2023	-	Passed	0.0097	Passed	Tap remediated
Sackville High School	Girls Wash Room tap 3 by Cafeteria	WCN234	June 13, 2023	0.001	Passed	0.0520	Passed	Tap remediated
Sackville High School	Girls Wash Room tap 4 by Cafeteria	WCN235	June 13, 2023	0.001	Passed	0.0310	Passed	Tap remediated
Sackville High School	Cafeteria kitchen triple sink tap 1	WCN236	June 13, 2023	0.004	Passed	0.1500	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Sackville High School	Cafeteria kitchen triple sink tap 2	WCN237	June 13, 2023	0.004	Passed	0.1700	Passed	
Sackville High School	Cafeteria hand wash sink tap	XJS448	October 24, 2023	0.001	Passed	0.0480	Passed	
Sackville High School	Fountain by Cafeteria	WCN239	June 13, 2023	-	Passed	0.0007	Passed	
Sackville High School	Boys Wash Room tap 1 by Cafeteria	WCN240	June 13, 2023	-	Passed	0.0180	Passed	Tap remediated
Sackville High School	Fountain by Caretakers Office	WCN241	June 13, 2023	-	Passed	0.0021	Passed	
Sackville High School	Fountain by Room 104	WCN259	June 13, 2023	-	Passed	0.0061	Passed	
Sackville High School	Fountain by Room 204	WCN260	June 13, 2023	-	Passed	0.0042	Passed	
Sackville High School	Gym Fountain	WCN261	June 13, 2023	-	Passed	0.0007	Passed	
Sackville High School	Fountain By Main Office	WCN262	June 13, 2023	-	Passed	0.0150	Passed	
Sackville High School	Staff Room Wash Room 1 tap	WCN265	June 13, 2023	-	Passed	0.0120	Passed	Tap remediated
Sackville High School	Staff Room Wash Room 2 tap							Out-of-Service
Sackville High School	Class Room 311 tap	WCN266	June 13, 2023	0.004	Passed	0.0720	Passed	Tap remediated
Sackville High School	Fountain by Room 326	WCN267	June 13, 2023	-	Passed	0.0008	Passed	
Sackville High School	Class Room 313 tap 2	WCN268	June 13, 2023	0.002	Passed	0.3400	Passed	Tap remediated
Sackville High School	Caretakers Office tap	WCN287	June 13, 2023	0.002	Passed	0.1400	Passed	
Sackville High School	Skilled Trades Room tap 1	WCN288	June 13, 2023	-	Passed	0.0450	Passed	Tap remediated
Saint Mary's Elementary	Class Room tap Room 206	MTP609	May 28, 2020	0.004	Passed	0.0630	Passed	
Saint Mary's Elementary	Janitors Closet tap Room 204	MTP611	May 28, 2020	0.001	Passed	0.0380	Passed	
Saint Mary's Elementary	1st Floor Girls Wash Room tap 1	MTP613	May 28, 2020	0.001	Passed	0.0840	Passed	
Saint Mary's Elementary	1st Floor Girls Wash Room tap 2	MTP614	May 28, 2020	-	Passed	0.0140	Passed	
Saint Mary's Elementary	1st Floor Girls Wash Room tap 3	MTP615	May 28, 2020	-	Passed	0.0062	Passed	
Saint Mary's Elementary	1st Floor Girls Wash Room tap 4	MTP616	May 28, 2020	-	Passed	0.0054	Passed	
Saint Mary's Elementary	Staff Wash Room in Gym	MTP617	May 28, 2020	-	Passed	0.0320	Passed	
Saint Mary's Elementary	1st Floor Boys Wash Room tap 1	MTP618	May 28, 2020	0.001	Passed	0.0420	Passed	
Saint Mary's Elementary	1st Floor Boys Wash Room tap 2	MTP619	May 28, 2020	-	Passed	0.0150	Passed	
Saint Mary's Elementary	1st Floor Boys Wash Room tap 3	MTP620	May 28, 2020	-	Passed	0.0056	Passed	
Saint Mary's Elementary	Maintenance Closet tap Room 110	MTP621	May 28, 2020	0.002	Passed	0.0580	Passed	
Saint Mary's Elementary	Staff Room tap 1	VUA120	May 9, 2023	-	Passed	0.0090	Passed	
Saint Mary's Elementary	Staff Room tap 2	VUA121	May 9, 2023	-	Passed	0.0340	Passed	
Saint Mary's Elementary	Fountain by Janitors Closet	VUA122	May 9, 2023	-	Passed	0.0740	Passed	
Saint Mary's Elementary	Class Room tap Room 205	VUA123	May 9, 2023	-	Passed	0.1000	Passed	Tap remediated
Saint Mary's Elementary	Fountain by Gym	VUA124	May 9, 2023	-	Passed	0.0450	Passed	
Sambro Elementary	Janitors tap in Staff Room	MRV120	May 22, 2020	0.002	Passed	0.7100	Passed	
Sambro Elementary	Boys Wash Room tap 2	RG943	November 17, 2021	0.004	Passed	0.6000	Passed	
Sambro Elementary	Boys Wash Room tap 3	RG944	November 17, 2021	0.003	Passed	0.5900	Passed	
Sambro Elementary	Girls Wash Room tap 1	RG947	November 17, 2021	0.004	Passed	0.5400	Passed	
Sambro Elementary	Girls Wash Room tap 2	RG949	November 17, 2021	0.004	Passed	0.5100	Passed	
Sambro Elementary	Girls Wash Room tap 3	RG950	November 17, 2021	0.004	Passed	0.5100	Passed	
Sambro Elementary	Janitors Closet Room 108 tap	RG951	November 17, 2021	0.002	Passed	0.3300	Passed	
Sambro Elementary	Staff Wash Room 201 tap	RG955	November 17, 2021	0.002	Passed	0.3300	Passed	
Sambro Elementary	Fountain by Room 112	VQL396	April 25, 2023	-	Passed	0.0028	Passed	
Sambro Elementary	Class Room 110 Wash Room tap	VQL397	April 25, 2023	0.004	Passed	1.5000	Passed	
Sambro Elementary	Boys Wash Room tap 1	VQL398	April 25, 2023	0.002	Passed	0.5100	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Sambro Elementary	Fountain by Room 202	VQL399	April 25, 2023	-	Passed	0.0047	Passed	
Sambro Elementary	Staff Room 201 tap	VQL400	April 25, 2023	0.002	Passed	0.3700	Passed	
Sambro Elementary	Staff Room 208 tap	VQL401	April 25, 2023	0.002	Passed	0.4400	Passed	
Sambro Elementary	Cafe Kitchen tap	VQL402	April 25, 2023	0.002	Passed	0.4000	Passed	
Seaside Elementary	3rd Floor Boys Wash Room tap 1	MYZ230	June 25, 2020	0.004	Passed	0.2400	Passed	
Seaside Elementary	3rd Floor Boys Wash Room tap 2	WFH018	June 22, 2023	-	Passed	0.0390	Passed	Tap remediated
Seaside Elementary	Janitors Closet tap by 3rd Floor Wash Rooms	MYZ232	June 25, 2020	0.004	Passed	0.1300	Passed	
Seaside Elementary	3rd Floor Girls Wash Room tap 1	MYZ234	June 25, 2020	0.003	Passed	0.0840	Passed	
Seaside Elementary	3rd Floor Girls Wash Room tap 2	MYZ235	June 25, 2020	0.002	Passed	0.0690	Passed	
Seaside Elementary	Staff Room 308 tap 1	WFH019	June 23, 2023	-	Passed	0.0056	Passed	
Seaside Elementary	Staff Room 308 tap 2	WFH020	June 23, 2023	-	Passed	0.0048	Passed	
Seaside Elementary	Staff Room 308 tap 3	WFH021	June 23, 2023	-	Passed	0.0410	Passed	
Seaside Elementary	Cafeteria/Kitchen tap 1 (2nd Floor)	WFH011	June 22, 2023	0.001	Passed	0.0510	Passed	
Seaside Elementary	Cafeteria/Kitchen tap 2 (2nd Floor)	WFH012	June 22, 2023	-	Passed	0.0440	Passed	
Seaside Elementary	Cafeteria/Kitchen tap 3 (2nd Floor)	WFH013	June 22, 2023	-	Passed	0.0430	Passed	
Seaside Elementary	2nd Floor Boys Wash Room tap 1	MYZ291	June 25, 2020	-	Passed	0.0079	Passed	
Seaside Elementary	2nd Floor Boys Wash Room tap 2	WFH015	June 22, 2023	-	Passed	0.0040	Passed	Tap remediated
Seaside Elementary	Janitors Closet tap by Girls Wash Room	MYZ293	June 25, 2020	0.001	Passed	0.4800	Passed	
Seaside Elementary	2nd Floor Girls Wash Room tap 1	WFH016	June 22, 2023	0.002	Passed	0.0770	Passed	Tap remediated
Seaside Elementary	2nd Floor Girls Wash Room tap 2	MYZ296	June 25, 2020	0.003	Passed	0.2300	Passed	
Seaside Elementary	Office Wash Room tap	MYZ297	June 25, 2020	0.002	Passed	0.0770	Passed	
Seaside Elementary	1st Floor Boys Wash Room tap 1	MYZ298	June 25, 2020	0.004	Passed	0.0840	Passed	
Seaside Elementary	1st Floor Boys Wash Room tap 2	MYZ320	June 25, 2020	0.003	Passed	0.1200	Passed	
Seaside Elementary	1st Floor Girls Wash Room tap 1	WFH025	June 22, 2023	-	Passed	0.0630	Passed	Tap remediated
Seaside Elementary	1st Floor Girls Wash Room tap 2	WFH026	June 22, 2023	-	Passed	0.0540	Passed	Tap remediated
Seaside Elementary	Fountain by 3rd Floor Wash Rooms	WFH017	June 22, 2023	-	Passed	0.0031	Passed	
Seaside Elementary	Fountain by Kitchen	WFH014	June 22, 2023	-	Passed	0.0120	Passed	
Seaside Elementary	Fountain by Room 103	WFH024	June 22, 2023	-	Passed	0.0007	Passed	
Shannon Park Elementary	Girls Wash Room tap 1 by Room 4	XBL783	September 19, 2023	0.003	Passed	0.0240	Passed	Tap remediated
Shannon Park Elementary	Girls Wash Room tap 2 by Room 4	MYA332	June 22, 2020	0.002	Passed	0.0220	Passed	
Shannon Park Elementary	Girls Wash Room tap 3 by Room 4	MYA333	June 22, 2020	0.002	Passed	0.0190	Passed	
Shannon Park Elementary	Girls Wash Room tap 4 by Room 4	MYA334	June 22, 2020	0.002	Passed	0.0190	Passed	
Shannon Park Elementary	Gender Neutral Wash Room 3 tap	XBL785	September 19, 2023	0.002	Passed	0.0620	Passed	Tap remediated
Shannon Park Elementary	Janitors Closet tap by Room 3	MYA336	June 22, 2020	-	Passed	0.0040	Passed	
Shannon Park Elementary	Girls Wash Room tap 1 by Room 5	XBL780	September 19, 2023	0.001	Passed	0.0061	Passed	Tap remediated
Shannon Park Elementary	Girls Wash Room tap 2 by Room 5	XBL781	September 19, 2023	0.003	Passed	0.0320	Passed	Tap remediated
Shannon Park Elementary	Girls Wash Room tap 3 by Room 5	XBL782	September 19, 2023	-	Passed	0.0061	Passed	Tap remediated
Shannon Park Elementary	Boys Wash Room tap 1 by Room 6	XBL778	September 19, 2023	0.001	Passed	0.0120	Passed	Tap remediated
Shannon Park Elementary	Boys Wash Room tap 2 by Room 6	XBL779	September 19, 2023	0.001	Passed	0.0170	Passed	Tap remediated
Shannon Park Elementary	Boys Gym Locker Room tap 1	XBL786	September 19, 2023	0.001	Passed	0.0088	Passed	Tap remediated
Shannon Park Elementary	Boys Gym Locker Room tap 2	MYA344	June 22, 2020	0.001	Passed	0.0095	Passed	
Shannon Park Elementary	Boys Gym Locker Room tap 3	MYA345	June 22, 2020	0.001	Passed	0.0089	Passed	
Shannon Park Elementary	Boys Gym Locker Room tap 4	MYA346	June 22, 2020	0.001	Passed	0.0100	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Shannon Park Elementary	Girls Gym Locker Room tap 1	XBL787	September 19, 2023	-	Passed	0.0220	Passed	Tap remediated
Shannon Park Elementary	Girls Gym Locker Room tap 2	MYA348	June 22, 2020	0.004	Passed	0.0930	Passed	
Shannon Park Elementary	Girls Gym Locker Room tap 3	MYA349	June 22, 2020	0.003	Passed	0.1000	Passed	
Shannon Park Elementary	Girls Gym Locker Room tap 4	MYA350	June 22, 2020	0.004	Passed	0.0900	Passed	
Shannon Park Elementary	Girls Wash Room tap 1 by Room 17	MYA351	June 22, 2020	0.004	Passed	0.0280	Passed	
Shannon Park Elementary	Girls Wash Room tap 2 by Room 17	XBL724	September 19, 2023	-	Passed	0.0050	Passed	Tap remediated
Shannon Park Elementary	Girls Wash Room tap 3 by Room 17	XBL725	September 19, 2023	0.001	Passed	0.0130	Passed	Tap remediated
Shannon Park Elementary	Boys Wash Room tap 1 by Room 17	MYA354	June 22, 2020	0.001	Passed	0.0260	Passed	
Shannon Park Elementary	Boys Wash Room tap 2 by Room 17	MYA355	June 22, 2020	0.002	Passed	0.0400	Passed	
Shannon Park Elementary	Boys Wash Room tap 3 by Room 17	XBL726	September 19, 2023	0.002	Passed	0.0360	Passed	Tap remediated
Shannon Park Elementary	Janitors Closet tap by Room 25	MYA357	June 22, 2020	-	Passed	0.0240	Passed	
Shannon Park Elementary	Boys Wash Room tap 1 by Room 25	XBL728	September 19, 2023	-	Passed	0.0089	Passed	Tap remediated
Shannon Park Elementary	Boys Wash Room tap 2 by Room 25	XBL729	September 19, 2023	-	Passed	0.0180	Passed	Tap remediated
Shannon Park Elementary	Boys Wash Room tap 3 by Room 25	MYA360	June 22, 2020	0.002	Passed	0.1500	Passed	
Shannon Park Elementary	Gender Neutral Wash Room tap by Room 25	MYA361	June 22, 2020	0.004	Passed	0.0670	Passed	
Shannon Park Elementary	Gender Neutral Wash Room tap by Room 26	MYA362	June 22, 2020	0.001	Passed	0.0760	Passed	
Shannon Park Elementary	Girls Wash Room tap 1 by Room 27	XBL730	September 19, 2023	-	Passed	0.0300	Passed	Tap remediated
Shannon Park Elementary	Girls Wash Room tap 2 by Room 27	MYA364	June 22, 2020	0.005	Passed	0.1400	Passed	
Shannon Park Elementary	Girls Wash Room tap 3 by Room 27	MYA365	June 22, 2020	0.004	Passed	0.0900	Passed	
Shannon Park Elementary	Girls Wash Room tap 4 by Room 27	MYA366	June 22, 2020	0.001	Passed	0.0270	Passed	
Shannon Park Elementary	Class Room 27 tap	XBL731	September 19, 2023	-	Passed	0.0140	Passed	Tap remediated
Shannon Park Elementary	Boys Wash Room tap 1 by Room 208	XBL676	September 19, 2023	0.001	Passed	0.0200	Passed	Tap remediated
Shannon Park Elementary	Boys Wash Room tap 2 by Room 208	MYA369	June 22, 2020	0.001	Passed	0.0160	Passed	
Shannon Park Elementary	Boys Wash Room tap 3 by Room 208	MYA370	June 22, 2020	0.002	Passed	0.0340	Passed	
Shannon Park Elementary	Janitors Closet tap by Room 208	MYA371	June 22, 2020	-	Passed	0.0170	Passed	
Shannon Park Elementary	Gender Neutral Wash Room tap by Room 207	MYA372	June 22, 2020	0.001	Passed	0.0310	Passed	
Shannon Park Elementary	Girls Wash Room tap 1 by Room 207	XBL673	September 19, 2023	-	Passed	0.0220	Passed	Tap remediated
Shannon Park Elementary	Girls Wash Room tap 2 by Room 207	MYA374	June 22, 2020	0.002	Passed	0.0150	Passed	
Shannon Park Elementary	Girls Wash Room tap 3 by Room 207	XBL674	September 19, 2023	-	Passed	0.0190	Passed	Tap remediated
Shannon Park Elementary	Caretaker Wash Room 18 tap	MYA376	June 22, 2020	0.002	Passed	0.0520	Passed	
Shannon Park Elementary	Janitors Closet tap by Room 18	MYA377	June 22, 2020	0.001	Passed	0.0280	Passed	
Shannon Park Elementary	Staff Room 16 tap	XBL677	September 19, 2023	-	Passed	0.0088	Passed	Tap remediated
Shannon Park Elementary	Main Office Wash Room 12 tap	XBL732	September 19, 2023	0.001	Passed	0.0630	Passed	Tap remediated
Shannon Park Elementary	Fountain by Room 4	XBL784	September 19, 2023	-	Passed	0.0006	Passed	
Shannon Park Elementary	Fountain by Gym / Room 137	XBL733	September 19, 2023	0.001	Passed	0.0460	Passed	
Shannon Park Elementary	Fountain by Room 17	MYH187	June 23, 2020	-	Passed	0.2900	Passed	
Shannon Park Elementary	Fountain by Room 25	XBL727	September 19, 2023	-	Passed	-	Passed	
Shannon Park Elementary	Boys Wash Room tap by Room 25	MYH189	June 23, 2020	0.002	Passed	0.2100	Passed	
Shannon Park Elementary	Fountain by Room 208	XBL675	September 19, 2023	-	Passed	0.0005	Passed	
Shannon Park Elementary	Fountain by Room 10	SCH052	March 15, 2022	-	Passed	0.1900	Passed	
Shatford Memorial Elementary	1st Floor Gender Neutral Wash Room tap by Room 2	MUQ753	June 4, 2020	0.002	Passed	0.4200	Passed	
Shatford Memorial Elementary	Class Room 1 tap	MUQ754	June 4, 2020	0.001	Passed	0.1200	Passed	
Shatford Memorial Elementary	Staff Room 3 Wash Room tap	MUQ756	June 4, 2020	0.002	Passed	0.5800	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Shatford Memorial Elementary	Boys Wash Room tap 1	MUQ758	June 4, 2020	0.003	Passed	0.0810	Passed	
Shatford Memorial Elementary	Boys Wash Room tap 2	MUQ759	June 4, 2020	0.001	Passed	0.0650	Passed	
Shatford Memorial Elementary	Janitors Closet tap	MUQ760	June 4, 2020	0.001	Passed	0.0600	Passed	
Shatford Memorial Elementary	Girls Wash Room tap 1	MUQ762	June 4, 2020	0.003	Passed	0.1300	Passed	
Shatford Memorial Elementary	Girls Wash Room tap 2	MUQ763	June 4, 2020	0.001	Passed	0.0710	Passed	
Shatford Memorial Elementary	Class Room 1 Wash Room tap 1	MUQ764	June 4, 2020	0.001	Passed	0.1500	Passed	
Shatford Memorial Elementary	Class Room 1 Wash Room tap 2	MUQ765	June 4, 2020	0.001	Passed	0.0790	Passed	
Shatford Memorial Elementary	Janitors Closet tap	MUQ768	June 4, 2020	0.003	Passed	0.5100	Passed	
Shatford Memorial Elementary	Boys Wash Room 5 tap 2	MUQ771	June 4, 2020	0.002	Passed	0.5700	Passed	
Shatford Memorial Elementary	Girls Wash Room 9 tap 1	MUQ772	June 4, 2020	0.004	Passed	0.3600	Passed	
Shatford Memorial Elementary	Girls Wash Room 9 tap 2	MUQ773	June 4, 2020	0.002	Passed	0.2700	Passed	
Shatford Memorial Elementary	Boys Wash Room 5 tap 1	RLA029	December 20, 2021	0.001	Passed	0.1400	Passed	
Shatford Memorial Elementary	Gender Neutral Wash Room 2 tap	RLA030	December 20, 2021	0.001	Passed	0.1100	Passed	
Shatford Memorial Elementary	Storage Room 2 tap (wash tub)	RLA031	December 20, 2021	0.001	Passed	0.1200	Passed	
Shatford Memorial Elementary	Staff Room 3 tap	VSJ598	May 3, 2023	0.001	Passed	0.1300	Passed	
Shatford Memorial Elementary	Fountain by Room 1	VSJ599	May 3, 2023	-	Passed	0.0012	Passed	
Shatford Memorial Elementary	Fountain by Wash Rooms	VSJ600	June 4, 2020	-	Passed	-	Passed	
Shatford Memorial Elementary	1st Floor Kitchen tap	VSJ601	May 3, 2023	0.007	Exceeded	0.0870	Passed	Hand washing only
Shatford Memorial Elementary	Fountain by Boys Wash Room 5	VSJ602	June 4, 2020	0.001	Passed	0.1200	Passed	
Sir Charles Tupper Elementary	Janitors Closet tap by Staff Room	MTO619	May 29, 2020	0.001	Passed	0.0910	Passed	
Sir Charles Tupper Elementary	Staff Gender Neutral Wash Room tap by Boys Wash Room	MTO620	May 29, 2020	-	Passed	0.0200	Passed	
Sir Charles Tupper Elementary	Boys Wash Room tap 1 by Staff Room	MTO621	May 29, 2020	0.005	Passed	0.5600	Passed	
Sir Charles Tupper Elementary	Boys Wash Room tap 2 by Staff Room	MTO622	May 29, 2020	-	Passed	0.0440	Passed	
Sir Charles Tupper Elementary	Boys Wash Room tap 3 by Staff Room	MTO623	May 29, 2020	-	Passed	0.0340	Passed	
Sir Charles Tupper Elementary	Boys Wash Room tap 4 by Staff Room	MTO624	May 29, 2020	-	Passed	0.0280	Passed	
Sir Charles Tupper Elementary	Boys Wash Room tap 5 by Staff Room	MTO625	May 29, 2020	-	Passed	0.0280	Passed	
Sir Charles Tupper Elementary	Resource Room Wash Room tap	MTO629	May 29, 2020	-	Passed	0.0600	Passed	
Sir Charles Tupper Elementary	Principals Office Wash Room 209 tap	MTO630	May 29, 2020	-	Passed	0.0300	Passed	
Sir Charles Tupper Elementary	Janitors Closet tap by Office	MTO631	May 29, 2020	-	Passed	0.0220	Passed	
Sir Charles Tupper Elementary	Girls Wash Room tap 1 by Office	MTO633	May 29, 2020	-	Passed	0.1300	Passed	
Sir Charles Tupper Elementary	Girls Wash Room tap 2 by Office	MTO634	May 29, 2020	0.001	Passed	0.0660	Passed	
Sir Charles Tupper Elementary	Girls Wash Room tap 3 by Office	MTO635	May 29, 2020	-	Passed	0.0400	Passed	
Sir Charles Tupper Elementary	Girls Wash Room tap 4 b Office	MTO636	May 29, 2020	-	Passed	0.0530	Passed	
Sir Charles Tupper Elementary	Girls Wash Room tap 5 by Office	MTO639	May 29, 2020	-	Passed	0.1000	Passed	
Sir Charles Tupper Elementary	Gender Neutral Wash Room 1 tap	MTO641	May 29, 2020	-	Passed	0.0270	Passed	
Sir Charles Tupper Elementary	Janitors Closet tap after Room 1	MTO642	May 29, 2020	-	Passed	0.0240	Passed	
Sir Charles Tupper Elementary	Girls Wash Room tap 1 by Room 1	MTO643	May 29, 2020	0.001	Passed	0.0160	Passed	
Sir Charles Tupper Elementary	Girls Wash Room tap 2 by Room 1	MTO644	May 29, 2020	0.001	Passed	0.0150	Passed	
Sir Charles Tupper Elementary	Boys Wash Room tap 1 by Art Room	MTO646	May 29, 2020	-	Passed	0.0085	Passed	
Sir Charles Tupper Elementary	Boys Wash Room tap 2 by Art Room	MTO647	May 29, 2020	-	Passed	0.0067	Passed	
Sir Charles Tupper Elementary	Art Room tap	MTO648	May 29, 2020	-	Passed	0.0400	Passed	
Sir Charles Tupper Elementary	Fountain by Office	TIH403	July 29, 2022	0.005	Passed	0.2500	Passed	
Sir Charles Tupper Elementary	Sink tap in the hallway	VTZ618	May 29, 2020	0.001	Passed	0.0990	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Sir Charles Tupper Elementary	Fountain by Room 9	VTZ619	May 9, 2023	-	Passed	0.0021	Passed	
Sir Charles Tupper Elementary	Fountain by Room 5	VTZ620	May 9, 2023	-	Passed	0.0007	Passed	
Sir Charles Tupper Elementary	Fountain by Girls Wash Room	VTZ621	May 9, 2023	-	Passed	0.0018	Passed	
Sir Charles Tupper Elementary	Staff Room tap 1	VTZ622	May 9, 2023	0.001	Passed	0.0450	Passed	
Sir Charles Tupper Elementary	Staff Room tap 2	VTZ623	May 9, 2023	-	Passed	0.0150	Passed	
Sir Charles Tupper Elementary	Staff Room tap 3	VTZ624	May 9, 2023	-	Passed	0.0120	Passed	
Sir Charles Tupper Elementary	Fountain in Basement	VTZ625	May 9, 2023	-	Passed	0.0540	Passed	
Sir Robert Borden Junior High School	Class Room 201 tap	XDA141	September 26, 2023	0.001	Passed	0.0340	Passed	Tap remediated
Sir Robert Borden Junior High School	Art Room 202 tap	RIL608	December 8, 2021	0.001	Passed	0.1200	Passed	
Sir Robert Borden Junior High School	Class Room 203 tap	NMD776	August 27, 2020	0.001	Passed	0.0250	Passed	
Sir Robert Borden Junior High School	Janitors Closet tap in HVAC Room	MWG494	June 12, 2020	0.002	Passed	0.0520	Passed	
Sir Robert Borden Junior High School	2nd Floor Female Staff Wash Room	XDA111	September 26, 2023	0.002	Passed	0.0330	Passed	Tap remediated
Sir Robert Borden Junior High School	2nd Floor Girls Wash Room tap 1	XDA137	September 26, 2023	0.006	Exceeded	0.0630	Passed	Hand washing only
Sir Robert Borden Junior High School	2nd Floor Girls Wash Room tap 2	XDA138	September 26, 2023	0.003	Passed	0.0350	Passed	Tap remediated
Sir Robert Borden Junior High School	2nd Floor Girls Wash Room tap 3	XDA139	September 26, 2023	0.001	Passed	0.0160	Passed	Tap remediated
Sir Robert Borden Junior High School	2nd Floor Girls Wash Room tap 4	XDA140	September 26, 2023	-	Passed	0.0150	Passed	Tap remediated
Sir Robert Borden Junior High School	2nd Floor Male Staff Wash Room	XDA108	September 26, 2023	0.001	Passed	0.0180	Passed	Tap remediated
Sir Robert Borden Junior High School	2nd Floor Boys Wash Room tap 1	MWG502	June 12, 2020	0.002	Passed	0.1100	Passed	
Sir Robert Borden Junior High School	2nd Floor Boys Wash Room tap 2	XDA106	September 26, 2023	-	Passed	0.0130	Passed	Tap remediated
Sir Robert Borden Junior High School	2nd Floor Boys Wash Room tap 3	XDA107	September 26, 2023	-	Passed	0.0150	Passed	Tap remediated
Sir Robert Borden Junior High School	2nd Floor Staff Room tap	XDA109	September 26, 2023	-	Passed	0.0270	Passed	
Sir Robert Borden Junior High School	Guidance Room Wash Room 1 tap	XDA053	September 26, 2023	0.001	Passed	0.0180	Passed	Tap remediated
Sir Robert Borden Junior High School	Guidance Room Wash Room 2 tap	XDA054	September 26, 2023	0.008	Exceeded	0.0270	Passed	Hand washing only
Sir Robert Borden Junior High School	1st Floor Boys Wash Room tap 1	MWG516	June 12, 2020	0.002	Passed	0.0520	Passed	
Sir Robert Borden Junior High School	1st Floor Boys Wash Room tap 2	MWG517	June 12, 2020	0.005	Passed	0.1900	Passed	
Sir Robert Borden Junior High School	1st Floor Boys Wash Room tap 3	MWG518	June 12, 2020	0.003	Passed	0.1600	Passed	
Sir Robert Borden Junior High School	Janitors Closet tap by Boys Wash Room	MWG519	June 12, 2020	0.004	Passed	0.0210	Passed	
Sir Robert Borden Junior High School	1st Floor Male Staff Wash Room	RIL600	December 8, 2021	0.001	Passed	0.0370	Passed	
Sir Robert Borden Junior High School	1st Floor Girls Wash Room tap 1	MWG521	June 12, 2020	0.002	Passed	0.3300	Passed	
Sir Robert Borden Junior High School	1st Floor Girls Wash Room tap 2	XDA046	September 26, 2023	0.002	Passed	0.1200	Passed	Tap remediated
Sir Robert Borden Junior High School	1st Floor Girls Wash Room tap 3	MWG523	June 12, 2020	0.004	Passed	0.2100	Passed	
Sir Robert Borden Junior High School	1st Floor Girls Wash Room tap 4	XDA046	September 26, 2023	0.002	Passed	0.0480	Passed	Tap remediated
Sir Robert Borden Junior High School	1st Floor Female Staff Wash Room	RIL597	December 8, 2021	-	Passed	0.0200	Passed	
Sir Robert Borden Junior High School	Wood Shop tap	XDA052	September 26, 2023	0.001	Passed	0.0430	Passed	Tap remediated
Sir Robert Borden Junior High School	Class Room tap by Wood Shop	XDA102	September 26, 2023	0.004	Passed	0.0920	Passed	Tap remediated
Sir Robert Borden Junior High School	Cafeteria/Kitchen single compartment sink tap	XDA049	September 26, 2023	-	Passed	0.1000	Passed	
Sir Robert Borden Junior High School	Cafeteria/Kitchen double compartment sink tap	XDA050	September 26, 2023	0.001	Passed	0.1100	Passed	
Sir Robert Borden Junior High School	Science Room tap	XDA051	September 26, 2023	-	Passed	0.1000	Passed	Laboratory or Hand washing only
Sir Robert Borden Junior High School	Boys Gym Teacher Wash Room tap	XDA045	September 26, 2023	0.005	Passed	0.0330	Passed	Tap remediated
Sir Robert Borden Junior High School	Girls Gym Teacher Wash Room tap	XDA103	September 26, 2023	0.002	Passed	0.2100	Passed	Tap remediated
Sir Robert Borden Junior High School	Fountain by 1st Floor Girls Wash Rooms	XDA045	September 26, 2023	-	Passed	0.0012	Passed	
Sir Robert Borden Junior High School	Fountain by 1st Floor Boys Wash Rooms	XDA048	September 26, 2023	-	Passed	0.0007	Passed	
Sir Robert Borden Junior High School	Fountain by Room 218	XDA110	September 26, 2023	-	Passed	0.0009	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Sir Robert Borden Junior High School	Fountain by Room 201	XDA105	September 26, 2023	-	Passed	0.0014	Passed	
Smokey Drive Elementary	1st Floor Boys Wash Room tap 1	MOM568	May 5, 2020	0.005	Passed	0.0470	Passed	
Smokey Drive Elementary	1st Floor Boys Wash Room tap 2	MOM569	May 5, 2020	0.002	Passed	0.0380	Passed	
Smokey Drive Elementary	1st Floor Boys Wash Room tap 3	MOM570	May 5, 2020	0.002	Passed	0.0340	Passed	
Smokey Drive Elementary	1st Floor Girls Wash Room tap 1	MOM571	May 5, 2020	0.004	Passed	0.0400	Passed	
Smokey Drive Elementary	1st Floor Girls Wash Room tap 2	WBC758	June 7, 2023	0.001	Passed	0.0100	Passed	Tap remediated
Smokey Drive Elementary	1st Floor Girls Wash Room tap 3	WBC759	June 7, 2023	-	Passed	0.0041	Passed	Tap remediated
Smokey Drive Elementary	Janitors Closet tap	MOM617	May 5, 2020	0.001	Passed	0.0300	Passed	
Smokey Drive Elementary	Class Room 101 Wash Room tap	MQK077	May 15, 2020	0.002	Passed	0.1200	Passed	
Smokey Drive Elementary	Class Room 102 Wash Room tap	WBC761	June 7, 2023	0.001	Passed	0.0540	Passed	Tap remediated
Smokey Drive Elementary	Janitors Closet tap by Room 102	MQK079	May 15, 2020	-	Passed	0.0320	Passed	
Smokey Drive Elementary	Staff Room Wash Room tap	MOM564	May 5, 2020	0.002	Passed	0.0370	Passed	
Smokey Drive Elementary	Staff Room Kitchen tap	WBC755	June 7, 2023	-	Passed	0.0046	Passed	
Smokey Drive Elementary	Fountain by Room 3	WBC756	June 7, 2023	-	Passed	-	Passed	
Smokey Drive Elementary	Class Room tap Room 3	WBC757	June 7, 2023	-	Passed	0.0059	Passed	Tap remediated
Smokey Drive Elementary	Fountain by Room 104	WBC760	June 7, 2023	-	Passed	-	Passed	
Smokey Drive Elementary	Fountain by Room 205	WBC762	June 7, 2023	-	Passed	-	Passed	
Smokey Drive Elementary	2nd Floor Girls Wash Room tap 1	WBC763	June 7, 2023	-	Passed	0.0031	Passed	Tap remediated
Smokey Drive Elementary	2nd Floor Girls Wash Room tap 2	WBC764	June 7, 2023	-	Passed	0.0042	Passed	Tap remediated
Smokey Drive Elementary	2nd Floor Girls Wash Room tap 3	WBC773	June 7, 2023	-	Passed	0.0058	Passed	Tap remediated
Smokey Drive Elementary	2nd Floor Girls Wash Room tap 4	WBC774	June 7, 2023	-	Passed	0.0028	Passed	Tap remediated
Smokey Drive Elementary	2nd Floor Boys Wash Room tap 1	WBC775	June 7, 2023	-	Passed	0.0050	Passed	Tap remediated
Smokey Drive Elementary	2nd Floor Boys Wash Room tap 2	WBC776	June 7, 2023	-	Passed	0.0029	Passed	
Smokey Drive Elementary	2nd Floor Boys Wash Room tap 3	MOM611	May 5, 2020	0.005	Passed	0.0210	Passed	
Smokey Drive Elementary	2nd Floor Boys Wash Room tap 4	XJR982	October 24, 2023	-	Passed	0.0030	Passed	Tap remediated
South Woodside School	Janitors Closet 7 tap	MYH220	June 23, 2020	0.003	Passed	0.2600	Passed	
South Woodside School	Multi-Purpose Room tap 1	WHX141	July 6, 2023	-	Passed	0.1100	Passed	Tap remediated
South Woodside School	Multi-Purpose Room tap 2	WHX142	July 6, 2023	-	Passed	0.0880	Passed	Tap remediated
South Woodside School	Boys Wash Room tap 1 in Rec Centre	MYH224	June 23, 2020	0.001	Passed	0.0940	Passed	
South Woodside School	Boys Wash Room tap 2 in Rec Centre	MYH225	June 23, 2020	0.002	Passed	0.0890	Passed	
South Woodside School	Girls Wash Room tap 1 in Rec Centre	MYH226	June 23, 2020	0.002	Passed	0.4900	Passed	
South Woodside School	Girls Wash Room tap 2 in Rec Centre	MYH227	June 23, 2020	0.003	Passed	0.5200	Passed	
South Woodside School	Staff Wash Room 14 tap	WHX145	July 6, 2023	-	Passed	0.0190	Passed	Tap remediated
South Woodside School	Staff Wash Room 15 tap	MYH233	June 23, 2020	0.001	Passed	0.3500	Passed	
South Woodside School	Room 17 tap	MYH234	June 23, 2020	0.001	Passed	0.3100	Passed	
South Woodside School	Class Room 28 tap	MYH235	June 23, 2020	-	Passed	0.1100	Passed	
South Woodside School	Class Room 33 tap	MYH236	June 23, 2020	-	Passed	0.1000	Passed	
South Woodside School	Class Room 36 tap	MYH237	June 23, 2020	0.002	Passed	0.9600	Passed	
South Woodside School	Girls Wash Room 34 tap 1	MYH238	June 23, 2020	0.002	Passed	0.1700	Passed	
South Woodside School	Girls Wash Room 34 tap 2	MYH239	June 23, 2020	0.001	Passed	0.1600	Passed	
South Woodside School	Girls Wash Room 34 tap 3	MYH240	June 23, 2020	0.003	Passed	0.1500	Passed	
South Woodside School	Girls Wash Room 34 tap 4	MYH241	June 23, 2020	0.001	Passed	0.1200	Passed	
South Woodside School	Janitors Closet 32 tap	MYH244	June 23, 2020	-	Passed	0.0390	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
South Woodside School	Boys Wash Room 31 tap 1	MYH245	June 23, 2020	0.001	Passed	0.2200	Passed	
South Woodside School	Boys Wash Room 31 tap 2	MYH246	June 23, 2020	0.003	Passed	0.1700	Passed	
South Woodside School	Boys Wash Room 31 tap 3	MYH247	June 23, 2020	0.002	Passed	0.2500	Passed	
South Woodside School	Gender Neutral Wash Room 5 tap	MYH249	June 23, 2020	0.002	Passed	0.3000	Passed	
South Woodside School	Library 3 tap	XJR732	October 24, 2023	0.001	Passed	0.0460	Passed	Tap remediated
South Woodside School	Caretaker Room 5 tap	WHX150	July 6, 2023	-	Passed	0.0230	Passed	Tap remediated
South Woodside School	Boys Wash Room tap 1 near Room 26	WHX146	July 6, 2023	0.001	Passed	0.1400	Passed	Tap remediated
South Woodside School	Boys Wash Room tap 2 near Room 26	WHX147	July 6, 2023	-	Passed	0.0790	Passed	Tap remediated
South Woodside School	Boys Wash Room tap 3 near Room 26	NBT455	July 9, 2020	0.004	Passed	0.3900	Passed	
South Woodside School	Fountain by Room 32	WHX149	July 6, 2023	0.002	Passed	0.1100	Passed	
South Woodside School	Fountain by Room 26	XJR733	October 24, 2023	0.001	Passed	0.2200	Passed	
South Woodside School	Staff Room 9 tap	WHX144	July 6, 2023	-	Passed	0.0270	Passed	
South Woodside School	Fountain by Recreation Centre	WHX143	July 6, 2023	-	Passed	0.0640	Passed	
Southdale - North Woodside Elementary	Class Room 23 Wash Room tap	NNS332	September 3, 2020	0.003	Passed	0.0440	Passed	
Southdale - North Woodside Elementary	Class Room 23 tap	NNS333	September 3, 2020	0.001	Passed	0.0520	Passed	
Southdale - North Woodside Elementary	Boys Wash Room tap 1 by Room 22	NNS335	September 3, 2020	0.081	Exceeded	1.3000	Passed	Hand washing only
Southdale - North Woodside Elementary	Boys Wash Room tap 2 by Room 22	NNS336	September 3, 2020	0.320	Exceeded	2.5000	Exceeded	Hand washing only
Southdale - North Woodside Elementary	Boys Wash Room tap 3 by Room 22	NNS337	September 3, 2020	0.740	Exceeded	3.5000	Exceeded	Hand washing only
Southdale - North Woodside Elementary	Girls Wash Room tap 1 by Room 22	NNS338	September 3, 2020	0.027	Exceeded	0.7100	Passed	Hand washing only
Southdale - North Woodside Elementary	Girls Wash Room tap 2 by Room 22	NNS339	September 3, 2020	0.039	Exceeded	0.8000	Passed	Hand washing only
Southdale - North Woodside Elementary	Girls Wash Room tap 3 by Room 22	NNS340	September 3, 2020	0.086	Exceeded	1.8000	Passed	Hand washing only
Southdale - North Woodside Elementary	Janitors Closet tap by Girls Wash Room	NNS341	September 3, 2020	0.001	Passed	0.0410	Passed	
Southdale - North Woodside Elementary	Fountain by Room 18	PXW751	June 24, 2021	0.003	Passed	0.1700	Passed	
Southdale - North Woodside Elementary	Fountain by Room 22	TBV733	July 4, 2022	0.003	Passed	0.2700	Passed	
Springvale Elementary	Boys Wash Room tap 1 by Room 304	MSA198	May 25, 2020	0.001	Passed	0.0480	Passed	
Springvale Elementary	Boys Wash Room tap 2 by Room 304	MSA199	May 25, 2020	0.001	Passed	0.0440	Passed	
Springvale Elementary	Boys Wash Room tap 3 by Room 304	MSA200	May 25, 2020	0.001	Passed	0.0460	Passed	
Springvale Elementary	Social Worker Room Wash Room tap	MSA201	May 25, 2020	0.001	Passed	0.1400	Passed	
Springvale Elementary	Early Literacy Room Wash Room tap	MSA202	May 25, 2020	0.001	Passed	0.0690	Passed	
Springvale Elementary	Class Room 314 tap	MSA204	May 25, 2020	0.001	Passed	0.1800	Passed	
Springvale Elementary	Girls Wash Room tap 1 by Room 309	MSA205	May 25, 2020	0.004	Passed	0.1500	Passed	
Springvale Elementary	Girls Wash Room tap 2 by Room 309	MSA206	May 25, 2020	0.001	Passed	0.0920	Passed	
Springvale Elementary	Gender Neutral Wash Room 308 tap	MSA208	May 25, 2020	0.004	Passed	0.0580	Passed	
Springvale Elementary	Girls Wash Room tap 1 by Room 204	MSA211	May 25, 2020	0.005	Passed	0.2300	Passed	
Springvale Elementary	Girls Wash Room tap 2 by Room 204	MSA212	May 25, 2020	0.001	Passed	0.0440	Passed	
Springvale Elementary	Girls Wash Room tap 3 by Room 204	MSA213	May 25, 2020	0.000	Passed	0.0260	Passed	
Springvale Elementary	Boys Wash Room tap 1 by Gym	MSA214	May 25, 2020	0.000	Passed	0.0360	Passed	
Springvale Elementary	Boys Wash Room tap 2 by Gym	MSA215	May 25, 2020	0.000	Passed	0.0330	Passed	
Springvale Elementary	Janitors Closet tap by Room 207	MSA216	May 25, 2020	0.001	Passed	0.0190	Passed	
Springvale Elementary	Class Room 103 tap	MSA219	May 25, 2020	0.002	Passed	0.4400	Passed	
Springvale Elementary	Crawl Space under Stairs tap	MSA220	May 25, 2020	0.001	Passed	0.3000	Passed	
Springvale Elementary	Boys Wash Room tap by Room 103	MSA221	May 25, 2020	0.002	Passed	0.0780	Passed	
Springvale Elementary	Girls Wash Room tap by Room 103	MSA222	May 25, 2020	0.001	Passed	0.0580	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Springvale Elementary	Class Room 106 tap	MSA223	May 25, 2020	0.005	Passed	0.2100	Passed	
Springvale Elementary	Class Room 109 tap	MSA224	May 25, 2020	0.001	Passed	0.2200	Passed	
Springvale Elementary	Girls Wash Room tap 3 by Room 309	NFE850	July 27, 2020	0.004	Passed	0.0410	Passed	
Springvale Elementary	Janitors Closet tap by Room 314	OWX522	February 18, 2021	-	Passed	0.0790	Passed	
Springvale Elementary	Fountain by Room 204	VVK854	May 16, 2023	-	Passed	0.0073	Passed	
Springvale Elementary	Fountain by Gym	VVK855	May 16, 2023	0.000	Passed	0.0350	Passed	
Springvale Elementary	Principals Office 218 tap	VVK856	May 16, 2023	0.003	Passed	0.0250	Passed	
Springvale Elementary	Staff Room 204 tap	VVK857	May 16, 2023	-	Passed	0.0120	Passed	
Springvale Elementary	Fountain by Room 304	VVK858	May 16, 2023	-	Passed	0.0740	Passed	
Springvale Elementary	Fountain by Room 104	VVK859	May 16, 2023	-	Passed	0.0200	Passed	
St. Agnes Junior High School	Science Lab Room 10 tap 1	MSA281	May 25, 2020	0.002	Passed	0.2100	Passed	
St. Agnes Junior High School	Science Lab Room 10 tap 2	MSA282	May 25, 2020	0.006	Exceeded	0.1300	Passed	Laboratory or Hand washing only
St. Agnes Junior High School	Girls Wash Room tap 1	VVC561	May 12, 2023	-	Passed	0.0540	Passed	Tap remediated
St. Agnes Junior High School	Girls Wash Room tap 2	MSA284	May 25, 2020	0.001	Passed	0.0240	Passed	
St. Agnes Junior High School	Girls Wash Room tap 3	MSA285	May 25, 2020	0.001	Passed	0.0170	Passed	
St. Agnes Junior High School	Girls Wash Room tap 4	MSA286	May 25, 2020	0.001	Passed	0.0160	Passed	
St. Agnes Junior High School	Janitors Closet tap	MSA287	May 25, 2020	-	Passed	0.0031	Passed	
St. Agnes Junior High School	Fountain by Staff Room	VVC560	May 12, 2023	-	Passed	0.0310	Passed	
St. Agnes Junior High School	Staff Wash Room tap	MSA288	May 25, 2020	-	Passed	0.0110	Passed	
St. Agnes Junior High School	Boys Wash Room tap 1	MSA290	May 25, 2020	0.004	Passed	0.1400	Passed	
St. Agnes Junior High School	Boys Wash Room tap 2	MSA291	May 25, 2020	0.001	Passed	0.0900	Passed	
St. Agnes Junior High School	Boys Wash Room tap 3	MSA292	May 25, 2020	-	Passed	0.0150	Passed	
St. Agnes Junior High School	Boys Wash Room tap 4	MSA293	May 25, 2020	-	Passed	0.0087	Passed	
St. Agnes Junior High School	Staff Learning Centre tap	MSA294	May 25, 2020	0.001	Passed	0.0720	Passed	
St. Agnes Junior High School	Staff Learning Centre Wash Room tap	MSA295	May 25, 2020	0.001	Passed	0.0500	Passed	
St. Agnes Junior High School	Art Room 3 tap 1	MSA297	May 25, 2020	0.001	Passed	0.3100	Passed	
St. Agnes Junior High School	Art Room 3 tap 2	MSA298	May 25, 2020	-	Passed	0.0710	Passed	
St. Agnes Junior High School	Tech Ed Room 15 tap	MSA305	May 25, 2020	0.002	Passed	0.0510	Passed	
St. Agnes Junior High School	Family Studies Room 15 tap 1	VVC554	May 12, 2023	-	Passed	0.0820	Passed	
St. Agnes Junior High School	Family Studies Room 15 tap 2	VVC555	May 12, 2023	-	Passed	0.0990	Passed	
St. Agnes Junior High School	Family Studies Room 15 tap 3	VCC556	May 12, 2023	-	Passed	0.0240	Passed	
St. Agnes Junior High School	Family Studies Room 15 tap 4	VVC557	May 12, 2023	0.001	Passed	0.0400	Passed	
St. Agnes Junior High School	Class Room 16 tap	NKX254	August 21, 2020	0.001	Passed	0.0310	Passed	
St. Agnes Junior High School	Class Room 18 tap	MSA311	May 25, 2020	0.003	Passed	0.0820	Passed	
St. Agnes Junior High School	Fountain by 2nd Floor Wash Rooms	VVC553	May 12, 2023	-	Passed	0.0010	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 1	MSA312	May 25, 2020	0.004	Passed	0.0740	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 2	MSA313	May 25, 2020	0.001	Passed	0.0570	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 3	MSA314	May 25, 2020	0.004	Passed	0.0190	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 4	MSA315	May 25, 2020	0.003	Passed	0.0250	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 5	MSA316	May 25, 2020	0.001	Passed	0.0110	Passed	
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 1	MSA317	May 25, 2020	0.001	Passed	0.0089	Passed	
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 2	MSA318	May 25, 2020	0.001	Passed	0.0086	Passed	
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 3	MSA319	May 25, 2020	0.001	Passed	0.0086	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 4	MSA320	May 25, 2020	0.001	Passed	0.0097	Passed	
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 5	MSA339	May 25, 2020	0.002	Passed	0.1200	Passed	
St. Agnes Junior High School	2nd Floor Janitors Closet tap	MSA340	May 25, 2020	0.002	Passed	0.0930	Passed	
St. Agnes Junior High School	2nd Floor Female Staff Wash Room tap	MSA341	May 25, 2020	0.001	Passed	0.0230	Passed	
St. Agnes Junior High School	2nd Floor Male Staff Wash Room tap	MSA342	May 25, 2020	-	Passed	0.0230	Passed	
St. Agnes Junior High School	2nd Floor Resource Room 19 tap	MSA343	May 25, 2020	0.001	Passed	0.0170	Passed	
St. Agnes Junior High School	Boys Locker Room tap 1	QDB663	July 16, 2021	-	Passed	0.0056	Passed	
St. Agnes Junior High School	Boys Locker Room tap 2	MSA303	May 25, 2020	0.003	Passed	0.0560	Passed	
St. Agnes Junior High School	Girls Locker Room tap 1	QDB664	July 16, 2021	0.001	Passed	0.0076	Passed	
St. Agnes Junior High School	Girls Locker Room tap 2	MSA301	May 25, 2020	0.001	Passed	0.0290	Passed	
St. Agnes Junior High School	Gender Neutral Wash Room tap	QDB665	July 16, 2021	-	Passed	0.0043	Passed	
St. Agnes Junior High School	Boys Wash Room by Gym	SHS319	April 5, 2022	-	Passed	0.0062	Passed	
St. Agnes Junior High School	Girls Wash Room by Gym	SHS320	April 5, 2022	-	Passed	0.0045	Passed	
St. Agnes Junior High School	Fountain by Gym Hall	VVC558	May 12, 2023	-	Passed	0.0034	Passed	
St. Agnes Junior High School	Fountain by Gym Wash Rooms	VVC559	May 12, 2023	-	Passed	0.0110	Passed	
St. Agnes Junior High School	Library Staff Room tap	VVC562	July 16, 2021	0.002	Passed	0.0530	Passed	
St. Catherine's Elementary	Staff Wash Room 216 tap	MSG967	May 26, 2020	0.000	Passed	0.0150	Passed	
St. Catherine's Elementary	Boys Wash Room 229 tap 2	MSG970	May 26, 2020	0.003	Passed	0.1300	Passed	
St. Catherine's Elementary	Boys Wash Room 229 tap 3	MSG971	May 26, 2020	0.002	Passed	0.0560	Passed	
St. Catherine's Elementary	Male Staff Wash Room by Room 229	MSG972	May 26, 2020	0.002	Passed	0.0260	Passed	
St. Catherine's Elementary	Girls Wash Room 227 tap 1	MSG974	May 26, 2020	0.003	Passed	0.1400	Passed	
St. Catherine's Elementary	Girls Wash Room 227 tap 2	MSG975	May 26, 2020	0.000	Passed	0.0130	Passed	
St. Catherine's Elementary	Girls Wash Room 227 tap 3	MSG976	May 26, 2020	0.002	Passed	0.0330	Passed	
St. Catherine's Elementary	Girls Wash Room 227 tap 4	MSG977	May 26, 2020	0.000	Passed	0.0048	Passed	
St. Catherine's Elementary	Boys Wash Room 215B tap 1	MSG980	May 26, 2020	0.000	Passed	0.0250	Passed	
St. Catherine's Elementary	Boys Wash Room 215B tap 2	MSG981	May 26, 2020	0.000	Passed	0.0270	Passed	
St. Catherine's Elementary	Girls Wash Room 215A tap 1	MSG983	May 26, 2020	0.000	Passed	0.0620	Passed	
St. Catherine's Elementary	Girls Wash Room 215A tap 2	MSG984	May 26, 2020	0.000	Passed	0.0260	Passed	
St. Catherine's Elementary	Janitors Closet tap by Room 204	MSG985	May 26, 2020	0.000	Passed	0.0040	Passed	
St. Catherine's Elementary	Class Room 204 tap	MSG986	May 26, 2020	0.000	Passed	0.0360	Passed	
St. Catherine's Elementary	Class Room 210 tap	MSG987	May 26, 2020	0.001	Passed	0.1600	Passed	
St. Catherine's Elementary	Gender Neutral Wash Room 212 tap	MSG988	May 26, 2020	0.000	Passed	0.1200	Passed	
St. Catherine's Elementary	Girls Wash Room 106 tap 1	MSG990	May 26, 2020	0.004	Passed	0.6700	Passed	
St. Catherine's Elementary	Girls Wash Room 106 tap 2	MSG991	May 26, 2020	0.000	Passed	0.1000	Passed	
St. Catherine's Elementary	Janitors Closet 106A tap	MSG992	May 26, 2020	0.000	Passed	0.0054	Passed	
St. Catherine's Elementary	Boys Wash Room 108 tap 1	MSG993	May 26, 2020	0.000	Passed	0.0160	Passed	
St. Catherine's Elementary	Boys Wash Room 108 tap 2	MSG994	May 26, 2020	0.000	Passed	0.0160	Passed	
St. Catherine's Elementary	Teachers Wash Room 108B tap	MSG995	May 26, 2020	0.000	Passed	0.0051	Passed	
St. Catherine's Elementary	Pottery Room 110 tap 1	MSG996	May 26, 2020	0.000	Passed	0.0260	Passed	
St. Catherine's Elementary	Pottery Room 110 tap 2	MSG997	May 26, 2020	0.000	Passed	0.0230	Passed	
St. Catherine's Elementary	Boys Wash Room 119 tap 1	MSG998	May 26, 2020	0.001	Passed	0.0880	Passed	
St. Catherine's Elementary	Boys Wash Room 119 tap 2	MSG999	May 26, 2020	0.000	Passed	0.0200	Passed	
St. Catherine's Elementary	Boys Wash Room 119 tap 3	MSH000	May 26, 2020	0.000	Passed	0.0150	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
St. Catherine's Elementary	Male Staff Wash Room 119 tap	MSH001	May 26, 2020	0.001	Passed	0.0070	Passed	
St. Catherine's Elementary	Female Staff Wash Room 117 tap	MSH003	May 26, 2020	-	Passed	0.0077	Passed	
St. Catherine's Elementary	Girls Wash Room 117 tap 1	MSH004	May 26, 2020	-	Passed	0.0200	Passed	
St. Catherine's Elementary	Girls Wash Room 117 tap 2	MSH005	May 26, 2020	-	Passed	0.0180	Passed	
St. Catherine's Elementary	Girls Wash Room 117 tap 3	MSH006	May 26, 2020	-	Passed	0.0210	Passed	
St. Catherine's Elementary	Class Room 107 tap	MSH007	May 26, 2020	-	Passed	0.0220	Passed	
St. Catherine's Elementary	Boiler Room tap	MSH008	May 26, 2020	0.001	Passed	0.0340	Passed	
St. Catherine's Elementary	Boys Wash Room 229 tap 1	NJI590	August 14, 2020	0.000	Passed	0.0160	Passed	
St. Catherine's Elementary	Class Room 221 tap	NJI591	August 14, 2020	0.000	Passed	0.0160	Passed	
St. Catherine's Elementary	Principals Office 218 tap	VSJ614	May 3, 2023	0.000	Passed	0.0045	Passed	
St. Catherine's Elementary	VP Office 217 tap	VSJ615	May 3, 2023	-	Passed	0.0120	Passed	
St. Catherine's Elementary	Fountain by Room 215B	VSJ616	May 3, 2023	-	Passed	0.0260	Passed	
St. Catherine's Elementary	Fountain by Room 229	VSJ617	May 3, 2023	0.000	Passed	0.0130	Passed	
St. Catherine's Elementary	Fountain by Room 119	VSJ618	May 3, 2023	-	Passed	0.0097	Passed	
St. Catherine's Elementary	Fountain by Room 107	VSJ619	May 3, 2023	-	Passed	0.0006	Passed	
St. Catherine's Elementary	Fountain by Gym	VSJ620	May 3, 2023	-	Passed	0.0610	Passed	
St. Margaret's Bay Elementary	Girls Wash Room 136 tap 1	MPB504	May 8, 2020	0.001	Passed	0.2000	Passed	
St. Margaret's Bay Elementary	Girls Wash Room 136 tap 2	MPB505	May 8, 2020	0.002	Passed	0.1300	Passed	
St. Margaret's Bay Elementary	Girls Wash Room 136 tap 3	MPB506	May 8, 2020	0.002	Passed	0.1500	Passed	
St. Margaret's Bay Elementary	Boys Wash Room 134 tap 2	MPB508	May 8, 2020	0.001	Passed	0.1600	Passed	
St. Margaret's Bay Elementary	Boys Wash Room 134 tap 3	MPB509	May 8, 2020	0.002	Passed	0.2100	Passed	
St. Margaret's Bay Elementary	Office Wash Room 184 tap	MPB511	May 8, 2020	0.001	Passed	0.2300	Passed	
St. Margaret's Bay Elementary	Class Room 107 tap	MPB513	May 8, 2020	0.001	Passed	0.1300	Passed	
St. Margaret's Bay Elementary	Gender Neutral Wash Room 108 tap	MPB514	May 8, 2020	0.003	Passed	0.2400	Passed	
St. Margaret's Bay Elementary	Gender Neutral Wash Room 109 tap	MPB515	May 8, 2020	0.002	Passed	0.1400	Passed	
St. Margaret's Bay Elementary	Class Room 110 tap	MPB516	May 8, 2020	0.001	Passed	0.1800	Passed	
St. Margaret's Bay Elementary	Class Room 115 tap 1	MPB517	May 8, 2020	0.001	Passed	0.1400	Passed	
St. Margaret's Bay Elementary	Class Room 115 tap 2	MPB518	May 8, 2020	0.001	Passed	0.1800	Passed	
St. Margaret's Bay Elementary	Gender Neutral Wash Room 119 tap	MPB519	May 8, 2020	0.001	Passed	0.1300	Passed	
St. Margaret's Bay Elementary	Class Room 118A tap	MPB521	May 8, 2020	0.002	Passed	0.1300	Passed	
St. Margaret's Bay Elementary	Class Room 123 tap 1	MPB522	May 8, 2020	0.000	Passed	0.1800	Passed	
St. Margaret's Bay Elementary	Class Room 123 tap 2	MPB523	May 8, 2020	0.001	Passed	0.1900	Passed	
St. Margaret's Bay Elementary	Class Room 154 tap	MPB524	May 8, 2020	0.001	Passed	0.1800	Passed	
St. Margaret's Bay Elementary	Class Room 155 tap	MPB525	May 8, 2020	0.001	Passed	0.1600	Passed	
St. Margaret's Bay Elementary	Class Room 157 tap 1	MPB526	May 8, 2020	0.001	Passed	0.1500	Passed	
St. Margaret's Bay Elementary	Class Room 157 tap 2	MPB527	May 8, 2020	0.002	Passed	0.2200	Passed	
St. Margaret's Bay Elementary	Girls Wash Room 164 tap 1	MPB529	May 8, 2020	0.004	Passed	0.1800	Passed	
St. Margaret's Bay Elementary	Girls Wash Room 164 tap 2	MPB530	May 8, 2020	0.003	Passed	0.1600	Passed	
St. Margaret's Bay Elementary	Girls Wash Room 164 tap 3	MPB531	May 8, 2020	0.002	Passed	0.2400	Passed	
St. Margaret's Bay Elementary	Boys Wash Room 166 tap 1	MPB532	May 8, 2020	0.003	Passed	0.1400	Passed	
St. Margaret's Bay Elementary	Boys Wash Room 166 tap 2	MPB559	May 8, 2020	0.002	Passed	0.1900	Passed	
St. Margaret's Bay Elementary	Boiler Room 179 tap	MPB569	May 8, 2020	0.001	Passed	0.1400	Passed	
St. Margaret's Bay Elementary	Music Room 180 tap	MPB570	May 8, 2020	0.001	Passed	0.2100	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
St. Margaret's Bay Elementary	Art Room 183 tap	MPB583	May 8, 2020	0.001	Passed	0.1600	Passed	
St. Margaret's Bay Elementary	Gym Office 139 tap	MPB584	May 8, 2020	0.002	Passed	0.3000	Passed	
St. Margaret's Bay Elementary	Gym Change Room 144 tap	MPB585	May 8, 2020	0.002	Passed	0.3300	Passed	
St. Margaret's Bay Elementary	Gym Change Room 145 tap	MPB586	May 8, 2020	0.002	Passed	0.1800	Passed	
St. Margaret's Bay Elementary	Storage Room 133 tap	RLA021	December 20, 2021	0.001	Passed	0.0740	Passed	
St. Margaret's Bay Elementary	Storage Room 174 tap	RLA022	December 20, 2021	0.002	Passed	0.1100	Passed	
St. Margaret's Bay Elementary	Boys Wash Room 166 tap 3	RLA026	December 20, 2021	0.002	Passed	0.5500	Passed	
St. Margaret's Bay Elementary	Boys Wash Room 134 tap 1	RLA027	December 20, 2021	0.004	Passed	0.7400	Passed	
St. Margaret's Bay Elementary	Kitchen 149 tap 1	VRZ789	May 2, 2023	0.002	Passed	0.0420	Passed	
St. Margaret's Bay Elementary	Kitchen 149 tap 2	VRZ790	May 2, 2023	0.001	Passed	0.0400	Passed	
St. Margaret's Bay Elementary	Kitchen 149 tap 3	VRZ791	May 2, 2023	0.020	Exceeded	0.5600	Passed	Hand washing only
St. Margaret's Bay Elementary	Staff Room 170 tap	VRZ792	May 2, 2023	0.002	Passed	0.0690	Passed	
St. Margaret's Bay Elementary	Staff Room 171 tap	VRZ793	May 2, 2023	0.001	Passed	0.0540	Passed	
St. Margaret's Bay Elementary	Staff Room 172 tap	VRZ794	May 2, 2023	0.002	Passed	0.3600	Passed	
St. Margaret's Bay Elementary	Fountain by Room 157	VRZ795	May 2, 2023	-	Passed	-	Passed	
St. Margaret's Bay Elementary	Fountain by Room 118	VRZ796	May 2, 2023	-	Passed	-	Passed	
St. Margaret's Bay Elementary	Fountain by Room 137	VRZ797	May 2, 2023	-	Passed	-	Passed	
St. Margaret's Bay Elementary	Health Room 189 tap	VRZ798	May 2, 2023	0.002	Passed	0.1200	Passed	
St. Stephen's Elementary	Class Room 20 tap	MSG933	May 26, 2020	-	Passed	0.0720	Passed	
St. Stephen's Elementary	Girls Wash Room tap 1 by Room 16	MSG934	May 26, 2020	-	Passed	0.1100	Passed	
St. Stephen's Elementary	Girls Wash Room tap 2 by Room 16	MSG935	May 26, 2020	0.001	Passed	0.1200	Passed	
St. Stephen's Elementary	Girls Wash Room tap 3 by Room 16	MSG936	May 26, 2020	0.002	Passed	0.1400	Passed	
St. Stephen's Elementary	Female Staff Wash Room tap	MSG937	May 26, 2020	0.000	Passed	0.0430	Passed	
St. Stephen's Elementary	Janitors Closet tap by Room 16	MSG939	May 26, 2020	0.000	Passed	0.0370	Passed	
St. Stephen's Elementary	Boys Wash Room tap 1 by Room 21	MSG941	May 26, 2020	0.000	Passed	0.0390	Passed	
St. Stephen's Elementary	Boys Wash Room tap 2 by Room 21	MSG942	May 26, 2020	0.000	Passed	0.0390	Passed	
St. Stephen's Elementary	Gym Office Wash Room tap	MSG945	May 26, 2020	0.000	Passed	0.0300	Passed	
St. Stephen's Elementary	PTA tap by Gym	MSG946	May 26, 2020	0.004	Passed	0.2400	Passed	
St. Stephen's Elementary	Boys Wash Room tap 2 by Gym	MSG948	May 26, 2020	0.001	Passed	0.1300	Passed	
St. Stephen's Elementary	Janitors Closet tap by Gym	MSG950	May 26, 2020	0.000	Passed	0.0150	Passed	
St. Stephen's Elementary	Girls Wash Room tap 1 by Gym	MSG951	May 26, 2020	-	Passed	0.0350	Passed	
St. Stephen's Elementary	Girls Wash Room tap 2 by Gym	MSG952	May 26, 2020	-	Passed	0.0270	Passed	
St. Stephen's Elementary	Class Room tap Room 1	MSG953	May 26, 2020	-	Passed	0.0330	Passed	
St. Stephen's Elementary	Boys Wash Room tap 1 by Room 9	MSG956	May 26, 2020	-	Passed	0.0130	Passed	
St. Stephen's Elementary	Boys Wash Room tap 2 by Room 9	MSG957	May 26, 2020	-	Passed	0.0130	Passed	
St. Stephen's Elementary	Male Staff Wash Room tap by Room 9	MSG958	May 26, 2020	-	Passed	0.0060	Passed	
St. Stephen's Elementary	Janitors Closet tap by Room 7	MSG959	May 26, 2020	-	Passed	0.0074	Passed	
St. Stephen's Elementary	Female Staff Wash Room tap by Room 7	MSG961	May 26, 2020	0.001	Passed	0.1700	Passed	
St. Stephen's Elementary	Girls Wash Room tap 1 by Room 7	MSG962	May 26, 2020	0.002	Passed	0.0440	Passed	
St. Stephen's Elementary	Girls Wash Room tap 2 by Room 7	MSG963	May 26, 2020	-	Passed	0.0200	Passed	
St. Stephen's Elementary	Girls Wash Room tap 3	MSP293	May 27, 2020	-	Passed	0.1400	Passed	
St. Stephen's Elementary	Staff Wash Room tap	MSP294	May 27, 2020	-	Passed	0.0290	Passed	
St. Stephen's Elementary	GEN Wash Room tap	MSP295	May 27, 2020	-	Passed	0.0390	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
St. Stephen's Elementary	VP Wash Room tap	MSP296	May 27, 2020	-	Passed	0.0510	Passed	
St. Stephen's Elementary	Fountain by Gym	VVC325	May 12, 2023	0.001	Passed	0.1800	Passed	
St. Stephen's Elementary	Boys Wash Room tap 1 by Gym	VVC326	May 12, 2023	-	Passed	0.1600	Passed	Tap remediated
St. Stephen's Elementary	Gym Office Wash Room tap	VVC327	May 12, 2023	0.001	Passed	0.0800	Passed	Tap remediated
St. Stephen's Elementary	Fountain by Room 16	VVC329	May 12, 2023	-	Passed	0.0580	Passed	
St. Stephen's Elementary	Fountain by Room 7	VVC330	May 12, 2023	-	Passed	0.0640	Passed	
St. Stephen's Elementary	Fountain by Staff Room	VVC331	May 12, 2023	-	Passed	0.0031	Passed	
St. Stephen's Elementary	Male Staff Wash Room by Room 21	VVC332	May 12, 2023	-	Passed	0.0240	Passed	Tap remediated
Sunnyside - Eaglewood Drive	Class Room 207 tap	MRU935	May 22, 2020	0.001	Passed	0.0930	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Boys Wash Room tap 1	MRU936	May 22, 2020	-	Passed	0.0120	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Boys Wash Room tap 2	MRU937	May 22, 2020	-	Passed	0.0170	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Janitors Closet tap	MRU938	May 22, 2020	-	Passed	0.0072	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Girls Wash Room tap 1	MRU939	May 22, 2020	-	Passed	0.0230	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Girls Wash Room tap 2	MRU940	May 22, 2020	-	Passed	0.0160	Passed	
Sunnyside - Eaglewood Drive	Staff Room Wash Room tap	MRU941	May 22, 2020	-	Passed	0.0450	Passed	
Sunnyside - Eaglewood Drive	Staff Room tap	MRU942	May 22, 2020	-	Passed	0.0630	Passed	
Sunnyside - Eaglewood Drive	Music Room tap	MRU943	May 22, 2020	0.002	Passed	1.0000	Passed	
Sunnyside - Eaglewood Drive	Staff Room tap	XJR558	October 24, 2023	-	Passed	0.0067	Passed	
Sunnyside - Eaglewood Drive	Staff Wash Room tap	MRU946	May 22, 2020	-	Passed	0.0058	Passed	
Sunnyside - Eaglewood Drive	1st Floor Boys Wash Room tap 1	MRU947	May 22, 2020	-	Passed	0.1200	Passed	
Sunnyside - Eaglewood Drive	1st Floor Boys Wash Room tap 2	MRU948	May 22, 2020	0.001	Passed	0.0440	Passed	
Sunnyside - Eaglewood Drive	1st Floor Janitors Closet tap	MRU949	May 22, 2020	0.001	Passed	0.0089	Passed	
Sunnyside - Eaglewood Drive	1st Floor Girls Wash Room tap 1	MRU951	May 22, 2020	-	Passed	0.0210	Passed	
Sunnyside - Eaglewood Drive	1st Floor Girls Wash Room tap 2	MRU952	May 22, 2020	-	Passed	0.0170	Passed	
Sunnyside - Eaglewood Drive	Fountain by Room 102	VXQ560	May 25, 2023	-	Passed	0.0039	Passed	
Sunnyside - Eaglewood Drive	Fountain by Room 202	VXQ561	May 25, 2023	-	Passed	0.0070	Passed	
Sunnyside - Eaglewood Drive	Main Office tap	VXQ562	May 25, 2023	-	Passed	0.0740	Passed	
Sunnyside - Eaglewood Drive	Staff Room Kitchen tap	VXQ563	May 25, 2023	-	Passed	0.0130	Passed	
Sunnyside - Fort Sackville	Boys Wash Room tap 1	MRM803	May 21, 2020	-	Passed	0.0620	Passed	
Sunnyside - Fort Sackville	Boys Wash Room tap 2	MRM804	May 21, 2020	0.002	Passed	0.0670	Passed	
Sunnyside - Fort Sackville	Pre Primary Wash Room tap 1	MRM806	May 21, 2020	0.001	Passed	0.3500	Passed	
Sunnyside - Fort Sackville	Pre Primary Wash Room tap 2	MRM807	May 21, 2020	-	Passed	0.1000	Passed	
Sunnyside - Fort Sackville	Storage Room Wash Room tap	MRM808	May 21, 2020	0.001	Passed	0.1800	Passed	
Sunnyside - Fort Sackville	Janitors Closet tap	MRM809	May 21, 2020	-	Passed	0.0570	Passed	
Sunnyside - Fort Sackville	Girls Wash Room tap 1	MRM811	May 21, 2020	-	Passed	0.1600	Passed	
Sunnyside - Fort Sackville	Girls Wash Room tap 2	MRM812	May 21, 2020	-	Passed	0.0610	Passed	
Sunnyside - Fort Sackville	Staff Kitchen tap	VXQ590	May 25, 2023	-	Passed	0.0150	Passed	
Sunnyside - Fort Sackville	Fountain by Janitors Closet	VXQ591	May 25, 2023	-	Passed	0.0800	Passed	
Sycamore Lane Elementary	2nd Floor Boys Wash Room tap 1	XJR706	October 24, 2023	-	Passed	0.0160	Passed	Hand washing only
Sycamore Lane Elementary	2nd Floor Boys Wash Room tap 2	MRD950	May 20, 2020	0.005	Passed	0.2000	Passed	
Sycamore Lane Elementary	2nd Floor Boys Wash Room tap 3	WCN424	June 13, 2023	0.001	Passed	0.0340	Passed	Tap remediated
Sycamore Lane Elementary	2nd Floor Janitors Closet tap	MRD952	May 20, 2020	0.000	Passed	0.0066	Passed	
Sycamore Lane Elementary	2nd Floor Girls Wash Room tap 1	WCN421	June 13, 2023	0.002	Passed	0.0630	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Sycamore Lane Elementary	2nd Floor Girls Wash Room tap 2	WCN422	June 13, 2023	0.001	Passed	0.0320	Passed	Tap remediated
Sycamore Lane Elementary	2nd Floor Girls Wash Room tap 3	MRD956	May 20, 2020	0.003	Passed	0.0220	Passed	
Sycamore Lane Elementary	2nd Floor Girls Wash Room tap 4	MRD957	May 20, 2020	0.004	Passed	0.0380	Passed	
Sycamore Lane Elementary	Boys Wash Room 110 tap 2	MRD959	May 20, 2020	0.001	Passed	0.0300	Passed	
Sycamore Lane Elementary	Janitors Closet 111 tap	MRD961	May 20, 2020	0.000	Passed	0.0063	Passed	
Sycamore Lane Elementary	Girls Wash Room 112 tap 4	MRD966	May 20, 2020	0.005	Passed	0.0150	Passed	
Sycamore Lane Elementary	Gender Neutral Wash Room 1036 tap	MRD967	May 20, 2020	0.004	Passed	0.1500	Passed	
Sycamore Lane Elementary	Class Room 101 tap	MRD968	May 20, 2020	0.001	Passed	0.0082	Passed	
Sycamore Lane Elementary	Class Room 101 Wash Room tap	MRD969	May 20, 2020	0.000	Passed	0.0088	Passed	
Sycamore Lane Elementary	Mechanical Room tap Room 121	MRD971	May 20, 2020	0.000	Passed	0.0160	Passed	
Sycamore Lane Elementary	Main Office Female Wash Room tap 1	MRD973	May 20, 2020	0.005	Passed	0.5900	Passed	
Sycamore Lane Elementary	Main Office Female Wash Room tap 2	MRD974	May 20, 2020	0.002	Passed	0.2100	Passed	
Sycamore Lane Elementary	Fountain by Caretaker Room	WCN411	June 13, 2023	-	Passed	0.0044	Passed	
Sycamore Lane Elementary	Fountain by Room 111	WCN412	June 13, 2023	-	Passed	0.0830	Passed	
Sycamore Lane Elementary	Girls Wash Room 112 tap 1	WCN413	June 13, 2023	0.002	Passed	0.0500	Passed	Tap remediated
Sycamore Lane Elementary	Girls Wash Room 112 tap 2	WCN414	June 13, 2023	0.001	Passed	0.0260	Passed	Tap remediated
Sycamore Lane Elementary	Girls Wash Room 112 tap 3	WCN415	June 13, 2023	-	Passed	0.0150	Passed	Tap remediated
Sycamore Lane Elementary	Boys Wash Room 110 tap 1	WCN416	June 13, 2023	0.002	Passed	0.0180	Passed	Tap remediated
Sycamore Lane Elementary	Boys Wash Room 110 tap 3	WCN417	June 13, 2023	-	Passed	0.0230	Passed	Tap remediated
Sycamore Lane Elementary	Staff Room tap	WCN418	June 13, 2023	-	Passed	0.0340	Passed	
Sycamore Lane Elementary	Main Office Gender Neutral Wash Room tap	WCN419	June 13, 2023	-	Passed	0.0140	Passed	Tap remediated
Sycamore Lane Elementary	Fountain by Room 211	WCN420	June 13, 2023	0.002	Passed	0.0630	Passed	
Tantallon Junior Elementary	Class Room 105 tap	VRZ770	May 2, 2023	0.004	Passed	0.7300	Passed	Tap remediated
Tantallon Junior Elementary	Class Room 104 tap	MUW182	June 8, 2020	0.004	Passed	1.6000	Passed	
Tantallon Junior Elementary	Class Room 103 tap	RSN190	January 26, 2021	0.002	Passed	0.9800	Passed	
Tantallon Junior Elementary	Fountain by Room 108	VRZ766	May 2, 2023	0.001	Passed	0.0250	Passed	
Tantallon Junior Elementary	Janitors Closet 109 tap	RKZ986	June 8, 2020	0.003	Passed	0.7500	Passed	
Tantallon Junior Elementary	Class Room 115 tap	RKZ988	June 8, 2020	0.003	Passed	0.9500	Passed	
Tantallon Junior Elementary	1st Floor Boys Wash Room tap 1	MUW184	June 8, 2020	0.001	Passed	1.6000	Passed	
Tantallon Junior Elementary	1st Floor Boys Wash Room tap 2	VRZ767	May 2, 2023	0.001	Passed	0.3500	Passed	
Tantallon Junior Elementary	1st Floor Boys Wash Room tap 3	MUW186	June 8, 2020	0.001	Passed	1.6000	Passed	
Tantallon Junior Elementary	1st Floor Girls Wash Room tap 1	XKK134	October 26, 2023	0.001	Passed	0.1700	Passed	Tap remediated
Tantallon Junior Elementary	1st Floor Girls Wash Room tap 2	MUW189	June 8, 2020	0.001	Passed	0.8200	Passed	
Tantallon Junior Elementary	1st Floor Girls Wash Room tap 3	MUW190	June 8, 2020	0.003	Passed	0.5100	Passed	
Tantallon Junior Elementary	Staff Room tap	VRZ769	May 2, 2023	0.001	Passed	0.0900	Passed	
Tantallon Junior Elementary	Staff Wash Room 1 tap	MUW193	June 8, 2020	0.001	Passed	0.4000	Passed	
Tantallon Junior Elementary	Staff Wash Room 2 tap	MUW194	June 8, 2020	0.001	Passed	0.4700	Passed	
Tantallon Junior Elementary	2nd Floor Girls Wash Room tap 1	RKZ989	June 8, 2020	0.001	Passed	0.2600	Passed	
Tantallon Junior Elementary	2nd Floor Girls Wash Room tap 2	RSN198	January 26, 2022	0.001	Passed	0.1500	Passed	
Tantallon Junior Elementary	2nd Floor Girls Wash Room tap 3	MUW197	June 8, 2020	0.005	Passed	1.6000	Passed	
Tantallon Junior Elementary	2nd Floor Janitors Closet tap	MUW198	June 8, 2020	0.004	Passed	1.2000	Passed	
Tantallon Junior Elementary	2nd Floor Boys Wash Room tap 1	MUW199	June 8, 2020	0.002	Passed	0.6200	Passed	
Tantallon Junior Elementary	2nd Floor Boys Wash Room tap 2	MUW200	June 8, 2020	0.001	Passed	0.7900	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Tantallon Junior Elementary	Fountain by Room 208	VRZ771	May 2, 2023	0.001	Passed	0.2300	Passed	
Tantallon Junior Elementary	Class Room 212 tap	XKK135	October 26, 2023	0.023	Exceeded	0.2600	Passed	Hand washing only
Tantallon Senior Elementary	1st Floor Boys Wash Room tap 2	TBH378	June 30, 2022	0.002	Passed	1.4000	Passed	
Tantallon Senior Elementary	1st Floor Boys Wash Room tap 3	TBH379	June 30, 2022	0.002	Passed	1.9000	Passed	
Tantallon Senior Elementary	1st Floor Fountain	TBH380	June 30, 2022	-	Passed	0.0006	Passed	Fountain out of service. Other sources available.
Tantallon Senior Elementary	Staff Wash Room 1 tap	TBH381	June 30, 2022	0.003	Passed	1.3000	Passed	
Tantallon Senior Elementary	Staff Wash Room 2 tap	TBH382	June 30, 2022	0.001	Passed	1.1000	Passed	
Tantallon Senior Elementary	1st Floor Girls Wash Room tap 3	TBH385	June 30, 2022	0.003	Passed	2.6000	Exceeded	Hand washing only
Tantallon Senior Elementary	Class Room 152 tap	TBH386	June 30, 2022	0.002	Passed	1.2000	Passed	
Tantallon Senior Elementary	Band Room	TBH387	June 30, 2022	0.002	Passed	0.7500	Passed	
Tantallon Senior Elementary	1st Floor Janitors Closet tap	TBH388	June 30, 2022	0.001	Passed	0.3000	Passed	
Tantallon Senior Elementary	2nd Floor Staff Wash Room 2 tap	TBH390	June 30, 2022	0.004	Passed	1.5000	Passed	
Tantallon Senior Elementary	2nd Floor Male Staff Wash Room tap	TBH392	June 30, 2022	0.004	Passed	1.5000	Passed	
Tantallon Senior Elementary	2nd Floor Fountain	TBH393	June 30, 2022	0.007	Exceeded	0.0310	Passed	Fountain out of service. Other sources available.
Tantallon Senior Elementary	Cafeteria tap 1	VSJ493	May 3, 2023	0.002	Passed	4.6000	Exceeded	Hand washing only
Tantallon Senior Elementary	Cafeteria tap 2	VSJ494	May 3, 2023	0.001	Passed	2.9000	Exceeded	Hand washing only
Tantallon Senior Elementary	Cafeteria tap 3	VSJ495	May 3, 2023	0.009	Exceeded	4.4000	Exceeded	Hand washing only
Tantallon Senior Elementary	1st Floor Boys Wash Room tap 1	VSJ496	May 3, 2023	0.001	Passed	2.7000	Exceeded	Hand washing only
Tantallon Senior Elementary	1st Floor Girls Wash Room tap 1	VSJ497	May 3, 2023	0.003	Passed	2.6000	Exceeded	Hand washing only
Tantallon Senior Elementary	1st Floor Girls Wash Room tap 2	VSJ498	May 3, 2023	0.002	Passed	2.2000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Girls Wash Room tap 1	VSJ499	May 3, 2023	0.003	Passed	1.9000	Passed	Tap remediated
Tantallon Senior Elementary	2nd Floor Boys Wash Room tap 1	VSJ502	May 3, 2023	0.007	Exceeded	2.7000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Boys Wash Room tap 2	VSJ503	May 3, 2023	0.004	Passed	3.0000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Boys Wash Room tap 3	VSJ504	May 3, 2023	0.005	Exceeded	2.7000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Boys Wash Room tap 4	VSJ505	May 3, 2023	0.006	Exceeded	4.3000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Janitors Closet tap	VSJ506	May 3, 2023	0.001	Passed	1.1000	Passed	Tap remediated
Tantallon Senior Elementary	2nd Floor Staff Room	VSJ507	May 3, 2023	0.001	Passed	3.1000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Staff Wash Room 1 tap	VSJ508	May 3, 2023	0.002	Passed	1.6000	Passed	Hand washing only
Tantallon Senior Elementary	2nd Floor Learning Centre tap 1	VSJ509	May 3, 2023	0.007	Exceeded	3.9000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Girls Wash Room tap 2	VSJ511	May 3, 2023	0.003	Passed	2.3000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Girls Wash Room tap 3	VSJ511	May 3, 2023	0.003	Passed	3.1000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Learning Centre tap 2	VSJ511	May 3, 2023	0.008	Exceeded	5.7000	Exceeded	Hand washing only
Tantallon Senior Elementary	2nd Floor Learning Centre tap 3	VSJ511	May 3, 2023	0.009	Exceeded	8.9000	Exceeded	Hand washing only
Upper Musquodoboit Consolidated Elementary	Cafeteria tap	MYZ361	June 25, 2020	0.001	Passed	0.0410	Passed	
Upper Musquodoboit Consolidated Elementary	Staff Kitchen tap 2	MYZ363	June 25, 2020	-	Passed	0.0220	Passed	
Upper Musquodoboit Consolidated Elementary	Staff Wash Room tap	MYZ364	June 25, 2020	0.002	Passed	0.0270	Passed	
Upper Musquodoboit Consolidated Elementary	Girls Wash Room tap 1	MYZ365	June 25, 2020	0.003	Passed	0.0340	Passed	
Upper Musquodoboit Consolidated Elementary	Girls Wash Room tap 2	MYZ366	June 25, 2020	0.001	Passed	0.0270	Passed	
Upper Musquodoboit Consolidated Elementary	Girls Wash Room tap 3	MYZ367	June 25, 2020	0.001	Passed	0.0130	Passed	
Upper Musquodoboit Consolidated Elementary	Janitors Closet tap by Wash Rooms	MYZ368	June 25, 2020	0.001	Passed	0.0920	Passed	
Upper Musquodoboit Consolidated Elementary	Boys Wash Room tap 1	MYZ369	June 25, 2020	0.002	Passed	0.1400	Passed	
Upper Musquodoboit Consolidated Elementary	Boys Wash Room tap 2	MYZ370	June 25, 2020	0.001	Passed	0.1100	Passed	
Upper Musquodoboit Consolidated Elementary	Boys Wash Room tap 3	MYZ379	June 25, 2020	0.001	Passed	0.0890	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Upper Musquodoboit Consolidated Elementary	Class Room 4 tap	MYZ380	June 25, 2020	0.001	Passed	0.0610	Passed	
Upper Musquodoboit Consolidated Elementary	Staff Kitchen tap 1	PWV191	June 21, 2021	0.002	Passed	0.0590	Passed	
Waverley Memorial Elementary	Girls Wash Room tap 1 by Staircase	MSP675	May 27, 2020	0.001	Passed	0.3100	Passed	
Waverley Memorial Elementary	Girls Wash Room tap 2 by Staircase	MSP676	May 27, 2020	0.001	Passed	0.3000	Passed	
Waverley Memorial Elementary	Girls Wash Room tap 3 by Staircase	MSP677	May 27, 2020	0.001	Passed	0.2900	Passed	
Waverley Memorial Elementary	Janitors Closet 216 tap	MSP679	May 27, 2020	-	Passed	0.0940	Passed	
Waverley Memorial Elementary	Staff Wash Room 214 tap	MSP680	May 27, 2020	-	Passed	0.1300	Passed	
Waverley Memorial Elementary	Special Needs Wash Room 213 tap	MSP681	May 27, 2020	-	Passed	0.0680	Passed	
Waverley Memorial Elementary	Boys Wash Room 212.1 tap 1	MSP682	May 27, 2020	-	Passed	0.4700	Passed	
Waverley Memorial Elementary	Boys Wash Room 212.1 tap 2	MSP683	May 27, 2020	-	Passed	0.2900	Passed	
Waverley Memorial Elementary	Boys Wash Room 212.1 tap 3	MSP684	May 27, 2020	0.001	Passed	0.3100	Passed	
Waverley Memorial Elementary	Class Room 201 tap 1	MSP686	May 27, 2020	-	Passed	0.6900	Passed	
Waverley Memorial Elementary	Class Room 201 tap 2	MSP687	May 27, 2020	-	Passed	0.9600	Passed	
Waverley Memorial Elementary	Class Room 202 tap	MSP688	May 27, 2020	-	Passed	0.1600	Passed	
Waverley Memorial Elementary	Class Room 203 tap	MSP689	May 27, 2020	-	Passed	0.0340	Passed	
Waverley Memorial Elementary	Class Room 204 tap	MSP690	May 27, 2020	-	Passed	0.0600	Passed	
Waverley Memorial Elementary	Class Room 205 tap	MSP691	May 27, 2020	-	Passed	0.5700	Passed	
Waverley Memorial Elementary	Girls Wash Room tap 1 by Stairs	MSP692	May 27, 2020	0.001	Passed	0.6000	Passed	
Waverley Memorial Elementary	Girls Wash Room tap 2 by Stairs	MSP693	May 27, 2020	-	Passed	0.9300	Passed	
Waverley Memorial Elementary	Girls Wash Room tap 3 by Stairs	MSP694	May 27, 2020	-	Passed	0.4200	Passed	
Waverley Memorial Elementary	Staff Wash Room 120 tap	MSP695	May 27, 2020	-	Passed	0.1400	Passed	
Waverley Memorial Elementary	Staff Wash Room 119 tap	MSP696	May 27, 2020	-	Passed	0.0770	Passed	
Waverley Memorial Elementary	Boys Wash Room tap 1 by Room 118.1	MSP697	May 27, 2020	0.001	Passed	0.4700	Passed	
Waverley Memorial Elementary	Boys Wash Room tap 2 by Room 118.1	MSP698	May 27, 2020	-	Passed	0.4200	Passed	
Waverley Memorial Elementary	Boys Wash Room tap 3 by Room 118.1	MSP699	May 27, 2020	0.001	Passed	0.3300	Passed	
Waverley Memorial Elementary	Janitors Closet 118.1 tap	MSP700	May 27, 2020	-	Passed	0.0590	Passed	
Waverley Memorial Elementary	Class Room 108 tap	MSP701	May 27, 2020	-	Passed	0.1000	Passed	
Waverley Memorial Elementary	Class Room 109 tap	MSP702	May 27, 2020	-	Passed	0.3600	Passed	
Waverley Memorial Elementary	Gender Neutral Wash Room 110.2 tap	MSP703	May 27, 2020	-	Passed	0.4600	Passed	
Waverley Memorial Elementary	Class Room 110 tap	MSP704	May 27, 2020	-	Passed	0.3800	Passed	
Waverley Memorial Elementary	Gender Neutral Wash Room 111.1 tap	MSP706	May 27, 2020	-	Passed	0.4000	Passed	
Waverley Memorial Elementary	Class Room 111 tap	MSP707	May 27, 2020	-	Passed	0.1900	Passed	
Waverley Memorial Elementary	Gender Neutral Wash Room 114.1B tap	MSP709	May 27, 2020	-	Passed	0.6300	Passed	
Waverley Memorial Elementary	Class Room 114 tap	MSP710	May 27, 2020	-	Passed	0.8900	Passed	
Waverley Memorial Elementary	Girls Locker Room 104.2 tap	MSP711	May 27, 2020	0.002	Passed	0.5600	Passed	
Waverley Memorial Elementary	Boys Locker Room 104.5 tap	MSP712	May 27, 2020	0.002	Passed	0.5200	Passed	
Waverley Memorial Elementary	Class Room 103.2 tap	MSP713	May 27, 2020	-	Passed	0.2400	Passed	
Waverley Memorial Elementary	Janitors Closet 102.1 tap	MSP715	May 27, 2020	-	Passed	0.1800	Passed	
Waverley Memorial Elementary	Cafeteria Kitchen Hand Wash sink tap	MTA424	May 28, 2020	-	Passed	0.1400	Passed	
Waverley Memorial Elementary	Fountain by Room 103.1A	WEK846	June 20, 2023	-	Passed	0.1200	Passed	
Waverley Memorial Elementary	Fountain by Room 110	WEK847	June 20, 2023	-	Passed	0.0620	Passed	
Waverley Memorial Elementary	Staff Room 112 tap	WEK848	June 20, 2023	-	Passed	0.0610	Passed	
Waverley Memorial Elementary	Room 102.1 triple sink tap	WEK849	June 20, 2023	-	Passed	0.1300	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Waverley Memorial Elementary	Room 102.1 sink tap	WEK850	June 20, 2023	0.001	Passed	0.0710	Passed	
Waverley Memorial Elementary	Main Office Room 101.4B tap	WEK851	June 20, 2023	-	Passed	0.0350	Passed	
Waverley Memorial Elementary	Fountain by Room 203	WEK852	June 20, 2023	-	Passed	0.0350	Passed	
Waverley Memorial Elementary	Mechanical Room 220 tap	WEK853	June 20, 2023	-	Passed	0.0490	Passed	
Westmount Elementary	Staff Wash Room by Room 6	MOS549	May 5, 2020	0.001	Passed	0.1800	Passed	
Westmount Elementary	Boys Wash Room tap 1 by Room 6	MOS550	May 5, 2020	0.001	Passed	0.2300	Passed	
Westmount Elementary	Boys Wash Room tap 2 by Room 6	MOS551	May 5, 2020	0.001	Passed	0.1300	Passed	
Westmount Elementary	Boys Wash Room tap 3 by Room 6	MOS552	May 5, 2020	0.002	Passed	0.1600	Passed	
Westmount Elementary	Staff Wash Room tap by Room 5	MOS553	May 5, 2020	0.003	Passed	0.2100	Passed	
Westmount Elementary	Girls Wash Room tap 1 by Room 5	MOS554	May 5, 2020	0.003	Passed	0.1400	Passed	
Westmount Elementary	Girls Wash Room tap 3 by Room 5	MOS556	May 5, 2020	0.003	Passed	0.1700	Passed	
Westmount Elementary	Girls Wash Room tap 4 by Room 5	MOS557	May 5, 2020	0.002	Passed	0.0470	Passed	
Westmount Elementary	Class Room 8 tap	MOS558	May 5, 2020	0.001	Passed	0.1000	Passed	
Westmount Elementary	Class Room 9 tap 2	MOS560	May 5, 2020	0.003	Passed	0.2300	Passed	
Westmount Elementary	Class Room 6 tap	MOS562	May 5, 2020	0.001	Passed	0.1300	Passed	
Westmount Elementary	Janitors Closet tap by Room 6	MOS563	May 5, 2020	0.002	Passed	0.1600	Passed	
Westmount Elementary	Class Room 2	MOS564	May 5, 2020	0.002	Passed	0.0600	Passed	
Westmount Elementary	Art Room tap	MPB691	May 8, 2020	0.002	Passed	0.4500	Passed	
Westmount Elementary	Gym Office tap	MPB692	May 8, 2020	0.004	Passed	0.1600	Passed	
Westmount Elementary	Janitors Closet tap by Room 17	MPB693	May 8, 2020	0.001	Passed	0.0370	Passed	
Westmount Elementary	Staff Wash Room tap by Room 17	MPB695	May 8, 2020	0.000	Passed	0.0470	Passed	
Westmount Elementary	Boys Wash Room tap 1 by Room 17	MPB696	May 8, 2020	0.001	Passed	0.1900	Passed	
Westmount Elementary	Boys Wash Room tap 2 by Room 17	MPB697	May 8, 2020	0.001	Passed	0.2300	Passed	
Westmount Elementary	Boys Wash Room tap 3 by Room 17	MPB698	May 8, 2020	0.002	Passed	0.2600	Passed	
Westmount Elementary	Staff Wash Room tap by Room 18	MPB700	May 8, 2020	0.002	Passed	0.3200	Passed	
Westmount Elementary	Girls Wash Room tap 1 by Room 18	MPB701	May 8, 2020	0.004	Passed	0.1500	Passed	
Westmount Elementary	Girls Wash Room tap 2 by Room 18	MPB702	May 8, 2020	0.003	Passed	0.0800	Passed	
Westmount Elementary	Girls Wash Room tap 3 by Room 18	MPB703	May 8, 2020	0.001	Passed	0.1400	Passed	
Westmount Elementary	Gender Neutral Wash Room tap by Gym	MPB704	May 8, 2020	0.001	Passed	0.0390	Passed	
Westmount Elementary	Staff Wash Room 1 tap by Gym	MPB705	May 8, 2020	0.002	Passed	0.1300	Passed	
Westmount Elementary	Staff Wash Room 2 tap by Gym	MPB706	May 8, 2020	0.001	Passed	0.0960	Passed	
Westmount Elementary	Main Office Wash Room tap	MPB707	May 8, 2020	0.001	Passed	0.4800	Passed	
Westmount Elementary	Class Room 9 tap 1	NJI779	August 14, 2020	-	Passed	0.0090	Passed	
Westmount Elementary	Class Room 10 tap	NJI780	August 14, 2020	-	Passed	0.0100	Passed	
Westmount Elementary	Principal's Office Wash Room tap	NJI781	August 14, 2020	-	Passed	0.0160	Passed	
Westmount Elementary	Girls Wash Room tap 2 by Room 5	NJI782	August 14, 2020	-	Passed	0.0030	Passed	
Westmount Elementary	Fountain by Room 17	VSJ574	May 3, 2023	-	Passed	0.0069	Passed	
Westmount Elementary	Fountain by Room 18	VSJ575	May 3, 2023	-	Passed	0.0009	Passed	
Westmount Elementary	Fountain by Caretaker Room	VSJ576	May 3, 2023	-	Passed	0.0650	Passed	
Westmount Elementary	Caretaker Room tap	VSJ577	May 3, 2023	-	Passed	0.0180	Passed	
Westmount Elementary	Fountain by Room 6	VSJ578	May 3, 2023	-	Passed	0.0210	Passed	
Westmount Elementary	Fountain by Room 8	VSJ579	May 3, 2023	-	Passed	0.0013	Passed	
William King Elementary	Boys Wash Room 153 tap 2	MQS660	May 19, 2020	0.002	Passed	0.2400	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
William King Elementary	Boys Wash Room 153 tap 3	MQS661	May 19, 2020	0.001	Passed	0.2200	Passed	
William King Elementary	Girls Wash Room 155 tap 1	MQS663	May 19, 2020	-	Passed	0.2900	Passed	
William King Elementary	Girls Wash Room 155 tap 2	MQS664	May 19, 2020	-	Passed	0.0320	Passed	
William King Elementary	Class Room 159 tap	MQS666	May 19, 2020	0.004	Passed	0.3000	Passed	
William King Elementary	Class Room 161 tap	MQS667	May 19, 2020	0.000	Passed	0.7400	Passed	
William King Elementary	Class Room 161 Wash Room tap	MQS668	May 19, 2020	0.003	Passed	0.5600	Passed	
William King Elementary	Class Room 158 tap	MQS669	May 19, 2020	0.005	Passed	0.4400	Passed	
William King Elementary	Janitors Closet Room 154 tap	MQS671	May 19, 2020	-	Passed	0.0320	Passed	
William King Elementary	Boys Locker Room 149 tap 1	MQS672	May 19, 2020	0.001	Passed	0.1700	Passed	
William King Elementary	Boys Locker Room 149 tap 2	MQS673	May 19, 2020	-	Passed	0.1200	Passed	
William King Elementary	Boys Locker Room 149 tap 3	MQS674	May 19, 2020	0.001	Passed	0.1200	Passed	
William King Elementary	Gym Office Wash Room tap	MQS675	May 19, 2020	0.001	Passed	0.1200	Passed	
William King Elementary	Girls Locker Room tap 1	MQS676	May 19, 2020	0.001	Passed	0.3800	Passed	
William King Elementary	Girls Locker Room tap 2	MQS677	May 19, 2020	0.001	Passed	0.1500	Passed	
William King Elementary	Girls Locker Room tap 3	MQS678	May 19, 2020	0.002	Passed	0.8300	Passed	
William King Elementary	Class Room 137 tap	MQS679	May 19, 2020	0.002	Passed	0.1000	Passed	
William King Elementary	Janitors Closet Room 130 tap	MQS684	May 19, 2020	-	Passed	0.0970	Passed	
William King Elementary	Class Room 122 Wash Room tap	MQS685	May 19, 2020	-	Passed	0.0780	Passed	
William King Elementary	Class Room 122 tap	MQS686	May 19, 2020	-	Passed	0.0950	Passed	
William King Elementary	Class Room 108 tap	MQS687	May 19, 2020	0.003	Passed	0.3100	Passed	
William King Elementary	Class Room 107 tap	MQS688	May 19, 2020	0.001	Passed	0.4900	Passed	
William King Elementary	Boys Wash Room 115 tap 1	MQS689	May 19, 2020	-	Passed	0.3700	Passed	
William King Elementary	Boys Wash Room 115 tap 2	MQS690	May 19, 2020	-	Passed	0.1700	Passed	
William King Elementary	Boys Wash Room 115 tap 3	MQS691	May 19, 2020	-	Passed	0.1100	Passed	
William King Elementary	Janitors Closet Room 116 tap	MQS692	May 19, 2020	-	Passed	0.2400	Passed	
William King Elementary	Girls Wash Room 117 tap 1	MQS694	May 19, 2020	-	Passed	0.2000	Passed	
William King Elementary	Girls Wash Room 117 tap 2	MQS695	May 19, 2020	-	Passed	0.0910	Passed	
William King Elementary	Girls Wash Room 117 tap 3	MQS696	May 19, 2020	-	Passed	0.3000	Passed	
William King Elementary	Class Room 119 tap	MQS697	May 19, 2020	-	Passed	0.1400	Passed	
William King Elementary	Class Room 129 tap	MQS698	May 19, 2020	0.001	Passed	0.0960	Passed	
William King Elementary	Class Room 125 Wash Room tap	MQS699	May 19, 2020	0.001	Passed	0.1800	Passed	
William King Elementary	Class Room 126 Wash Room tap	MQS700	May 19, 2020	-	Passed	0.0610	Passed	
William King Elementary	Fountain (Upper) by Room 135	VQL662	April 25, 2023	-	Passed	0.0010	Passed	
William King Elementary	Fountain (Lower) by Room 135	VQL663	April 25, 2023	-	Passed	0.0014	Passed	
William King Elementary	Kitchen Room 135 sink tap	VQL664	April 25, 2023	-	Passed	0.0046	Passed	
William King Elementary	Kitchen Room 135 three compartment sink tap	VQL665	April 25, 2023	-	Passed	0.0032	Passed	
William King Elementary	Fountain by Room 116	VQL666	April 25, 2023	-	Passed	0.0007	Passed	
William King Elementary	Fountain by Room 153	VQL667	April 25, 2023	-	Passed	0.0010	Passed	
William King Elementary	Boys Wash Room 153 tap 1	VQL668	April 25, 2023	-	Passed	0.0061	Passed	Tap remediated
William King Elementary	Girls Wash Room 155 tap 3	VQL669	April 25, 2023	-	Passed	0.0082	Passed	Tap remediated
William King Elementary	Gender Neutral Wash Room 158 tap	VQL670	April 25, 2023	-	Passed	0.0026	Passed	Tap remediated
Woodlawn High School	2nd Floor Male Staff Room Wash Room tap	MXH491	June 17, 2020	0.001	Passed	0.1200	Passed	
Woodlawn High School	2nd Floor Female Staff Room Wash Room tap	WHU700	June 5, 2023	-	Passed	0.0170	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Woodlawn High School	2nd Floor Staff Room tap	MXH493	June 17, 2020	-	Passed	0.0940	Passed	
Woodlawn High School	2nd Floor Janitors Closet	MXH494	June 17, 2020	-	Passed	0.1100	Passed	
Woodlawn High School	2nd Floor Male Staff Wash Room	WHU696	June 5, 2023	-	Passed	0.0150	Passed	Tap remediated
Woodlawn High School	2nd Floor Boys Wash Room tap 1	WHU697	June 5, 2023	0.003	Passed	0.0440	Passed	Tap remediated
Woodlawn High School	2nd Floor Boys Wash Room tap 2	WHU698	June 5, 2023	0.001	Passed	0.0260	Passed	Tap remediated
Woodlawn High School	2nd Floor Boys Wash Room tap 3	WHU699	June 5, 2023	0.005	Passed	0.0600	Passed	Tap remediated
Woodlawn High School	2nd Floor Boys Wash Room tap 4	MXH499	June 17, 2020	0.002	Passed	0.5800	Passed	
Woodlawn High School	2nd Floor Female Staff Wash Room	WHU695	June 5, 2023	0.001	Passed	0.0330	Passed	
Woodlawn High School	2nd Floor Girls Wash Room tap 1	WHU691	June 5, 2023	0.040	Exceeded	0.2700	Passed	Hand washing only
Woodlawn High School	2nd Floor Girls Wash Room tap 2	WHU692	June 5, 2023	0.030	Exceeded	0.1900	Passed	Hand washing only
Woodlawn High School	2nd Floor Girls Wash Room tap 3	WHU693	June 5, 2023	0.017	Exceeded	0.2800	Passed	Hand washing only
Woodlawn High School	2nd Floor Girls Wash Room tap 4 by Room 232	WHU694	June 5, 2023	0.008	Exceeded	0.1100	Passed	Hand washing only
Woodlawn High School	Fountain by Room 232	WHU690	June 5, 2023	-	Passed	0.0012	Passed	
Woodlawn High School	Class Room 232 tap	MXH505	June 17, 2020	0.005	Passed	0.1200	Passed	
Woodlawn High School	Class Room 230 tap	WHU689	June 5, 2023	0.005	Passed	0.3500	Passed	Tap remediated
Woodlawn High School	Chemistry Lab 228 tap 1	MXH508	June 17, 2020	0.001	Passed	1.9000	Passed	
Woodlawn High School	Chemistry Lab 228 tap 2	MXH509	June 17, 2020	0.009	Exceeded	2.9000	Exceeded	Laboratory or Hand washing only
Woodlawn High School	Chemistry Lab 228 tap 3	MXH510	June 17, 2020	0.007	Exceeded	2.6000	Exceeded	Laboratory or Hand washing only
Woodlawn High School	Chemistry Lab 228 tap 4	MXH511	June 17, 2020	0.002	Passed	0.8400	Passed	
Woodlawn High School	Chemistry Lab 228 tap 5	MXH512	June 17, 2020	0.001	Passed	1.1000	Passed	
Woodlawn High School	Chemistry Lab 228 tap 6	MXH513	June 17, 2020	-	Passed	0.5600	Passed	
Woodlawn High School	Chemistry Lab 228 tap 7	MXH514	June 17, 2020	0.001	Passed	0.9800	Passed	
Woodlawn High School	Chemistry Lab 228 tap 8	MXH515	June 17, 2020	0.001	Passed	1.2000	Passed	
Woodlawn High School	Chemistry Lab 228 tap 9	MXH516	June 17, 2020	-	Passed	1.5000	Passed	
Woodlawn High School	Chemistry Lab 228 tap 10	MXH517	June 17, 2020	-	Passed	1.2000	Passed	
Woodlawn High School	2nd Floor Fountain by Room 228	WHU680	June 5, 2023	-	Passed	-	Passed	
Woodlawn High School	Class Room 226 tap 1	WHU688	June 5, 2023	0.002	Passed	0.1000	Passed	Tap remediated
Woodlawn High School	Class Room 226 tap 2	MXH519	June 17, 2020	-	Passed	0.5700	Passed	
Woodlawn High School	Class Room 225 tap 1	MXH520	June 17, 2020	0.001	Passed	0.5100	Passed	
Woodlawn High School	Class Room 225 tap 2	MXH521	June 17, 2020	0.001	Passed	0.6100	Passed	
Woodlawn High School	Youth Room 219 tap	WHU679	June 5, 2023	0.001	Passed	0.0850	Passed	
Woodlawn High School	Music Room 218 tap	WHU677	June 5, 2023	0.003	Passed	0.0830	Passed	
Woodlawn High School	Fountain by Room 217	WHU676	June 5, 2023	-	Passed	0.4800	Passed	
Woodlawn High School	Class Room tap left of Room 217	MXH525	June 17, 2020	0.004	Passed	1.6000	Passed	
Woodlawn High School	Class Room 211 tap	WHU675	June 5, 2023	0.001	Passed	0.0240	Passed	Tap remediated
Woodlawn High School	Fine Arts Office 5 Wash Room tap	WHU701	June 5, 2023	0.006	Exceeded	0.1100	Passed	Hand washing only
Woodlawn High School	Fine Arts Office 4 Wash Room tap	MXH528	June 17, 2020	0.005	Passed	0.1800	Passed	
Woodlawn High School	2nd Floor Girls Wash Room tap 1	MXH529	June 17, 2020	0.003	Passed	1.3000	Passed	
Woodlawn High School	2nd Floor Girls Wash Room tap 2	WHU682	June 5, 2023	0.009	Exceeded	0.1700	Passed	Hand washing only
Woodlawn High School	2nd Floor Girls Wash Room tap 3	WHU683	June 5, 2023	0.014	Exceeded	0.1300	Passed	Hand washing only
Woodlawn High School	2nd Floor Female Staff Wash Room tap	WHU681	June 5, 2023	0.002	Passed	0.0830	Passed	Tap remediated
Woodlawn High School	2nd Floor Male Staff Wash Room tap	WHU687	June 5, 2023	0.001	Passed	0.0780	Passed	Tap remediated
Woodlawn High School	2nd Floor Boys Wash Room tap 1	WHU684	June 5, 2023	0.008	Exceeded	0.0800	Passed	Hand washing only

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Woodlawn High School	2nd Floor Boys Wash Room tap 2	WHU685	June 5, 2023	0.004	Passed	0.0660	Passed	Tap remediated
Woodlawn High School	2nd Floor Boys Wash Room tap 3	WHU686	June 5, 2023	0.003	Passed	0.0590	Passed	Tap remediated
Woodlawn High School	Class Room 229 tap	MXH539	June 17, 2020	0.002	Passed	0.1900	Passed	
Woodlawn High School	Science Lab 231 tap 1	MXH540	June 17, 2020	0.004	Passed	0.4100	Passed	
Woodlawn High School	Science Lab 231 tap 2	MXH541	June 17, 2020	0.018	Exceeded	0.6200	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 3	MXH542	June 17, 2020	0.021	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 4	MXH543	June 17, 2020	0.019	Exceeded	1.4000	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 5	MXH544	June 17, 2020	0.018	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 6	MXH545	June 17, 2020	0.014	Exceeded	0.4800	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 7	MXH546	June 17, 2020	0.006	Exceeded	0.6800	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 8	MXH547	June 17, 2020	0.009	Exceeded	0.8700	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 9	MXH548	June 17, 2020	0.006	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 10	MXH549	June 17, 2020	0.002	Passed	0.7300	Passed	
Woodlawn High School	Science Lab 231 tap 11	MXH550	June 17, 2020	0.007	Exceeded	0.4500	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 12	MXH551	June 17, 2020	0.006	Exceeded	0.9600	Passed	Laboratory or Hand washing only
Woodlawn High School	Class Room 108 tap	MXH552	June 17, 2020	-	Passed	0.3700	Passed	
Woodlawn High School	Class Room 108 Wash Room 1 tap	MXH553	June 17, 2020	0.001	Passed	0.3500	Passed	
Woodlawn High School	Class Room 108 Wash Room 2 tap	MXH554	June 17, 2020	0.001	Passed	0.4200	Passed	
Woodlawn High School	Class Room 108 Wash Room 3 tap	MXH555	June 17, 2020	-	Passed	0.4000	Passed	
Woodlawn High School	1st Floor Male Staff Wash Room tap	MXH556	June 17, 2020	0.001	Passed	0.0700	Passed	
Woodlawn High School	1st Floor Boys Wash Room tap 1	MXH557	June 17, 2020	0.001	Passed	0.0850	Passed	
Woodlawn High School	1st Floor Boys Wash Room tap 2	MXH558	June 17, 2020	0.001	Passed	0.1200	Passed	
Woodlawn High School	1st Floor Boys Wash Room tap 3	MXH559	June 17, 2020	0.001	Passed	0.0550	Passed	
Woodlawn High School	1st Floor Boys Wash Room tap 4	MXH560	June 17, 2020	0.001	Passed	0.0790	Passed	
Woodlawn High School	1st Floor Female Staff Wash Room tap	MXH561	June 17, 2020	0.002	Passed	0.0440	Passed	
Woodlawn High School	1st Floor Girls Wash Room tap 1	MXH562	June 17, 2020	0.002	Passed	0.1100	Passed	
Woodlawn High School	1st Floor Girls Wash Room tap 2	MXH563	June 17, 2020	0.002	Passed	0.0850	Passed	
Woodlawn High School	1st Floor Girls Wash Room tap 3	MXH564	June 17, 2020	0.002	Passed	0.0850	Passed	
Woodlawn High School	1st Floor Girls Wash Room tap 4	MXH565	June 17, 2020	0.001	Passed	0.0770	Passed	
Woodlawn High School	1st Floor Boiler Room tap	MXH567	June 17, 2020	0.002	Passed	0.1400	Passed	
Woodlawn High School	1st Floor Caretaker Room tap	WHU673	June 5, 2023	-	Passed	0.0440	Passed	
Woodlawn High School	Class Room 127 tap 1	MXH569	June 17, 2020	0.001	Passed	1.2000	Passed	
Woodlawn High School	Class Room 127 tap 2	MXH570	June 17, 2020	-	Passed	0.8800	Passed	
Woodlawn High School	Class Room 127 tap 3	MXH571	June 17, 2020	0.003	Passed	0.4800	Passed	
Woodlawn High School	1st Floor Cafeteria tap 1	WHU657	June 5, 2023	0.004	Passed	0.2300	Passed	
Woodlawn High School	1st Floor Cafeteria tap 2	WHU658	June 5, 2023	0.003	Passed	0.1500	Passed	
Woodlawn High School	1st Floor Cafeteria tap 3	NLS558	August 25, 2022	0.001	Passed	0.1500	Passed	
Woodlawn High School	Class Room 125 tap	MXH575	June 17, 2020	0.002	Passed	0.7300	Passed	
Woodlawn High School	Class Room 124 tap	MXH576	June 17, 2020	0.001	Passed	0.7100	Passed	
Woodlawn High School	Fountain near Room 124	WHU659	June 5, 2023	-	Passed	0.0067	Passed	
Woodlawn High School	Main Office Wash Room 1 tap	WHU674	June 5, 2023	-	Passed	0.0120	Passed	Tap remediated
Woodlawn High School	Main Office Wash Room 2 tap	MXH578	June 17, 2020	0.002	Passed	0.0440	Passed	
Woodlawn High School	Fountain by Room 116	XBL409	September 19, 2023	-	Passed	-	Passed	

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - October 31, 2023

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Woodlawn High School	1st Floor Janitors Closet tap by Room 116	MXH580	June 17, 2020	0.005	Exceeded	0.8100	Passed	Hand washing only
Woodlawn High School	Gender Neutral Wash Room 1 tap near Room 124	WHU660	June 5, 2023	0.001	Passed	0.0660	Passed	Tap remediated
Woodlawn High School	Gender Neutral Wash Room 2 tap near Room 124	MXH583	June 17, 2020	0.003	Passed	0.0850	Passed	
Woodlawn High School	1st Floor Staff Wash Room tap by Room 125	WHU661	June 5, 2023	0.001	Passed	0.0530	Passed	Tap remediated
Woodlawn High School	1st Floor Staff Wash Room tap by Room 125	MXH585	June 17, 2020	0.003	Passed	0.0800	Passed	
Woodlawn High School	Class Room 128 tap 1	MXH586	June 17, 2020	0.002	Passed	0.6200	Passed	
Woodlawn High School	Class Room 128 tap 2	WHU662	June 5, 2023	0.001	Passed	0.1500	Passed	Tap remediated
Woodlawn High School	Class Room 128 tap 3	WHU663	June 5, 2023	0.001	Passed	0.1400	Passed	Tap remediated
Woodlawn High School	Class Room 128 tap 4	MXH589	June 17, 2020	0.004	Passed	1.0000	Passed	
Woodlawn High School	Class Room 128 tap 5	MXH590	June 17, 2020	0.002	Passed	1.0000	Passed	
Woodlawn High School	Girls Locker Room back tap	WHU670	June 5, 2023	0.013	Exceeded	0.3900	Passed	Hand washing only
Woodlawn High School	Girls Locker Room tap 1	WHU668	June 5, 2023	-	Passed	0.0410	Passed	Tap remediated
Woodlawn High School	Girls Locker Room tap 2	MXH593	June 17, 2020	0.004	Passed	0.2400	Passed	
Woodlawn High School	Girls Locker Room tap 3	WHU669	June 5, 2023	0.001	Passed	0.0440	Passed	Tap remediated
Woodlawn High School	Gym Office 11 Wash Room tap	WHU665	June 5, 2023	0.003	Passed	0.5500	Passed	Tap remediated
Woodlawn High School	Fountain in Gym	WHU666	June 5, 2023	-	Passed	0.0006	Passed	
Woodlawn High School	Boys Locker Room tap 1	WHU671	June 5, 2023	0.006	Exceeded	0.0880	Passed	Hand washing only
Woodlawn High School	Boys Locker Room tap 2	WHU672	June 5, 2023	0.002	Passed	0.0710	Passed	Tap remediated
Woodlawn High School	Boys Locker Room tap 3	MXH599	June 17, 2020	0.002	Passed	0.1500	Passed	
Woodlawn High School	Gym Office 1 Wash Room tap	MXH600	June 17, 2020	0.002	Passed	0.0370	Passed	
Woodlawn High School	Gym Office 12 Wash Room tap	MXH601	June 17, 2020	0.002	Passed	0.0480	Passed	
Woodlawn High School	1st Floor Fountain by Boiler Room	WHU665	June 6, 2023	-	Passed	0.0006	Passed	