

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
117 Kearney Lake Lower Unit	Wash Room tap 1	NTW460	October 1, 2020	0.002	Passed	0.1010	Passed		
117 Kearney Lake Lower Unit	Wash Room tap 2	NTW461	October 1, 2020	0.003	Passed	0.0800	Passed		
117 Kearney Lake Lower Unit	Wash Room tap 3	NTW462	October 1, 2020	0.003	Passed	0.0680	Passed		
117 Kearney Lake Lower Unit	Wash Room tap 4	NTW463	October 1, 2020	0.005	Passed	0.0620	Passed		
117 Kearney Lake Lower Unit	Gender Neutral Wash Room tap	NTW464	October 1, 2020	0.003	Passed	0.0890	Passed		
117 Kearney Lake Lower Unit	Staff Kitchen tap	AQHV15	April 28, 2025	-	Passed	0.0065	Passed		
117 Kearney Lake Upper Unit	Gender Neutral Wash Room tap	NTW466	October 1, 2020	0.005	Passed	0.1200	Passed		
117 Kearney Lake Upper Unit	Wash Room tap 1	NTW467	October 1, 2020	0.004	Passed	0.0790	Passed		
117 Kearney Lake Upper Unit	Wash Room tap 2	NTW468	October 1, 2020	0.005	Passed	0.0780	Passed		
117 Kearney Lake Upper Unit	Wash Room tap 3	NTW469	October 1, 2020	0.004	Passed	0.0680	Passed		
117 Kearney Lake Upper Unit	Wash Room tap 4	NTW470	October 1, 2020	0.003	Passed	0.0890	Passed		
117 Kearney Lake Upper Unit	Wash Room tap 5	NTW471	October 1, 2020	0.003	Passed	0.0810	Passed		
117 Kearney Lake Upper Unit	Staff Kitchen tap	AQHV10	April 28, 2025	-	Passed	0.0032	Passed		
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 1	MPX522	May 13, 2020	0.003	Passed	0.4100	Passed		
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 2	MPX523	May 13, 2020	0.001	Passed	0.0610	Passed		
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 2	MPX529	May 13, 2020	0.001	Passed	0.0840	Passed		
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 3	MPX530	May 13, 2020	0.001	Passed	0.0700	Passed		
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 4	MPX531	May 13, 2020	0.002	Passed	0.4500	Passed		
A. J. Smeltzer Junior High School	Guidance Room Wash Room tap	MPX541	May 13, 2020	0.001	Passed	0.0880	Passed		
A. J. Smeltzer Junior High School	Main Office Wash Room tap	MPX542	May 13, 2020	-	Passed	0.0590	Passed		
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 2	MPX544	May 13, 2020	0.002	Passed	0.1300	Passed		
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 3	MPX545	May 13, 2020	0.002	Passed	0.1500	Passed		
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 4	MPX546	May 13, 2020	0.002	Passed	0.1200	Passed		
A. J. Smeltzer Junior High School	2nd Floor Janitors Closet tap	MPX548	May 13, 2020	0.002	Passed	0.0420	Passed		
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 2	MPX550	May 13, 2020	0.002	Passed	0.0590	Passed		
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 3	MPX551	May 13, 2020	-	Passed	0.0067	Passed		
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 4	MPX552	May 13, 2020	0.001	Passed	0.0084	Passed		
A. J. Smeltzer Junior High School	Class Room 222 tap	MPX553	May 13, 2020	0.001	Passed	0.0250	Passed		
A. J. Smeltzer Junior High School	Class Room 227 tap	MPX563	May 13, 2020	0.001	Passed	0.0530	Passed		
A. J. Smeltzer Junior High School	Staff Room 27A Wash Room tap	MPX565	May 13, 2020	0.004	Passed	0.0280	Passed		
A. J. Smeltzer Junior High School	Wood Shop tap 1	SCA060	March 14, 2022	0.001	Passed	0.0420	Passed		
A. J. Smeltzer Junior High School	Wood Shop tap 2	SCA061	March 14, 2022	0.001	Passed	0.0420	Passed		
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 1	SCA062	March 14, 2022	0.001	Passed	0.0160	Passed		
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 3	SCA063	March 15, 2022	-	Passed	0.0400	Passed		
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 4	SCA064	March 15, 2022	0.001	Passed	0.1600	Passed		
A. J. Smeltzer Junior High School	1st Floor Janitors Closet tap	SCA065	March 15, 2022	-	Passed	0.0110	Passed		
A. J. Smeltzer Junior High School	Class Room 115 Wash Room tap	SCA069	March 15, 2022	0.003	Passed	0.1400	Passed		
A. J. Smeltzer Junior High School	Class Room 115 tap	SCA070	March 15, 2022	0.001	Passed	0.1300	Passed		
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 1	SCA071	March 15, 2022	0.002	Passed	0.0940	Passed		
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 1	SCA072	March 15, 2022	-	Passed	0.0088	Passed		
A. J. Smeltzer Junior High School	Staff Room 27B Wash Room tap	SCA079	March 15, 2022	-	Passed	0.0300	Passed		
A. J. Smeltzer Junior High School	Class Room 26 tap	SCA080	March 15, 2022	0.001	Passed	0.0280	Passed		
A. J. Smeltzer Junior High School	Fountain by 1st Floor Janitors Closet	AQQC32	May 7, 2025	-	Passed	0.0190	Passed		
A. J. Smeltzer Junior High School	Fountain by Room 16	AQQC31	May 7, 2025	-	Passed	0.0011	Passed		
A. J. Smeltzer Junior High School	Kitchen Wash Room tap	AQQC33	May 7, 2025	-	Passed	0.0150	Passed		
A. J. Smeltzer Junior High School	Kitchen sink tap 1	AQQC34	May 7, 2025	-	Passed	0.0061	Passed		
A. J. Smeltzer Junior High School	Kitchen sink tap 2	AQQC35	May 7, 2025	-	Passed	0.0090	Passed		
A. J. Smeltzer Junior High School	Kitchen sink tap 3	AQQC36	May 7, 2025	-	Passed	0.0086	Passed		
A. J. Smeltzer Junior High School	Fountain by 2nd Floor Janitors Closet	AQQC37	May 7, 2025	-	Passed	0.0110	Passed		
A. J. Smeltzer Junior High School	Food Lab sink tap	AQQC38	May 7, 2025	0.002	Passed	0.0240	Passed		
A. J. Smeltzer Junior High School	Food Lab washtub tap	AQQC39	May 7, 2025	0.001	Passed	0.0140	Passed		
A. J. Smeltzer Junior High School	Food Lab tap 1	AQQC40	May 7, 2025	-	Passed	0.0110	Passed		
A. J. Smeltzer Junior High School	Food Lab tap 2	AQQC41	May 7, 2025	-	Passed	0.0160	Passed		
A. J. Smeltzer Junior High School	Food Lab tap 3	AQQC42	May 7, 2025	-	Passed	0.0140	Passed		
A. J. Smeltzer Junior High School	Food Lab tap 4	AQQC43	May 7, 2025	-	Passed	0.0110	Passed		
A. J. Smeltzer Junior High School	Food Lab Wash Room tap	XXK289	October 26, 2023	0.002	Passed	0.0150	Passed	Tap remediated	
A. J. Smeltzer Junior High School	Fountain by Food Lab	AQQC44	May 7, 2025	-	Passed	0.0009	Passed		
A. J. Smeltzer Junior High School	Library Room 43A tap	WBD200	June 7, 2023	0.001	Passed	0.0190	Passed	Tap remediated	
A. J. Smeltzer Junior High School	Family Living Class Room tap	KKK288	October 26, 2023	0.003	Passed	0.0140	Passed	Tap remediated	
A. J. Smeltzer Junior High School	Staff Room 27 tap	AQQC45	May 7, 2025	-	Passed	0.0071	Passed		
Admiral Westphal Elementary	Boys Wash Room tap 1 by Room 12	XGV073	October 12, 2023	0.008	Exceeded	0.1100	Passed	Hand washing only	
Admiral Westphal Elementary	Boys Wash Room tap 2 by Room 12	XGV074	October 12, 2023	0.005	Exceeded	0.1100	Passed	Hand washing only	
Admiral Westphal Elementary	Boys Wash Room tap 3 by Room 12	XGV075	October 12, 2023	0.005	Passed	0.1100	Passed	Tap remediated	
Admiral Westphal Elementary	Boys Wash Room tap 4 by Room 12	XGV076	October 12, 2023	0.003	Passed	0.0890	Passed	Tap remediated	
Admiral Westphal Elementary	Class Room 16 tap	MYH088	June 23, 2020	0.003	Passed	0.5300	Passed		
Admiral Westphal Elementary	Class Room 24 tap 1	XGV085	October 12, 2023	-	Passed	0.0410	Passed	Tap remediated	
Admiral Westphal Elementary	Class Room 24 tap 2	XGV086	October 12, 2023	-	Passed	0.0430	Passed	Tap remediated	
Admiral Westphal Elementary	Class Room 3	XGV067	October 12, 2023	0.001	Passed	0.0420	Passed	Tap remediated	
Admiral Westphal Elementary	Class Room 3 Wash Room tap	XGV068	October 12, 2023	-	Passed	0.0400	Passed	Tap remediated	
Admiral Westphal Elementary	Class Room 4 tap	XGV069	October 12, 2023	-	Passed	0.0440	Passed	Tap remediated	
Admiral Westphal Elementary	Class Room 5 tap	XGV071	October 12, 2023	-	Passed	0.0470	Passed	Tap remediated	
Admiral Westphal Elementary	Fountain by Janitors Closet tap	ARSM08	June 9, 2025	-	Passed	0.0190	Passed		
Admiral Westphal Elementary	Fountain by Room 16	ARSM09	June 9, 2025	0.001	Passed	0.0240	Passed		
Admiral Westphal Elementary	Fountain by Room 2	ARSM07	June 9, 2025	0.001	Passed	0.0410	Passed		
Admiral Westphal Elementary	Fountain by Room 21	ARSM10	June 9, 2025	-	Passed	0.0470	Passed		
Admiral Westphal Elementary	Gender Neutral Wash Room tap by Room 4	XGV070	October 12, 2023	0.001	Passed	0.0580	Passed	Tap remediated	
Admiral Westphal Elementary	Girls Wash Room tap 1 by Room 12	XGV077	October 12, 2023	0.009	Exceeded	0.1900	Passed	Hand washing only	
Admiral Westphal Elementary	Girls Wash Room tap 2 by Room 12	XGV078	October 12, 2023	0.010	Exceeded	0.1700	Passed	Hand washing only	
Admiral Westphal Elementary	Girls Wash Room tap 3 by Room 12	XGV077	October 12, 2023	0.010	Exceeded	0.1400	Passed	Hand washing only	
Admiral Westphal Elementary	Girls Wash Room tap 4 by Room 12	XGV077	October 12, 2023	0.005	Exceeded	0.1200	Passed	Hand washing only	
Admiral Westphal Elementary	Janitors Closet by Girls Wash Room	MYH082	June 23, 2020	-	Passed	0.0670	Passed		
Admiral Westphal Elementary	Janitors Closet tap by Room 12	MYH099	June 23, 2020	0.014	Exceeded	0.1800	Passed	Hand washing only	
Admiral Westphal Elementary	Janitors Closet tap by Room 4	MYH103	June 23, 2020	0.030	Exceeded	0.2700	Passed	Hand washing only	
Admiral Westphal Elementary	Principal's Office Wash Room tap	XGV082	October 12, 2023	0.002	Passed	0.0780	Passed	Tap remediated	
Admiral Westphal Elementary	Room 10 Wash Room tap	XGV081	October 12, 2023	0.002	Passed	0.0440	Passed	Tap remediated	
Admiral Westphal Elementary	Room 23 tap	XGV084	October 12, 2023	0.001	Passed	0.0820	Passed		
Admiral Westphal Elementary	Special Needs Wash Room tap by Room 19	MYH083	June 23, 2020	0.001	Passed	0.1600	Passed		
Admiral Westphal Elementary	Staff Kitchen tap	ARSM05	June 9, 2025	-	Passed	0.0210	Passed		
Admiral Westphal Elementary	Staff Room Female Wash Room tap 1	XGV065	October 12, 2023	0.001	Passed	0.0550	Passed	Tap remediated	
Admiral Westphal Elementary	Staff Room Female Wash Room tap 2	XGV066	October 12, 2023	0.008	Exceeded	0.0640	Passed	Hand washing only	
Admiral Westphal Elementary	Staff Room Male Wash Room tap 1	MYH109	June 23, 2020	0.003	Passed	0.0780	Passed		
Alderney Elementary	1st Floor Boys Wash Room tap 1	PZN578	June 30, 2021	0.001	Passed	0.0430	Passed		
Alderney Elementary	1st Floor Boys Wash Room tap 2	PZN579	June 30, 2021	-	Passed	0.0370	Passed		
Alderney Elementary	1st Floor Girls Wash Room tap 1	PZN580	June 30, 2021	0.001	Passed	0.0200	Passed		
Alderney Elementary	1st Floor Girls Wash Room tap 2	PZN581	June 30, 2021	-	Passed	0.0130	Passed		
Alderney Elementary	Basement Boys Wash Room tap 1	PZN585	June 30, 2021	-	Passed	0.0097	Passed		
Alderney Elementary	Basement Boys Wash Room tap 2	PZN586	June 30, 2021	-	Passed	0.0091	Passed		
Alderney Elementary	Basement Boys Wash Room tap 3	PZN587	June 30, 2021	-	Passed	0.0130	Passed		
Alderney Elementary	Basement Fountain by Wash Rooms	ARGH41	May 27, 2025	-	Passed	-	Passed		
Alderney Elementary	Basement Girls Wash Room tap 1	PZN582	June 30, 2021	-	Passed	0.0190	Passed		
Alderney Elementary	Basement Girls Wash Room tap 2	PZN583	June 30, 2021	-	Passed	0.0260	Passed		
Alderney Elementary	Basement Girls Wash Room tap 3	PZN584	June 30, 2021	0.001	Passed	0.0340	Passed		
Alderney Elementary	Basement Janitors Closet tap Room 109	NAN889	June 30, 2020	0.001	Passed	0.0790	Passed		
Alderney Elementary	Fountain by Main Entrance	ARGH42	May 27, 2025	0.002	Passed	0.0480	Passed		
Alderney Elementary	Fountain by 305	ARGH43	May 27, 2025	0.003	Passed	0.2300	Passed		
Alderney Elementary	Janitors Closet tap in Sprinkler Room	NAN883	June 30, 2020	0.003	Passed	0.1800	Passed		
Alderney Elementary	Staff Room/Basement staff room tap	ARGH40	May 27, 2025	-	Passed	0.0072	Passed	Tap remediated	
Alderney Elementary	Staff Wash Room tap by Main Entrance	NAN8820							

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Ash Lee Jefferson Elementary	Girls Change Room tap	MVG470	June 9, 2020	0.001	Passed	0.2200	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room 128 tap 1	WEK923	June 20, 2023	-	Passed	0.0310	Passed	Tap remediated	
Ash Lee Jefferson Elementary	Girls Wash Room 128 tap 2	MVG499	June 9, 2020	0.003	Passed	0.2600	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room 128 tap 3	MVG500	June 9, 2020	0.003	Passed	0.1000	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room tap 1	MVG513	June 9, 2020	0.001	Passed	0.5500	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room tap 1 by Change Room	MVG473	June 9, 2020	0.001	Passed	0.1400	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room tap 1 by Room 271	MVG481	June 9, 2020	-	Passed	0.3100	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room tap 2	MVG505	June 9, 2020	0.001	Passed	0.5900	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room tap 2 by Change Room	MVG474	June 9, 2020	0.002	Passed	0.1100	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room tap 2 by Room 271	MVG482	June 9, 2020	-	Passed	0.1200	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room tap 3	MVG512	June 9, 2020	0.000	Passed	0.5800	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room tap 3 by Change Room	WEK920	June 20, 2023	-	Passed	0.0310	Passed	Tap remediated	
Ash Lee Jefferson Elementary	Girls Wash Room tap 3 by Room 271	MVG483	June 9, 2020	-	Passed	0.1100	Passed		
Ash Lee Jefferson Elementary	Girls Wash Room tap 4 by Room 271	MVG484	June 9, 2020	-	Passed	0.1100	Passed		
Ash Lee Jefferson Elementary	Gym Office 231 tap	MVG469	June 9, 2020	0.003	Passed	1.6000	Passed		
Ash Lee Jefferson Elementary	Janitors Closet Room 127 tap	MVG501	June 9, 2020	0.001	Passed	0.2800	Passed		
Ash Lee Jefferson Elementary	Janitors Closet tap	MVG486	June 9, 2020	-	Passed	0.4200	Passed		
Ash Lee Jefferson Elementary	Janitors Closet tap	MVG476	June 9, 2020	-	Passed	0.3000	Passed		
Ash Lee Jefferson Elementary	Kitchen Room 219 tap 1	ARDX09	May 23, 2025	-	Passed	0.0200	Passed		
Ash Lee Jefferson Elementary	Kitchen Room 219 tap 2	ARDX10	May 23, 2025	-	Passed	0.0270	Passed		
Ash Lee Jefferson Elementary	Kitchen Room 219 tap 3	ARDX11	May 23, 2025	-	Passed	0.0270	Passed		
Ash Lee Jefferson Elementary	Kitchen Room 219 tap 4	ARDX12	May 23, 2025	-	Passed	0.0240	Passed		
Ash Lee Jefferson Elementary	Staff Room tap	ARDX08	May 23, 2025	-	Passed	0.0240	Passed		
Ash Lee Jefferson Elementary	Staff Room Wash Room tap 1	MVG506	June 9, 2020	-	Passed	0.0920	Passed		
Ash Lee Jefferson Elementary	Staff Room Wash Room tap 2	MVG507	June 9, 2020	0.002	Passed	0.2300	Passed		
Astral Drive Elementary	1st Floor Boys Wash Room tap 1	XBV394	September 20, 2023	-	Passed	0.0370	Passed	Tap remediated	
Astral Drive Elementary	1st Floor Boys Wash Room tap 2	MXV305	June 19, 2020	0.004	Passed	0.1600	Passed		
Astral Drive Elementary	1st Floor Boys Wash Room tap 3	MXV306	June 19, 2020	0.001	Passed	0.0170	Passed		
Astral Drive Elementary	1st Floor Girls Wash Room tap 1	MXV307	June 19, 2020	0.005	Passed	0.0660	Passed		
Astral Drive Elementary	1st Floor Girls Wash Room tap 2	XBV392	September 20, 2023	-	Passed	0.0150	Passed	Tap remediated	
Astral Drive Elementary	1st Floor Girls Wash Room tap 3	XBV393	September 20, 2023	-	Passed	0.0150	Passed		
Astral Drive Elementary	2nd Floor Boys Wash Room tap 1	XBV399	September 20, 2023	0.001	Passed	0.0610	Passed	Tap remediated	
Astral Drive Elementary	2nd Floor Boys Wash Room tap 2	MXV293	June 19, 2020	0.003	Passed	0.1200	Passed		
Astral Drive Elementary	2nd Floor Boys Wash Room tap 3	MXV294	June 19, 2020	0.003	Passed	0.1400	Passed		
Astral Drive Elementary	2nd Floor Girls Wash Room tap 1	MXV295	June 19, 2020	0.003	Passed	0.1100	Passed		
Astral Drive Elementary	2nd Floor Girls Wash Room tap 2	MXV296	June 19, 2020	0.004	Passed	0.0330	Passed		
Astral Drive Elementary	2nd Floor Girls Wash Room tap 3	MXV297	June 19, 2020	-	Passed	0.0100	Passed		
Astral Drive Elementary	Art Room 215 tap	XBV645	September 20, 2023	0.001	Passed	0.0400	Passed	Tap remediated	
Astral Drive Elementary	Boiler Room tap	MXV344	June 19, 2020	0.019	Exceeded	0.2100	Passed	Hand washing only	
Astral Drive Elementary	Class Room 101 tap	NLS541	August 25, 2020	0.001	Passed	0.0430	Passed		
Astral Drive Elementary	Class Room 102 tap	NLS540	August 25, 2020	0.001	Passed	0.0450	Passed		
Astral Drive Elementary	Class Room 102 Wash Room tap	MXV317	June 19, 2020	0.003	Passed	0.1700	Passed		
Astral Drive Elementary	Class Room 103 tap	XBV396	September 20, 2023	0.001	Passed	0.0470	Passed	Tap remediated	
Astral Drive Elementary	Class Room 104 tap 1	NLS542	August 25, 2020	0.001	Passed	0.0390	Passed		
Astral Drive Elementary	Class Room 105 tap	XBV397	September 20, 2023	0.001	Passed	0.0960	Passed	Tap remediated	
Astral Drive Elementary	Class Room 105 Wash Room tap	MXV311	June 19, 2020	0.041	Exceeded	0.3000	Passed	Hand washing only	
Astral Drive Elementary	Class Room 107 tap	NLS543	August 25, 2020	0.002	Passed	0.0690	Passed		
Astral Drive Elementary	Fountain by Gym	AROK94	June 4, 2025	-	Passed	0.0150	Passed		
Astral Drive Elementary	Fountain by Office	AROK93	June 4, 2025	-	Passed	0.0014	Passed		
Astral Drive Elementary	Fountain by Room 216	AROK96	June 4, 2025	-	Passed	0.0009	Passed		
Astral Drive Elementary	Janitors Closet 115 tap	MXV318	June 19, 2020	0.001	Passed	0.0300	Passed		
Astral Drive Elementary	Janitors Closet Room 217 tap	MXV298	June 19, 2020	0.001	Passed	0.0600	Passed		
Astral Drive Elementary	Main Office Staff Wash Room tap	MXV313	June 19, 2020	0.000	Passed	0.0350	Passed		
Astral Drive Elementary	Music Room 109 tap	NLS538	August 25, 2020	0.001	Passed	0.0170	Passed		
Astral Drive Elementary	Staff Room 216 tap	AROK95	June 4, 2025	-	Passed	0.0052	Passed		
Astral Drive Elementary	Staff Room 216 Wash Room 1	XBV644	September 20, 2023	-	Passed	0.0071	Passed	Tap remediated	
Astral Drive Elementary	Staff Room 216 Wash Room 2	MXV302	June 19, 2020	0.003	Passed	0.1500	Passed		
Astral Drive Junior High School	1st Floor Boys Wash Room tap 1 by Room 132	XBV790	September 20, 2023	0.001	Passed	0.0340	Passed	Tap remediated	
Astral Drive Junior High School	1st Floor Boys Wash Room tap 2 by Room 132	XBV791	September 20, 2023	0.001	Passed	0.0270	Passed	Tap remediated	
Astral Drive Junior High School	1st Floor Boys Wash Room tap 3 by Room 132	XBV792	September 20, 2023	0.001	Passed	0.0350	Passed	Tap remediated	
Astral Drive Junior High School	1st Floor Canteen tap 1	AROL07	June 4, 2025	-	Passed	0.0330	Passed		
Astral Drive Junior High School	1st Floor Canteen tap 2	AROL08	June 4, 2025	-	Passed	0.0460	Passed		
Astral Drive Junior High School	1st Floor Girls Wash Room tap 1 by Room 133	XBV793	September 20, 2023	0.003	Passed	0.0710	Passed	Tap remediated	
Astral Drive Junior High School	1st Floor Girls Wash Room tap 2 by Room 133	MXU391	June 19, 2020	0.004	Passed	0.0920	Passed		
Astral Drive Junior High School	1st Floor Girls Wash Room tap 3 by Room 133	MXU392	June 19, 2020	0.001	Passed	0.0610	Passed		
Astral Drive Junior High School	1st Floor Girls Wash Room tap 4 by Room 133	MXU393	June 19, 2020	0.001	Passed	0.0980	Passed		
Astral Drive Junior High School	1st Floor Staff Room tap	AROL09	June 4, 2025	-	Passed	0.0170	Passed		
Astral Drive Junior High School	Art Room 142 tap 1	XBV734	September 20, 2023	0.087	Exceeded	0.1400	Passed	Hand washing only	
Astral Drive Junior High School	Art Room 142 tap 2	XBV735	September 20, 2023	0.004	Passed	0.0740	Passed	Tap remediated	
Astral Drive Junior High School	Boys Locker Room tap 1	MXU375	June 19, 2020	0.004	Passed	0.1100	Passed		
Astral Drive Junior High School	Boys Locker Room tap 2	MXU376	June 19, 2020	0.001	Passed	0.0440	Passed		
Astral Drive Junior High School	Boys Wash Room tap 1 by Room 143	MXU364	June 19, 2020	0.001	Passed	0.0740	Passed		
Astral Drive Junior High School	Boys Wash Room tap 1 by Room 232	MXU348	June 19, 2020	0.001	Passed	0.0380	Passed		
Astral Drive Junior High School	Boys Wash Room tap 2 by Room 143	MXU365	June 19, 2020	0.002	Passed	0.0580	Passed		
Astral Drive Junior High School	Boys Wash Room tap 2 by Room 232	MXU349	June 19, 2020	0.001	Passed	0.0310	Passed		
Astral Drive Junior High School	Boys Wash Room tap 3 by Room 232	MXU350	June 19, 2020	0.001	Passed	0.0310	Passed		
Astral Drive Junior High School	Class Room 143 tap	MXU378	June 19, 2020	0.002	Passed	0.0540	Passed		
Astral Drive Junior High School	Class Room Lab 211 tap 1	MXU344	June 19, 2020	0.025	Exceeded	1.6000	Passed	Laboratory or Hand washing only	
Astral Drive Junior High School	Class Room Lab 211 tap 2	MXU345	June 19, 2020	0.042	Exceeded	1.5000	Passed	Laboratory or Hand washing only	
Astral Drive Junior High School	Class Room Lab 211 tap 3	MXU346	June 19, 2020	0.400	Exceeded	5.6000	Exceeded	Laboratory or Hand washing only	
Astral Drive Junior High School	Class Room Lab 211 tap 4	MXU347	June 19, 2020	0.028	Exceeded	2.0000	Exceeded	Laboratory or Hand washing only	
Astral Drive Junior High School	Fountain by Room 132	AROL14	June 4, 2025	-	Passed	0.0210	Passed		
Astral Drive Junior High School	Fountain by Room 149	AROL10	June 4, 2025	-	Passed	0.0160	Passed		
Astral Drive Junior High School	Fountain by Room 232	AROL15	June 4, 2025	-	Passed	0.0620	Passed		
Astral Drive Junior High School	Girls Locker Room tap 1	MXU373	June 19, 2020	0.001	Passed	0.1000	Passed		
Astral Drive Junior High School	Girls Locker Room tap 2	MXU374	June 19, 2020	0.002	Passed	0.1000	Passed		
Astral Drive Junior High School	Girls Wash Room tap 1 by Room 143	MXU361	June 19, 2020	0.002	Passed	0.0410	Passed		
Astral Drive Junior High School	Girls Wash Room tap 1 by Room 204	XBV787	September 23, 2023	0.008	Exceeded	0.1100	Passed	Hand washing only	
Astral Drive Junior High School	Girls Wash Room tap 2 by Room 143	MXU362	June 19, 2020	-	Passed	0.0400	Passed		
Astral Drive Junior High School	Girls Wash Room tap 2 by Room 204	MXU331	June 19, 2020	0.001	Passed	0.0500	Passed		
Astral Drive Junior High School	Girls Wash Room tap 3 by Room 204	XBV788	September 23, 2023	0.001	Passed	0.0680	Passed	Tap remediated	
Astral Drive Junior High School	Girls Wash Room tap 4 by Room 204	MXU333	June 19, 2020	0.002	Passed	0.0480	Passed		
Astral Drive Junior High School	Gym Office 153 Wash Room tap	MXU372	June 19, 2020	0.002	Passed	0.0510	Passed		
Astral Drive Junior High School	Gym Office 157 Wash Room tap	MXU377	June 19, 2020	0.002	Passed	0.0540	Passed		
Astral Drive Junior High School	Home Ec. 174 tap 1	AROL11	June 4, 2025	-	Passed	0.0240	Passed		
Astral Drive Junior High School	Home Ec. 174 tap 2	AROL12	June 4, 2025	-	Passed	0.0330	Passed		
Astral Drive Junior High School	Janitors Closet 132 tap	MXU386	June 19, 2020	0.002	Passed	0.0540	Passed		
Astral Drive Junior High School	Janitors Closet 164 tap	MXU369	June 19, 2020	0.003	Passed	0.0430	Passed		
Astral Drive Junior High School	Janitors Closet 232 tap	MXU351	June 19, 2020	-	Passed	0.0320	Passed		
Astral Drive Junior High School	Office Room 194 tap	XBV732	September 20, 2023	0.032	Exceeded	0.7700	Passed	Hand washing only	
Astral Drive Junior High School	Office Wash Room 193 tap	XBV733	September 20, 2023	0.008	Exceeded	0.2100	Passed	Hand washing only	
Astral Drive Junior High School	Resource Room 140 tap	AROL13	June 4, 2025	-	Passed	0.0110	Passed		
Astral Drive Junior High School	Science Lab 204 tap 1	MXU334	June 19, 2020	0.028	Exceeded	1.0000	Passed	Laboratory or Hand washing only	
Astral Drive Junior High School	Science Lab 204 tap 2	MXU335	June 19, 2020	0.031	Exceeded	0.1800	Passed	Laboratory or Hand washing only	
Astral Drive Junior High School	Science Lab 204 tap 3	MXU336	June 19, 2020	0.036	Exceeded	0.8300	Passed	Laboratory or Hand washing only	
Astral Drive Junior High School	Science Lab 204 tap 4	MXU337	June 19, 2020	0.002	Passed	0.0570	Passed		
Astral Drive Junior High School	Science Lab 206 tap 1	MXU338	June 19, 2020	0.011	Exceeded	0.0760	Passed	Laboratory or Hand washing only	
Astral Drive Junior High School	Science Lab 206 tap 2	MXU339	June 19, 2020	0.047	Exceeded	0.4300	Passed	Laboratory or Hand washing only	
Astral Drive Junior High School	Staff Room Wash Room 181 tap	MXU359	June 19, 2020	0.001	Passed	0.0370	Passed		
Astral Drive Junior High School	Staff Room Wash Room 182 tap	MXU360	June 19, 2020	0.001	Passed	0.0360	Passed		
Astral Drive Junior High School	Student Services 141 Wash Room tap	XBV737	September 20, 2023	-	Passed	0.0170	Passed	Tap remediated	
Astral Drive Junior High School	Wood Shop 165 tap	XBV731	September 20, 2023	0.001	Passed	0.1500	Passed	Tap remediated	
Atl. Mem. - Terence Bay Elem (Shad Bay)	Fountain by Room 107	ZIG104	June 5, 2024	0.006	Exceeded	0.1100	Passed	Fountain out of service. Other sources available.	
</									

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Girls Wash Room tap 1	MUM350	June 4, 2020	0.085	Exceeded	0.0990	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Girls Wash Room tap 2	MUM351	June 4, 2020	0.017	Exceeded	0.3700	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Janitors Closet tap	MUM352	June 4, 2020	0.006	Exceeded	0.2500	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Boys Wash Room tap 1	MUM353	June 4, 2020	0.018	Exceeded	0.0540	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Boys Wash Room tap 2	MUM354	June 4, 2020	0.016	Exceeded	0.0600	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room tap 1 by Reading Room	MUM355	June 4, 2020	0.045	Exceeded	0.1700	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room tap 2 by Reading Room	MUM356	June 4, 2020	0.019	Exceeded	0.2100	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room tap at end of the building	MUM357	June 4, 2020	0.120	Exceeded	0.1300	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room 1 tap	MUM358	June 4, 2020	0.019	Exceeded	0.2100	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Gender Neutral Wash Room 2 tap	MUM368	June 4, 2020	0.025	Exceeded	0.1200	Passed	Hand washing only	
Atl. Mem. -Terence Bay Elem (Terence Bay)	Staff Room tap	ZIG103	June 5, 2024	0.001	Passed	0.1200	Passed	Hand washing only	
Atlantic View Elementary	Boys Wash Room tap 1 by Janitors Closet	SWD840	June 9, 2022	-	Passed	0.0400	Passed		
Atlantic View Elementary	Boys Wash Room tap 2 by Janitors Closet	SWD841	June 9, 2022	0.001	Passed	0.0310	Passed		
Atlantic View Elementary	Boys Wash Room tap 3 by Janitors Closet	SWD842	June 9, 2022	0.001	Passed	0.0310	Passed		
Atlantic View Elementary	Breakfast Club Room tap	ASHA32	June 24, 2025	0.001	Passed	0.0440	Passed		
Atlantic View Elementary	Class Room 3 Wash Room tap	SWD834	June 9, 2022	0.001	Passed	0.0540	Passed		
Atlantic View Elementary	Fountain by Girls Wash Room	ASHA31	June 24, 2025	-	Passed	-	Passed		
Atlantic View Elementary	Fountain by Library	ASHA27	June 24, 2025	-	Passed	-	Passed		
Atlantic View Elementary	Girls Locker Room tap	XGE399	October 11, 2023	0.007	Exceeded	0.0060	Passed	Hand washing only	
Atlantic View Elementary	Girls Wash Room tap 1 by Fountain	SWD836	June 9, 2022	0.002	Passed	0.0330	Passed		
Atlantic View Elementary	Girls Wash Room tap 2 by Fountain	SWD837	June 9, 2022	0.001	Passed	0.0350	Passed		
Atlantic View Elementary	Girls Wash Room tap 3 by Fountain	SWD838	June 9, 2022	0.003	Passed	0.0320	Passed		
Atlantic View Elementary	Gym Caretaker Room tap in Gym	SWD846	June 9, 2022	0.002	Passed	0.0260	Passed		
Atlantic View Elementary	Gym Kitchen Handwash tap 1	ASHA29	June 24, 2025	0.008	Exceeded	0.0710	Passed	Hand washing only	
Atlantic View Elementary	Gym Kitchen Handwash tap 2	ASHA30	June 24, 2025	0.007	Exceeded	0.0710	Passed	Hand washing only	
Atlantic View Elementary	Gym Staff Wash Room tap	XGE398	October 11, 2023	0.002	Passed	0.0120	Passed	Tap remediated	
Atlantic View Elementary	Janitors Closet tap between Wash Rooms	SWD839	June 9, 2022	-	Passed	0.0018	Passed		
Atlantic View Elementary	Main Office Sick Room tap	XGE394	October 11, 2023	0.003	Passed	0.0150	Passed	Tap remediated	
Atlantic View Elementary	Main Office Staff Wash Room 1 tap	SWD852	June 9, 2022	0.004	Passed	0.0710	Passed		
Atlantic View Elementary	Main Office Staff Wash Room 2 tap	SWD853	June 9, 2022	0.002	Passed	0.0130	Passed		
Atlantic View Elementary	Room 9 tap	XGE395	October 11, 2023	0.001	Passed	0.0100	Passed		
Atlantic View Elementary	Staff Kitchen tap (STAFF ROOM)	ASHA28	June 24, 2025	0.003	Passed	0.0700	Passed		
Auburn Drive High School	Basement Boys Wash Room tap 1	MXH476	June 17, 2020	0.001	Passed	0.1100	Passed		
Auburn Drive High School	Basement Boys Wash Room tap 2	MXH477	June 17, 2020	0.001	Passed	0.1200	Passed		
Auburn Drive High School	Basement Boys Wash Room tap 3	MXH478	June 17, 2020	0.001	Passed	0.0970	Passed		
Auburn Drive High School	Basement Girls Wash Room tap 1	XCL322	September 22, 2023	-	Passed	0.1100	Passed	Tap remediated	
Auburn Drive High School	Basement Girls Wash Room tap 2	MXH483	June 17, 2020	0.002	Passed	0.0260	Passed		
Auburn Drive High School	Basement Girls Wash Room tap 3	MXH484	June 17, 2020	0.001	Passed	0.0290	Passed		
Auburn Drive High School	Basement Girls Wash Room tap 4	XCL323	September 22, 2023	-	Passed	0.0730	Passed	Tap remediated	
Auburn Drive High School	Basement Girls Wash Room tap 5	MXH486	June 17, 2020	-	Passed	0.0180	Passed		
Auburn Drive High School	Boys Wash Room tap 1 by Room 301	MXA181	June 16, 2020	0.001	Passed	0.5000	Passed		
Auburn Drive High School	Boys Wash Room tap 2 by Room 301	MXA182	June 16, 2020	-	Passed	0.1900	Passed		
Auburn Drive High School	Boys Wash Room tap 3 by Room 301	MXA183	June 16, 2020	0.001	Passed	0.0570	Passed		
Auburn Drive High School	Boys Wash Room tap 4 by Room 301	XCL329	September 22, 2023	-	Passed	0.0690	Passed	Tap remediated	
Auburn Drive High School	Boys Wash Room tap 5 by Room 301	MXA185	June 16, 2020	0.001	Passed	0.1600	Passed		
Auburn Drive High School	Cafeteria tap 1	ARGJ15	May 27, 2025	-	Passed	0.0130	Passed		
Auburn Drive High School	Cafeteria tap 2	ARGJ16	May 27, 2025	-	Passed	0.0310	Passed	Out-of-Service	
Auburn Drive High School	Cafeteria tap 3	ARGJ17	May 27, 2025	-	Passed	0.0140	Passed		
Auburn Drive High School	Class Room 209 tap	MXA203	June 16, 2020	0.004	Passed	0.2600	Passed		
Auburn Drive High School	Class Room 313 tap 1	XCL304	September 22, 2023	-	Passed	0.1600	Passed	Tap remediated	
Auburn Drive High School	Class Room 313 tap 2	XCL305	September 22, 2023	-	Passed	0.0940	Passed	Tap remediated	
Auburn Drive High School	Class Room 313 tap 3	XCL306	September 22, 2023	-	Passed	0.0300	Passed	Tap remediated	
Auburn Drive High School	Class Room 313 tap 4	MXA160	June 16, 2020	0.002	Passed	0.5200	Passed		
Auburn Drive High School	Class Room 313 tap 5	MXA161	June 16, 2020	-	Passed	0.3500	Passed		
Auburn Drive High School	Female Staff Room Wash Room tap	MXA210	June 16, 2020	-	Passed	0.2900	Passed		
Auburn Drive High School	Fine Arts Room 202 tap 1	MXA197	June 16, 2020	-	Passed	0.9500	Passed		
Auburn Drive High School	Fine Arts Room 202 tap 2	MXA198	June 16, 2020	-	Passed	0.4300	Passed		
Auburn Drive High School	Fine Arts Room 203 tap 1	XCL315	September 22, 2023	-	Passed	0.3500	Passed	Tap remediated	
Auburn Drive High School	Fine Arts Room 203 tap 2	XCL316	September 22, 2023	-	Passed	0.3200	Passed	Tap remediated	
Auburn Drive High School	Fine Arts Room 204 tap	MXA201	June 16, 2020	-	Passed	0.7300	Passed		
Auburn Drive High School	Food Lab 213 tap 1	ARGJ09	May 27, 2025	-	Passed	0.0120	Passed		
Auburn Drive High School	Food Lab 213 tap 2	ARGJ10	May 27, 2025	-	Passed	0.0120	Passed		
Auburn Drive High School	Food Lab 213 tap 3	ARGJ11	May 27, 2025	-	Passed	0.0094	Passed		
Auburn Drive High School	Food Lab 213 wash tap	ARGJ12	May 27, 2025	0.001	Passed	0.2200	Passed		
Auburn Drive High School	Food Lab 214 tap 1	ARGJ07	May 27, 2025	-	Passed	0.0290	Passed		
Auburn Drive High School	Food Lab 214 tap 2	ARGJ08	May 27, 2025	-	Passed	0.0250	Passed		
Auburn Drive High School	Fountain by Basement Gender Neutral Wash Rooms	ARGJ23	May 27, 2025	-	Passed	0.0013	Passed		
Auburn Drive High School	Fountain by Cafeteria	ARGJ14	May 27, 2025	-	Passed	0.0720	Passed		
Auburn Drive High School	Fountain by Room 108	ARGJ24	May 27, 2025	-	Passed	0.0019	Passed		
Auburn Drive High School	Fountain by Room 202	ARGJ13	May 27, 2025	-	Passed	0.0023	Passed		
Auburn Drive High School	Fountain by Room 207	ARGJ06	May 27, 2025	-	Passed	0.0930	Passed		
Auburn Drive High School	Fountain by Room 212	XCL336	September 22, 2023	-	Passed	0.0023	Passed		
Auburn Drive High School	Fountain by Room 223	ARGJ05	May 27, 2025	-	Passed	0.0063	Passed		
Auburn Drive High School	Fountain by Room 304	ARGJ19	May 27, 2025	-	Passed	0.0034	Passed		
Auburn Drive High School	Fountain by Room 307	ARGJ20	May 27, 2025	-	Passed	0.0530	Passed		
Auburn Drive High School	Fountain by Stairs	ARGJ18	May 27, 2025	-	Passed	0.0012	Passed		
Auburn Drive High School	Fountain in Gym	ARGJ22	May 27, 2025	0.001	Passed	0.1300	Passed		
Auburn Drive High School	Gender Neutral Wash Room 209 tap 1	XCL313	September 22, 2023	-	Passed	0.0680	Passed	Tap remediated	
Auburn Drive High School	Gender Neutral Wash Room 209 tap 2	MXA205	June 16, 2020	-	Passed	0.4800	Passed		
Auburn Drive High School	Gender Neutral Wash Room tap by Boys Wash Room	MXH479	June 17, 2020	0.001	Passed	0.1600	Passed		
Auburn Drive High School	Gender Neutral Wash Room tap by Girls Wash Room	XCL325	September 22, 2023	-	Passed	0.0110	Passed	Tap remediated	
Auburn Drive High School	Girls Wash Room tap 1 by Room 301	MXA188	June 16, 2020	0.003	Passed	0.4900	Passed		
Auburn Drive High School	Girls Wash Room tap 2 by Room 301	MXA189	June 16, 2020	-	Passed	0.5400	Passed		
Auburn Drive High School	Girls Wash Room tap 3 by Room 301	MXA190	June 16, 2020	0.005	Passed	0.3900	Passed		
Auburn Drive High School	Girls Wash Room tap 4 by Room 301	MXA191	June 16, 2020	0.003	Passed	0.1500	Passed		
Auburn Drive High School	Girls Wash Room tap 5 by Room 301	XCL328	September 22, 2023	0.001	Passed	0.0700	Passed	Tap remediated	
Auburn Drive High School	Gym Boys Change Room tap 1	MXA218	June 16, 2020	0.004	Passed	0.4600	Passed		
Auburn Drive High School	Gym Boys Change Room tap 2	MXA219	June 16, 2020	0.001	Passed	0.3000	Passed		
Auburn Drive High School	Gym Female Change Room tap 1	XCL334	September 22, 2023	0.002	Passed	0.2000	Passed	Tap remediated	
Auburn Drive High School	Gym Female Change Room tap 2	MXA221	June 16, 2020	-	Passed	0.4700	Passed		
Auburn Drive High School	Gym Gender Neutral Wash Room 1 tap	XCL344	September 22, 2023	0.002	Passed	0.2000	Passed	Tap remediated	
Auburn Drive High School	Gym Gender Neutral Wash Room 2 tap	XCL345	September 22, 2023	0.001	Passed	0.2200	Passed		
Auburn Drive High School	Gym Office Wash Room tap	MXA223	June 16, 2020	0.001	Passed	0.7600	Passed		
Auburn Drive High School	Janitors Closet 110 tap	MXH473	June 17, 2020	0.001	Passed	0.3000	Passed		
Auburn Drive High School	Janitors Closet 111 tap	MXH474	June 17, 2020	0.002	Passed	0.3600	Passed		
Auburn Drive High School	Janitors Closet 112 tap	MXH475	June 17, 2020	0.002	Passed	0.1700	Passed		
Auburn Drive High School	Janitors Closet tap by Girls Wash Room	MXH487	June 17, 2020	0.001	Passed	1.0000	Passed		
Auburn Drive High School	Janitors Closet tap by Student Services	MXA207	June 16, 2020	-	Passed	0.1500	Passed		
Auburn Drive High School	Janitors Closet tap by Wash Rooms	MXA193	June 16, 2020	0.001	Passed	0.3600	Passed		
Auburn Drive High School	Janitors Closet tap in Maintenance Room near Room 223	XCL312	September 22, 2023	-	Passed	0.0230	Passed	Tap remediated	
Auburn Drive High School	Library tap	XCL320	September 22, 2023	-	Passed	0.0450	Passed		
Auburn Drive High School	Library Wash Room tap	MXA212	June 16, 2020	0.002	Passed	1.0000	Passed		
Auburn Drive High School	Main Floor Boys Wash Room tap 1	MXA236	June 16, 2020	0.001	Passed	0.1500	Passed		
Auburn Drive High School	Main Floor Boys Wash Room tap 2	MXA237	June 16, 2020	0.001	Passed	0.1300	Passed		
Auburn Drive High School	Main Floor Boys Wash Room tap 3	XCL343	September 22, 2023	-	Passed	0.0510	Passed	Tap remediated	
Auburn Drive High School	Main Floor Boys Wash Room tap 4	MXA239	June 16, 2020	-	Passed	0.2500	Passed		
Auburn Drive High School	Main Floor Girls Wash Room tap 1	MXA232	June 16, 2020	0.004	Passed	0.2000	Passed		
Auburn Drive High School	Main Floor Girls Wash Room tap 2	MXA233	June 16, 2020	0.001	Passed	0.2600	Passed		
Auburn Drive High School	Main Floor Girls Wash Room tap 3	MXA234	June 16, 2020	0.001	Passed	0.1900	Passed		
Auburn Drive High School	Main Floor Girls Wash Room tap 4	MXA235	June 16, 2020	0.001	Passed	0.1600	Passed		
Auburn Drive High School	Male Staff Room Wash Room tap	MXA209	June 16, 2020	0.001	Passed	0.0580	Passed		
Auburn Drive High School	Music Room 201 tap	XCL326	September 22, 2023	-	Passed	0.0220	Passed	Tap remediated	
Auburn Drive High School	Prep Room 314 tap	MXA162	June 16, 2020	0.001	Passed	0.5400	Passed		
Auburn Drive High School	Science Lab 301 tap	MXA146	June 16, 2020	-	Passed	1.1000	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Auburn Drive High School	Science Lab 315 tap 4	MXA175	June 16, 2020	0.002	Passed	0.2100	Passed		
Auburn Drive High School	Science Lab 315 tap 5	XCL331	September 22, 2023	0.005	Passed	0.1300	Passed	Tap remediated	
Auburn Drive High School	Science Lab 315 tap 6	XCL332	September 22, 2023	-	Passed	0.0770	Passed	Tap remediated	
Auburn Drive High School	Science Lab 315 tap 7	XCL303	September 22, 2023	0.001	Passed	0.0570	Passed	Tap remediated	
Auburn Drive High School	Science Lab 315 tap 8	MXA179	June 16, 2020	0.001	Passed	0.8700	Passed		
Auburn Drive High School	Science Lab 315 tap 9	MXA180	June 16, 2020	0.002	Passed	0.4700	Passed		
Auburn Drive High School	Staff Room Kitchen tap	ARGJ21	May 27, 2025	-	Passed	0.0230	Passed		
Auburn Drive High School	Staff Wash Room 1 tap by Room 301	XCL311	September 22, 2023	-	Passed	0.0180	Passed	Tap remediated	
Auburn Drive High School	Staff Wash Room 2 tap by Room 301	MXA187	June 16, 2020	0.001	Passed	0.6600	Passed		
Auburn Drive High School	Student Services tap	XCL318	September 22, 2023	-	Passed	0.0230	Passed	Tap remediated	
Basinview Drive Elementary	1st Floor Boys Wash Room tap 1	MSP527	May 27, 2020	-	Passed	0.0280	Passed		
Basinview Drive Elementary	1st Floor Boys Wash Room tap 1	MSP528	May 27, 2020	-	Passed	0.0310	Passed		
Basinview Drive Elementary	1st Floor Girls Wash Room tap 1	MSP529	May 27, 2020	0.001	Passed	0.1500	Passed		
Basinview Drive Elementary	1st Floor Girls Wash Room tap 2	MSP530	May 27, 2020	-	Passed	0.1100	Passed		
Basinview Drive Elementary	2nd Floor Boys Wash Room tap 1	MSP549	May 27, 2020	-	Passed	0.0170	Passed		
Basinview Drive Elementary	2nd Floor Boys Wash Room tap 2	MSP550	May 27, 2020	-	Passed	0.0170	Passed		
Basinview Drive Elementary	2nd Floor Boys Wash Room tap 3	MSP551	May 27, 2020	0.002	Passed	0.0550	Passed		
Basinview Drive Elementary	2nd Floor Girls Wash Room tap 1	MSP552	May 27, 2020	0.001	Passed	0.1000	Passed		
Basinview Drive Elementary	2nd Floor Girls Wash Room tap 2	MSP553	May 27, 2020	-	Passed	0.0330	Passed		
Basinview Drive Elementary	2nd Floor Girls Wash Room tap 3	MSP554	May 27, 2020	-	Passed	0.0370	Passed		
Basinview Drive Elementary	Boiler Room tap after Room 107	MSP534	May 27, 2020	-	Passed	0.0073	Passed		
Basinview Drive Elementary	Boys Locker Room tap 1	MSP536	May 27, 2020	0.002	Passed	0.0540	Passed		
Basinview Drive Elementary	Boys Locker Room tap 2	MSP537	May 27, 2020	-	Passed	0.0240	Passed		
Basinview Drive Elementary	Cafeteria large sink tap	AQVY49	May 14, 2025	-	Passed	0.0160	Passed		
Basinview Drive Elementary	Cafeteria small sink tap	AQVY50	May 14, 2025	-	Passed	0.0140	Passed		
Basinview Drive Elementary	Caretaker Office tap	WAT236	June 6, 2023	0.002	Passed	0.1100	Passed		
Basinview Drive Elementary	Class Room 131 tap	MSP511	May 27, 2020	-	Passed	0.4200	Passed		
Basinview Drive Elementary	Class Room 132 tap	MSP512	May 27, 2020	0.001	Passed	0.1900	Passed		
Basinview Drive Elementary	Class Room 133 tap	MSP514	August 26, 2020	-	Passed	0.0110	Passed		
Basinview Drive Elementary	Class Room 133 Wash Room tap	MSP513	May 27, 2020	0.001	Passed	0.1200	Passed		
Basinview Drive Elementary	Class Room 138 tap	MSP517	May 27, 2020	0.001	Passed	0.6700	Passed		
Basinview Drive Elementary	Class Room 139 tap	MSP519	May 27, 2020	-	Passed	0.0460	Passed		
Basinview Drive Elementary	Class Room 139 Wash Room tap	MSP518	May 27, 2020	-	Passed	0.0420	Passed		
Basinview Drive Elementary	Class Room 212 tap	NLV834	August 26, 2020	0.000	Passed	0.0060	Passed		
Basinview Drive Elementary	Class Room 213 tap	MSP548	May 27, 2020	0.001	Passed	0.1700	Passed		
Basinview Drive Elementary	Class Room 213 Wash Room tap	MSP547	May 27, 2020	-	Passed	0.0210	Passed		
Basinview Drive Elementary	Class Room tap Room 106	MSP532	May 27, 2020	0.001	Passed	0.1800	Passed		
Basinview Drive Elementary	Class Room tap Room 107	MSP533	May 27, 2020	-	Passed	0.0700	Passed		
Basinview Drive Elementary	Fountain by 1st Floor Girls Wash Room	AQVY51	May 14, 2025	-	Passed	0.0270	Passed		
Basinview Drive Elementary	Fountain by 2nd Floor Girls Wash Room	AQVY55	May 14, 2025	-	Passed	0.0086	Passed		
Basinview Drive Elementary	Fountain in Boys Locker Room	AQVY53	May 14, 2025	-	Passed	0.1000	Passed		
Basinview Drive Elementary	Fountain in Girls Locker Room	AQVY52	May 14, 2025	-	Passed	0.0018	Passed		
Basinview Drive Elementary	Fountain in Modular	AQVY54	May 14, 2025	-	Passed	0.0170	Passed		
Basinview Drive Elementary	Gender Neutral Staff Wash Room tap	MSP557	May 27, 2020	0.001	Passed	0.0490	Passed		
Basinview Drive Elementary	Gender Neutral Wash Room 137 tap	MSP516	May 27, 2020	-	Passed	0.0980	Passed		
Basinview Drive Elementary	Girls Locker Room tap 1	MSP540	May 27, 2020	0.002	Passed	0.1600	Passed		
Basinview Drive Elementary	Girls Locker Room tap 2	MSP541	May 27, 2020	0.003	Passed	0.0560	Passed		
Basinview Drive Elementary	Girls Locker Room Wash Room tap	MSP542	May 27, 2020	-	Passed	0.0130	Passed		
Basinview Drive Elementary	Janitors Closet tap by Room 133	MSP515	May 27, 2020	0.001	Passed	0.0900	Passed		
Basinview Drive Elementary	Mechanical Room tap	MSP556	May 27, 2020	-	Passed	0.0061	Passed		
Basinview Drive Elementary	Mechanical Room tap after Room 207	MSP545	May 27, 2020	-	Passed	0.0540	Passed		
Basinview Drive Elementary	Modular Boys Wash Room tap 1	WAT289	June 6, 2023	-	Passed	0.0088	Passed		
Basinview Drive Elementary	Modular Boys Wash Room tap 2	WAT290	June 6, 2023	-	Passed	0.0074	Passed		
Basinview Drive Elementary	Modular Boys Wash Room tap 3	WAT291	June 6, 2023	-	Passed	0.0088	Passed		
Basinview Drive Elementary	Modular Gender Neutral Wash Room tap	WAT293	June 6, 2023	-	Passed	0.0270	Passed		
Basinview Drive Elementary	Modular Girls Wash Room tap 1	WAT242	June 6, 2023	-	Passed	0.0076	Passed		
Basinview Drive Elementary	Modular Girls Wash Room tap 2	WAT243	June 6, 2023	-	Passed	0.0062	Passed		
Basinview Drive Elementary	Modular Girls Wash Room tap 3	WAT286	June 6, 2023	-	Passed	0.0075	Passed		
Basinview Drive Elementary	Modular Girls Wash Room tap 4	WAT287	June 6, 2023	-	Passed	0.0077	Passed		
Basinview Drive Elementary	Modular Girls Wash Room tap 5	WAT288	June 6, 2023	-	Passed	0.0093	Passed		
Basinview Drive Elementary	Modular Staff Room tap	WAT294	June 6, 2023	0.001	Passed	0.0550	Passed		
Basinview Drive Elementary	Music Room tap	MSP535	May 27, 2020	-	Passed	0.0088	Passed		
Basinview Drive Elementary	Staff Room tap	WAT238	June 6, 2023	-	Passed	0.0600	Passed		
Basinview Drive Elementary	Staff Wash Room 1 by Room 139	MSP524	May 27, 2020	-	Passed	0.0590	Passed		
Basinview Drive Elementary	Staff Wash Room 2 by Room 139	MSP525	May 27, 2020	-	Passed	0.0750	Passed		
Bay View High School	1st Floor Girls Wash Room tap 1	MWH990	June 12, 2020	-	Passed	0.2000	Passed		
Bay View High School	1st Floor Girls Wash Room tap 2	MWH991	June 12, 2020	0.001	Passed	0.4100	Passed		
Bay View High School	1st Floor Male Wash Room tap 1	RVX290	February 11, 2022	0.001	Passed	0.1300	Passed		
Bay View High School	1st Floor Male Wash Room tap 2	MWH985	June 12, 2020	0.001	Passed	0.1700	Passed		
Bay View High School	2nd Floor Boys Wash Room tap 1	MUV838	June 8, 2020	0.002	Passed	0.1700	Passed		
Bay View High School	2nd Floor Boys Wash Room tap 2	MUV839	June 8, 2020	0.001	Passed	0.1400	Passed		
Bay View High School	2nd Floor Fountain 1	AQOM98	May 6, 2025	-	Passed	0.0860	Passed		
Bay View High School	2nd Floor Fountain 2	AQOM97	May 6, 2025	-	Passed	0.0850	Passed		
Bay View High School	2nd Floor Girls Wash Room tap 1	MUV836	June 8, 2020	0.003	Passed	0.4700	Passed		
Bay View High School	2nd Floor Girls Wash Room tap 2	RVX289	February 11, 2022	-	Passed	0.0750	Passed		
Bay View High School	2nd Floor Janitors Closet tap	MUV841	June 8, 2020	-	Passed	0.1300	Passed		
Bay View High School	2nd Floor Staff Wash Room tap	MUV840	June 8, 2020	0.003	Passed	0.1300	Passed		
Bay View High School	Admin Wash Room 1040 tap	MWI007	June 12, 2020	0.001	Passed	0.0900	Passed		
Bay View High School	Biology Lab 2068 tap 1	RVO107	February 10, 2022	0.001	Passed	0.1600	Passed		
Bay View High School	Biology Lab 2068 tap 2	MUV869	June 8, 2020	0.001	Passed	0.3200	Passed		
Bay View High School	Biology Lab 2068 tap 3	RVO108	February 10, 2022	0.001	Passed	0.1700	Passed		
Bay View High School	Biology Lab 2068 tap 4	MUV871	June 8, 2020	0.003	Passed	0.4000	Passed		
Bay View High School	Biology Lab 2068 tap 5	MUV872	June 8, 2020	0.003	Passed	0.3000	Passed		
Bay View High School	Boys Locker Room 1032 tap	RVX295	February 11, 2022	-	Passed	0.1300	Passed		
Bay View High School	Boys Wash Room tap 1 by Cafeteria	MWH999	June 12, 2020	0.001	Passed	0.1300	Passed		
Bay View High School	Boys Wash Room tap 2 by Cafeteria	MWI000	June 12, 2020	0.001	Passed	0.1100	Passed		
Bay View High School	Cafeteria Kitchen Prep tap	AQON02	May 6, 2025	-	Passed	0.0510	Passed		
Bay View High School	Cafeteria Kitchen tap 1	AQOM99	May 6, 2025	-	Passed	0.0470	Passed		
Bay View High School	Cafeteria Kitchen tap 2	AQON00	May 6, 2025	-	Passed	0.0500	Passed		
Bay View High School	Cafeteria Kitchen tap 3	AQON01	May 6, 2025	-	Passed	0.0520	Passed		
Bay View High School	Cafeteria Kitchen Wash tap	AQON03	May 6, 2025	-	Passed	0.0500	Passed		
Bay View High School	Chemistry Lab 2062 tap 1	MUV847	June 8, 2020	0.001	Passed	0.2100	Passed		
Bay View High School	Chemistry Lab 2062 tap 10	RVO121	February 10, 2022	0.001	Passed	0.1700	Passed		
Bay View High School	Chemistry Lab 2062 tap 2	MUV848	February 10, 2022	0.002	Passed	0.2100	Passed		
Bay View High School	Chemistry Lab 2062 tap 3	MUV849	June 8, 2020	0.001	Passed	0.2300	Passed		
Bay View High School	Chemistry Lab 2062 tap 4	MUV850	June 8, 2020	0.001	Passed	0.1700	Passed		
Bay View High School	Chemistry Lab 2062 tap 5	RVO118	February 10, 2022	-	Passed	0.1700	Passed		
Bay View High School	Chemistry Lab 2062 tap 6	RVO119	February 10, 2022	0.001	Passed	0.1800	Passed		
Bay View High School	Chemistry Lab 2062 tap 7	MUV853	June 8, 2020	0.002	Passed	0.2100	Passed		
Bay View High School	Chemistry Lab 2062 tap 8	RVO120	February 10, 2022	0.001	Passed	0.2000	Passed		
Bay View High School	Chemistry Lab 2062 tap 9	MUV855	June 8, 2020	0.003	Passed	0.1400	Passed		
Bay View High School	Chemistry Lab 2067 tap 1	RVO122	February 10, 2022	0.001	Passed	0.1900	Passed		
Bay View High School	Chemistry Lab 2067 tap 10	MWG706	June 12, 2020	0.001	Passed	0.2600	Passed		
Bay View High School	Chemistry Lab 2067 tap 2	RVO123	February 10, 2022	0.001	Passed	0.1800	Passed		
Bay View High School	Chemistry Lab 2067 tap 3	MUV860	June 8, 2020	0.005	Passed	0.2600	Passed		
Bay View High School	Chemistry Lab 2067 tap 4	RVO124	February 10, 2022	0.001	Passed	0.2400	Passed		
Bay View High School	Chemistry Lab 2067 tap 5	RVO125	February 10, 2022	0.001	Passed	0.2000	Passed		
Bay View High School	Chemistry Lab 2067 tap 6	MUV863	June 8, 2020	0.004	Passed	0.2000	Passed		
Bay View High School	Chemistry Lab 2067 tap 7	MUV864	June 8, 2020	0.001	Passed	0.4300	Passed		
Bay View High School	Chemistry Lab 2067 tap 8	MWG705	June 12, 2020	0.002	Passed	0.3400	Passed		
Bay View High School	Chemistry Lab 2067 tap 9	RVO126	February 10, 2022	0.001	Passed	0.2000	Passed		
Bay View High School	Chemistry Lab Preparation Room 2064 tap	MUV857	June 8, 2020	0.002	Passed	0.0460	Passed		
Bay View High School	Class Room 1016 tap	RVX292	February 11, 2022	-	Passed	0.1600	Passed		
Bay View High School	Class Room 1109 tap	MWI003	June 12, 2020	0.001	Passed	0.1600	Passed		
Bay View High School	Fountain by Cafeteria	AQON04	May 6, 2025	-	Passed	0.0710	Passed		
Bay View High School	Fountain by Gym	AQON06	May 6, 2025	-	Passed	0.1200	Passed		
Bay View High School	Fountain by Room 1033	AQON05	May 6, 2025	-	Passed	0.1900	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Bay View High School	Physics Lab 2057 tap 3	RVX264	February 11, 2022	0.001	Passed	0.1900	Passed		
Bay View High School	Physics Lab 2057 tap 4	RVX265	February 11, 2022	0.003	Passed	0.3500	Passed		
Bay View High School	Physics Lab 2057 tap 5	MWH972	June 12, 2020	0.002	Passed	0.2000	Passed		
Bay View High School	Science Lab 2056 tap 1	RVO109	February 10, 2022	0.001	Passed	0.1700	Passed		
Bay View High School	Science Lab 2056 tap 2	MUV843	June 8, 2020	0.002	Passed	0.1600	Passed		
Bay View High School	Science Lab 2056 tap 3	RVO110	February 10, 2022	0.005	Passed	0.2100	Passed		
Bay View High School	Science Lab 2056 tap 4	RVO111	February 10, 2022	0.002	Passed	0.2000	Passed		
Bay View High School	Science Lab 2056 tap 5	MUV846	June 8, 2020	0.001	Passed	0.0930	Passed		
Bay View High School	Science Lab 2058 tap 1	RVX268	February 11, 2022	0.001	Passed	0.0830	Passed		
Bay View High School	Science Lab 2058 tap 2	RVX266	February 11, 2022	0.003	Passed	0.2200	Passed		
Bay View High School	Science Lab 2058 tap 3	MWH965	June 12, 2020	0.003	Passed	0.2100	Passed		
Bay View High School	Science Lab 2058 tap 4	RVX267	February 11, 2022	0.005	Exceeded	0.3700	Passed	Laboratory or Hand washing only	
Bay View High School	Science Lab 2058 tap 5	RVX269	February 11, 2022	0.004	Passed	0.2900	Passed		
Bay View High School	Science Lab 2063 tap 1	RVO113	February 10, 2022	0.002	Passed	0.1400	Passed		
Bay View High School	Science Lab 2063 tap 2	RVO114	February 10, 2022	0.003	Passed	0.1400	Passed		
Bay View High School	Science Lab 2063 tap 3	RVO115	February 10, 2022	0.002	Passed	0.1700	Passed		
Bay View High School	Science Lab 2063 tap 4	MWH961	June 12, 2020	0.005	Passed	0.5400	Passed		
Bay View High School	Science Lab 2063 tap 5	RVO116	February 10, 2022	0.006	Exceeded	0.1900	Passed	Laboratory or Hand washing only	
Bay View High School	Science Lab 2066 tap 1	RVX270	February 11, 2022	0.001	Passed	0.1900	Passed		
Bay View High School	Science Lab 2066 tap 2	MWH957	June 12, 2020	0.004	Passed	0.2300	Passed		
Bay View High School	Science Lab 2066 tap 3	RVX271	February 11, 2022	0.003	Passed	0.0700	Passed		
Bay View High School	Science Lab 2066 tap 4	RVX272	February 11, 2022	0.001	Passed	0.1800	Passed		
Bay View High School	Skilled Trades Janitors tap	MWG708	June 12, 2020	0.004	Passed	0.2200	Passed		
Bay View High School	Skilled Trades Wash Room tap	MWG707	June 12, 2020	0.001	Passed	0.2500	Passed		
Bay View High School	Skilled Trades Wash Sink tap	MWG709	June 12, 2020	0.002	Passed	0.3800	Passed		
Bay View High School	Staff Room 1101 tap	AQON07	May 6, 2025	-	Passed	0.0580	Passed		
Bay View High School	Staff Room 1101 Wash Room 1 tap	MWI005	June 12, 2020	0.001	Passed	0.1700	Passed		
Bay View High School	Staff Room 1101 Wash Room 2 tap	MWI006	June 12, 2020	0.002	Passed	0.1800	Passed		
Bay View High School	Staff Wash Room tap	MWH986	June 12, 2020	0.002	Passed	0.1800	Passed		
Bay View High School	Staff Wash Room tap	RVX291	February 11, 2022	-	Passed	0.1400	Passed		
Bay View High School	Tech Ed. 1088 tap	MWI001	June 12, 2020	0.005	Passed	0.3000	Passed		
Bay View High School	Youth Centre Wash Room 1021 tap	MWH983	June 12, 2020	0.002	Passed	0.1700	Passed		
Beaver Bank-Kinsac Elementary	Staff Room Male Wash Room	RWE760	February 15, 2022	0.001	Passed	0.0640	Passed		
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 1 by Room 203	MUQ659	June 4, 2020	0.002	Passed	0.0740	Passed		
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 1 by Room 204	MUQ688	June 4, 2020	0.003	Passed	0.0570	Passed		
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 1 in Basement	MUQ667	June 4, 2020	0.002	Passed	0.0840	Passed		
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 2 by Room 203	RWE755	February 15, 2022	-	Passed	0.0870	Passed		
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 2 by Room 204	MUQ689	June 4, 2020	0.001	Passed	0.0520	Passed		
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 2 in Basement	WDJ082	June 20, 2023	-	Passed	0.0360	Passed	Tap remediated	
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 3 by Room 203	RWE756	February 15, 2022	-	Passed	0.0810	Passed		
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 3 by Room 204	MUQ690	June 4, 2020	0.001	Passed	0.0250	Passed		
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 4 by Room 204	MUQ691	June 4, 2020	0.004	Passed	0.0390	Passed		
Beaver Bank-Kinsac Elementary	Boys Wash Room tap 5 by Room 204	MUQ692	June 4, 2020	0.002	Passed	0.0620	Passed		
Beaver Bank-Kinsac Elementary	Breakfast Club Room tap in Basement	AQUS83	May 13, 2025	-	Passed	0.0290	Passed		
Beaver Bank-Kinsac Elementary	Class Room 202 tap	MUQ674	June 4, 2020	0.001	Passed	0.1700	Passed		
Beaver Bank-Kinsac Elementary	Class Room 203 tap	MUQ675	June 4, 2020	0.003	Passed	0.1900	Passed		
Beaver Bank-Kinsac Elementary	Class Room 217 tap	MUQ680	June 4, 2020	0.002	Passed	0.0410	Passed		
Beaver Bank-Kinsac Elementary	Fountain by Boys Wash Room	AQUS85	May 13, 2025	-	Passed	0.0250	Passed		
Beaver Bank-Kinsac Elementary	Fountain by Janitors Closet	AQUS82	May 13, 2025	-	Passed	0.0340	Passed		
Beaver Bank-Kinsac Elementary	Fountain in Basement by Wash Rooms	AQUS84	May 13, 2025	-	Passed	0.0410	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 1 by Room 201	MUQ664	June 4, 2020	0.003	Passed	0.1800	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 1 by Room 204	RWE762	February 15, 2022	-	Passed	0.0240	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 1 in Basement	RWE758	February 15, 2022	-	Passed	0.0810	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 2 by Room 201	MUQ665	June 4, 2020	0.002	Passed	0.1300	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 2 by Room 204	RWE763	February 15, 2022	-	Passed	0.0240	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 2 in Basement	MUQ671	June 4, 2020	0.004	Passed	0.0860	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 3 by Room 201	MUQ666	June 4, 2020	0.001	Passed	0.0820	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 3 by Room 204	RWE764	February 15, 2022	-	Passed	0.0260	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 4 by Room 204	RWE765	February 15, 2022	-	Passed	0.0240	Passed		
Beaver Bank-Kinsac Elementary	Girls Wash Room tap 5 by Room 204	MUQ686	June 4, 2020	0.004	Passed	0.0650	Passed		
Beaver Bank-Kinsac Elementary	Janitors Closet 204 tap	MUQ687	June 4, 2020	0.002	Passed	0.0240	Passed		
Beaver Bank-Kinsac Elementary	Janitors Closet tap by Boys Wash Room	RWE757	February 15, 2022	-	Passed	0.0220	Passed		
Beaver Bank-Kinsac Elementary	Janitors Closet tap in Basement	MUQ672	June 4, 2020	0.001	Passed	0.0820	Passed		
Beaver Bank-Kinsac Elementary	Main Office Staff Wash Room tap	RWE759	February 15, 2022	-	Passed	0.0750	Passed		
Beaver Bank-Kinsac Elementary	Staff Room Female Wash Room	RWE761	February 15, 2022	-	Passed	0.0580	Passed		
Beaver Bank-Kinsac Elementary	Staff Room tap	AQUS81	May 13, 2025	-	Passed	0.0180	Passed		
Beaver Bank-Kinsac Elementary	Staff Wash Room tap by Room 217	MUQ681	June 4, 2020	0.001	Passed	0.0260	Passed		
Beaver Bank-Monarch Drive Elementary	2nd Floor Boys Wash Room tap 1	RWE853	February 15, 2022	-	Passed	0.0320	Passed		
Beaver Bank-Monarch Drive Elementary	2nd Floor Boys Wash Room tap 2	RWE854	February 15, 2022	-	Passed	0.0330	Passed		
Beaver Bank-Monarch Drive Elementary	2nd Floor Boys Wash Room tap 3	RWE855	February 15, 2022	-	Passed	0.0320	Passed		
Beaver Bank-Monarch Drive Elementary	2nd Floor Girls Wash Room tap 1	MUN107	June 4, 2020	0.003	Passed	0.1900	Passed		
Beaver Bank-Monarch Drive Elementary	2nd Floor Girls Wash Room tap 2	MUN108	June 4, 2020	0.002	Passed	0.4800	Passed		
Beaver Bank-Monarch Drive Elementary	2nd Floor Girls Wash Room tap 3	MUN109	June 4, 2020	0.002	Passed	0.2600	Passed		
Beaver Bank-Monarch Drive Elementary	Art Room 205B tap	RWE852	February 15, 2022	-	Passed	0.0610	Passed		
Beaver Bank-Monarch Drive Elementary	Boys Change Room tap	MUN192	June 4, 2020	0.004	Passed	0.0160	Passed		
Beaver Bank-Monarch Drive Elementary	Boys Wash Room tap 1 by Mechanical Room	WDJ167	June 15, 2023	0.001	Passed	0.0043	Passed	Tap remediated	
Beaver Bank-Monarch Drive Elementary	Boys Wash Room tap 2 by Mechanical Room	WDJ168	June 15, 2023	0.002	Passed	0.0087	Passed	Tap remediated	
Beaver Bank-Monarch Drive Elementary	Boys Wash Room tap 3 by Mechanical Room	WDJ169	June 15, 2023	0.001	Passed	0.0092	Passed	Tap remediated	
Beaver Bank-Monarch Drive Elementary	Canteen Room tap	AQUX55	May 13, 2025	-	Passed	0.0005	Passed		
Beaver Bank-Monarch Drive Elementary	Class Room 101 tap	MUN136	June 4, 2020	0.001	Passed	0.0120	Passed		
Beaver Bank-Monarch Drive Elementary	Class Room 104 tap	MUN137	June 4, 2020	0.002	Passed	0.0052	Passed		
Beaver Bank-Monarch Drive Elementary	Class Room 121 tap	MUN120	June 4, 2020	0.002	Passed	0.0064	Passed		
Beaver Bank-Monarch Drive Elementary	Class Room 122 tap	MUN114	June 4, 2020	0.002	Passed	0.0130	Passed		
Beaver Bank-Monarch Drive Elementary	Class Room 122 Wash Room tap	RWE857	February 15, 2022	0.001	Passed	0.0083	Passed		
Beaver Bank-Monarch Drive Elementary	Class Room 124 Wash Room tap	RWE856	February 15, 2022	0.001	Passed	0.0069	Passed		
Beaver Bank-Monarch Drive Elementary	Class Room tap Room 123	MUN118	June 4, 2020	0.004	Passed	0.0039	Passed		
Beaver Bank-Monarch Drive Elementary	Class Room tap Room 124	MUN117	June 4, 2020	0.001	Passed	0.0280	Passed		
Beaver Bank-Monarch Drive Elementary	Fountain by Girls Wash Room	AQUS59	May 13, 2025	-	Passed	-	Passed		
Beaver Bank-Monarch Drive Elementary	Fountain by Gym	AQUS56	May 13, 2025	-	Passed	0.0036	Passed		
Beaver Bank-Monarch Drive Elementary	Fountain by Machine Shop Room	WDJ165	June 15, 2023	0.001	Passed	0.0051	Passed		
Beaver Bank-Monarch Drive Elementary	Fountain by 106 (new)	AQUS60	May 13, 2025	0.003	Passed	0.0120	Passed		
Beaver Bank-Monarch Drive Elementary	Fountain by Room 123	AQUS58	May 13, 2025	-	Passed	0.0100	Passed		
Beaver Bank-Monarch Drive Elementary	Fountain by Room 224	AQUS57	May 13, 2025	-	Passed	-	Passed		
Beaver Bank-Monarch Drive Elementary	Girls Change Room tap	MUN191	June 4, 2020	0.002	Passed	0.0056	Passed		
Beaver Bank-Monarch Drive Elementary	Girls Wash Room tap 1 by Room 121	RWE861	February 15, 2022	0.003	Passed	0.0180	Passed		
Beaver Bank-Monarch Drive Elementary	Girls Wash Room tap 2 by Room 121	RWE867	February 15, 2022	0.001	Passed	0.0300	Passed		
Beaver Bank-Monarch Drive Elementary	Girls Wash Room tap 3 by Room 121	RWE868	February 15, 2022	0.001	Passed	0.0980	Passed		
Beaver Bank-Monarch Drive Elementary	Janitors Closet 210 tap	MUN113	June 4, 2020	0.001	Passed	0.0200	Passed		
Beaver Bank-Monarch Drive Elementary	Janitors Closet tap by Gym	MUN189	June 4, 2020	0.001	Passed	0.0082	Passed		
Beaver Bank-Monarch Drive Elementary	Library Room tap	KKX231	October 26, 2023	0.001	Passed	0.0250	Passed	Tap remediated	
Beaver Bank-Monarch Drive Elementary	Main Office Sick Room tap	WDJ172	June 15, 2023	-	Passed	0.0014	Passed		
Beaver Bank-Monarch Drive Elementary	Music Room 109 tap	RWE869	February 15, 2022	0.001	Passed	0.0120	Passed		
Beaver Bank-Monarch Drive Elementary	Staff Kitchen tap	AQUX54	May 13, 2025	-	Passed	0.0020	Passed		
Beaver Bank-Monarch Drive Elementary	Staff Room Wash Room 1 tap	MUN139	June 4, 2020	0.001	Passed	0.4300	Passed		
Beaver Bank-Monarch Drive Elementary	Staff Room Wash Room 2 tap	MUN140	June 4, 2020	0.003	Passed	0.4100	Passed		
Bedford South School	Arts Room 1069 tap 1	MYX142	June 25, 2020	-	Passed	0.0240	Passed		
Bedford South School	Arts Room 1069 tap 2	MYX143	June 25, 2020	0.001	Passed	0.0500	Passed		
Bedford South School	Boys Locker Room 1060 tap 1	MYX074	June 25, 2020	0.002	Passed	0.2000	Passed		
Bedford South School	Boys Locker Room 1060 tap 2	VXQ653	May 25, 2023	-	Passed	0.1800	Passed	Tap remediated	
Bedford South School	Boys Wash Room 1043 tap 1	MYX170	June 25, 2020	-	Passed	0.1100	Passed		
Bedford South School	Boys Wash Room 1043 tap 2	MYX171	June 25, 2020	0.001	Passed	0.1100	Passed		
Bedford South School	Boys Wash Room 1043 tap 3	MYX172	June 25, 2020	0.001	Passed	0.1300			

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Bedford South School	Class Room 2027 tap	MYX230	June 25, 2020	0.001	Passed	0.1800	Passed		
	Class Room 2028 tap 1	MYX226	June 25, 2020	0.001	Passed	0.5300	Passed		
	Class Room 2028 tap 2	MYX227	June 25, 2020	0.003	Passed	0.6000	Passed		
	Class Room 2028 tap 3	MYX228	June 25, 2020	0.001	Passed	0.2000	Passed		
	Class Room 2028 tap 4	MYX229	June 25, 2020	0.001	Passed	0.2200	Passed		
	Class Room 2029 tap 1	MYX222	June 25, 2020	0.001	Passed	0.1400	Passed		
	Class Room 2029 tap 2	MYX223	June 25, 2020	0.001	Passed	0.2500	Passed		
	Class Room 2029 tap 3	VXQ658	May 25, 2023	-	Passed	0.0540	Passed	Tap remediated	
	Class Room 2029 tap 4	MYX225	June 25, 2020	0.001	Passed	0.5300	Passed		
	Class Room 2036 tap 1	MYX200	June 25, 2020	0.001	Passed	0.1600	Passed		
	Class Room 2036 tap 2	MYX221	June 25, 2020	0.001	Passed	0.1900	Passed		
	Class Room 2037 tap	MYX199	June 25, 2020	0.001	Passed	0.2700	Passed		
	Class Room 2038 tap	MYX198	June 25, 2020	0.001	Passed	0.6700	Passed		
	Class Room 2039 tap 1	MYX196	June 25, 2020	-	Passed	0.1800	Passed		
	Class Room 2039 tap 2	MYX197	June 25, 2020	0.001	Passed	0.1800	Passed		
	Class Room 2046 tap	MYX292	June 25, 2020	-	Passed	0.1600	Passed		
	Class Room 2047 tap	MYX291	June 25, 2020	-	Passed	0.3700	Passed		
	Class Room 2048 tap	VXQ656	May 25, 2023	-	Passed	0.1300	Passed	Tap remediated	
	Class Room 2049 tap	MYX251	June 25, 2020	0.001	Passed	0.2200	Passed		
	Class Room Wash Room 1029 tap	MYW989	June 25, 2020	0.001	Passed	0.3400	Passed		
	Fountain by Room 1048	AQTU69	May 12, 2025	-	Passed	0.0280	Passed		
	Fountain by Room 1061	AQTU64	May 12, 2025	-	Passed	0.0440	Passed		
	Fountain by Room 2029	AQTU71	May 12, 2025	-	Passed	0.0540	Passed		
	Fountain by Room 2065	Q1TU70	May 12, 2025	-	Passed	0.0100	Passed		
	Fountain in Modular	AQTU72	May 12, 2025	-	Passed	0.0230	Passed		
	Gender Neutral Wash Room 1016 tap	MYW983	June 25, 2020	0.004	Passed	0.2600	Passed		
	Gender Neutral Wash Room 1036 tap	MYX070	June 25, 2020	0.001	Passed	0.1600	Passed		
	Gender Neutral Wash Room 1047 tap	MYX175	June 25, 2020	0.001	Passed	0.2200	Passed		
	Gender Neutral Wash Room 1067 tap	MYX145	June 25, 2020	-	Passed	0.1300	Passed		
	Gender Neutral Wash Room 1068 tap	MYX144	June 25, 2020	0.002	Passed	0.1600	Passed		
	Gender Neutral Wash Room 2065 tap	MYX295	June 25, 2020	0.001	Passed	0.1800	Passed		
	Girls Locker Room 1057 tap 1	MYX076	June 25, 2020	0.004	Passed	0.2500	Passed		
	Girls Locker Room 1057 tap 2	MYX077	June 25, 2020	0.005	Passed	0.3100	Passed		
	Girls Wash Room 1048 tap 1	MYX191	June 25, 2020	0.001	Passed	0.1400	Passed		
	Girls Wash Room 1048 tap 2	MYX192	June 25, 2020	0.003	Passed	0.2900	Passed		
	Girls Wash Room 1048 tap 3	MYX193	June 25, 2020	0.002	Passed	0.2000	Passed		
	Girls Wash Room 1048 tap 4	MYX194	June 25, 2020	0.001	Passed	0.1400	Passed		
	Girls Wash Room 2056 tap 1	VXQ663	May 25, 2023	-	Passed	0.0830	Passed	Tap remediated	
	Girls Wash Room 2056 tap 2	MYX298	June 25, 2020	0.002	Passed	0.2400	Passed		
	Girls Wash Room 2056 tap 3	MYX299	June 25, 2020	0.003	Passed	0.3100	Passed		
Girls Wash Room 2056 tap 4	MYX300	June 25, 2020	0.002	Passed	0.2300	Passed			
Gym Office Wash Room tap	MYX141	June 25, 2020	0.001	Passed	0.2700	Passed			
Health Room tap	VXQ651	May 25, 2023	-	Passed	0.0350	Passed			
Home Ec. Room 2012 tap 1	VXQ664	May 25, 2023	-	Passed	0.0250	Passed			
Home Ec. Room 2012 tap 2	VXQ665	May 25, 2023	-	Passed	0.0280	Passed			
Home Ec. Room 2012 tap 3	VXQ666	May 25, 2023	-	Passed	0.0210	Passed			
Home Ec. Room 2012 tap 4	VXQ667	May 25, 2023	-	Passed	0.0210	Passed			
Janitors Closet 1046 tap	MYX174	June 25, 2020	-	Passed	0.0610	Passed			
Janitors Closet 1066 tap	MYX146	June 25, 2020	-	Passed	0.0940	Passed			
Janitors Closet 2064 tap	MYX294	June 25, 2020	-	Passed	0.0620	Passed			
Library Work Room 1081 tap	MYX169	June 25, 2020	0.001	Passed	0.1700	Passed			
Main Office Wash Room 1081 tap	MYX168	June 25, 2020	-	Passed	0.1100	Passed			
Modular Boys Wash Room tap 1	XCE571	September 21, 2023	-	Passed	0.0220	Passed			
Modular Boys Wash Room tap 2	XCE572	September 21, 2023	-	Passed	0.0280	Passed			
Modular Gender Neutral Wash Room tap	XCE574	September 21, 2023	-	Passed	0.0320	Passed			
Modular Girls Wash Room tap 1	XCE568	September 21, 2023	-	Passed	0.0160	Passed			
Modular Girls Wash Room tap 2	XCE569	September 21, 2023	-	Passed	0.0190	Passed			
Modular Girls Wash Room tap 3	XCE570	September 21, 2023	-	Passed	0.0200	Passed			
Modular Janitors Closet tap	XCE567	September 21, 2023	-	Passed	0.0130	Passed			
Modular Staff Room tap	XCE575	September 21, 2023	0.001	Passed	0.0450	Passed			
Modular Staff Wash Room tap	XCE576	September 21, 2023	-	Passed	0.0340	Passed			
Staff Room 2075 tap	VXQ654	May 25, 2023	-	Passed	0.1100	Passed			
Staff Room Wash Room 2073 tap	MYX248	June 25, 2020	-	Passed	0.0370	Passed			
Staff Room Wash Room 2074 tap	MYX250	June 25, 2020	-	Passed	0.0290	Passed			
Storage Room 1079 tap	MYX147	May 25, 2023	0.004	Passed	0.1500	Passed			
Tech Ed Room 2071 tap	MYX247	June 25, 2020	0.001	Passed	0.2200	Passed			
Beechville-Lakeside-Timberlea Junior Elementary	2nd Floor Janitors Closet tap	TCM850	June 3, 2020	0.005	Passed	0.0400	Passed		
	Art Room 207 tap 1	VR2967	May 2, 2023	-	Passed	0.0260	Passed	Tap remediated	
	Art Room 207 tap 2	VR2968	May 2, 2023	0.001	Passed	0.0450	Passed	Tap remediated	
	Boys Wash Room 109 tap 1	VR2925	May 2, 2023	-	Passed	0.0220	Passed	Tap remediated	
	Boys Wash Room 109 tap 2	VR2926	May 2, 2023	-	Passed	0.0330	Passed	Tap remediated	
	Boys Wash Room 109 tap 3	VR2927	May 2, 2023	0.001	Passed	0.0580	Passed	Tap remediated	
	Boys Wash Room 109 tap 4	VR2928	May 2, 2023	0.001	Passed	0.0800	Passed	Tap remediated	
	Boys Wash Room 216 tap 1	VQU356	April 26, 2023	0.002	Passed	0.0055	Passed		
	Boys Wash Room 216 tap 2	VQU357	April 26, 2023	0.001	Passed	0.0030	Passed		
	Boys Wash Room 216 tap 3	VQU358	April 26, 2023	0.001	Passed	0.0420	Passed		
	Boys Wash Room 216 tap 4	VQU359	April 26, 2023	-	Passed	0.0013	Passed		
	Cafeteria/Kitchen double compartment sink tap	AQU119	May 1, 2025	-	Passed	0.0100	Passed		
	Cafeteria/Kitchen hand washing sink tap	AQU120	May 1, 2025	-	Passed	0.0110	Passed		
	Class Room 101 tap	MUK860	June 3, 2020	0.001	Passed	0.4400	Passed		
	Class Room 102 tap	MUK859	June 3, 2020	0.003	Passed	0.2100	Passed		
	Class Room 104 tap	MUK857	June 3, 2020	0.001	Passed	0.2800	Passed		
	Class Room 110 tap	MUK879	June 3, 2020	0.002	Passed	0.2300	Passed		
	Class Room 111 tap	VR2960	May 2, 2023	0.001	Passed	0.0970	Passed	Tap remediated	
	Class Room 112 tap	KKX002	October 26, 2023	0.001	Passed	0.0180	Passed	Tap remediated	
	Class Room 113 tap	MUK875	June 3, 2020	0.003	Passed	0.1500	Passed		
	Class Room 114 tap	VR2962	May 2, 2023	0.002	Passed	0.1600	Passed	Tap remediated	
	Class Room 116 tap	VR2963	May 2, 2023	0.002	Passed	0.2600	Passed	Tap remediated	
	Fountain by Janitors Closet	AQU123	May 1, 2025	-	Passed	0.0009	Passed		
	Fountain by Room 212	AQU124	May 1, 2025	-	Passed	0.0010	Passed		
	Fountain by Room 216	AQU125	May 1, 2025	-	Passed	0.0011	Passed		
	Fountain by Staff Room	AQU122	May 1, 2025	-	Passed	0.0010	Passed		
	Gender Neutral Wash Room 131 tap	TCM782	July 5, 2022	0.004	Passed	0.0990	Passed		
	Girls Wash Room 107 tap 1	VR2954	May 2, 2023	0.001	Passed	0.0520	Passed	Tap remediated	
	Girls Wash Room 107 tap 2	VR2955	May 2, 2023	-	Passed	0.0230	Passed	Tap remediated	
	Girls Wash Room 107 tap 3	VR2956	May 2, 2023	0.001	Passed	0.0550	Passed	Tap remediated	
	Girls Wash Room 107 tap 4	VR2957	May 2, 2023	0.001	Passed	0.0310	Passed	Tap remediated	
	Girls Wash Room 212 tap 1	VQU352	April 26, 2023	0.001	Passed	0.0049	Passed		
	Girls Wash Room 212 tap 2	VQU353	April 26, 2023	0.001	Passed	0.0031	Passed		
	Girls Wash Room 212 tap 3	VQU354	April 26, 2023	0.002	Passed	0.0033	Passed		
	Girls Wash Room 212 tap 4	VQU354	April 26, 2023	0.002	Passed	0.0550	Passed		
	Gym Gender Neutral Wash Room 1 tap	TCM 786	July 5, 2022	0.002	Passed	0.1400	Passed		
	Gym Gender Neutral Wash Room 2 tap	TCM788	July 5, 2022	0.003	Passed	0.1400	Passed		
	Gym Office Wash Room tap	KKX001	October 26, 2023	0.001	Passed	0.0970	Passed	Tap remediated	
	Janitors Closet tap by Room 131	TCM783	July 5, 2022	-	Passed	0.0230	Passed		
	Music Room 108 tap	TCM785	July 5, 2022	0.002	Passed	0.0830	Passed		
	Room 100 Gender Neutral Wash Room tap	VR2958	May 2, 2023	-	Passed	0.0460	Passed	Tap remediated	
	Room 105 Kitchen tap	VR2959	May 2, 2023	0.001	Passed	0.0200	Passed	Tap remediated	
	Room 132 Gender Neutral Wash Room tap	VR2964	May 2, 2023	0.003	Passed	0.0420	Passed	Tap remediated	
	Room 133 Gender Neutral Wash Room tap	VR2966	May 2, 2023	-	Passed	0.0420	Passed	Tap remediated	
	Staff Room Gender Neutral Wash Room 1 tap	MUK854	June 3, 2020	0.001	Passed	0.0370	Passed		
	Staff Room Gender Neutral Wash Room 2 tap	MUK855	June 3, 2020	0.002	Passed	0.0420	Passed		
	Staff Room Kitchen tap	AQU121	May 1, 2025	-	Passed	0.0096	Passed	Tap remediated	
	1st Floor Janitors Closet tap	TCM774	July 5, 2022	0.001	Passed	0.1000	Passed		
	Art Room multi tap sink tap 1	TCM770	July 5, 2022	0.001	Passed	0.0620	Passed		
	Art Room multi tap sink tap 2	TCM771	July 5, 2022	0.001	Passed	0.0590	Passed		
Art Room multi tap sink tap 3	TCM772	July 5, 2022	0.001	Passed	0.0760	Passed			
Art Room multi tap sink tap 4	TCM773	July 5, 2022	0.001	Passed	0.0660	Passed			
Boys Change Room tap 1	VQU718	April 26, 2023	-	Passed	0.0630	Passed	Tap remediated		
Boys Change Room tap 2	TCM763	July 5, 2022	0.001	Passed	0.0640	Passed			
Boys Wash Room tap 1 by Library	TCM746	July 5, 2022	0.001	Passed	0.0600	Passed			
Boys Wash Room tap 2 by Library	TCM747	July 5, 2022	0.001	Passed	0.0580	Passed			
Boys Wash Room tap 3 by Library	TCM748	July 5, 2022	-	Passed	0.0450	Passed			
Cafeteria/Kitchen double compartment sink tap	VQU717	April 26, 2023	-	Passed	0.0150	Passed			
Cafeteria/Kitchen hand washing sink tap	AQLH87	May 1, 2025	-	Passed	0.0140	Passed	Tap remediated		
Cafeteria/Kitchen sink tap	AQLH								

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Beechville-Lakeside-Timberlea Senior Elementary	Girls Wash Room tap 1 by Room 203	TCM751	July 5, 2022	0.002	Passed	0.0670	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Girls Wash Room tap 2 by Room 203	TCM752	July 5, 2022	0.000	Passed	0.0630	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Girls Wash Room tap 3 by Room 203	TCM753	July 5, 2022	0.001	Passed	0.0580	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Girls Wash Room tap 4 by Room 203	TCM754	July 5, 2022	0.001	Passed	0.0530	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Janitors Closet tap by Library	TCM749	July 5, 2022	0.001	Passed	0.0450	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Metal Room sink tap	TCM769	July 5, 2022	-	Passed	0.1800	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Modular Accessible Wash Room tap	VQU727	April 26, 2023	-	Passed	0.0100	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Modular Boys Wash Room tap 1	VQU723	April 26, 2023	-	Passed	0.0100	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Modular Boys Wash Room tap 2	VQU724	April 26, 2023	-	Passed	0.0100	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Modular Girls Wash Room tap 1	VQU725	April 26, 2023	-	Passed	0.0110	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Modular Girls Wash Room tap 2	VQU726	April 26, 2023	-	Passed	0.0100	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Modular Staff Room tap	AQLH92	May 1, 2025	-	Passed	0.0130	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Modular Staff Room Wash Room tap	VQU722	April 26, 2023	-	Passed	0.0110	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Sewing Room tap	VQU711	April 26, 2023	0.002	Passed	0.1900	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Female Wash Room tap 1	TCM743	July 5, 2022	-	Passed	0.0170	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Female Wash Room tap 1	TCM743	July 5, 2022	-	Passed	0.0170	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Female Wash Room tap 2	TCM744	July 5, 2022	0.001	Passed	0.0180	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Female Wash Room tap 2	TCM744	July 5, 2022	0.001	Passed	0.0180	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Kitchen tap	ZLK600	June 13, 2024	-	Passed	0.0096	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Male Wash Room tap	TCM745	July 5, 2022	-	Passed	0.0140	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room Male Wash Room tap	TCM745	July 5, 2022	-	Passed	0.0140	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Room tap	AQLH89	May 1, 2025	-	Passed	0.0075	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Wash Room tap by Room 104	TCM766	July 5, 2022	-	Passed	0.0190	Passed		
Beechville-Lakeside-Timberlea Senior Elementary	Staff Wash Room tap by Room 105	TCM765	July 5, 2022	-	Passed	0.0220	Passed		
Bel Ayr Elementary	Boys Wash Room tap 1 by Room 122	XGE445	October 11, 2023	0.005	Exceeded	0.0190	Passed	Hand washing only	
Bel Ayr Elementary	Boys Wash Room tap 1 by Room 124	XGE440	October 11, 2023	-	Passed	0.0150	Passed	Tap remediated	
Bel Ayr Elementary	Boys Wash Room tap 2 by Room 122	MXJ940	June 18, 2020	0.002	Passed	0.0620	Passed		
Bel Ayr Elementary	Boys Wash Room tap 2 by Room 124	XGE441	October 11, 2023	-	Passed	0.0123	Passed	Tap remediated	
Bel Ayr Elementary	Boys Wash Room tap 3 by Room 122	MXJ941	June 18, 2020	0.001	Passed	0.0510	Passed		
Bel Ayr Elementary	Boys Wash Room tap 3 by Room 124	MXJ931	June 18, 2020	0.002	Passed	0.0570	Passed		
Bel Ayr Elementary	Fountain by Room 112	ARWG75	June 12, 2025	0.001	Passed	0.0510	Passed		
Bel Ayr Elementary	Fountain by Room 123	ARWG77	June 12, 2025	-	Passed	0.1000	Passed		
Bel Ayr Elementary	Girls Wash Room tap 1 by Room 122	MXJ937	June 18, 2020	0.001	Passed	0.3200	Passed		
Bel Ayr Elementary	Girls Wash Room tap 1 by Room 124	MXJ933	June 18, 2020	0.003	Passed	0.0840	Passed		
Bel Ayr Elementary	Girls Wash Room tap 2 by Room 122	MXJ938	June 18, 2020	-	Passed	0.0510	Passed		
Bel Ayr Elementary	Girls Wash Room tap 2 by Room 124	XGE442	October 11, 2023	-	Passed	0.0180	Passed	Tap remediated	
Bel Ayr Elementary	Girls Wash Room tap 3 by Room 124	MXJ935	June 18, 2020	0.003	Passed	0.0410	Passed		
Bel Ayr Elementary	Gym Storage Room tap	XGE450	October 11, 2023	0.012	Exceeded	0.0170	Passed	Hand washing only	
Bel Ayr Elementary	Janitors Closet 123 tap	MXJ944	June 18, 2020	0.002	Passed	0.1100	Passed		
Bel Ayr Elementary	Janitors Closet 124 tap	XGE439	October 11, 2023	-	Passed	0.0120	Passed	Tap remediated	
Bel Ayr Elementary	Learning Centre Wash Room tap	MXJ936	June 18, 2020	0.001	Passed	0.0540	Passed		
Bel Ayr Elementary	Main Office 118 tap 1	ARWG73	June 12, 2025	-	Passed	0.0160	Passed		
Bel Ayr Elementary	Main Office 118 tap 2	ARWG74	June 12, 2025	-	Passed	0.0140	Passed		
Bel Ayr Elementary	Staff Room 120 tap	ARWG76	June 12, 2025	-	Passed	0.0100	Passed		
Bel Ayr Elementary	Staff Room 120 Wash Room 1 tap	XGE449	October 11, 2023	-	Passed	0.0200	Passed	Tap remediated	
Bel Ayr Elementary	Staff Room 120 Wash Room 2 tap	MXJ927	June 18, 2020	0.001	Passed	0.0590	Passed		
Bell Park Academic Centre	Boys Wash Room tap 1 by Office	XCZ737	September 26, 2023	-	Passed	0.0380	Passed		
Bell Park Academic Centre	Boys Wash Room tap 1 by Room 205	XCZ710	September 26, 2023	-	Passed	0.0290	Passed		
Bell Park Academic Centre	Boys Wash Room tap 2 by Office	XCZ738	September 26, 2023	-	Passed	0.0300	Passed		
Bell Park Academic Centre	Boys Wash Room tap 2 by Room 205	XCZ711	September 26, 2023	-	Passed	0.0280	Passed		
Bell Park Academic Centre	Boys Wash Room tap 3 by Room 205	XCZ712	September 26, 2023	-	Passed	0.0310	Passed		
Bell Park Academic Centre	Class Room 101 tap	MYA913	June 22, 2020	0.003	Passed	0.1800	Passed		
Bell Park Academic Centre	Class Room 101 Wash Room tap	XCZ743	September 26, 2023	-	Passed	0.0430	Passed		
Bell Park Academic Centre	Class Room 102 tap	MYA915	June 22, 2020	0.001	Passed	0.4500	Passed		
Bell Park Academic Centre	Class Room 102 Wash Room tap	MYA916	June 22, 2020	0.001	Passed	0.1700	Passed		
Bell Park Academic Centre	Class Room 103 Wash Room tap	XCZ744	September 26, 2023	-	Passed	0.1000	Passed		
Bell Park Academic Centre	Class Room 216 tap	RWW641	February 17, 2022	-	Passed	0.0310	Passed		
Bell Park Academic Centre	Fountain by Room 101	ARTT53	June 10, 2025	-	Passed	0.0009	Passed		
Bell Park Academic Centre	Fountain by Room 105	ARTT57	June 10, 2025	-	Passed	0.0008	Passed		
Bell Park Academic Centre	Fountain by Room 201 (formerly 208)	ARTT55	June 10, 2025	-	Passed	0.0019	Passed		
Bell Park Academic Centre	Fountain by Room 206	ARTT56	June 10, 2025	-	Passed	0.0007	Passed		
Bell Park Academic Centre	Girls Wash Room tap 1 by Office	XCZ739	September 26, 2023	-	Passed	0.0340	Passed		
Bell Park Academic Centre	Girls Wash Room tap 1 by Room 206	MYA899	June 22, 2020	0.002	Passed	0.0650	Passed		
Bell Park Academic Centre	Girls Wash Room tap 2 by Office	XCZ740	September 26, 2023	-	Passed	0.0490	Passed		
Bell Park Academic Centre	Girls Wash Room tap 2 by Room 206	MYA900	June 22, 2020	0.003	Passed	0.1400	Passed		
Bell Park Academic Centre	Girls Wash Room tap 3 by Office	XCZ741	September 26, 2023	-	Passed	0.0310	Passed		
Bell Park Academic Centre	Girls Wash Room tap 3 by Room 206	XCZ709	September 26, 2023	-	Passed	0.0320	Passed		
Bell Park Academic Centre	Janitors Closet 203	MYA912	June 22, 2020	0.001	Passed	0.1300	Passed		
Bell Park Academic Centre	Janitors Closet tap by Boys Wash Room	MYH202	June 23, 2020	0.001	Passed	0.0450	Passed		
Bell Park Academic Centre	Kitchen/Cafeteria hand washing tap	ARTT58	June 10, 2025	-	Passed	0.0290	Passed		
Bell Park Academic Centre	Kitchen/Cafeteria triple compartment tap 1	ARTT59	June 10, 2025	-	Passed	0.0230	Passed		
Bell Park Academic Centre	Kitchen/Cafeteria triple compartment tap 2	ARTT60	June 10, 2025	-	Passed	0.0230	Passed		
Bell Park Academic Centre	Main Office tap	XCZ705	September 26, 2023	-	Passed	0.0480	Passed		
Bell Park Academic Centre	Staff Room 218 Female Wash Room tap	MYA897	June 22, 2020	0.002	Passed	0.2300	Passed		
Bell Park Academic Centre	Staff Room 218 Male Wash Room tap	MYA896	June 22, 2020	0.004	Passed	0.3200	Passed		
Bell Park Academic Centre	Staff Room 218 tap	ARTT54	June 10, 2025	-	Passed	0.0240	Passed		
Bell Park Academic Centre	Staff Wash Room tap by Office	MYH195	June 23, 2020	0.001	Passed	0.1000	Passed		
BFEC - BPM	Class Room 124 tap	NZB932	October 22, 2020	-	Passed	0.0310	Passed		
BFEC - BPM	Food Lab 136 tap 1	ARCW40	May 22, 2025	-	Passed	0.0140	Passed		
BFEC - BPM	Food Lab 136 tap 2	ARCW41	May 22, 2025	-	Passed	0.0130	Passed		
BFEC - BPM	Food Lab 136 tap 3	ARCW42	May 22, 2025	-	Passed	0.0160	Passed		
BFEC - BPM	Food Lab 136 tap 4	ARCW43	May 22, 2025	-	Passed	0.0140	Passed		
BFEC - BPM	Fountain by Wash Rooms	ARCW44	May 22, 2025	-	Passed	0.0330	Passed		
BFEC - BPM	Gender Neutral Wash Room 107 tap	NZB942	October 22, 2020	0.001	Passed	0.0510	Passed		
BFEC - BPM	Gender Neutral Wash Room 138 tap	OCN147	November 5, 2020	0.003	Passed	0.0890	Passed		
BFEC - BPM	Gender Neutral Wash Room 139 tap	OAM002	October 29, 2020	0.005	Passed	0.1700	Passed		
BFEC - BPM	Gender Neutral Wash Room 140 tap	OCN148	November 5, 2020	0.002	Passed	0.0840	Passed		
BFEC - BPM	Gender Neutral Wash Room 141 tap	OAM000	October 29, 2020	0.005	Passed	0.1600	Passed		
BFEC - BPM	Gender Neutral Wash Room 142 tap	OAM999	October 29, 2020	0.005	Passed	0.1700	Passed		
BFEC - BPM	Gender Neutral Wash Room 143 tap	OAM998	October 29, 2020	0.005	Passed	0.1700	Passed		
BFEC - BPM	Gender Neutral Wash Room 144 tap	NZB927	October 22, 2020	0.001	Passed	0.0450	Passed		
BFEC - BPM	Janitors Closet 137 tap	NZB931	October 22, 2020	-	Passed	0.0180	Passed		
BFEC - BPM	Staff Room 109 tap	ARCW45	May 22, 2025	-	Passed	0.0210	Passed		
BFEC - BPM	Staff Wash Room 110 tap	NZB940	October 22, 2020	0.001	Passed	0.0480	Passed		
BFEC - BPM	Staff Wash Room 111 tap	NZB941	October 22, 2020	0.001	Passed	0.0470	Passed		
BFEC - Dartmouth	1st Floor Boys Wash Room tap 1	SVW026	June 8, 2022	0.005	Exceeded	0.0490	Passed	Hand washing only	
BFEC - Dartmouth	1st Floor Boys Wash Room tap 2	SVW027	June 8, 2022	0.008	Exceeded	0.0570	Passed	Hand washing only	
BFEC - Dartmouth	1st Floor Boys Wash Room tap 3	WHX466	July 6, 2023	0.015	Exceeded	0.1600	Passed	Hand washing only	
BFEC - Dartmouth	1st Floor Boys Wash Room tap 4	WHX467	July 6, 2023	0.010	Exceeded	0.1100	Passed	Hand washing only	
BFEC - Dartmouth	1st Floor Fountain by Janitors Room	AROK50	June 4, 2025	0.001	Passed	0.0550	Passed		
BFEC - Dartmouth	1st Floor Girls Wash Room tap 1	WHX463	July 6, 2023	0.020	Exceeded	0.7900	Passed	Hand washing only	
BFEC - Dartmouth	1st Floor Girls Wash Room tap 2	SVW005	June 8, 2022	0.017	Exceeded	0.5300	Passed	Hand washing only	
BFEC - Dartmouth	1st Floor Girls Wash Room tap 3	WHX464	July 6, 2023	0.022	Exceeded	0.8900	Passed	Hand washing only	
BFEC - Dartmouth	1st Floor Girls Wash Room tap 4	WHX465	July 6, 2023	0.030	Exceeded	0.4500	Passed	Hand washing only	
BFEC - Dartmouth	1st Floor Janitors Closet tap	SVW003	June 8, 2022	-	Passed	0.0180	Passed		
BFEC - Dartmouth	2nd Floor Boys Wash Room tap 1	SVW015	June 8, 2022	0.027	Exceeded	0.1100	Passed	Hand washing only	
BFEC - Dartmouth	2nd Floor Boys Wash Room tap 2	SVW016	June 8, 2022	0.020	Exceeded	0.0770	Passed	Hand washing only	
BFEC - Dartmouth	2nd Floor Boys Wash Room tap 3	SVW017	June 8, 2022	0.024	Exceeded	0.0890	Passed	Hand washing only	
BFEC - Dartmouth	2nd Floor Boys Wash Room tap 4	SVW018	June 8, 2022	0.025	Exceeded	0.0980	Passed	Hand washing only	
BFEC - Dartmouth	2nd Floor Fountain By Wash Rooms	AROK51	June 4, 2025	-	Passed	0.0047	Passed		
BFEC - Dartmouth	2nd Floor Girls Wash Room tap 1	SVW021	June 8, 2022	0.094	Exceeded	0.5100	Passed	Hand washing only	
BFEC - Dartmouth	2nd Floor Girls Wash Room tap 2	WHX470	July 6, 2023	0.001	Passed	0			

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Bicentennial School	Boys Wash Room tap 4 by Library	MYR718	June 24, 2020	-	Passed	0.0310	Passed		
Bicentennial School	Boys Wash Room tap 4 by Room 30	MYR780	June 24, 2020	0.001	Passed	0.0800	Passed		
Bicentennial School	Boys Wash Room tap 5 by Library	MYR719	June 24, 2020	-	Passed	0.0320	Passed		
Bicentennial School	Boys Wash Room tap 6 by Library	MYR720	June 24, 2020	0.001	Passed	0.0360	Passed		
Bicentennial School	Boys Wash Room tap 7 by Library	MYR721	June 24, 2020	0.001	Passed	0.0310	Passed		
Bicentennial School	Boys Wash Room tap 8 by Library	MYR722	June 24, 2020	0.001	Passed	0.0350	Passed		
Bicentennial School	Class Room 29 tap	MYR772	June 24, 2020	0.002	Passed	0.1700	Passed		
Bicentennial School	Class Room 30 tap	XBG927	September 15, 2023	-	Passed	0.0300	Passed	Tap remediated	
Bicentennial School	Excel Room tap by Room 31	ARHL76	May 28, 2025	-	Passed	0.0070	Passed		
Bicentennial School	Fountain by Gym	ARHL77	May 28, 2025	-	Passed	0.0011	Passed	Same as Fountain by Staff room	
Bicentennial School	Fountain by Gym Office	ARHL72	May 28, 2025	-	Passed	0.0430	Passed		
Bicentennial School	Fountain by Library	ARHL73	May 28, 2025	-	Passed	0.0140	Passed		
Bicentennial School	Fountain by Room 29	ARHL74	May 28, 2025	-	Passed	0.0520	Passed		
Bicentennial School	Fountain by Room 31	ARHL75	May 28, 2025	-	Passed	0.0012	Passed		
Bicentennial School	Fountain by Staff Room	NMK042	August 28, 2020	0.002	Passed	0.0960	Passed	Same as Fountain by Gym	
Bicentennial School	Gender Neutral Wash Room tap by Boys Wash Room	MYR782	June 24, 2020	0.001	Passed	0.1300	Passed		
Bicentennial School	Gender Neutral Wash Room tap by Room 29	MYR781	June 24, 2020	0.001	Passed	0.0280	Passed		
Bicentennial School	Girls Wash Room tap 1 by Library	XBG941	September 15, 2023	0.001	Passed	0.0510	Passed	Tap remediated	
Bicentennial School	Girls Wash Room tap 1 by Room 29	XBG930	September 15, 2023	0.001	Passed	0.1300	Passed	Tap remediated	
Bicentennial School	Girls Wash Room tap 2 by Library	MYR727	June 24, 2020	0.002	Passed	0.0580	Passed		
Bicentennial School	Girls Wash Room tap 2 by Room 29	XBG931	September 15, 2023	0.005	Exceeded	0.2700	Passed	Hand washing only	
Bicentennial School	Girls Wash Room tap 3 by Library	MYR728	June 24, 2020	0.001	Passed	0.0310	Passed		
Bicentennial School	Girls Wash Room tap 3 by Room 29	MYR785	June 24, 2020	0.002	Passed	0.2100	Passed		
Bicentennial School	Girls Wash Room tap 4 by Library	MYR729	June 24, 2020	-	Passed	0.0240	Passed		
Bicentennial School	Girls Wash Room tap 4 by Room 29	XBG932	September 15, 2023	0.001	Passed	0.0650	Passed	Tap remediated	
Bicentennial School	Girls Wash Room tap 5 by Library	MYR730	June 24, 2020	-	Passed	0.0220	Passed		
Bicentennial School	Girls Wash Room tap 6 by Library	MYR731	June 24, 2020	-	Passed	0.0190	Passed		
Bicentennial School	Girls Wash Room tap 7 by Library	MYR732	June 24, 2020	-	Passed	0.0160	Passed		
Bicentennial School	Girls Wash Room tap 8 by Library	MYR733	June 24, 2020	-	Passed	0.0200	Passed		
Bicentennial School	Gym Office Wash Room tap	XBG928	September 15, 2023	0.021	Exceeded	0.1800	Passed	Hand washing only	
Bicentennial School	Janitors Closet tap by Class Room 2	MYR737	June 24, 2020	-	Passed	0.0170	Passed		
Bicentennial School	Janitors Closet tap by Room 18	MYR714	June 24, 2020	0.001	Passed	0.0330	Passed		
Bicentennial School	Janitors Closet tap by Room 29	MYR771	June 24, 2020	0.001	Passed	0.0370	Passed		
Bicentennial School	Janitors Closet tap by Room 9	MYR747	June 24, 2020	0.001	Passed	0.0610	Passed		
Bicentennial School	Learning Centre Wash Room 1 tap	MYR735	June 24, 2020	0.002	Passed	0.3700	Passed		
Bicentennial School	Learning Centre Wash Room 2 tap	MYR736	June 24, 2020	0.002	Passed	0.3200	Passed		
Bicentennial School	Office Wash Room 04 tap	MYR713	June 24, 2020	0.006	Exceeded	0.0520	Passed	Hand washing only	
Bicentennial School	Principle Office Wash Room tap	MYR712	June 24, 2020	0.004	Passed	0.2300	Passed		
Bicentennial School	Science Lab tap 1 Room 27	MYR752	June 24, 2020	0.180	Exceeded	0.7400	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 10 Room 27	MYR761	June 24, 2020	0.009	Exceeded	0.2600	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 11 Room 27	MYR762	June 24, 2020	0.014	Exceeded	0.3100	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 12 Room 27	MYR763	June 24, 2020	0.007	Exceeded	0.1900	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 13 Room 27	MYR764	June 24, 2020	0.004	Passed	0.1300	Passed		
Bicentennial School	Science Lab tap 14 Room 27	MYR765	June 24, 2020	0.004	Passed	0.1200	Passed		
Bicentennial School	Science Lab tap 15 Room 27	MYR766	June 24, 2020	0.007	Exceeded	0.2400	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 16 Room 27	MYR767	June 24, 2020	0.013	Exceeded	0.2700	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 17 Room 27	MYR768	June 24, 2020	0.005	Passed	0.1400	Passed		
Bicentennial School	Science Lab tap 18 Room 27	MYR769	June 24, 2020	0.002	Passed	0.1000	Passed		
Bicentennial School	Science Lab tap 19 Room 27	MYR770	June 24, 2020	0.008	Exceeded	0.2100	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 2 Room 27	MYR753	June 24, 2020	0.074	Exceeded	1.0000	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 3 Room 27	MYR754	June 24, 2020	0.120	Exceeded	1.1000	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 4 Room 27	MYR755	June 24, 2020	0.052	Exceeded	1.0000	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 5 Room 27	MYR756	June 24, 2020	0.023	Exceeded	0.8500	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 6 Room 27	MYR757	June 24, 2020	0.035	Exceeded	0.9800	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 7 Room 27	MYR758	June 24, 2020	0.079	Exceeded	1.3000	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 8 Room 27	MYR759	June 24, 2020	0.073	Exceeded	0.7100	Passed	Laboratory or Hand washing only	
Bicentennial School	Science Lab tap 9 Room 27	MYR760	June 24, 2020	0.008	Exceeded	0.2400	Passed	Laboratory or Hand washing only	
Bicentennial School	Staff Gender Neutral Wash Room tap by Library	MYR723	June 24, 2020	0.002	Passed	0.0610	Passed		
Bicentennial School	Staff Gender Neutral Wash Room tap by Library	MYR725	June 24, 2020	0.001	Passed	0.0500	Passed		
Bicentennial School	Staff Room tap	ARHL78	May 28, 2025	-	Passed	0.0320	Passed		
Bicentennial School	Tech Ed sink tap	MYR774	June 24, 2020	0.002	Passed	0.0670	Passed		
Brookhouse Elementary	Boys Wash Room 125 tap 1	XKA753	October 25, 2023	-	Passed	0.0200	Passed	Tap remediated	
Brookhouse Elementary	Boys Wash Room 125 tap 2	XKA754	October 25, 2023	-	Passed	0.0180	Passed	Tap remediated	
Brookhouse Elementary	Boys Wash Room 125 tap 3	XKA755	October 25, 2023	-	Passed	0.0300	Passed	Tap remediated	
Brookhouse Elementary	Boys Wash Room 134 tap 1	XKA765	October 25, 2023	-	Passed	0.0400	Passed	Tap remediated	
Brookhouse Elementary	Boys Wash Room 134 tap 2	MWI340	June 15, 2020	0.005	Passed	0.1800	Passed		
Brookhouse Elementary	Boys Wash Room 134 tap 3	MWI341	June 15, 2020	0.002	Passed	0.0590	Passed		
Brookhouse Elementary	Boys Wash Room tap 1 by Room 127	MWI344	June 15, 2020	0.003	Passed	0.0500	Passed		
Brookhouse Elementary	Boys Wash Room tap 2 by Room 127	MWI345	June 15, 2020	0.003	Passed	0.0420	Passed		
Brookhouse Elementary	Boys Wash Room tap 3 by Room 127	MWI348	June 15, 2020	0.002	Passed	0.0280	Passed		
Brookhouse Elementary	Fountain by Room 105	ARHL07	May 28, 2025	-	Passed	0.2300	Passed		
Brookhouse Elementary	Fountain by Room 118	ARHL11	May 28, 2025	-	Passed	0.0750	Passed		
Brookhouse Elementary	Fountain by Room 125	ARHL10	May 28, 2025	-	Passed	0.0130	Passed		
Brookhouse Elementary	Fountain by Room 136	ARHL08	May 28, 2025	0.001	Passed	0.0300	Passed		
Brookhouse Elementary	Fountain by Room 205	ARHL09	May 28, 2025	-	Passed	0.0130	Passed		
Brookhouse Elementary	Girls Wash Room 112 tap 1	MWI353	June 15, 2020	0.002	Passed	0.0300	Passed		
Brookhouse Elementary	Girls Wash Room 112 tap 2	MWI354	June 15, 2020	0.001	Passed	0.0180	Passed		
Brookhouse Elementary	Girls Wash Room 112 tap 3	MWI355	June 15, 2020	0.001	Passed	0.0130	Passed		
Brookhouse Elementary	Girls Wash Room 112 tap 4	MWI356	June 15, 2020	0.001	Passed	0.0130	Passed		
Brookhouse Elementary	Girls Wash Room 208 tap 1	XKA761	October 25, 2023	0.003	Passed	0.0490	Passed	Tap remediated	
Brookhouse Elementary	Girls Wash Room 208 tap 2	XKA762	October 25, 2023	0.003	Passed	0.0470	Passed	Tap remediated	
Brookhouse Elementary	Girls Wash Room 208 tap 3	XKA763	October 25, 2023	0.001	Passed	0.0350	Passed	Tap remediated	
Brookhouse Elementary	Girls Wash Room 208 tap 4	XKA764	October 25, 2023	-	Passed	0.0310	Passed	Tap remediated	
Brookhouse Elementary	Gym Office Wash Room tap	XKA757	October 25, 2023	-	Passed	0.0120	Passed	Tap remediated	
Brookhouse Elementary	Janitors Closet 136 tap	MWI338	June 15, 2020	0.001	Passed	0.0400	Passed		
Brookhouse Elementary	Janitors Closet tap by Room 127	MWI349	June 15, 2020	0.004	Passed	0.0370	Passed		
Brookhouse Elementary	Janitors Closet tap by Room 205	MWI331	June 15, 2020	0.001	Passed	0.0330	Passed		
Brookhouse Elementary	Learning Centre Wash Room tap	XKA759	October 25, 2023	-	Passed	0.0470	Passed	Tap remediated	
Brookhouse Elementary	Office Room 115 tap	XKA751	October 25, 2023	-	Passed	0.0180	Passed		
Brookhouse Elementary	Principal's Office Wash Room 116 tap	MWI395	June 15, 2020	0.003	Passed	0.0830	Passed		
Brookhouse Elementary	Staff Room 111 Kitchen tap	ARHL06	May 28, 2025	-	Passed	0.0029	Passed		
Brookhouse Elementary	Staff Room 111 Wash Room 1 tap	XKA750	October 25, 2023	-	Passed	0.0120	Passed	Tap remediated	
Brookhouse Elementary	Staff Room 111 Wash Room 2 tap	MWI328	June 15, 2020	-	Passed	0.0210	Passed		
Brookhouse Elementary	Staff Wash Room 204 tap	MWI336	June 15, 2020	0.002	Passed	0.4700	Passed		
Brookside Junior High School	2nd Floor Boys Wash Room tap 1	TBH521	June 30, 2022	0.004	Passed	0.5400	Passed		
Brookside Junior High School	2nd Floor Boys Wash Room tap 2	TBH522	June 30, 2022	0.002	Passed	0.4900	Passed		
Brookside Junior High School	2nd Floor Boys Wash Room tap 3	TBH523	June 30, 2022	0.002	Passed	0.5200	Passed		
Brookside Junior High School	2nd Floor Female Staff Room tap 1	VXD739	May 24, 2023	0.001	Passed	0.4100	Passed	Tap remediated	
Brookside Junior High School	2nd Floor Female Staff Room tap 2	VXD740	May 24, 2023	0.001	Passed	0.3900	Passed	Tap remediated	
Brookside Junior High School	2nd Floor Girls Wash Room tap 1	TBH517	June 30, 2022	0.002	Passed	0.5500	Passed		
Brookside Junior High School	2nd Floor Girls Wash Room tap 2	TBH518	June 30, 2022	0.002	Passed	0.5600	Passed		
Brookside Junior High School	2nd Floor Girls Wash Room tap 3	TBH519	June 30, 2022	0.001	Passed	0.5600	Passed		
Brookside Junior High School	2nd Floor Janitors Closet tap	TBH520	June 30, 2022	0.001	Passed	0.4900	Passed		
Brookside Junior High School	2nd Floor Male Staff Wash Room tap	TBH514	June 30, 2022	0.002	Passed	0.5600	Passed		
Brookside Junior High School	Boiler Room tap	TBH507	June 30, 2022	0.001	Passed	0.4800	Passed		
Brookside Junior High School	Boys Wash Room tap 1	TBH498	June 30, 2022	0.002	Passed	0.5300	Passed		
Brookside Junior High School	Boys Wash Room tap 2	TBH499	June 30, 2022	0.004	Passed	0.5600	Passed		
Brookside Junior High School	Boys Wash Room tap 3	VXD735	May 24, 2023	0.015	Exceeded	0.6200	Passed	Hand washing only	
Brookside Junior High School	Class Room 215 tap 1	VXD699	May 24, 2023	0.001	Passed	0.3000	Passed		
Brookside Junior High School	Class Room 215 tap 2	VXD700	May 24, 2023	0.001	Passed	0.3000	Passed	Tap remediated	
Brookside Junior High School	Class Room 215 tap 3	VXD701	May 24, 2023	0.001	Passed</				

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Burton Ettinger Elementary	Boys Wash Room tap 2 by Room 108	VVU930	May 17, 2023	-	Passed	0.0590	Passed	Tap remediated	
Burton Ettinger Elementary	Boys Wash Room tap 3 by Room 108	MRX372	May 25, 2020	0.002	Passed	0.1200	Passed		
Burton Ettinger Elementary	Class Room 218 tap	MRX345	May 25, 2020	0.003	Passed	0.0540	Passed		
Burton Ettinger Elementary	Class Room 220 tap	VVU934	May 17, 2023	-	Passed	0.0780	Passed	Tap remediated	
Burton Ettinger Elementary	Class Room 221 tap	MRX347	May 25, 2020	0.003	Passed	0.1600	Passed		
Burton Ettinger Elementary	Class Room 222 tap	VVU933	May 17, 2023	-	Passed	0.0940	Passed	Tap remediated	
Burton Ettinger Elementary	Class Room 223 tap	MRX349	May 25, 2020	0.004	Passed	0.2000	Passed		
Burton Ettinger Elementary	Fountain by Office Room 101	APSC45	April 9, 2025	-	Passed	0.0730	Passed		
Burton Ettinger Elementary	Fountain by Room 112	APSC49	April 9, 2025	-	Passed	0.0290	Passed		
Burton Ettinger Elementary	Fountain by Room 224	APSC46	April 9, 2025	-	Passed	0.0120	Passed		
Burton Ettinger Elementary	Fountain by Room 236	APSC48	April 9, 2025	-	Passed	0.0550	Passed		
Burton Ettinger Elementary	Gender Neutral Locker Room in Gym	MRX375	May 25, 2020	0.003	Passed	0.0850	Passed		
Burton Ettinger Elementary	Gender Neutral Wash Room 231 tap	MRX354	May 25, 2020	0.002	Passed	0.1600	Passed		
Burton Ettinger Elementary	Girls Wash Room 236 tap 1	MRX355	May 25, 2020	-	Passed	0.1700	Passed		
Burton Ettinger Elementary	Girls Wash Room 236 tap 2	MRX356	May 25, 2020	-	Passed	0.0600	Passed		
Burton Ettinger Elementary	Girls Wash Room tap 1 by Room 108	VVU928	May 17, 2023	-	Passed	0.0110	Passed	Tap remediated	
Burton Ettinger Elementary	Girls Wash Room tap 1 by Room 116	MRX379	May 25, 2020	0.001	Passed	0.3300	Passed		
Burton Ettinger Elementary	Girls Wash Room tap 2 by Room 108	MRX367	May 25, 2020	0.002	Passed	0.0920	Passed		
Burton Ettinger Elementary	Girls Wash Room tap 2 by Room 116	MRX380	May 25, 2020	-	Passed	0.0420	Passed		
Burton Ettinger Elementary	Girls Wash Room tap 3 by Room 108	VVU929	May 17, 2023	-	Passed	0.0180	Passed	Tap remediated	
Burton Ettinger Elementary	Girls Wash Room tap 3 by Room 116	MRX381	May 25, 2020	-	Passed	0.2700	Passed		
Burton Ettinger Elementary	Gym Girls Locker Room tap	MRX374	May 25, 2020	0.005	Passed	0.1100	Passed		
Burton Ettinger Elementary	Janitors Closet 111A double compartment sink	MRX377	May 25, 2020	0.001	Passed	0.1000	Passed		
Burton Ettinger Elementary	Janitors Closet 224 tap	XMQ683	November 3, 2023	-	Passed	0.0078	Passed	Tap remediated	
Burton Ettinger Elementary	Janitors Closet 238 tap	MRX353	May 25, 2020	0.001	Passed	0.0160	Passed		
Burton Ettinger Elementary	Janitors Closet tap by Room 102	VVU931	May 17, 2023	0.001	Passed	0.0350	Passed	Tap remediated	
Burton Ettinger Elementary	Staff Female Wash Room 236 tap	MRX357	May 25, 2020	-	Passed	0.0076	Passed		
Burton Ettinger Elementary	Staff Male Wash Room 237 tap	MRX361	May 25, 2020	-	Passed	0.0630	Passed		
Burton Ettinger Elementary	Staff Room 104 tap	APSC50	April 9, 2025	-	Passed	0.0100	Passed	Tap remediated	
Burton Ettinger Elementary	Staff Room 104 Wash Room tap 1	MRX363	May 25, 2020	0.005	Passed	0.0550	Passed		
Burton Ettinger Elementary	Staff Room 104 Wash Room tap 2	VVU931	May 17, 2023	-	Passed	0.0041	Passed	Tap remediated	
Burton Ettinger Elementary	Staff Room 227 tap	APSC47	April 9, 2025	-	Passed	0.0140	Passed		
Burton Ettinger Elementary	Staff Wash Room tap by Room 108	MRX369	May 25, 2020	0.002	Passed	0.0840	Passed		
Caldwell Road Elementary	1st Floor Staff Kitchen tap	AROK64	June 4, 2025	-	Passed	0.0081	Passed		
Caldwell Road Elementary	1st Floor Staff Wash Room 1 tap	MQE476	May 14, 2020	-	Passed	0.0200	Passed		
Caldwell Road Elementary	1st Floor Staff Wash Room 2 tap	MQE477	May 14, 2020	-	Passed	0.0130	Passed		
Caldwell Road Elementary	2nd Floor Boys Wash Room tap	MQE471	May 14, 2020	0.004	Passed	0.0960	Passed		
Caldwell Road Elementary	2nd Floor Girls Wash Room tap	XDW322	September 28, 2023	-	Passed	0.0210	Passed	Tap remediated	
Caldwell Road Elementary	2nd Floor Janitors Closet tap by Room 208	MQE473	May 14, 2020	0.002	Passed	0.0950	Passed		
Caldwell Road Elementary	Boys Wash Room tap 1 by Gym	MQE465	May 14, 2020	0.003	Passed	0.1900	Passed		
Caldwell Road Elementary	Boys Wash Room tap 1 by Room 6	MQE456	May 14, 2020	0.001	Passed	0.3200	Passed		
Caldwell Road Elementary	Boys Wash Room tap 2 by Gym	MQE466	May 14, 2020	0.001	Passed	0.0390	Passed		
Caldwell Road Elementary	Boys Wash Room tap 2 by Room 6	MQE457	May 14, 2020	0.002	Passed	0.1700	Passed		
Caldwell Road Elementary	Boys Wash Room tap 3 by Room 6	MQE458	May 14, 2020	0.001	Passed	0.1000	Passed		
Caldwell Road Elementary	Class Room Wash Room 1a tap	MQE455	May 14, 2020	0.003	Passed	0.1900	Passed		
Caldwell Road Elementary	Fountain by Main Entrance	AROK63	June 4, 2025	-	Passed	0.0430	Passed		
Caldwell Road Elementary	Fountain by Room 208	AROK66	June 4, 2025	-	Passed	0.0460	Passed		
Caldwell Road Elementary	Fountain by Room 6	AROK65	June 4, 2025	-	Passed	0.0150	Passed		
Caldwell Road Elementary	Girls Wash Room tap 1 by Gym	MQE467	May 14, 2020	0.002	Passed	0.1500	Passed		
Caldwell Road Elementary	Girls Wash Room tap 1 by Room 6	MQE461	May 14, 2020	0.003	Passed	0.1300	Passed		
Caldwell Road Elementary	Girls Wash Room tap 2 by Gym	XDW318	September 28, 2023	-	Passed	0.0200	Passed	Tap remediated	
Caldwell Road Elementary	Girls Wash Room tap 2 by Room 6	MQE462	May 14, 2020	0.002	Passed	0.0760	Passed		
Caldwell Road Elementary	Girls Wash Room tap 3 by Room 6	MQE463	May 14, 2020	0.001	Passed	0.0520	Passed		
Caldwell Road Elementary	Janitors Closet tap 1 by Room 6	MQE459	May 14, 2020	0.001	Passed	0.0760	Passed		
Caldwell Road Elementary	Learning Centre Wash Room tap by Room 7	MQE464	May 14, 2020	0.002	Passed	0.1400	Passed		
Caldwell Road Elementary	Music Room 122 tap	XDW320	September 28, 2023	0.003	Passed	0.2500	Passed		
Caledonia Junior High School	1st Floor Boys Wash Room tap 1	MXU490	June 18, 2020	0.002	Passed	0.2200	Passed		
Caledonia Junior High School	1st Floor Boys Wash Room tap 2	WIH456	July 7, 2023	0.001	Passed	0.1100	Passed	Tap remediated	
Caledonia Junior High School	1st Floor Boys Wash Room tap 3	WIH457	July 7, 2023	0.001	Passed	0.1000	Passed	Tap remediated	
Caledonia Junior High School	1st Floor Girls Wash Room tap 1	WIH453	July 7, 2023	0.049	Exceeded	0.4800	Passed	Hand washing only	
Caledonia Junior High School	1st Floor Girls Wash Room tap 2	WIH454	July 7, 2023	0.016	Exceeded	0.2500	Passed	Hand washing only	
Caledonia Junior High School	1st Floor Girls Wash Room tap 3	WIH480	July 7, 2023	0.005	Exceeded	0.1600	Passed	Hand washing only	
Caledonia Junior High School	1st Floor Girls Wash Room tap 4	MXU497	June 18, 2020	0.003	Passed	0.3700	Passed		
Caledonia Junior High School	1st Floor Girls Wash Room tap 5	WIH455	July 7, 2023	0.002	Passed	0.0960	Passed	Tap remediated	
Caledonia Junior High School	2nd Floor Boys Wash Room tap 1	WIH473	July 7, 2023	0.003	Passed	0.0920	Passed	Tap remediated	
Caledonia Junior High School	2nd Floor Boys Wash Room tap 2	WIH474	July 7, 2023	0.013	Exceeded	0.0780	Passed	Hand washing only	
Caledonia Junior High School	2nd Floor Boys Wash Room tap 3	WIH475	July 7, 2023	0.007	Exceeded	0.0900	Passed	Hand washing only	
Caledonia Junior High School	2nd Floor Girls Wash Room tap 1	WIH471	July 7, 2023	0.003	Passed	0.1100	Passed	Tap remediated	
Caledonia Junior High School	2nd Floor Girls Wash Room tap 2	WIH472	July 7, 2023	0.001	Passed	0.0850	Passed	Tap remediated	
Caledonia Junior High School	2nd Floor Girls Wash Room tap 3	MXU541	June 18, 2020	0.005	Passed	0.1300	Passed		
Caledonia Junior High School	Class Room 108 tap	WIH458	July 7, 2023	0.001	Passed	0.1200	Passed	Tap remediated	
Caledonia Junior High School	Class Room 109 tap 1	MXU506	June 18, 2020	0.003	Passed	0.2100	Passed		
Caledonia Junior High School	Class Room 109 tap 2	WIH460	July 7, 2023	0.001	Passed	0.0710	Passed	Tap remediated	
Caledonia Junior High School	Class Room 207 tap 1	WIH469	July 7, 2023	-	Passed	0.0750	Passed	Tap remediated	
Caledonia Junior High School	Class Room 207 tap 2	WIH481	July 7, 2023	0.001	Passed	0.0530	Passed	Hand washing only	
Caledonia Junior High School	Class Room 207 tap 3	WIH470	July 7, 2023	0.011	Exceeded	0.1800	Passed	Hand washing only	
Caledonia Junior High School	Family Studies 215 tap 1	ARKL17	May 30, 2025	-	Passed	0.0150	Passed		
Caledonia Junior High School	Family Studies 215 tap 2	ARKL18	May 30, 2025	-	Passed	0.0170	Passed		
Caledonia Junior High School	Family Studies 215 tap 3	ARKL19	May 30, 2025	-	Passed	0.0180	Passed		
Caledonia Junior High School	Family Studies 215 tap 4	ARKL20	May 30, 2025	-	Passed	0.0280	Passed		
Caledonia Junior High School	Family Studies 215 tap 5	ARKL21	May 30, 2025	-	Passed	0.0280	Passed		
Caledonia Junior High School	Fountain by Room 109	ARKL24	May 30, 2025	-	Passed	0.0570	Passed		
Caledonia Junior High School	Fountain by Room 115	ARKL22	May 30, 2025	-	Passed	0.0430	Passed		
Caledonia Junior High School	Fountain by Room 213	ARKL15	May 30, 2025	0.001	Passed	0.0410	Passed		
Caledonia Junior High School	Fountain by Science Lab	ARKL16	May 30, 2025	-	Passed	0.0460	Passed		
Caledonia Junior High School	Gender Neutral Wash Room 115 tap	WIH459	July 7, 2023	0.001	Passed	0.1500	Passed	Tap remediated	
Caledonia Junior High School	Janitors Closet 112 tap	MXU511	June 18, 2020	0.001	Passed	0.0230	Passed		
Caledonia Junior High School	Janitors Closet tap by 1st Floor Wash Rooms	MXU493	June 18, 2020	0.001	Passed	0.0320	Passed		
Caledonia Junior High School	Janitors Closet tap by 2nd Floor Wash Rooms	WIH476	July 7, 2023	0.002	Passed	0.1000	Passed	Tap remediated	
Caledonia Junior High School	Science Lab tap 1	MXU515	June 18, 2020	0.053	Exceeded	0.4300	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 10	MXU524	June 18, 2020	0.410	Exceeded	3.5000	Exceeded	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 11	MXU525	June 18, 2020	0.270	Exceeded	0.9600	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 12	MXU526	June 18, 2020	0.060	Exceeded	0.5700	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 13	MXU527	June 18, 2020	0.230	Exceeded	0.9500	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 14	MXU528	June 18, 2020	0.047	Exceeded	1.2000	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 15	MXU529	June 18, 2020	0.021	Exceeded	1.1000	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 2	MXU516	June 18, 2020	0.068	Exceeded	0.6700	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 3	MXU517	June 18, 2020	0.410	Exceeded	3.0000	Exceeded	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 4	MXU518	June 18, 2020	0.270	Exceeded	1.8000	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 5	MXU519	June 18, 2020	0.170	Exceeded	0.9900	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 6	MXU520	June 18, 2020	0.004	Passed	0.0710	Passed		
Caledonia Junior High School	Science Lab tap 7	MXU521	June 18, 2020	1.200	Exceeded	8.2000	Exceeded	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 8	MXU522	June 18, 2020	0.100	Exceeded	0.3700	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Science Lab tap 9	MXU523	June 18, 2020	0.074	Exceeded	0.8700	Passed	Laboratory or Hand washing only	
Caledonia Junior High School	Staff Room 110 tap	ARKL23	May 30, 2025	-	Passed	0.0310	Passed		
Caledonia Junior High School	Staff Room 110 Wash Room 1 tap	WIH462	July 7, 2023	0.002	Passed	0.0820	Passed	Tap remediated	
Caledonia Junior High School	Staff Room 110 Wash Room 2 tap	WIH463	July 7, 2023	-	Passed	0.0610	Passed	Tap remediated	
Caudle Park Elementary	1st Floor Boys Wash Room tap 1	MPX380	May 13, 2020	0.002	Passed	0.1100	Passed		
Caudle Park Elementary	1st Floor Boys Wash Room tap 2	MPX381	May 13, 2020	0.001	Passed	0.0920	Passed		
Caudle Park Elementary	1st Floor Girls Wash Room tap 1	MPX385	May 13, 2020	0.002	Passed	0.1500	Passed		
Caudle Park Elementary	1st Floor Girls Wash Room tap 2	MPX386	May 13, 2020	0.001	Passed	0.1000	Passed		
Caudle Park Elementary	1st Floor Girls Wash Room tap 3								

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Cavalier Drive School	1st Floor Boys Wash Room tap 1	WBC871	June 7, 2023	-	Passed	0.0130	Passed	Tap remediated	
Cavalier Drive School	1st Floor Boys Wash Room tap 2	WBC872	June 7, 2023	-	Passed	0.0081	Passed	Tap remediated	
Cavalier Drive School	1st Floor Girls Wash Room tap 1	WBC889	June 7, 2023	0.001	Passed	0.0840	Passed	Tap remediated	
Cavalier Drive School	1st Floor Girls Wash Room tap 2	WBC890	June 7, 2023	0.001	Passed	0.0098	Passed	Tap remediated	
Cavalier Drive School	1st Floor Girls Wash Room tap 3	WBC891	June 7, 2023	0.001	Passed	0.0100	Passed	Tap remediated	
Cavalier Drive School	1st Floor Janitors Closet tap	MPQ791	May 12, 2020	0.001	Passed	0.0230	Passed		
Cavalier Drive School	2nd Floor Boys Wash Room tap 1	WBC895	June 7, 2023	-	Passed	0.0100	Passed	Tap remediated	
Cavalier Drive School	2nd Floor Boys Wash Room tap 2	WBC906	June 7, 2023	-	Passed	0.0055	Passed	Tap remediated	
Cavalier Drive School	2nd Floor Boys Wash Room tap 3	WBC907	June 7, 2023	-	Passed	0.0140	Passed	Tap remediated	
Cavalier Drive School	2nd Floor Girls Wash Room tap 1	WBC908	June 7, 2023	-	Passed	0.0210	Passed	Tap remediated	
Cavalier Drive School	2nd Floor Girls Wash Room tap 2	WBC909	June 7, 2023	-	Passed	0.0097	Passed	Tap remediated	
Cavalier Drive School	2nd Floor Girls Wash Room tap 3	WBC910	June 7, 2023	-	Passed	0.0064	Passed	Tap remediated	
Cavalier Drive School	2nd Floor Janitors Closet tap	MPQ814	May 12, 2020	-	Passed	0.0058	Passed		
Cavalier Drive School	Class Room 108 tap	MPQ783	May 12, 2020	0.004	Passed	0.0200	Passed		
Cavalier Drive School	Class Room 110 tap	MPQ784	May 12, 2020	0.004	Passed	0.4400	Passed		
Cavalier Drive School	Class Room 111 tap	SCH537	March 15, 2022	0.001	Passed	0.0450	Passed		
Cavalier Drive School	Class Room 152 tap 1	MPQ803	May 12, 2020	0.001	Passed	0.0170	Passed		
Cavalier Drive School	Class Room 152 tap 2	SCH555	March 15, 2022	0.001	Passed	0.0520	Passed		
Cavalier Drive School	Class Room 156 tap	SCH553	March 15, 2022	0.002	Passed	0.1200	Passed		
Cavalier Drive School	Class Room 201 tap	MPQ817	May 12, 2020	0.003	Passed	0.2300	Passed		
Cavalier Drive School	Class Room 202 tap	SCH557	March 15, 2022	0.002	Passed	0.0620	Passed		
Cavalier Drive School	Class Room 203 tap	SCH556	March 15, 2022	0.001	Passed	0.0430	Passed		
Cavalier Drive School	Class Room 204 tap	MPQ819	May 12, 2020	0.001	Passed	0.0210	Passed		
Cavalier Drive School	Class Room 204 Wash Room tap	SCH558	March 15, 2022	0.001	Passed	0.0370	Passed		
Cavalier Drive School	Class Room 205 tap	MPQ815	May 12, 2020	0.003	Passed	0.0210	Passed		
Cavalier Drive School	Class Room tap Room 206	MPQ824	May 12, 2020	0.003	Passed	0.0150	Passed		
Cavalier Drive School	Class Room Wash Room tap Room 206	MPQ825	May 12, 2020	0.003	Passed	0.0680	Passed		
Cavalier Drive School	Fountain by Room 102	ARCW72	May 22, 2025	-	Passed	0.0260	Passed		
Cavalier Drive School	Fountain by Room 107	ARCW71	May 22, 2025	-	Passed	0.0008	Passed		
Cavalier Drive School	Fountain by Room 165	ARCW73	May 22, 2025	-	Passed	0.0670	Passed		
Cavalier Drive School	Fountain by Room 204	ARCW75	May 22, 2025	-	Passed	0.0009	Passed		
Cavalier Drive School	Fountain by Room 209	ARCW74	May 22, 2025	-	Passed	0.0300	Passed		
Cavalier Drive School	Gym Boys Wash Room tap	WBC887	June 7, 2023	0.001	Passed	0.0270	Passed	Tap remediated	
Cavalier Drive School	Gym Girls Wash Room tap	WBC888	June 7, 2023	-	Passed	0.0230	Passed	Tap remediated	
Cavalier Drive School	Kitchen tap by Room 167	ARCW76	May 22, 2025	0.001	Passed	0.0500	Passed		
Cavalier Drive School	Learning Centre tap	WBC865	June 7, 2023	0.001	Passed	0.0210	Passed		
Cavalier Drive School	Main Office Wash Room tap	MPQ776	May 12, 2020	0.003	Passed	0.0310	Passed		
Cavalier Drive School	Staff Room Kitchen tap	ARCW70	May 22, 2025	-	Passed	0.0072	Passed		
Cavalier Drive School	Staff Room Wash Room tap 1	WBC894	June 7, 2023	-	Passed	0.0110	Passed	Tap remediated	
Cavalier Drive School	Staff Room Wash Room tap 2	MPQ796	May 12, 2020	0.002	Passed	0.0190	Passed		
Cavalier Drive School	Wash Room by Room 102 tap 1	WBC868	June 7, 2023	0.001	Passed	0.0220	Passed	Tap remediated	
Cavalier Drive School	Wash Room by Room 102 tap 2	WBC869	June 7, 2023	0.001	Passed	0.0210	Passed	Tap remediated	
Cavalier Drive School	Wash Room by Room 104 tap 1	WBC870	June 7, 2023	-	Passed	0.0330	Passed	Tap remediated	
Cavalier Drive School	Wash Room by Room 104 tap 2	MPQ782	May 12, 2020	0.001	Passed	0.0340	Passed		
Central Spryfield Elementary	Boys Wash Room 214 tap 1	VQM084	April 25, 2023	-	Passed	0.0006	Passed		
Central Spryfield Elementary	Boys Wash Room 214 tap 2	VQM085	April 25, 2023	-	Passed	0.0007	Passed	Tap remediated	
Central Spryfield Elementary	Boys Wash Room 214 tap 3	VQM086	April 25, 2023	-	Passed	0.0011	Passed	Tap remediated	
Central Spryfield Elementary	Boys Wash Room tap 1 by Caretaker Office	VQL998	April 25, 2023	-	Passed	0.0068	Passed		
Central Spryfield Elementary	Boys Wash Room tap 1 by Room 104	VQM003	April 25, 2023	0.001	Passed	0.0140	Passed	Tap remediated	
Central Spryfield Elementary	Boys Wash Room tap 2 by Caretaker Office	VQL999	April 25, 2023	-	Passed	0.0095	Passed	Tap remediated	
Central Spryfield Elementary	Boys Wash Room tap 2 by Room 104	VQM004	April 25, 2023	-	Passed	0.0080	Passed	Tap remediated	
Central Spryfield Elementary	Boys Wash Room tap 3 by Room 104	VQM005	April 25, 2023	-	Passed	0.0083	Passed	Tap remediated	
Central Spryfield Elementary	Class Room 100B tap	MRD016	May 20, 2020	0.002	Passed	0.1700	Passed		
Central Spryfield Elementary	Class Room 100C tap	MRD008	May 20, 2020	-	Passed	0.0600	Passed		
Central Spryfield Elementary	Class Room 200B tap	MRD028	May 20, 2020	0.003	Passed	0.0610	Passed		
Central Spryfield Elementary	Fountain by Room 100B	APSD08	April 9, 2025	-	Passed	0.0130	Passed		
Central Spryfield Elementary	Fountain by Room 104	APSD11	April 9, 2025	-	Passed	0.0470	Passed		
Central Spryfield Elementary	Fountain by Room 200B	APSD09	April 9, 2025	-	Passed	0.0150	Passed		
Central Spryfield Elementary	Fountain by Room 212	APSD10	April 9, 2025	0.001	Passed	0.0021	Passed		
Central Spryfield Elementary	Girls Wash Room 215 tap 1	VQM055	April 25, 2023	-	Passed	0.0005	Passed		
Central Spryfield Elementary	Girls Wash Room 215 tap 2	VQM056	April 25, 2023	-	Passed	0.0005	Passed	Tap remediated	
Central Spryfield Elementary	Girls Wash Room 215 tap 3	VQM083	April 25, 2023	-	Passed	0.0023	Passed		
Central Spryfield Elementary	Girls Wash Room tap 1 by Room 100C	MRD009	May 20, 2020	-	Passed	0.1000	Passed		
Central Spryfield Elementary	Girls Wash Room tap 1 by Room 104	VQM006	April 25, 2023	-	Passed	0.0013	Passed	Tap remediated	
Central Spryfield Elementary	Girls Wash Room tap 2 by Room 100C	MRD010	May 20, 2020	0.001	Passed	0.0990	Passed		
Central Spryfield Elementary	Girls Wash Room tap 2 by Room 104	VQM007	April 25, 2023	0.001	Passed	0.0340	Passed	Tap remediated	
Central Spryfield Elementary	Girls Wash Room tap 3 by Room 100C	MRD011	May 20, 2020	0.001	Passed	0.0600	Passed		
Central Spryfield Elementary	Girls Wash Room tap 3 by Room 104	VQM048	April 25, 2023	-	Passed	0.0013	Passed	Tap remediated	
Central Spryfield Elementary	Guidance Room 217 tap	APSD14	April 9, 2025	-	Passed	0.0140	Passed		
Central Spryfield Elementary	Guidance Room 217 Wash Room tap	VQM087	April 25, 2023	-	Passed	0.0010	Passed	Tap remediated	
Central Spryfield Elementary	Janitors Closet 113 tap	NKV272	August 21, 2020	0.000	Passed	0.0080	Passed		
Central Spryfield Elementary	Janitors Closet 212 tap	MRD020	May 20, 2020	0.002	Passed	0.0520	Passed		
Central Spryfield Elementary	Janitors Closet tap by Caretaker Office	MRD014	May 20, 2020	0.001	Passed	0.0670	Passed		
Central Spryfield Elementary	Kitchen 104 tap	ZEF864	April 25, 2023	-	Passed	0.0012	Passed		
Central Spryfield Elementary	Kitchen 116 tap 1	APSD12	April 9, 2025	-	Passed	0.0110	Passed		
Central Spryfield Elementary	Learning Centre 103 tap	VQM051	April 25, 2023	-	Passed	0.0006	Passed		
Central Spryfield Elementary	Learning Centre 103 Wash Room tap	VQM052	April 25, 2023	-	Passed	0.0012	Passed	Tap remediated	
Central Spryfield Elementary	Staff Room 112 tap	APSD13	April 9, 2025	0.000	Passed	0.0040	Passed		
Central Spryfield Elementary	Staff Room 112 Wash Room tap 1	VQM001	April 25, 2023	-	Passed	0.0006	Passed	Tap remediated	
Central Spryfield Elementary	Staff Room 112 Wash Room tap 2	VQM002	April 25, 2023	-	Passed	0.0046	Passed	Tap remediated	
Charles P. Allen High School	Boys Wash Room 1028 tap 1	MPM955	May 11, 2020	-	Passed	0.8500	Passed		
Charles P. Allen High School	Boys Wash Room 1028 tap 2	MPM956	May 11, 2020	-	Passed	0.8400	Passed		
Charles P. Allen High School	Boys Wash Room 1028 tap 3	MPM957	May 11, 2020	-	Passed	0.8000	Passed		
Charles P. Allen High School	Boys Wash Room 1054 tap 1	MPM971	May 11, 2020	-	Passed	0.7200	Passed		
Charles P. Allen High School	Boys Wash Room 1054 tap 2	MPM972	May 11, 2020	-	Passed	0.6900	Passed		
Charles P. Allen High School	Boys Wash Room 1054 tap 3	MPM973	May 11, 2020	-	Passed	0.7700	Passed		
Charles P. Allen High School	Boys Wash Room 2029 tap 1	MNX512	May 1, 2020	-	Passed	0.5600	Passed		
Charles P. Allen High School	Boys Wash Room 2029 tap 2	MNX513	May 1, 2020	-	Passed	0.4700	Passed		
Charles P. Allen High School	Boys Wash Room 2029 tap 3	MNX514	May 1, 2020	-	Passed	0.6500	Passed		
Charles P. Allen High School	Boys Wash Room 2045 tap 1	MNX529	May 1, 2020	-	Passed	0.7400	Passed		
Charles P. Allen High School	Boys Wash Room 2045 tap 2	MNX530	May 1, 2020	-	Passed	0.6500	Passed		
Charles P. Allen High School	Boys Wash Room 2045 tap 3	MNX531	May 1, 2020	-	Passed	0.7900	Passed		
Charles P. Allen High School	Boys Wash Room 3029 tap 1	MSA130	May 25, 2020	-	Passed	0.4900	Passed		
Charles P. Allen High School	Boys Wash Room 3029 tap 2	MSA131	May 25, 2020	-	Passed	0.5200	Passed		
Charles P. Allen High School	Boys Wash Room 3029 tap 3	MSA132	May 25, 2020	-	Passed	0.5500	Passed		
Charles P. Allen High School	Boys Wash Room 3045 tap 1	MSA171	May 25, 2020	-	Passed	0.9300	Passed		
Charles P. Allen High School	Boys Wash Room 3045 tap 2	MSA172	May 25, 2020	-	Passed	0.8300	Passed		
Charles P. Allen High School	Boys Wash Room 3045 tap 3	MSA173	May 25, 2020	-	Passed	1.0000	Passed		
Charles P. Allen High School	Cafeteria tap 1	ARCW01	May 22, 2025	-	Passed	0.0230	Passed		
Charles P. Allen High School	Cafeteria tap 2	ARCW02	May 22, 2025	-	Passed	0.0310	Passed		
Charles P. Allen High School	Caretaker Room 1066 tap	MPM964	May 11, 2020	-	Passed	0.4100	Passed		
Charles P. Allen High School	Change Room 3052A	MSA147	May 25, 2020	-	Passed	1.1000	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 1	MSA161	May 25, 2020	0.003	Passed	0.7500	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 1	MSA174	May 25, 2020	-	Passed	1.1000	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 2	MSA162	May 25, 2020	-	Passed	0.5000	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 2	MSA175	May 25, 2020	-	Passed	0.7400	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 3	MSA163	May 25, 2020	-	Passed	0.6400	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 3	MSA176	May 25, 2020	-	Passed	0.6100	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 4	MSA164	May 25, 2020	-	Passed	0.6100	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 4	MSA177	May 25, 2020	-	Passed	0.8000	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 5	MSA178	May 25, 2020	-	Passed	0.7900	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 6	MSA179	May 25, 2020	-	Passed	0.6800	Passed		
Charles P. Allen High School	Chemistry Lab 3044 tap 7	MSA180	May 25, 2020	-	Passed	0.9900	Passed		
Charles P. Allen High School	Class Room 1004 tap	MPM946	May 11, 2020	-	Passed	0.7200	Passed		
Charles P. Allen High School	Class Room 1015 tap	MPM948	May 11, 2020	-	Passed	0.7200	Passed		
Charles P. Allen High School	Class Room 1016 tap	MPM949	May 11, 2020	-	Passed	0.8100	Passed		
Charles P. Allen High School	Class Room 1024 tap 1	MPM950	May 11, 2020	-	Passed	1.1000	Passed		
Charles P. Allen High School	Class Room 1024 tap 2	MPM951	May 11, 2020	-	Passed	0.9400	Passed		
Charles P. Allen High School	Class Room 1026 tap	MPM954	May 11, 2020	-	Passed	0.8300	Passed		
Charles P. Allen High School	Class Room 1027 tap 1	MPM952	May 11, 2020	-	Passed	0.0720	Passed		
Charles P. Allen High School	Class Room 1027 tap 2	MPM953	May 11, 2020	-	Passed	0.7400	Passed		
Charles P. Allen High School	Class Room 2028	MNX525	May 1, 2020	-	Passed	0.6600	Passed		
Charles P. Allen High School	Class Room 3004 tap	MSA126	May 25, 2020	-	Passed	0.2100	Passed		
Charles P. Allen High School	Class Room 3028 tap	MSA128	May 25, 2020	-	Passed	0.8100	Passed		
Charles P. Allen High School	Class Room 3049 tap 1	MSA154	May 25, 2020	-	Passed	0.3600	Passed		
Charles P. Allen High School	Class Room 3049 tap 2	MSA155	May 25, 2020	-	Passed	0.1600	Passed		
Charles P. Allen High School	Class Room 3050 tap	MSA153	May 25, 2020	-	Passed	0.1100	Passed		
Charles P. Allen High School	Class Room 3051 tap 1	MSA148	May 25, 2020	-	Passed	0.2200	Passed		
Charles P. Allen High School	Class Room 3051 tap 2	MSA149	May 25, 2020	-	Passed	0.9300	Passed		
Charles P. Allen High School	Class Room 3051 tap 3	MSA150	May 25, 2020	-	Passed	1.1000	Passed		
Charles P. Allen High School	Class Room 3051 tap 4	MSA151	May 25, 2020	-	Passed				

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Charles P. Allen High School	Class Room 3060 tap 3	MSA141	May 25, 2020	-	Passed	0.5900	Passed		
Charles P. Allen High School	Class Room 3061 tap	MSA143	May 25, 2020	-	Passed	0.1500	Passed		
Charles P. Allen High School	Fountain before Room 3046	ARCW11	May 22, 2025	-	Passed	0.0610	Passed		
Charles P. Allen High School	Fountain by Class Room 2028	ARCW07	May 22, 2025	-	Passed	0.0990	Passed		
Charles P. Allen High School	Fountain by Learning Centre 249	ARCW08	May 22, 2025	-	Passed	0.0640	Passed		
Charles P. Allen High School	Fountain by Locker Room 2065	ARCW09	May 22, 2025	-	Passed	0.1700	Passed		
Charles P. Allen High School	Fountain by Locker Room 2067	ARCW10	May 22, 2025	-	Passed	0.2700	Passed		
Charles P. Allen High School	Fountain by Room 1003	ARCW04	May 22, 2025	-	Passed	0.2300	Passed		
Charles P. Allen High School	Fountain by Room 1015	ARCW05	May 22, 2025	-	Passed	0.0950	Passed		
Charles P. Allen High School	Fountain by Room 1054	ARCW03	May 22, 2025	-	Passed	0.0530	Passed		
Charles P. Allen High School	Fountain by Room 3006	ARCW13	May 22, 2025	-	Passed	0.2200	Passed		
Charles P. Allen High School	Fountain by Room 3028	ARCW12	May 22, 2025	-	Passed	0.1200	Passed		
Charles P. Allen High School	Fountain by Wash Room 2008A	ARCW06	May 22, 2025	-	Passed	0.1800	Passed		
Charles P. Allen High School	Gender Neutral Wash Room 2008A tap	MNX510	May 1, 2020	-	Passed	0.2800	Passed		
Charles P. Allen High School	Gender Neutral Wash Room 2031 tap	MNX524	May 1, 2020	-	Passed	0.0790	Passed		
Charles P. Allen High School	Gender Neutral Wash Room 2047 tap	MNX542	May 1, 2020	-	Passed	0.3700	Passed		
Charles P. Allen High School	Gender Neutral Wash Room 3059	MSA138	May 25, 2020	-	Passed	0.3800	Passed		
Charles P. Allen High School	Girls Wash Room 1029 tap 1	MPM960	May 11, 2020	-	Passed	0.5400	Passed		
Charles P. Allen High School	Girls Wash Room 1029 tap 2	MPM961	May 11, 2020	-	Passed	0.6500	Passed		
Charles P. Allen High School	Girls Wash Room 1029 tap 3	MPM962	May 11, 2020	-	Passed	0.6000	Passed		
Charles P. Allen High School	Girls Wash Room 1055 tap 1	MPM966	May 11, 2020	0.002	Passed	0.4400	Passed		
Charles P. Allen High School	Girls Wash Room 1055 tap 2	MPM967	May 11, 2020	0.002	Passed	0.5500	Passed		
Charles P. Allen High School	Girls Wash Room 1055 tap 3	MPM968	May 11, 2020	-	Passed	0.7200	Passed		
Charles P. Allen High School	Girls Wash Room 2030 tap 1	MNX515	May 1, 2020	-	Passed	0.7500	Passed		
Charles P. Allen High School	Girls Wash Room 2030 tap 2	MNX516	May 1, 2020	-	Passed	0.7000	Passed		
Charles P. Allen High School	Girls Wash Room 2030 tap 3	MNX517	May 1, 2020	-	Passed	0.6800	Passed		
Charles P. Allen High School	Girls Wash Room 2046 tap 1	MNX532	May 1, 2020	-	Passed	0.9900	Passed		
Charles P. Allen High School	Girls Wash Room 2046 tap 2	MNX533	May 1, 2020	-	Passed	0.6900	Passed		
Charles P. Allen High School	Girls Wash Room 2046 tap 3	MNX541	May 1, 2020	-	Passed	0.7200	Passed		
Charles P. Allen High School	Girls Wash Room 3030 tap 1	MSA135	May 25, 2020	-	Passed	0.6500	Passed		
Charles P. Allen High School	Girls Wash Room 3030 tap 2	MSA136	May 25, 2020	-	Passed	0.5600	Passed		
Charles P. Allen High School	Girls Wash Room 3030 tap 3	MSA137	May 25, 2020	-	Passed	0.6500	Passed		
Charles P. Allen High School	Girls Wash Room 3046 tap 1	MSA157	May 25, 2020	-	Passed	0.7100	Passed		
Charles P. Allen High School	Girls Wash Room 3046 tap 2	MSA158	May 25, 2020	-	Passed	0.6200	Passed		
Charles P. Allen High School	Girls Wash Room 3046 tap 3	MSA159	May 25, 2020	-	Passed	0.6200	Passed		
Charles P. Allen High School	Janitors Closet 1031 tap	MPM958	May 11, 2020	-	Passed	0.5400	Passed		
Charles P. Allen High School	Janitors Closet 1057 tap	MPM970	May 11, 2020	0.001	Passed	0.3200	Passed		
Charles P. Allen High School	Janitors Closet 1065 tap	MPM965	May 11, 2020	0.001	Passed	0.1300	Passed		
Charles P. Allen High School	Janitors Closet 2032 tap	MNX519	May 1, 2020	-	Passed	0.3800	Passed		
Charles P. Allen High School	Janitors Closet 2048 tap	MNX543	May 1, 2020	0.004	Passed	0.4400	Passed		
Charles P. Allen High School	Janitors Closet 3032 tap	MSA133	May 25, 2020	0.001	Passed	0.3800	Passed		
Charles P. Allen High School	Janitors Closet 3048 tap	MSA181	May 25, 2020	-	Passed	0.2600	Passed		
Charles P. Allen High School	Learning Centre 1002 tap	MPM943	May 11, 2020	-	Passed	0.9300	Passed		
Charles P. Allen High School	Locker Room 2065 tap 1	MOE406	May 4, 2020	-	Passed	0.5900	Passed		
Charles P. Allen High School	Locker Room 2065 tap 2	MOE407	May 4, 2020	-	Passed	0.5400	Passed		
Charles P. Allen High School	Locker Room 2066 tap 1	MOE404	May 4, 2020	0.003	Passed	0.8200	Passed		
Charles P. Allen High School	Locker Room 2066 tap 2	MOE405	May 4, 2020	0.001	Passed	0.4900	Passed		
Charles P. Allen High School	Locker Room 2067 tap 1	MOE402	May 4, 2020	0.001	Passed	0.8400	Passed		
Charles P. Allen High School	Locker Room 2067 tap 2	MOE403	May 4, 2020	-	Passed	0.8200	Passed		
Charles P. Allen High School	Locker Room 2068 tap 1	MOE400	May 4, 2020	-	Passed	1.0000	Passed		
Charles P. Allen High School	Locker Room 2068 tap 2	MOE401	May 4, 2020	-	Passed	1.2000	Passed		
Charles P. Allen High School	Mechanical Room ST 9.1 tap	MSA142	May 25, 2020	-	Passed	0.1100	Passed		
Charles P. Allen High School	Multipurpose Lab 3041 tap 1	MSA165	May 25, 2020	-	Passed	0.8300	Passed		
Charles P. Allen High School	Multipurpose Lab 3041 tap 2	MSA166	May 25, 2020	-	Passed	0.8100	Passed		
Charles P. Allen High School	Multipurpose Lab 3041 tap 3	MSA167	May 25, 2020	-	Passed	1.0000	Passed		
Charles P. Allen High School	Multipurpose Lab 3041 tap 4	MSA168	May 25, 2020	-	Passed	0.3700	Passed		
Charles P. Allen High School	Multipurpose Lab 3041 tap 5	MSA169	May 25, 2020	-	Passed	1.2000	Passed		
Charles P. Allen High School	Multipurpose Lab 3041 tap 6	MSA170	May 25, 2020	-	Passed	1.1000	Passed		
Charles P. Allen High School	Multipurpose Lab 3041 tap 7	MSA182	May 25, 2020	-	Passed	0.1600	Passed		
Charles P. Allen High School	Multipurpose Lab 3041 tap 8	MSA183	May 25, 2020	-	Passed	0.2800	Passed		
Charles P. Allen High School	Music Room 1069 tap	NE5631	July 24, 2020	-	Passed	0.0620	Passed		
Charles P. Allen High School	Science Lab 3062 tap 1	MSA144	May 25, 2020	-	Passed	0.1700	Passed		
Charles P. Allen High School	Science Lab 3062 tap 2	MSA145	May 25, 2020	-	Passed	0.0970	Passed		
Charles P. Allen High School	Science Lab 3062 tap 3	MSA146	May 25, 2020	-	Passed	1.2000	Passed		
Charles P. Allen High School	Staff Room 2044 tap	MNX526	May 1, 2020	-	Passed	0.3600	Passed		
Charles P. Allen High School	Staff Room Wash Room 2044B tap 1	MNX527	May 1, 2020	-	Passed	0.2700	Passed		
Charles P. Allen High School	Staff Room Wash Room 2044B tap 2	MNX528	May 1, 2020	-	Passed	0.3100	Passed		
Charles P. Allen High School	Staff Wash Room 1030 tap	MPM959	May 11, 2020	-	Passed	1.1000	Passed		
Charles P. Allen High School	Staff Wash Room 1048	MPM975	May 11, 2020	-	Passed	1.1000	Passed		
Charles P. Allen High School	Staff Wash Room 1056 tap	MPM969	May 11, 2020	-	Passed	1.0000	Passed		
Charles P. Allen High School	Staff Wash Room 3031 tap	MSA134	May 25, 2020	-	Passed	0.2600	Passed		
Charles P. Allen High School	Staff Wash Room 3047 tap	MSA160	May 25, 2020	-	Passed	0.6800	Passed		
Charles P. Allen High School	Wash Room 1005 tap	MPM945	May 11, 2020	-	Passed	0.4600	Passed		
Chebucto Heights Elementary	2nd Floor Girls Wash Room tap 1	MQS753	May 19, 2020	0.002	Passed	0.0910	Passed		
Chebucto Heights Elementary	2nd Floor Girls Wash Room tap 2	MQS754	May 19, 2020	0.004	Passed	0.0700	Passed		
Chebucto Heights Elementary	2nd Floor Girls Wash Room tap 3	MQS755	May 19, 2020	0.002	Passed	0.1500	Passed		
Chebucto Heights Elementary	2nd Floor Boys Wash Room tap 1	MQS757	May 19, 2020	0.003	Passed	0.0670	Passed		
Chebucto Heights Elementary	2nd Floor Boys Wash Room tap 2	MQS758	May 19, 2020	0.003	Passed	0.0620	Passed		
Chebucto Heights Elementary	2nd Floor Boys Wash Room tap 3	MQS759	May 19, 2020	0.001	Passed	0.0720	Passed		
Chebucto Heights Elementary	2nd Floor Boys Wash Room tap 4	MQS760	May 19, 2020	0.002	Passed	0.0730	Passed		
Chebucto Heights Elementary	Class Room 203 tap	MQS761	May 19, 2020	0.003	Passed	0.0220	Passed		
Chebucto Heights Elementary	Janitors Closet tap by Room 202	MQS762	May 19, 2020	0.001	Passed	0.0069	Passed		
Chebucto Heights Elementary	Class Room 202 tap	MQS763	May 19, 2020	0.002	Passed	0.0150	Passed		
Chebucto Heights Elementary	Class Room 116 tap 2	MQS766	May 19, 2020	0.002	Passed	0.0900	Passed		
Chebucto Heights Elementary	Class Room 213 tap	MQS767	May 19, 2020	0.003	Passed	0.0780	Passed		
Chebucto Heights Elementary	Boys Locker Room 152 tap	MQS768	May 19, 2020	0.002	Passed	0.1200	Passed		
Chebucto Heights Elementary	Janitors Closet 157 tap	MQS769	May 19, 2020	0.002	Passed	0.1800	Passed		
Chebucto Heights Elementary	Girls Locker Room 147 tap	MQS771	May 19, 2020	0.002	Passed	0.0960	Passed		
Chebucto Heights Elementary	Janitors Closet tap by Gym	MQS773	May 19, 2020	0.001	Passed	0.1600	Passed		
Chebucto Heights Elementary	Girls Wash Room 114 tap 1	MQS775	May 19, 2020	-	Passed	0.0130	Passed		
Chebucto Heights Elementary	Girls Wash Room 114 tap 2	MQS776	May 19, 2020	0.001	Passed	0.0180	Passed		
Chebucto Heights Elementary	Girls Wash Room 114 tap 3	MQS777	May 19, 2020	0.002	Passed	0.0430	Passed		
Chebucto Heights Elementary	Boys Wash Room 115 tap 1	MQS778	May 19, 2020	0.001	Passed	0.0028	Passed		
Chebucto Heights Elementary	Boys Wash Room 115 tap 2	MQS779	May 19, 2020	-	Passed	0.0018	Passed		
Chebucto Heights Elementary	Boys Wash Room 115 tap 3	MQS780	May 19, 2020	-	Passed	0.0025	Passed		
Chebucto Heights Elementary	Boys Wash Room 115 tap 4	MQS781	May 19, 2020	0.001	Passed	0.0078	Passed		
Chebucto Heights Elementary	Class Room 120 tap	MQS782	May 19, 2020	0.002	Passed	0.0330	Passed		
Chebucto Heights Elementary	Janitors Closet 121 tap	MQS784	May 19, 2020	-	Passed	0.0057	Passed		
Chebucto Heights Elementary	Class Room 124 Wash Room tap	MQS786	May 19, 2020	0.001	Passed	0.0220	Passed		
Chebucto Heights Elementary	Staff Wash Room 112 tap 1	MQS788	May 19, 2020	0.001	Passed	0.0260	Passed		
Chebucto Heights Elementary	Staff Wash Room 112 tap 2	MQS789	May 19, 2020	0.001	Passed	0.0240	Passed		
Chebucto Heights Elementary	Health Room 109 Wash Room tap	MQS792	May 19, 2020	0.002	Passed	0.1400	Passed		
Chebucto Heights Elementary	Class Room 212 tap	NKX388	August 21, 2020	0.000	Passed	0.0100	Passed		
Chebucto Heights Elementary	Class Room 116 tap 1	NKX389	August 21, 2020	0.004	Passed	0.0100	Passed		
Chebucto Heights Elementary	Class Room 124 tap	NKX390	August 21, 2020	0.001	Passed	0.0040	Passed		
Chebucto Heights Elementary	Fountain by Room 132	ZEF615	May 15, 2024	-	Passed	0.0056	Passed		
Chebucto Heights Elementary	Gender Neutral Wash Room 120 tap	VQL845	April 25, 2023	-	Passed	0.0230	Passed	Tap remediated	
Chebucto Heights Elementary									

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Citadel High School	1st Floor Staff Room tap 2	APZO37	April 17, 2025	-	Passed	0.0920	Passed	Tap remediated	
Citadel High School	1st Floor Staff Wash Room tap1 (Main office)	APZO40	April 17, 2025	-	Passed	0.2000	Passed		
Citadel High School	1st Floor Staff Wash Room tap 2 (Main office)	APZO41	April 17, 2025	-	Passed	0.1200	Passed		
Citadel High School	2nd Floor Boys Wash Room tap 1	MTU855	June 1, 2020	0.001	Passed	0.0980	Passed		
Citadel High School	2nd Floor Boys Wash Room tap 2	MTU856	June 1, 2020	0.001	Passed	0.0550	Passed		
Citadel High School	2nd Floor Boys Wash Room tap 3	MTU857	June 1, 2020	0.001	Passed	0.0700	Passed		
Citadel High School	2nd Floor Boys Wash Room tap 4	MTU858	June 1, 2020	-	Passed	0.0490	Passed		
Citadel High School	2nd Floor Boys Wash Room tap 5	MTU859	June 1, 2020	0.001	Passed	0.0400	Passed		
Citadel High School	2nd Floor Fountain by Elevator	APZO35	April 17, 2025	-	Passed	0.1200	Passed		
Citadel High School	2nd Floor Girls Wash Room tap 1	MTU862	June 1, 2020	-	Passed	0.0440	Passed		
Citadel High School	2nd Floor Girls Wash Room tap 2	MTU863	June 1, 2020	0.001	Passed	0.0710	Passed		
Citadel High School	2nd Floor Girls Wash Room tap 3	MTU864	June 1, 2020	0.001	Passed	0.1100	Passed		
Citadel High School	2nd Floor Girls Wash Room tap 4	MTU868	June 1, 2020	0.001	Passed	0.0940	Passed		
Citadel High School	2nd Floor Girls Wash Room tap 5	MTU869	June 1, 2020	0.001	Passed	0.0590	Passed		
Citadel High School	2nd Floor Staff Room tap 1	APZO28	April 17, 2025	-	Passed	0.1600	Passed		
Citadel High School	2nd Floor Staff Room tap 2	APZO29	April 17, 2025	-	Passed	0.0490	Passed		
Citadel High School	2nd Floor Teen Health Room tap	APZO25	April 17, 2025	-	Passed	0.0980	Passed		
Citadel High School	3rd Floor Janitors Closet tap	MTV211	June 1, 2020	-	Passed	0.0330	Passed		
Citadel High School	3rd Floor Staff Room tap 1	APZO30	April 17, 2025	-	Passed	0.1100	Passed		
Citadel High School	3rd Floor Staff Room tap 2	APZO31	April 17, 2025	-	Passed	0.0240	Passed		
Citadel High School	3rd Floor Staff Room tap 3	APZO32	April 17, 2025	-	Passed	0.0230	Passed		
Citadel High School	Biology Lab 209 tap 1	MTU825	June 1, 2020	-	Passed	0.0400	Passed		
Citadel High School	Biology Lab 209 tap 2	MTU826	June 1, 2020	-	Passed	0.0600	Passed		
Citadel High School	Biology Lab 209 tap 3	MTU827	June 1, 2020	-	Passed	0.0480	Passed		
Citadel High School	Biology Lab 209 tap 4	MTU828	June 1, 2020	-	Passed	0.0330	Passed		
Citadel High School	Biology Lab 209 tap 5	MTU829	June 1, 2020	-	Passed	0.0300	Passed		
Citadel High School	Boiler Room tap	MTU887	June 1, 2020	-	Passed	0.2400	Passed		
Citadel High School	Boys Locker Room tap 1	MTU917	June 1, 2020	0.001	Passed	0.2600	Passed		
Citadel High School	Boys Locker Room tap 2 Room 153	MTU918	June 1, 2020	0.003	Passed	0.1200	Passed		
Citadel High School	Boys Wash Room 316 tap 1	MTV192	June 1, 2020	-	Passed	0.0550	Passed		
Citadel High School	Boys Wash Room 316 tap 2	MTV193	June 1, 2020	-	Passed	0.0410	Passed		
Citadel High School	Boys Wash Room 316 tap 3	MTV194	June 1, 2020	0.001	Passed	0.0590	Passed		
Citadel High School	Boys Wash Room 316 tap 4	MTV195	June 1, 2020	0.002	Passed	0.3300	Passed		
Citadel High School	Boys Wash Room 316 tap 5	MTV196	June 1, 2020	0.001	Passed	0.1200	Passed		
Citadel High School	Boys Wash Room tap 1 by Room 122	MTU922	June 1, 2020	0.001	Passed	0.0400	Passed		
Citadel High School	Boys Wash Room tap 2 by Room 122	MTU923	June 1, 2020	-	Passed	0.0310	Passed		
Citadel High School	Boys Wash Room tap 3 by Room 122	MTU924	June 1, 2020	-	Passed	0.0640	Passed		
Citadel High School	Boys Wash Room tap 4 by Room 122	MTU925	June 1, 2020	-	Passed	0.0380	Passed		
Citadel High School	Cafeteria/Kitchen tap 1	APZ017	April 17, 2025	-	Passed	0.1100	Passed		
Citadel High School	Cafeteria/Kitchen tap 2	APZO18	April 17, 2025	-	Passed	0.1100	Passed		
Citadel High School	Cafeteria/Kitchen tap 3	APZO19	April 17, 2025	-	Passed	0.1100	Passed		
Citadel High School	Cafeteria/Kitchen tap 4	APZO20	April 17, 2025	-	Passed	0.1000	Passed		
Citadel High School	Cafeteria/Kitchen tap 5	APZO21	April 17, 2025	-	Passed	0.1300	Passed		
Citadel High School	Class Room 301 tap 1	MTV128	June 1, 2020	-	Passed	0.0360	Passed		
Citadel High School	Class Room 301 tap 2	MTV129	June 1, 2020	-	Passed	0.0250	Passed		
Citadel High School	Class Room 302 tap 1	MTV130	June 1, 2020	-	Passed	0.1400	Passed		
Citadel High School	Class Room 302 tap 2	MTV131	June 1, 2020	-	Passed	0.1300	Passed		
Citadel High School	Class Room 311 tap 2	MTV135	June 1, 2020	0.001	Passed	0.1600	Passed		
Citadel High School	Class Room 311 tap 3	MTV136	June 1, 2020	0.001	Passed	0.0920	Passed		
Citadel High School	Class Room 311 tap 4	MTV137	June 1, 2020	-	Passed	0.0580	Passed		
Citadel High School	Class Room 311 tap 5	MTV155	June 1, 2020	0.001	Passed	0.0880	Passed		
Citadel High School	Class Room 312 tap 1	MTV156	June 1, 2020	0.001	Passed	0.1100	Passed		
Citadel High School	Class Room 312 tap 2	MTV157	June 1, 2020	0.001	Passed	0.0690	Passed		
Citadel High School	Class Room 312 tap 3	MTV158	June 1, 2020	-	Passed	0.0610	Passed		
Citadel High School	Class Room 312 tap 4	MTV159	June 1, 2020	-	Passed	0.0560	Passed		
Citadel High School	Class Room 312 tap 5	MTV215	June 1, 2020	0.001	Passed	0.1300	Passed		
Citadel High School	Class Room 314 tap 1	MTV160	June 1, 2020	0.001	Passed	0.0560	Passed		
Citadel High School	Class Room 314 tap 10	MTV169	June 1, 2020	-	Passed	0.0300	Passed		
Citadel High School	Class Room 314 tap 2	MTV161	June 1, 2020	-	Passed	0.0400	Passed		
Citadel High School	Class Room 314 tap 3	MTV162	June 1, 2020	0.001	Passed	0.0530	Passed		
Citadel High School	Class Room 314 tap 4	MTV163	June 1, 2020	0.001	Passed	0.0710	Passed		
Citadel High School	Class Room 314 tap 5	MTV164	June 1, 2020	-	Passed	0.0420	Passed		
Citadel High School	Class Room 314 tap 6	MTV165	June 1, 2020	-	Passed	0.0490	Passed		
Citadel High School	Class Room 314 tap 7	MTV166	June 1, 2020	-	Passed	0.0510	Passed		
Citadel High School	Class Room 314 tap 8	MTV167	June 1, 2020	-	Passed	0.0480	Passed		
Citadel High School	Class Room 314 tap 9	MTV168	June 1, 2020	-	Passed	0.0160	Passed		
Citadel High School	Class Room 315 tap 1	MTV170	June 1, 2020	0.001	Passed	0.1000	Passed		
Citadel High School	Class Room 315 tap 2	MTV171	June 1, 2020	-	Passed	0.0430	Passed		
Citadel High School	Class Room 315 tap 3	MTV172	June 1, 2020	0.001	Passed	0.0520	Passed		
Citadel High School	Class Room 315 tap 4	MTV173	June 1, 2020	-	Passed	0.0510	Passed		
Citadel High School	Class Room 315 tap 5	MTV174	June 1, 2020	-	Passed	0.0430	Passed		
Citadel High School	Class Room 315 tap 6	MTV188	June 1, 2020	-	Passed	0.0380	Passed		
Citadel High School	Class Room 315 tap 7	MTV189	June 1, 2020	-	Passed	0.0220	Passed		
Citadel High School	Class Room 315 tap 8	MTV190	June 1, 2020	-	Passed	0.0140	Passed		
Citadel High School	Class Room 315 tap 9	MTV191	June 1, 2020	-	Passed	0.0140	Passed		
Citadel High School	Class Room 321 tap 1	MTV205	June 1, 2020	-	Passed	0.1100	Passed		
Citadel High School	Class Room 321 tap 2	MTV206	June 1, 2020	-	Passed	0.0410	Passed		
Citadel High School	Class Room 321 tap 3	MTV207	June 1, 2020	-	Passed	0.0380	Passed		
Citadel High School	Class Room 321 tap 4	MTV208	June 1, 2020	-	Passed	0.0310	Passed		
C									

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - December, 2025

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Clayton Park Junior High School	Boys Wash Room tap 1 by Room 100	MRM476	May 21, 2020	-	Passed	0.0084	Passed	
Clayton Park Junior High School	Boys Wash Room tap 2 by Room 100	MRM477	May 21, 2020	-	Passed	0.0140	Passed	
Clayton Park Junior High School	Boys Wash Room tap 3 by Room 100	MRM478	May 21, 2020	0.002	Passed	0.0530	Passed	
Clayton Park Junior High School	Janitors Closet tap by Room 100	MRM480	May 21, 2020	-	Passed	0.0099	Passed	
Clayton Park Junior High School	Girls Wash Room tap 1 by Room 104	MRM481	May 21, 2020	-	Passed	0.0600	Passed	
Clayton Park Junior High School	Girls Wash Room tap 2 by Room 104	MRM482	May 21, 2020	-	Passed	0.0840	Passed	
Clayton Park Junior High School	Janitors Closet tap by Room 003	MRM485	May 21, 2020	0.001	Passed	0.0650	Passed	
Clayton Park Junior High School	Class Room tap Room 023	MRM488	May 21, 2020	-	Passed	0.0830	Passed	
Clayton Park Junior High School	Class Room tap Room 025	MRM489	May 21, 2020	-	Passed	0.0470	Passed	
Clayton Park Junior High School	Principals Office Wash Room tap Room 117	MRM490	May 21, 2020	0.001	Passed	0.0280	Passed	
Clayton Park Junior High School	Art Room tap by Gym	MRM491	May 21, 2020	0.001	Passed	0.0730	Passed	
Clayton Park Junior High School	Fountain by Room 118	APTC54	April 10, 2025	-	Passed	0.0880	Passed	
Clayton Park Junior High School	Family Studies tap 1 by Room 106	APTC57	April 10, 2025	-	Passed	0.0180	Passed	
Clayton Park Junior High School	Family Studies tap 2 by Room 106	APTC58	April 10, 2025	-	Passed	0.0310	Passed	
Clayton Park Junior High School	Family Studies tap 3 by Room 106	APTC59	April 10, 2025	-	Passed	0.0260	Passed	
Clayton Park Junior High School	Family Studies tap 4 by Room 106	APTC60	April 10, 2025	-	Passed	0.0180	Passed	
Clayton Park Junior High School	Family Studies tap 5 by Room 106	APTC61	April 10, 2025	-	Passed	0.0510	Passed	
Clayton Park Junior High School	Staff Room 104 tap	APTC56	April 10, 2025	-	Passed	0.0170	Passed	
Clayton Park Junior High School	Fountain by Room 100B	APTC55	April 10, 2025	-	Passed	0.0410	Passed	
Clayton Park Junior High School	Fountain by Room 200	APTC62	April 10, 2025	-	Passed	0.0450	Passed	
Clayton Park Junior High School	Boys Wash Room tap 3 by Room 200	WAT329	June 6, 2023	-	Passed	0.0220	Passed	
Clayton Park Junior High School	Family Studies tap 3 by Room 106	WAT332	June 6, 2023	-	Passed	0.0420	Passed	
Clayton Park Junior High School	Band Room Kitchen tap by Room 144	WAT362	June 6, 2023	0.004	Passed	0.0660	Passed	Tap remediated
Clayton Park Junior High School	Band Room Closet Kitchen tap by Room 144	WAT363	June 6, 2023	0.003	Passed	0.0410	Passed	Tap remediated
Clayton Park Junior High School	Class Room 214 tap	WAT364	June 6, 2023	0.002	Passed	0.2300	Passed	Tap remediated
Clayton Park Junior High School	Girls Wash Room tap 3 by Room 104	WAT365	June 6, 2023	-	Passed	0.0260	Passed	Tap remediated
Clayton Park Junior High School	Girls Locker Room tap by Room 114	WAT366	June 6, 2023	0.001	Passed	0.1000	Passed	Tap remediated
Clayton Park Junior High School	Conference Room 134 tap	WAT367	June 6, 2023	0.001	Passed	0.0360	Passed	
Clayton Park Junior High School	Modular Janitors Closet tap	WAT368	June 6, 2023	-	Passed	0.1100	Passed	
Clayton Park Junior High School	Modular Girls Wash Room tap 1	WAT369	June 6, 2023	-	Passed	0.1100	Passed	
Clayton Park Junior High School	Modular Girls Wash Room tap 2	WAT370	June 6, 2023	-	Passed	0.0940	Passed	
Clayton Park Junior High School	Modular Girls Wash Room tap 3	WAT371	June 6, 2023	0.001	Passed	0.1000	Passed	
Clayton Park Junior High School	Modular Boys Wash Room tap 1	WAT375	June 6, 2023	-	Passed	0.0650	Passed	
Clayton Park Junior High School	Modular Boys Wash Room tap 2	WAT376	June 6, 2023	-	Passed	0.0620	Passed	
Clayton Park Junior High School	Modular Staff Wash Room tap	WAT377	June 6, 2023	-	Passed	0.2400	Passed	
Clayton Park Junior High School	Fountain in Modular	APTC63	April 10, 2025	-	Passed	0.0340	Passed	
Clayton Park Junior High School	Modular Gender Neutral Wash Room tap	WAT379	June 6, 2023	-	Passed	0.0960	Passed	
Colby Village Elementary	Boys Wash Room 114 tap 1	XDA402	June 12, 2020	-	Passed	0.0140	Passed	
Colby Village Elementary	Boys Wash Room 114 tap 2	MWG583	June 12, 2020	0.003	Passed	0.2600	Passed	
Colby Village Elementary	Boys Wash Room 114 tap 3	XDA403	September 26, 2023	-	Passed	0.0068	Passed	Tap remediated
Colby Village Elementary	Boys Wash Room 114 tap 4	XDA404	September 26, 2023	-	Passed	0.0061	Passed	Tap remediated
Colby Village Elementary	Boys Wash Room 216 tap 1	XDA401	September 26, 2023	0.001	Passed	0.1200	Passed	Tap remediated
Colby Village Elementary	Boys Wash Room 216 tap 2	MWG571	June 12, 2020	0.004	Passed	0.1300	Passed	
Colby Village Elementary	Boys Wash Room 216 tap 3	MWG572	June 12, 2020	0.003	Passed	0.0270	Passed	
Colby Village Elementary	Boys Wash Room 216 tap 4	MWG573	June 12, 2020	0.003	Passed	0.0250	Passed	
Colby Village Elementary	Class Room 203 tap	XDA400	September 26, 2023	-	Passed	0.0150	Passed	Tap remediated
Colby Village Elementary	Fountain by Gym	AROK60	June 4, 2025	-	Passed	0.0290	Passed	
Colby Village Elementary	Fountain by Staff Room 105	AROK59	June 4, 2025	-	Passed	0.0011	Passed	
Colby Village Elementary	Gender Neutral Wash Room 215 tap	MWG580	June 12, 2020	0.004	Passed	0.0700	Passed	
Colby Village Elementary	Gender Neutral Wash Room 217 tap	XDA384	September 26, 2023	-	Passed	0.0650	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 110 tap 1	XDA378	September 26, 2023	0.003	Passed	0.2600	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 110 tap 2	XDA379	September 26, 2023	0.002	Passed	0.1400	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 110 tap 3	XDA380	September 26, 2023	0.001	Passed	0.0390	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 110 tap 4	XDA381	September 26, 2023	0.001	Passed	0.0520	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 214 tap 1	MWG576	June 12, 2020	0.004	Passed	0.0660	Passed	
Colby Village Elementary	Girls Wash Room 214 tap 2	MWG577	June 12, 2020	0.004	Passed	0.0640	Passed	
Colby Village Elementary	Girls Wash Room 214 tap 3	XDA399	September 26, 2023	-	Passed	0.0170	Passed	Tap remediated
Colby Village Elementary	Girls Wash Room 214 tap 4	MWG579	June 12, 2020	0.005	Passed	0.0670	Passed	
Colby Village Elementary	Janitors Closet tap by Gym	MWG574	June 12, 2020	0.001	Passed	0.0520	Passed	
Colby Village Elementary	Janitors Closet tap by Staff Room 105	MWG586	June 12, 2020	0.001	Passed	0.0470	Passed	
Colby Village Elementary	Staff Room 105 tap	AROK58	June 4, 2025	-	Passed	0.0049	Passed	
Colby Village Elementary	Staff Room Wash Room 105A tap	XDA383	September 26, 2023	-	Passed	0.0260	Passed	Tap remediated
Colby Village Elementary	Staff Room Wash Room 105B tap	XDA382	September 26, 2023	-	Passed	0.0260	Passed	Tap remediated
Cole Harbour District High School	Air Handler Room tap	MXH664	June 17, 2020	-	Passed	0.3300	Passed	
Cole Harbour District High School	Boys Wash Room tap 1 by Cafeteria	XDF167	September 27, 2023	0.001	Passed	0.0620	Passed	Tap remediated
Cole Harbour District High School	Boys Wash Room tap 1 by Room 108	MXH689	June 17, 2020	0.002	Passed	0.0950	Passed	
Cole Harbour District High School	Boys Wash Room tap 1 by Room 309	MXH630	June 17, 2020	0.004	Passed	0.2500	Passed	
Cole Harbour District High School	Boys Wash Room tap 2 by Cafeteria	MXH645	June 17, 2020	0.001	Passed	0.1100	Passed	
Cole Harbour District High School	Boys Wash Room tap 2 by Room 108	XDF163	September 27, 2023	0.001	Passed	0.0420	Passed	Tap remediated
Cole Harbour District High School	Boys Wash Room tap 2 by Room 309	MXH631	June 17, 2020	0.002	Passed	0.3400	Passed	
Cole Harbour District High School	Boys Wash Room tap 3 by Cafeteria	MXH646	June 17, 2020	0.002	Passed	0.0950	Passed	
Cole Harbour District High School	Cafeteria/Kitchen handwashing tap	ARGG84	May 27, 2025	-	Passed	0.0250	Passed	
Cole Harbour District High School	Cafeteria/Kitchen single compartment sink tap	ARGG85	May 27, 2025	-	Passed	0.0250	Passed	
Cole Harbour District High School	Cafeteria/Kitchen triple compartment sink tap	ARGG86	May 27, 2025	-	Passed	0.0250	Passed	
Cole Harbour District High School	Class Room 109 tap 1	XDF158	September 27, 2023	0.002	Passed	0.1000	Passed	Tap remediated
Cole Harbour District High School	Class Room 109 tap 2	XDF159	September 27, 2023	0.001	Passed	0.0700	Passed	Tap remediated
Cole Harbour District High School	Class Room 116 tap	XDF160	September 27, 2023	0.001	Passed	0.2800	Passed	Tap remediated
Cole Harbour District High School	Class Room 117 tap	NMD829	August 27, 2020	0.000	Passed	0.0260	Passed	
Cole Harbour District High School	Class Room 118 tap	NMD841	August 27, 2020	0.000	Passed	0.0040	Passed	
Cole Harbour District High School	Female Locker Room tap 1	MXH660	June 17, 2020	-	Passed	0.6200	Passed	
Cole Harbour District High School	Female Locker Room tap 2	MXH661	June 17, 2020	0.001	Passed	0.6200	Passed	
Cole Harbour District High School	Female Locker Room tap 3	MXH662	June 17, 2020	-	Passed	0.4900	Passed	
Cole Harbour District High School	Female Locker Room tap 4	MXH663	June 17, 2020	-	Passed	0.4100	Passed	
Cole Harbour District High School	Food Lab Tap 1 (Breakfast room)	ARGG91	May 27, 2025	-	Passed	0.0062	Passed	
Cole Harbour District High School	Food Lab Tap 2 (Breakfast room)	ARGG92	May 27, 2025	-	Passed	0.0062	Passed	
Cole Harbour District High School	Food Lab Tap 3 (Breakfast room)	ARGG93	May 27, 2025	-	Passed	0.0049	Passed	
Cole Harbour District High School	Food Lab Tap 4 (Breakfast room)	ARGG94	May 27, 2025	-	Passed	0.0052	Passed	
Cole Harbour District High School	Fountain by Cafeteria	XDF141	September 27, 2023	-	Passed	0.4900	Passed	Removed
Cole Harbour District High School	Fountain by Gym	ARGG87	May 27, 2025	-	Passed	0.1300	Passed	
Cole Harbour District High School	Fountain by Room 108	ARGG95	May 27, 2025	0.003	Passed	0.0082	Passed	
Cole Harbour District High School	Fountain by Room 117	ARGG96	May 27, 2025	-	Passed	0.0520	Passed	
Cole Harbour District High School	Fountain by Room 208	ARGG88	May 27, 2025	-	Passed	0.0220	Passed	
Cole Harbour District High School	Fountain by Room 308	ARGG90	May 27, 2025	-	Passed	0.0710	Passed	
Cole Harbour District High School	Fountain in Skilled Trades Room	ARGG97	May 27, 2025	0.001	Passed	0.2300	Passed	
Cole Harbour District High School	Gender Neutral Wash Room tap by Learning Centre	MXH640	June 17, 2020	-	Passed	0.7000	Passed	
Cole Harbour District High School	Gender Neutral Wash Room tap Room 116	MXH694	June 17, 2020	0.003	Passed	0.3600	Passed	
Cole Harbour District High School	Girls Wash Room tap 1 by Janitors Closet	MXH648	June 17, 2020	0.005	Passed	0.1900	Passed	
Cole Harbour District High School	Girls Wash Room tap 1 by Room 108	XDF164	September 27, 2023	0.001	Passed	0.0430	Passed	Tap remediated
Cole Harbour District High School	Girls Wash Room tap 1 by Room 309	XDF154	September 27, 2023	0.001	Passed	0.1500	Passed	Tap remediated
Cole Harbour District High School	Girls Wash Room tap 2 by Janitors Closet	MXH649	June 17, 2020	0.002	Passed	0.1200	Passed	
Cole Harbour District High School	Girls Wash Room tap 2 by Room 108	MXH687	June 17, 2020	0.004	Passed	0.1600	Passed	
Cole Harbour District High School	Girls Wash Room tap 2 by Room 309	MXH635	June 17, 2020	0.003	Passed	0.2300	Passed	
Cole Harbour District High School	Girls Wash Room tap 3 by Janitors Closet	XDF168	September 27, 2023	0.001	Passed	0.0490	Passed	Tap remediated
Cole Harbour District High School	Janitors Closet 112 tap	XDF165	September 27, 2023	0.001	Passed	0.0860	Passed	Tap remediated
Cole Harbour District High School	Janitors Closet tap by Cafeteria	MXH647	June 17, 2020	0.001	Passed	0.0450	Passed	
Cole Harbour District High School	Janitors Closet tap by Room 117	XDF157	September 27, 2023	-	Passed	0.0150	Passed	Tap remediated
Cole Harbour District High School	Janitors Closet tap by Room 309	MXH632	June 17, 2020	0.001	Passed	0.1600	Passed	
Cole Harbour District High School	Janitors Closet tap in Mechanical Room	XDF171	September 27, 2023	-	Passed	0.0220	Passed	Tap remediated
Cole Harbour District High School	Lab sink between Room 120 and 119	XDF166	September 27, 2023	0.004	Passed	0.0500	Passed	Tap remediated
Cole Harbour District High School	Learning Centre tap (204)	ARGG98	May 27, 2025	-	Passed	0.0130	Passed	
Cole Harbour District High School	Learning Centre Wash Room tap	MXH638	June 17, 2020	0.001	Passed	1.2000	Passed	
Cole Harbour District High School	Male Locker Room tap 1	XDF170	September 27, 2023	-	Passed	0.1800	Passed	Tap remediated
Cole Harbour District High School	Male Locker Room tap 2	MXH656	June 17, 2020	-	Passed	0.7900	Passed	
Cole Harbour District High School	Male Locker Room tap 3	MXH657	June 17, 2020	0.001	Passed	0.7800	Passed	
Cole Harbour District High School	Male Locker Room tap 4	MXH658	June 17, 2020	-	Passed	0.8200	Passed	
Cole Harbour District High School	Science Lab 113 tap 1	MXH704	June 17, 2020	0.083	Exceeded	0.7500	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 113 tap 2	MXH705	June 17, 2020	0.011	Exceeded	1.1000	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 113 tap 3	MXH706	June 17, 2020	1.100	Exceeded	0.5200	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 114 tap 1	MXH700	June 17, 2020	0.052	Exceeded	2.4000	Exceeded	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 114 tap 2	MXH701	June 17, 2020	0.017	Exceeded	1.5000	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 114 tap 3	MXH702	June 17, 2020	0.007	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 114 tap 4	MXH703	June 17, 2020	0.010	Exceeded	0.1600	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 115 tap 1	MXH696	June 17, 2020	0.094	Exceeded	0.8200	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 115 tap 2	MXH697	June 17, 2020	0.061	Exceeded	0.3200	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 115 tap 3	MXH698	June 17, 2020	0.030	Exceeded	0.7900	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 115 tap 4	MXH699	June 17, 2020	0.093	Exceeded	0.5600	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 1	MXH678	June 17, 2020	0.007	Exceeded	0.5600	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 2	MXH679	June 17, 2020	0.066	Exceeded	0.7400	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 3	MXH680	June 17, 2020	0.220	Exceeded	0.4700	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 4	MXH681	June 17, 2020	0.120	Exceeded	0.5000	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 5	MXH682	June 17, 2020	0.067	Exceeded	0.7200	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 6	MXH683	June 17, 2020	0.007	Exceeded	0.3900	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 119 tap 7	MXH684	June 17, 2020	0.030	Exceeded	0.8500	Passed	Laboratory or Hand washing only
Cole Harbour District High School	Science Lab 120 tap 1	MXH669	June 17, 2020	0.006	Exceeded	0.1100	Passed	Laboratory or Hand washing only

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Cole Harbour District High School	Science Lab 120 tap 2	MXH670	June 17, 2020	0.370	Exceeded	1.7000	Passed	Laboratory or Hand washing only	
Cole Harbour District High School	Science Lab 120 tap 3	MXH671	June 17, 2020	0.013	Exceeded	0.8500	Passed	Laboratory or Hand washing only	
Cole Harbour District High School	Science Lab 120 tap 4	MXH672	June 17, 2020	0.080	Exceeded	0.6500	Passed	Laboratory or Hand washing only	
Cole Harbour District High School	Science Lab 120 tap 5	MXH673	June 17, 2020	0.036	Exceeded	1.1000	Passed	Laboratory or Hand washing only	
Cole Harbour District High School	Science Lab 120 tap 6	MXH674	June 17, 2020	0.100	Exceeded	0.9400	Passed	Laboratory or Hand washing only	
Cole Harbour District High School	Science Lab 120 tap 7	MXH675	June 17, 2020	0.016	Exceeded	0.7400	Passed	Laboratory or Hand washing only	
Cole Harbour District High School	Science Lab 120 tap 8	MXH676	June 17, 2020	0.026	Exceeded	0.9200	Passed	Laboratory or Hand washing only	
Cole Harbour District High School	Server Room tap in Library	XDF154	September 27, 2023	0.025	Exceeded	0.0560	Passed	Hand washing only	
Cole Harbour District High School	Staff Room 208 tap	ARGG89	May 27, 2025	-	Passed	0.0230	Passed		
Cole Harbour District High School	Staff Wash Room tap By Room 108	XDF162	September 27, 2023	-	Passed	0.0170	Passed	Tap remediated	
Cole Harbour District High School	Staff Wash Room tap by Room 208	MXH642	June 17, 2020	0.004	Passed	0.0710	Passed		
Cole Harbour District High School	Staff Wash Room tap by Room 308	MXH629	June 17, 2020	0.001	Passed	0.0660	Passed		
Cole Harbour District High School	Staff Wash Room tap in main Office	MXH667	June 17, 2020	0.001	Passed	0.3700	Passed		
Cole Harbour District High School	Student Services Gender Neutral Wash Room tap	MXH651	June 17, 2020	-	Passed	0.5600	Passed		
Cole Harbour District High School	Student Services Gender Neutral Wash Room tap	MXH659	June 17, 2020	0.002	Passed	0.8000	Passed		
Colonel John Stuart Elementary	Boys Wash Room tap 1 by fountain	MWG665	June 12, 2020	0.003	Passed	0.1700	Passed		
Colonel John Stuart Elementary	Boys Wash Room tap 2 by fountain	MWG666	June 12, 2020	0.003	Passed	0.1100	Passed		
Colonel John Stuart Elementary	Boys Wash Room tap 3 by fountain	MWG667	June 12, 2020	0.004	Passed	0.0930	Passed		
Colonel John Stuart Elementary	Class Room 101 tap	NMD725	August 27, 2020	0.001	Passed	0.1600	Passed		
Colonel John Stuart Elementary	Class Room 102 tap 1	XGX861	October 13, 2023	-	Passed	0.0520	Passed		
Colonel John Stuart Elementary	Class Room 102 tap 2	XGX862	October 13, 2023	-	Passed	0.0480	Passed		
Colonel John Stuart Elementary	Excel 102	ARXU10	June 13, 2025	-	Passed	0.0300	Passed		
Colonel John Stuart Elementary	Fountain between Wash Rooms	ARXU09	June 13, 2025	-	Passed	0.0180	Passed		
Colonel John Stuart Elementary	Fountain by Main Entrance	ARXU11	June 13, 2025	-	Passed	0.0460	Passed		
Colonel John Stuart Elementary	Girls Wash Room tap 1 by fountain	MWG660	June 12, 2020	0.004	Passed	0.0990	Passed		
Colonel John Stuart Elementary	Girls Wash Room tap 2 by fountain	MWG661	June 12, 2020	0.004	Passed	0.0670	Passed		
Colonel John Stuart Elementary	Girls Wash Room tap 3 by fountain	MWG662	June 12, 2020	0.003	Passed	0.0540	Passed		
Colonel John Stuart Elementary	Girls Wash Room tap 4 by fountain	MWG663	June 12, 2020	0.004	Passed	0.0880	Passed		
Colonel John Stuart Elementary	Janitors Closet by Wash Rooms tap	MWG659	June 12, 2020	0.001	Passed	0.1000	Passed		
Colonel John Stuart Elementary	Staff Room tap	ARXU08	June 13, 2025	-	Passed	0.0091	Passed		
Colonel John Stuart Elementary	Staff Room Wash Room 1 tap	MWG656	June 12, 2020	0.001	Passed	0.0510	Passed		
Colonel John Stuart Elementary	Staff Room Wash Room 2 tap	MWG657	June 12, 2020	0.002	Passed	0.0840	Passed		
Colonel John Stuart Elementary	Wash Room by Gym	MWG653	June 12, 2020	0.001	Passed	0.1700	Passed		
Creighton Park Elementary	Boys Wash Room 111 tap 1	XBL630	September 19, 2023	-	Passed	0.0033	Passed	Tap remediated	
Creighton Park Elementary	Boys Wash Room 111 tap 2	XBL631	September 19, 2023	-	Passed	0.0046	Passed	Tap remediated	
Creighton Park Elementary	Boys Wash Room 111 tap 3	MYR672	June 24, 2020	-	Passed	0.0080	Passed		
Creighton Park Elementary	Boys Wash Room 122 tap	XBL594	September 19, 2023	-	Passed	0.0120	Passed	Tap remediated	
Creighton Park Elementary	Boys Wash Room 204 tap 1	XBL595	September 19, 2023	-	Passed	0.0840	Passed	Tap remediated	
Creighton Park Elementary	Boys Wash Room 204 tap 2	MYR677	June 24, 2020	0.001	Passed	0.0150	Passed		
Creighton Park Elementary	Class Room 101 Wash Room tap	XBL593	September 19, 2023	0.001	Passed	0.0320	Passed	Tap remediated	
Creighton Park Elementary	Class Room 102 Wash Room tap	XBL637	September 19, 2023	0.003	Passed	0.0550	Passed	Tap remediated	
Creighton Park Elementary	Class Room 103 Wash Room tap	XBL636	September 19, 2023	0.001	Passed	0.0310	Passed	Tap remediated	
Creighton Park Elementary	Class Room 126 tap	KKX081	October 26, 2023	0.004	Passed	0.2500	Passed	Tap remediated	
Creighton Park Elementary	Class Room 208 tap	XBL540	September 19, 2023	0.003	Passed	0.0370	Passed	Tap remediated	
Creighton Park Elementary	Fountain by Main Entrance	AROK72	June 4, 2025	-	Passed	0.1600	Passed		
Creighton Park Elementary	Fountain by Room 110	AROK73	June 4, 2025	-	Passed	0.0950	Passed		
Creighton Park Elementary	Fountain by Room 121	AROK74	June 4, 2025	-	Passed	0.2900	Passed		
Creighton Park Elementary	Fountain by Room 201	AROK75	June 4, 2025	-	Passed	0.0006	Passed		
Creighton Park Elementary	Girls Wash Room 109 tap 1	XBL629	September 19, 2023	-	Passed	0.0150	Passed	Tap remediated	
Creighton Park Elementary	Girls Wash Room 109 tap 2	MYR665	June 24, 2020	0.001	Passed	0.0790	Passed		
Creighton Park Elementary	Girls Wash Room 109 tap 3	MYR666	June 24, 2020	0.003	Passed	0.1800	Passed		
Creighton Park Elementary	Girls Wash Room 109 tap 4	MYR667	June 24, 2020	0.002	Passed	0.1100	Passed		
Creighton Park Elementary	Girls Wash Room 120 tap	MYR705	June 24, 2020	-	Passed	0.0082	Passed		
Creighton Park Elementary	Girls Wash Room 206 tap 1	XBL598	September 19, 2023	0.001	Passed	0.0076	Passed	Tap remediated	
Creighton Park Elementary	Girls Wash Room 206 tap 2	XBL599	September 19, 2023	-	Passed	0.0067	Passed	Tap remediated	
Creighton Park Elementary	Gym Office 125 tap	XBL596	September 19, 2023	0.001	Passed	0.0680	Passed	Tap remediated	
Creighton Park Elementary	Janitors Closet 121 tap	MYR687	June 24, 2020	0.005	Passed	0.0640	Passed		
Creighton Park Elementary	Janitors Closet 205 tap	XBL600	September 19, 2023	-	Passed	0.0070	Passed	Tap remediated	
Creighton Park Elementary	Janitors Closet tap in Boiler Room	MYR673	June 24, 2020	0.001	Passed	0.0170	Passed		
Creighton Park Elementary	Janitors Closet tap in Boys Wash Room 111	XBL632	September 19, 2023	0.001	Passed	0.0065	Passed	Tap remediated	
Creighton Park Elementary	Staff Room 107 tap	AROK76	June 4, 2025	-	Passed	0.0092	Passed		
Creighton Park Elementary	Staff Room 203 tap	AROK77	June 4, 2025	0.002	Passed	0.0040	Passed	Tap remediated	
Creighton Park Elementary	Staff Room 203 Wash Room tap	KKX062	October 26, 2023	-	Passed	0.0230	Passed	Tap remediated	
Cunard Junior High School	Boys Wash Room 107 tap 1	VQL889	April 25, 2023	-	Passed	0.0036	Passed	Tap remediated	
Cunard Junior High School	Boys Wash Room 107 tap 2	MRE126	May 20, 2020	0.001	Passed	0.0560	Passed		
Cunard Junior High School	Boys Wash Room 107 tap 3	MRE127	May 20, 2020	-	Passed	0.0220	Passed		
Cunard Junior High School	Boys Wash Room 107 tap 4	MRE136	May 20, 2020	0.001	Passed	0.0300	Passed		
Cunard Junior High School	Boys Wash Room 209 tap 1	MRE108	May 20, 2020	0.002	Passed	0.1700	Passed		
Cunard Junior High School	Boys Wash Room 209 tap 2	MRE109	May 20, 2020	0.001	Passed	0.0900	Passed		
Cunard Junior High School	Boys Wash Room 209 tap 3	MRE110	May 20, 2020	0.001	Passed	0.0680	Passed		
Cunard Junior High School	Boys Wash Room 209 tap 4	MRE111	May 20, 2020	0.001	Passed	0.0630	Passed		
Cunard Junior High School	Class Room 106 tap	NKX298	August 14, 20						

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Dartmouth High School	Class Room 112 tap	XDB395	September 15, 2023	0.038	Exceeded	0.6700	Passed	Hand washing only	
Dartmouth High School	Class Room 114 tap	RVY046	February 14, 2022	0.002	Passed	0.4400	Passed		
Dartmouth High School	Class Room 116 tap	RVY026	February 14, 2022	0.003	Passed	0.2300	Passed		
Dartmouth High School	Class Room 120 tap 1	MYV870	June 24, 2020	0.001	Passed	0.1300	Passed		
Dartmouth High School	Class Room 120 tap 2	RVY044	February 14, 2022	0.001	Passed	0.1400	Passed		
Dartmouth High School	Class Room 213A tap	RVY037	February 14, 2022	0.002	Passed	0.2300	Passed		
Dartmouth High School	Class Room tap 1 Room 223	MYV894	June 24, 2020	0.002	Passed	0.2000	Passed		
Dartmouth High School	Class Room tap 2 Room 223	MYV895	June 24, 2020	0.001	Passed	0.4600	Passed		
Dartmouth High School	Family Studies tap 1	ARHM15	May 28, 2025	0.001	Passed	0.0580	Passed		
Dartmouth High School	Family Studies tap 2	ARHM16	May 28, 2025	0.001	Passed	0.0500	Passed		
Dartmouth High School	Family Studies tap 3	ARHM17	May 28, 2025	-	Passed	0.1000	Passed		
Dartmouth High School	Family Studies tap 4	ARHM18	May 28, 2025	-	Passed	0.0440	Passed		
Dartmouth High School	Family Studies tap 5	ARHM19	May 28, 2025	-	Passed	0.0540	Passed		
Dartmouth High School	Female Change Room 165 tap 1	MYV815	June 24, 2020	-	Passed	0.2900	Passed		
Dartmouth High School	Female Change Room 165 tap 2	MYV816	June 24, 2020	-	Passed	0.3600	Passed		
Dartmouth High School	Fountain by 218	ARHM24	May 28, 2025	-	Passed	0.1000	Passed		
Dartmouth High School	Fountain by 228 (New)	ARHM30	May 28, 2025	-	Passed	0.0500	Passed		
Dartmouth High School	Fountain by Cafeteria (Library)	ARHM31	May 28, 2025	-	Passed	0.0340	Passed		
Dartmouth High School	Fountain by 237	ARHM28	May 28, 2025	-	Passed	0.0530	Passed		
Dartmouth High School	Fountain by Health Centre	ARHM21	May 28, 2025	-	Passed	0.0810	Passed		
Dartmouth High School	Fountain by Office	ARHM20	May 28, 2025	-	Passed	0.0730	Passed		
Dartmouth High School	Fountain by Room 107	ARHM22	May 28, 2025	-	Passed	0.0430	Passed		
Dartmouth High School	Fountain by Room 115	ARHM23	May 28, 2025	-	Passed	0.0031	Passed		
Dartmouth High School	Fountain by Room 201	MYV900	June 24, 2020	-	Passed	0.3400	Passed	Out-of-Service	
Dartmouth High School	Fountain by Room 209	ARHM29	May 28, 2025	-	Passed	0.0200	Passed		
Dartmouth High School	Fountain by Room 251	XBD390	September 15, 2023	-	Passed	0.0480	Passed		
Dartmouth High School	Fountain near Physics Lab	XBD397	September 15, 2023	-	Passed	0.0005	Passed		
Dartmouth High School	Girls Locker Room 164 tap 1	MYV809	June 24, 2020	0.001	Passed	0.0310	Passed		
Dartmouth High School	Girls Locker Room 164 tap 2	MYV810	June 24, 2020	0.001	Passed	0.0980	Passed		
Dartmouth High School	Girls Wash Room tap 1 by Gym	MYV807	June 24, 2020	0.002	Passed	0.0390	Passed		
Dartmouth High School	Girls Wash Room tap 1 by Gym	MYV808	June 24, 2020	0.001	Passed	0.0470	Passed		
Dartmouth High School	Girls Wash Room tap 1 by Room 107	RVY022	February 14, 2022	-	Passed	0.4000	Passed		
Dartmouth High School	Girls Wash Room tap 1 by Room 112	MYV844	June 24, 2020	0.002	Passed	1.6000	Passed		
Dartmouth High School	Girls Wash Room tap 1 by Room 201	MYV898	June 24, 2020	0.001	Passed	0.3200	Passed		
Dartmouth High School	Girls Wash Room tap 1 by Room 208	MYV901	June 24, 2020	0.004	Passed	1.2000	Passed		
Dartmouth High School	Girls Wash Room tap 1 by Room 213	RVY040	February 14, 2022	0.002	Passed	0.2400	Passed		
Dartmouth High School	Girls Wash Room tap 1 near Library	MYV858	June 24, 2020	0.001	Passed	0.0940	Passed		
Dartmouth High School	Girls Wash Room tap 2 by Room 107	RVY023	February 14, 2022	-	Passed	0.4200	Passed		
Dartmouth High School	Girls Wash Room tap 2 by Room 112	MYV845	June 24, 2020	0.001	Passed	0.3100	Passed		
Dartmouth High School	Girls Wash Room tap 2 by Room 201	RVY043	February 14, 2022	0.001	Passed	0.2300	Passed		
Dartmouth High School	Girls Wash Room tap 2 by Room 208	RVY047	February 14, 2022	-	Passed	1.5000	Passed		
Dartmouth High School	Girls Wash Room tap 2 by Room 213	MYV890	June 24, 2020	0.005	Passed	0.1200	Passed		
Dartmouth High School	Girls Wash Room tap 2 near Library	MYV859	June 24, 2020	0.001	Passed	0.2700	Passed		
Dartmouth High School	Girls Wash Room tap 3 by Room 107	RVY024	February 14, 2022	0.001	Passed	0.2200	Passed		
Dartmouth High School	Girls Wash Room tap 3 by Room 112	MYV846	June 24, 2020	0.001	Passed	0.1800	Passed		
Dartmouth High School	Girls Wash Room tap 3 by Room 208	MYV903	June 24, 2020	0.002	Passed	0.3300	Passed		
Dartmouth High School	Girls Wash Room tap 3 by Room 213	MYV891	June 24, 2020	0.004	Passed	0.1100	Passed		
Dartmouth High School	Girls Wash Room tap 4 by Room 112	MYV847	June 24, 2020	0.001	Passed	0.2100	Passed		
Dartmouth High School	Girls Wash Room tap 4 by Room 208	MYV904	June 24, 2020	0.001	Passed	0.1500	Passed		
Dartmouth High School	Girls Wash Room tap 4 by Room 213	MYV892	June 24, 2020	0.004	Passed	0.1100	Passed		
Dartmouth High School	Gym Office Wash Room 161 tap	NAI329	June 29, 2020	0.003	Passed	0.6500	Passed		
Dartmouth High School	Gym Office Wash Room 162 tap	MYV811	June 24, 2020	-	Passed	0.6300	Passed		
Dartmouth High School	Health Centre Gender Neutral Wash Room tap	MYV803	June 24, 2020	0.001	Passed	0.9100	Passed		
Dartmouth High School	Janitors Closet tap by Room 106	MYV834	June 24, 2020	0.001	Passed	0.0880	Passed		
Dartmouth High School	Janitors Closet tap by Room 112	MYV848	June 24, 2020	-	Passed	1.1000	Passed		
Dartmouth High School	Janitors Closet tap by Room 208	RVY045	February 14, 2022	0.001	Passed	0.2600	Passed		
Dartmouth High School	Janitors Closet tap by Room 213	RVY039	February 14, 2022	0.002	Passed	0.4000	Passed		
Dartmouth High School	Janitors Closet tap by Staff Room	MYV863	June 24, 2020	0.003	Passed	0.0820	Passed		
Dartmouth High School	Learning Centre tap 1	XBD398	September 15, 2023	-	Passed	0.0160	Passed		
Dartmouth High School	Learning Centre tap 2	XBD399	September 15, 2023	-	Passed	0.0380	Passed		
Dartmouth High School	Main Office Wash Room tap	MYV801	June 24, 2020	-	Passed	0.1300	Passed		
Dartmouth High School	Music Room 125 tap	XDB393	September 15, 2023	-	Passed	0.0440	Passed		
Dartmouth High School	Music Storage Room 201 tap	RVY042	February 14, 2022	0.011	Exceeded	0.4400	Passed	Out-of-Service	
Dartmouth High School	Physics Lab tap 1 by Room 106	RVY015	February 14, 2022	0.007	Exceeded	0.2800	Passed	Laboratory or hand washing only	
Dartmouth High School	Physics Lab tap 2 by Room 106	RVY016	February 14, 2022	0.009	Exceeded	0.9700	Passed	Laboratory or hand washing only	
Dartmouth High School	Physics Lab Wash Room tap	RVY017	February 14, 2022	0.001	Passed	0.9700	Passed		
Dartmouth High School	Staff Room Wash Room 1 tap	RVY027	February 14, 2022	-	Passed	0.2700	Passed		
Dartmouth High School	Staff Room Wash Room 2 tap	RVY028	February 14, 2022	-	Passed	0.2700	Passed		
Dartmouth High School	Staff Wash Room tap by Room 213	RVY031	February 14, 2022	0.001	Passed	0.2000	Passed		
Dartmouth High School	Tech Ed Room tap	MYV872	June 24, 2020	0.001	Passed	1.7000	Passed		
Dartmouth High School	Wash Room 107 tap	RVY018	February 14, 2022	0.017	Exceeded	0.6000	Passed	Hand washing only	
Dartmouth South Academy	Art Room 230 tap 1	NAI191	June 29, 2020	0.002	Passed	0.1600	Passed		
Dartmouth South Academy	Art Room 230 tap 2	NAI192	June 29, 2020	0.001	Passed	0.1100	Passed		
Dartmouth South Academy	Art Room 230 tap 3	NAI193	June 29, 2020	-	Passed	0.8400	Passed		
Dartmouth South Academy	Class Room 148 tap	MYV784	June 24, 2020	-	Passed	0.1600	Passed		
Dartmouth South Academy	Class Room 148 Wash Room tap 1	MYV782	June 24, 2020	-	Passed	0.0880	Passed		
Dartmouth South Academy	Class Room 148 Wash Room tap 2	MYV783	June 24, 2020	0.001	Passed	0.1200	Passed		
Dartmouth South Academy	Class Room 149 tap	NAI211	June 29, 2020	-	Passed	0.2600	Passed		
Dartmouth South Academy	Class Room 150 tap	MYV785	June 24, 2020	-	Passed	0.0480	Passed		
Dartmouth South Academy	Class Room 151 tap	MYV789	June 24, 2020	-	Passed	0.3400	Passed		
Dartmouth South Academy	Class Room 152 tap	MYV786	June 24, 2020	-	Passed	0.1200	Passed		
Dartmouth South Academy	Class Room 153 tap	MYV788	June 24, 2020	0.001	Passed	0.2400	Passed		
Dartmouth South Academy	Class Room 155 tap	MYV787	June 24, 2020	-	Passed	0.2400	Passed		
Dartmouth South Academy	Class Room 241 tap	NAI207	June 29, 2020	-	Passed	0.0700	Passed		
Dartmouth South Academy	Class Room 244 tap	NAI197	June 29, 2020	-	Passed	0.3900	Passed		
Dartmouth South Academy	Class Room 245 tap	NAI206	June 29, 2020	-	Passed	0.4500	Passed		
Dartmouth South Academy	Class Room 247 tap	NAI200	June 29, 2020	0.002	Passed	1.2000	Passed		
Dartmouth South Academy	Class Room 251 tap	NAI199	June 29, 2020	-	Passed	0.4800	Passed		
Dartmouth South Academy	Family Studies Room 208 tap 1	ARFB55	May 26, 2025	-	Passed	0.0760	Passed		
Dartmouth South Academy	Family Studies Room 208 tap 2	ARFB56	May 26, 2025	-	Passed	0.0760	Passed		
Dartmouth South Academy	Family Studies Room 208 tap 3	ARFB57	May 26, 2025	-	Passed	0.0600	Passed		
Dartmouth South Academy	Family Studies Room 208 tap 4	ARFB58	May 26, 2025	-	Passed	0.0560	Passed		
Dartmouth South Academy	Family Studies Room 208 tap 5	ARFB59	May 26, 2025	-	Passed	0.0560	Passed		
Dartmouth South Academy	Fountain by Room 110A	ARFB67	May 26, 2025	-	Passed	0.2400	Passed		
Dartmouth South Academy	Fountain by Room 135	ARFB66	May 26, 2025	-	Passed	0.0930	Passed		
Dartmouth South Academy	Fountain by Room 204	ARFB60	May 26, 2025	-	Passed	0.3000	Passed		
Dartmouth South Academy	Fountain by Room 231	ARFB62	May 26, 2025	-	Passed	0.0870	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 106A tap	NAI156	June 29, 2020	-	Passed	0.0520	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 106B tap	NAI155	June 29, 2020	-	Passed	0.0690	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 106C tap	NAI154	June 29, 2020	0.001	Passed	0.0770	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 106D tap	NAI153	June 29, 2020	-	Passed	0.0600	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 106E tap	NAI152	June 29, 2020	0.002	Passed	0.1100	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 140 tap	MYV779	June 24, 2020	-	Passed	0.0850	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 142 tap 1	MYV780	June 24, 2020	0.001	Passed	0.1100	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 142 tap 2	MYV781	June 24, 2020	0.001	Passed	0.0940	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 206A tap	NAI178	June 29, 2020	-	Passed	0.0800	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 206B tap	NAI177	June 29, 2020	0.001	Passed	0.0700	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 206C tap	NAI176	June 29, 2020	0.001	Passed	0.1000	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 206D tap	NAI175	June 29, 2020	0.002	Passed	0.0710	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 206E tap	NAI174	June 29, 2020	0.001	Passed	0.0500	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 236 tap	NAI194	June 29, 2020	0.001	Passed	0.0700	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 238 tap 1	NAI195	June 29, 2020	0.001	Passed	0.1100	Passed		
Dartmouth South Academy	Gender Neutral Wash Room 238 tap 2	NAI196	June 29, 2020	0.001	Passed	0.2100	Passed		
Dartmouth South Academy	Gym Change Room 133DA tap	MYV799	June 24, 2020	0.001	Passed	0.1800	Passed		
Dartmouth South Academy	Gym Change Room 133DB Wash Room tap	MYV797	June 24, 2020	0.001	Passed	0.2900	Passed		
Dartmouth South Academy	Gym Change Room 133DN tap	MYV798	June 24, 2020						

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Dartmouth South Academy	Staff Room 204 tap	ARFB61	May 26, 2025	-	Passed	0.0410	Passed		
Dartmouth South Academy	Staff Room Wash Room 204A tap	NAI170	June 29, 2020	0.002	Passed	0.1400	Passed		
Dartmouth South Academy	Staff Room Wash Room 204B tap	NAI171	June 29, 2020	0.001	Passed	0.0720	Passed		
Dartmouth South Academy	Tech Ed Room 108 tap	NAI158	June 29, 2020	-	Passed	0.1600	Passed		
Dartmouth South Academy	Youth Health Room 107 tap	XAB766	September 14, 2023	-	Passed	0.0650	Passed		
Dartmouth Teachers Centre	Music Centre 1st Floor Janitors Closet tap	XGT705	October 12, 2023	-	Passed	0.0330	Passed		
Dartmouth Teachers Centre	Music Centre 2nd Floor Janitors Closet tap	XGT698	October 12, 2023	-	Passed	0.0110	Passed		
Dartmouth Teachers Centre	Music Centre Boys Wash Room tap 1	XGT702	October 12, 2023	0.003	Passed	0.0710	Passed		
Dartmouth Teachers Centre	Music Centre Boys Wash Room tap 2	XGT703	October 12, 2023	0.002	Passed	0.0880	Passed		
Dartmouth Teachers Centre	Music Centre Boys Wash Room tap 3	XGT704	October 12, 2023	0.001	Passed	0.0370	Passed		
Dartmouth Teachers Centre	Music Centre Fountain by Entrance	ARSN15	June 9, 2025	-	Passed	0.0770	Passed		
Dartmouth Teachers Centre	Music Centre Girls Wash Room tap 1	XGT699	October 12, 2023	0.001	Passed	0.0380	Passed		
Dartmouth Teachers Centre	Music Centre Girls Wash Room tap 2	XGT700	October 12, 2023	0.001	Passed	0.0390	Passed		
Dartmouth Teachers Centre	Music Centre Jarbold Room tap	ARSN16	June 9, 2025	0.003	Passed	0.0170	Passed	Hand washing only	
Dartmouth Teachers Centre	Music Centre Staff Wash Room tap	XGT697	October 12, 2023	-	Passed	0.0200	Passed		
Dartmouth Teachers Centre	Operations Female Wash Room tap 1	XGV157	October 12, 2023	0.002	Passed	0.0310	Passed		
Dartmouth Teachers Centre	Operations Female Wash Room tap 2	XGV158	October 12, 2023	0.001	Passed	0.0220	Passed		
Dartmouth Teachers Centre	Operations Fountain by Meeting Room	ARSN14	June 9, 2025	-	Passed	0.0970	Passed		
Dartmouth Teachers Centre	Operations Fountain by Wood Shop	ARSN12	June 9, 2025	-	Passed	0.1100	Passed		
Dartmouth Teachers Centre	Operations Gender Neutral Wash Room tap	XGV163	October 12, 2023	-	Passed	0.0120	Passed		
Dartmouth Teachers Centre	Operations Kitchen tap	ARSN13	June 9, 2025	0.002	Passed	0.0830	Passed		
Dartmouth Teachers Centre	Operations Male Wash Room tap	XGV162	October 12, 2023	-	Passed	0.0150	Passed		
Dartmouth Teachers Centre	Operations Paint Shop tap	XGV164	October 12, 2023	-	Passed	0.0170	Passed		
Dartmouth Teachers Centre	Operations Wood Shop Lunch Room tap	ARSN11	June 9, 2025	-	Passed	0.0110	Passed		
Dartmouth Teachers Centre	Operations Wood Shop tap	XGV164	October 12, 2023	-	Passed	0.0089	Passed		
Duc d'Anville Elementary	Boys Wash Room 421 tap 1	MRM345	May 21, 2020	0.001	Passed	0.0390	Passed		
Duc d'Anville Elementary	Boys Wash Room 421 tap 2	MRM346	May 21, 2020	0.001	Passed	0.0650	Passed		
Duc d'Anville Elementary	Boys Wash Room tap 1 by Room 134	MRM331	May 21, 2020	0.001	Passed	0.0780	Passed		
Duc d'Anville Elementary	Boys Wash Room tap 1 by Room 230	MRM312	May 21, 2020	-	Passed	0.0140	Passed		
Duc d'Anville Elementary	Boys Wash Room tap 2 by Room 134	MRM332	May 21, 2020	-	Passed	0.0200	Passed		
Duc d'Anville Elementary	Boys Wash Room tap 2 by Room 230	MRM313	May 21, 2020	0.001	Passed	0.0170	Passed		
Duc d'Anville Elementary	Boys Wash Room tap 3 by Room 134	MRM333	May 21, 2020	0.001	Passed	0.0140	Passed		
Duc d'Anville Elementary	Boys Wash Room tap 3 by Room 230	MRM314	May 21, 2020	0.001	Passed	0.0220	Passed		
Duc d'Anville Elementary	Boys Wash Room tap 4 by Room 230	MRM315	May 21, 2020	0.001	Passed	0.0250	Passed		
Duc d'Anville Elementary	Caretaker Room tap in Boys Wash Room	SWA358	June 8, 2022	-	Passed	0.0082	Passed		
Duc d'Anville Elementary	Class Room 230 tap	MRM311	May 21, 2020	0.002	Passed	0.0670	Passed		
Duc d'Anville Elementary	Class Room 306 Wash Room tap	MRM352	May 21, 2020	0.003	Passed	0.0760	Passed		
Duc d'Anville Elementary	Class Room 307 Wash Room tap	MRM353	May 21, 2020	0.001	Passed	0.0510	Passed		
Duc d'Anville Elementary	Class Room 311 Wash Room tap	MRM351	May 21, 2020	0.001	Passed	0.0440	Passed		
Duc d'Anville Elementary	Class Room 312 Wash Room tap	MRM350	May 21, 2020	0.004	Passed	0.0700	Passed		
Duc d'Anville Elementary	Class Room 405 tap	MRM342	May 21, 2020	0.001	Passed	0.6000	Passed		
Duc d'Anville Elementary	Fountain by 2nd Floor Wash Rooms	APT882	April 10, 2025	-	Passed	0.0170	Passed		
Duc d'Anville Elementary	Fountain by Room 146	APT881	April 10, 2025	-	Passed	0.0006	Passed		
Duc d'Anville Elementary	Fountain by Room 320	APT880	April 10, 2025	-	Passed	0.0150	Passed		
Duc d'Anville Elementary	Fountain in Modular	APT884	April 10, 2025	-	Passed	0.0650	Passed		
Duc d'Anville Elementary	Gender Neutral Wash Room 146 tap	SWA360	June 8, 2022	-	Passed	0.0110	Passed		
Duc d'Anville Elementary	Girls Wash Room 150 tap 1	MRM336	May 21, 2020	0.003	Passed	0.1200	Passed		
Duc d'Anville Elementary	Girls Wash Room 150 tap 2	MRM337	May 21, 2020	0.001	Passed	0.0096	Passed		
Duc d'Anville Elementary	Girls Wash Room 150 tap 3	MRM339	May 21, 2020	-	Passed	0.0150	Passed		
Duc d'Anville Elementary	Girls Wash Room 250 tap 1	MRM318	May 21, 2020	0.001	Passed	0.0690	Passed		
Duc d'Anville Elementary	Girls Wash Room 250 tap 2	MRM319	May 21, 2020	-	Passed	0.0150	Passed		
Duc d'Anville Elementary	Girls Wash Room 250 tap 3	MRM320	May 21, 2020	-	Passed	0.0095	Passed		
Duc d'Anville Elementary	Girls Wash Room 250 tap 4	MRM328	May 21, 2020	-	Passed	0.0120	Passed		
Duc d'Anville Elementary	Girls Wash Room 425 tap 1	MRM347	May 21, 2020	-	Passed	0.0180	Passed		
Duc d'Anville Elementary	Girls Wash Room 425 tap 2	MRM348	May 21, 2020	0.001	Passed	0.0180	Passed		
Duc d'Anville Elementary	Gym Office 415 Wash Room tap	MRM343	May 21, 2020	0.001	Passed	0.0400	Passed		
Duc d'Anville Elementary	Janitors Closet tap by Room 326	MRM341	May 21, 2020	0.001	Passed	0.0180	Passed		
Duc d'Anville Elementary	Janitors Closet tap by Room 415	MRM344	May 21, 2020	0.001	Passed	0.0230	Passed		
Duc d'Anville Elementary	Modular Accessible Wash Room tap	WAT035	June 6, 2023	-	Passed	0.0079	Passed		
Duc d'Anville Elementary	Modular Boys Wash Room tap 1	WAT038	June 6, 2023	-	Passed	0.0110	Passed		
Duc d'Anville Elementary	Modular Boys Wash Room tap 2	WAT039	June 6, 2023	-	Passed	0.0089	Passed		
Duc d'Anville Elementary	Modular Girls Wash Room tap 1	WAT036	June 6, 2023	-	Passed	0.0064	Passed		
Duc d'Anville Elementary	Modular Girls Wash Room tap 2	WAT037	June 6, 2023	-	Passed	0.0070	Passed		
Duc d'Anville Elementary	Modular Janitors Closet tap	WAT040	June 6, 2023	-	Passed	0.0055	Passed		
Duc d'Anville Elementary	Modular Staff Room tap	APT885	April 10, 2025	-	Passed	0.0068	Passed		
Duc d'Anville Elementary	Modular Staff Room Wash Room tap	WAT034	June 6, 2023	-	Passed	0.0049	Passed		
Duc d'Anville Elementary	Resources Room 326 Wash Room tap	MRM340	May 21, 2020	0.001	Passed	0.0200	Passed		
Duc d'Anville Elementary	Staff Room 260 tap	APT883	April 10, 2025	-	Passed	0.0045	Passed		
Duc d'Anville Elementary	Staff Room 260 Wash Room tap	MRM329	May 21, 2020	0.001	Passed	0.0480	Passed		
Dutch Settlement Elementary	Boys Wash Room 121 tap	MYZ477	June 6, 2023	0.001	Passed	0.3800	Passed		
Dutch Settlement Elementary	Janitors Closet 120 tap	MYZ478	June 6, 2023	0.001	Passed	0.2300	Passed		
Dutch Settlement Elementary	Girls Wash Room 119 tap 1	MYZ479	June 6, 2023	0.002	Passed	0.5000	Passed		
Dutch Settlement Elementary	Girls Wash Room 119 tap 2	MYZ480	June 25, 2020	0.002	Passed	0.2600	Passed		
Dutch Settlement Elementary	Staff Wash Room 112A tap	MYZ481	June 25, 2020	0.003	Passed	0.2800	Passed		
Dutch Settlement Elementary	Staff Kitchen 112 tap	MYZ482	June 25, 2020	0.001	Passed	0.0990	Passed		
Dutch Settlement Elementary	Class Room Wash Room 109 B tap	MYZ483	June 25, 2020	0.001	Passed	0.2500	Passed		
Dutch Settlement Elementary	Janitors Closet 104 tap	MYZ484	June 25, 2020	0.001	Passed	0.0980	Passed		
Dutch Settlement Elementary	Girls Wash Room 107 tap 2	MYZ510	June 25, 2020	-	Passed	0.0570	Passed		
Dutch Settlement Elementary	Boys Wash Room 105 tap 1	MYZ511	June 25, 2020	0.001	Passed	0.0680	Passed		
Dutch Settlement Elementary	Boys Wash Room 105 tap 2	MYZ512	June 25, 2020	0.002	Passed	0.0540	Passed		
Dutch Settlement Elementary	Kitchen 103 tap	MYZ513	June 25, 2020	0.002	Passed	0.5800	Passed		
Dutch Settlement Elementary	Class Room 102 Wash Room tap	MYZ514	June 25, 2020	0.002	Passed	0.7000	Passed		
Dutch Settlement Elementary	Girls Wash Room 107 tap 1	PHC298	April 8, 2021	-	Passed	0.0088	Passed		
Dutch Settlement Elementary	Gym Storage Room tap	PHC299	April 8, 2021	-	Passed	0.0087	Passed		
Dutch Settlement Elementary	Gym Office Wash Room tap	PHC300	April 8, 2021	-	Passed	0.0210	Passed		
East St. Margaret's Elementary	2nd Floor Boys Wash Room tap 1	SOY026	May 10, 2022	0.001	Passed	0.2100	Passed		
East St. Margaret's Elementary	2nd Floor Boys Wash Room tap 2	SOY027	May 10, 2022	0.001	Passed	0.2200	Passed		
East St. Margaret's Elementary	2nd Floor Girls Wash Room tap 1	SOY028	May 10, 2022	0.001	Passed	0.5600	Passed		
East St. Margaret's Elementary	2nd Floor Girls Wash Room tap 2	SOY029	May 10, 2022	0.002	Passed	0.5200	Passed		
East St. Margaret's Elementary	2nd Floor Girls Wash Room tap 3	SOY030	May 10, 2022	0.005	Exceeded	0.9900	Passed	Hand washing only	
East St. Margaret's Elementary	2nd Floor Gender Neutral Wash Room 1 tap	SOY031	May 10, 2022	0.014	Exceeded	0.1600	Passed	Hand washing only	
East St. Margaret's Elementary	2nd Floor Gender Neutral Wash Room 2 tap	SOY032	May 10, 2022	0.003	Passed	0.1600	Passed		
East St. Margaret's Elementary	1st Floor Girls Wash Room tap 1	SOY033	May 10, 2022	-	Passed	0.1500	Passed		
East St. Margaret's Elementary	1st Floor Girls Wash Room tap 2	SOY034	May 10, 2022	0.001	Passed	0.1800	Passed		
East St. Margaret's Elementary	Class Room 11 tap	SOY035	May 10, 2022	0.001	Passed	0.3800	Passed		
East St. Margaret's Elementary	Janitors Closet Room 5 tap	SOY036	May 10, 2022	0.001	Passed	0.1800	Passed		
Eastern Passage Education Centre	Art Room 1061 tap	NCE106	July 10, 2020	0.001	Passed	0.5500	Passed		
Eastern Passage Education Centre	Boys Wash Room tap 1 by Room 2072	NCE150	July 10, 2020	0.001	Passed	0.3800	Passed		
Eastern Passage Education Centre	Boys Wash Room tap 2 by Room 2072	NCE151	July 10, 2020	0.001	Passed	0.3600	Passed		
Eastern Passage Education Centre	Boys Wash Room tap 2 by Room 2072	NCE152	July 10, 2020	0.001	Passed	0.4400	Passed		
Eastern Passage Education Centre	Boys Wash Room tap 3 by Room 2072	NCE153	July 10, 2020	0.002	Passed	0.3000	Passed		
Eastern Passage Education Centre	Cafeteria Sink (New)	ARPJ35	June 5, 2025	-	Passed	0.3200	Passed		
Eastern Passage Education Centre	Cafeteria Double Sink tap	ARPJ33	June 5, 2025	-	Passed	0.0990	Passed		
Eastern Passage Education Centre	Cafeteria Hand Wash tap	ARPJ34	June 5, 2025	-	Passed	0.0810	Passed		
Eastern Passage Education Centre	Class Room 1072 tap 1	NCE100	July 10, 2020	0.001	Passed	1.7000	Passed		
Eastern Passage Education Centre	Class Room 1072 tap 2	WFH033	June 22, 2023	-	Passed	0.0800	Passed	Tap remediated	
Eastern Passage Education Centre	Class Room 1076 tap	WFH034	June 22, 2023	-	Passed	0.0560	Passed	Tap remediated	
Eastern Passage Education Centre	Class Room 1091 tap 1	NCE083	July 10, 2020	0.001	Passed	0.0710	Passed		
Eastern Passage Education Centre	Class Room 1091 tap 2	NCE084	July 10, 2020	0.001	Passed	0.0730	Passed		
Eastern Passage Education Centre	Class Room 1095 tap	NCE082	July 10, 2020	-	Passed	0.0790	Passed		
Eastern Passage Education Centre	Class Room 2046 tap 1	WFH041	June 22, 2023	-	Passed	0.1100	Passed	Tap remediated	
Eastern Passage Education Centre	Class Room 2046 tap 2	NCE146	July 10, 2020	-	Passed	0.8700	Passed		
Eastern Passage Education Centre	Class Room 2050 tap	NCE144	July 10, 2020	-	Passed	0.5300	Passed		
Eastern Passage Education Centre	Class Room 2053 tap 1	WFH042	June 22, 2023	-	Passed	0.3400	Passed	Tap remediated	
Eastern Passage Education Centre	Class Room 2053 tap 2	NCE143	July 10, 2020	-	Passed	0.6900	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Eastern Passage Education Centre	Girls Wash Room 1102 tap 1	NCE107	July 10, 2020	0.001	Passed	0.3500	Passed		
Eastern Passage Education Centre	Girls Wash Room 1102 tap 2	NCE108	July 10, 2020	0.002	Passed	0.3500	Passed		
Eastern Passage Education Centre	Girls Wash Room 1102 tap 3	NCE109	July 10, 2020	0.001	Passed	0.2600	Passed		
Eastern Passage Education Centre	Girls Wash Room 1102 tap 4	NCE110	July 10, 2020	-	Passed	0.2300	Passed		
Eastern Passage Education Centre	Girls Wash Room tap 1 by Room 2074	NCE154	July 10, 2020	0.003	Passed	0.5600	Passed		
Eastern Passage Education Centre	Girls Wash Room tap 2 by Room 2074	NCE155	July 10, 2020	0.004	Passed	0.6200	Passed		
Eastern Passage Education Centre	Girls Wash Room tap 3 by Room 2074	NCE156	July 10, 2020	0.002	Passed	0.5100	Passed		
Eastern Passage Education Centre	Girls Wash Room tap 4 by Room 2074	NCE157	July 10, 2020	0.005	Passed	0.2000	Passed		
Eastern Passage Education Centre	Gym Office Wash Room 1046 tap	NCE119	July 10, 2020	0.001	Passed	1.2000	Passed		
Eastern Passage Education Centre	Gym Office Wash Room 1048 tap	WFH181	June 22, 2023	0.001	Passed	1.5000	Passed	Tap remediated	
Eastern Passage Education Centre	Janitors Closet 1035 tap	NCE125	July 10, 2020	0.002	Passed	0.5500	Passed		
Eastern Passage Education Centre	Janitors Closet 1100 tap	NCE102	July 10, 2020	-	Passed	0.1900	Passed		
Eastern Passage Education Centre	Janitors Closet 2036 tap	NCE133	July 10, 2020	-	Passed	0.1100	Passed		
Eastern Passage Education Centre	Janitors Closet 2071 tap	NCE147	July 10, 2020	0.001	Passed	0.1600	Passed		
Eastern Passage Education Centre	Learning Centre 1079 tap	WFH175	June 22, 2023	-	Passed	0.1200	Passed		
Eastern Passage Education Centre	Learning Centre Wash Room 1081 tap	NCE097	July 10, 2020	0.002	Passed	0.2100	Passed		
Eastern Passage Education Centre	Male Locker Room 1050 tap 1	WFH182	June 22, 2023	0.005	Passed	1.1000	Passed	Tap remediated	
Eastern Passage Education Centre	Male Locker Room 1050 tap 2	WFH183	June 22, 2023	0.002	Passed	1.3000	Passed	Tap remediated	
Eastern Passage Education Centre	Male Wash Room 1103 tap 1	NCE112	July 10, 2020	0.002	Passed	0.1800	Passed		
Eastern Passage Education Centre	Male Wash Room 1103 tap 2	NCE113	July 10, 2020	0.001	Passed	0.1500	Passed		
Eastern Passage Education Centre	Male Wash Room 1103 tap 3	NCE114	July 10, 2020	0.002	Passed	0.3600	Passed		
Eastern Passage Education Centre	Male Wash Room 1103 tap 4	NCE115	July 10, 2020	0.001	Passed	0.2200	Passed		
Eastern Passage Education Centre	Music Room 1064 tap	NMV188	August 31, 2020	0.001	Passed	0.0950	Passed		
Eastern Passage Education Centre	Office Wash Room 1025 tap	NCE131	July 10, 2020	-	Passed	0.1900	Passed		
Eastern Passage Education Centre	Science Lab Room 1085 tap 1	NCE091	July 10, 2020	0.015	Exceeded	6.3000	Exceeded	Laboratory or Hand washing only	
Eastern Passage Education Centre	Science Lab Room 1085 tap 2	NCE092	July 10, 2020	0.001	Passed	1.0000	Passed		
Eastern Passage Education Centre	Science Lab Room 1085 tap 3	NCE093	July 10, 2020	0.002	Passed	0.5200	Passed		
Eastern Passage Education Centre	Science Lab Room 1085 tap 4	NCE094	July 10, 2020	0.001	Passed	0.5300	Passed		
Eastern Passage Education Centre	Science Lab Room 1085 tap 5	NCE095	July 10, 2020	0.002	Passed	3.0000	Exceeded	Laboratory or Hand washing only	
Eastern Passage Education Centre	Science Lab Room 1085 tap 6	NCE096	July 10, 2020	0.001	Passed	1.9000	Passed		
Eastern Passage Education Centre	Science Lab Room 1086 tap 1	NCE085	July 10, 2020	0.001	Passed	28.0000	Exceeded	Laboratory or Hand washing only	
Eastern Passage Education Centre	Science Lab Room 1086 tap 2	NCE086	July 10, 2020	-	Passed	0.6400	Passed		
Eastern Passage Education Centre	Science Lab Room 1086 tap 3	NCE087	July 10, 2020	-	Passed	0.2400	Passed		
Eastern Passage Education Centre	Science Lab Room 1086 tap 4	NCE088	July 10, 2020	-	Passed	0.5200	Passed		
Eastern Passage Education Centre	Science Lab Room 1086 tap 5	NCE089	July 10, 2020	-	Passed	0.1900	Passed		
Eastern Passage Education Centre	Science Lab Room 1086 tap 6	NCE090	July 10, 2020	0.001	Passed	8.7000	Exceeded	Laboratory or Hand washing only	
Eastern Passage Education Centre	Staff Room 2025 tap	ARPJ45	June 5, 2025	-	Passed	0.0100	Passed		
Eastern Passage Education Centre	Staff Room Wash Room 2026 tap	NCE135	July 10, 2020	0.001	Passed	0.4400	Passed		
Eastern Passage Education Centre	Staff Room Wash Room 2027 tap	NCE136	July 10, 2020	0.002	Passed	0.5500	Passed		
Eastern Passage Education Centre	Tech Ed Room 2029 tap	WFH040	June 22, 2023	-	Passed	0.0910	Passed	Tap remediated	
Eastern Shore Consolidated School	Fountain by Library	ARXU82	June 13, 2025	-	Passed	0.1600	Passed		
Eastern Shore Consolidated School	Cafeteria tap 1	ARXU83	June 13, 2025	-	Passed	0.1100	Passed		
Eastern Shore Consolidated School	Cafeteria tap 2	ARXU84	June 13, 2025	-	Passed	0.2200	Passed		
Eastern Shore Consolidated School	Cafeteria tap 3	ARXU85	June 13, 2025	-	Passed	0.1000	Passed		
Eastern Shore Consolidated School	Fountain by Cafeteria	ARXU86	June 13, 2025	-	Passed	1.2000	Passed		
Eastern Shore Consolidated School	Room 103	ARXU87	June 13, 2025	-	Passed	0.1500	Passed		
Eastern Shore Consolidated School	Staff Room 128	ARXU88	June 13, 2025	-	Passed	0.3900	Passed		
Eastern Shore Consolidated School	Food Lab 127 tap 1	ARXU89	June 13, 2025	-	Passed	0.1200	Passed		
Eastern Shore Consolidated School	Food Lab 127 tap 2	ARXU90	June 13, 2025	-	Passed	0.1100	Passed		
Eastern Shore Consolidated School	Food Lab 127 tap 3	ARXU91	June 13, 2025	-	Passed	0.1100	Passed		
Eastern Shore Consolidated School	Food Lab 127 tap 4	ARXU92	June 13, 2025	-	Passed	0.1000	Passed		
Eastern Shore Consolidated School	Food Lab 127 tap 5	ARXU93	June 13, 2025	-	Passed	0.0800	Passed		
Eastern Shore District High School	Girls Wash Room tap 1 by Room 225	NAI278	June 26, 2020	0.005	Passed	0.1300	Passed		
Eastern Shore District High School	Girls Wash Room tap 2 by Room 225	WQG871	June 29, 2023	0.002	Passed	0.0590	Passed	Tap remediated	
Eastern Shore District High School	Janitors Closet tap by Room 225	RXI401	February 18, 2022	0.001	Passed	0.1900	Passed		
Eastern Shore District High School	Fountain by Room 225	ZPF663	June 28, 2024	-	Passed	-	Passed		
Eastern Shore District High School	Boys Wash Room tap 1 by Room 224	WQG869	June 29, 2023	0.015	Exceeded	0.0210	Passed	Hand washing only	
Eastern Shore District High School	Boys Wash Room tap 2 by Room 224	WQG870	June 29, 2023	0.006	Exceeded	0.0180	Passed	Hand washing only	
Eastern Shore District High School	Class Room 220 tap	NAI284	June 26, 2020	0.002	Passed	0.2400	Passed		
Eastern Shore District High School	Science Lab 217 tap 1	RWW763	February 17, 2022	0.001	Passed	0.0880	Passed		
Eastern Shore District High School	Science Lab 217 tap 2	NAI286	June 26, 2020	0.002	Passed	0.2600	Passed		
Eastern Shore District High School	Science Lab 217 tap 3	RWW764	February 17, 2022	0.016	Exceeded	0.8600	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 217 tap 4	NAI291	June 26, 2020	0.002	Passed	0.2600	Passed		
Eastern Shore District High School	Science Lab 217 tap 5	NAI292	June 26, 2020	0.004	Passed	0.3700	Passed		
Eastern Shore District High School	Science Lab 217 tap 6	NAI293	June 26, 2020	0.003	Passed	0.4000	Passed		
Eastern Shore District High School	Science Lab 217 tap 1a	RWW765	February 17, 2022	0.022	Exceeded	1.2000	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 217 tap 2a	RWW766	February 17, 2022	0.005	Exceeded	0.1800	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 217 tap 3a	RWW767	February 17, 2022	0.180	Exceeded	0.0870	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 217 tap 4a	NAI297	June 26, 2020	0.005	Exceeded	0.3000	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 217 tap 5a	NAI298	February 17, 2022	0.010	Exceeded	0.0470	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 217 tap 6a	NAI299	June 26, 2020	0.003	Passed	0.1100	Passed		
Eastern Shore District High School	Science Lab 217 tap 1b	RWW769	February 17, 2022	0.004	Passed	0.0640	Passed		
Eastern Shore District High School	Science Lab 217 tap 2b	RWW770	February 17, 2022	0.003	Passed	0.0630	Passed		
Eastern Shore District High School	Science Lab 217 tap 3b	RWW771	February 17, 2022	0.009	Exceeded	0.0720	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 217 tap 4b	NAI305	June 26, 2020	0.002	Passed	0.2800	Passed		
Eastern Shore District High School	Science Lab 217 tap 5b	RWW773	February 17, 2022	0.015	Exceeded	0.0400	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 217 tap 6b	NAI307	June 26, 2020	0.002	Passed	0.2300	Passed		
Eastern Shore District High School	Science Lab 217 tap 1c	RWW787	February 17, 2022	0.023	Exceeded	1.0000	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 217 tap 2c	RWW788	February 17, 2022	0.005	Exceeded	0.1100	Passed	Laboratory or hand washing only	
Eastern Shore District High School	Science Lab 317 tap 3c	NAI310	June 26, 2020	0.004	Passed	0.4300	Passed		
Eastern Shore District High School	Science Lab 219 tap 1a	RWW789	February 17, 2022	0.002	Passed	0.0460	Passed		
Eastern Shore District High School	Science Lab 219 tap 2	RWW790	February 17, 2022	-	Passed	0.0220	Passed		
Eastern Shore District High School	Science Lab 219 tap 3	RWW791	February 17, 2022	0.001	Passed	0.0740	Passed		
Eastern Shore District High School	Science Lab 219 tap 4	RWW792	February 17, 2022	0.003	Passed	1.9000	Passed		
Eastern Shore District High School	Science Lab 219 tap 5	RWW793	February 17, 2022	-	Passed	0.0260	Passed		
Eastern Shore District High School	Science Lab 219 tap 6	RWW794	February 17, 2022	0.001	Passed	0.0560	Passed		
Eastern Shore District High School	Science Lab 219 tap 1a	RXI397	February 18, 2022	-	Passed	0.0570	Passed		
Eastern Shore District High School	Staff Wash Room 201a tap 1	RXI403	February 18, 2022	-	Passed	0.0660	Passed		
Eastern Shore District High School	Staff Wash Room 201a tap 2	NAI338	June 26, 2020	0.005	Passed	0.0300	Passed		
Eastern Shore District High School	Class Room 201a tap	RXI404	February 18, 2022	-	Passed	0.0930	Passed		
Eastern Shore District High School	Boys Wash Room tap 1 by Room 202	WQG864	June 29, 2023	0.001	Passed	0.0190	Passed	Tap remediated	
Eastern Shore District High School	Boys Wash Room tap 2 by Room 202	WQG865	June 29, 2023	-	Passed	0.0160	Passed	Tap remediated	
Eastern Shore District High School	Boys Wash Room tap 3 by Room 202	WQG866	June 29, 2023	0.002	Passed	0.0097	Passed	Tap remediated	
Eastern Shore District High School	Fountain by Boys Wash Room / Room 202	ZPF666	June 28, 2024	-	Passed	-	Passed		
Eastern Shore District High School	Staff Wash Room tap by Janitors Closet	RXI410	February 18, 2022	0.001	Passed	0.1500	Passed		
Eastern Shore District High School	Janitors Closet in Janitors Sink Room	NAI350	June 26, 2020	0.001	Passed	0.0740	Passed		
Eastern Shore District High School	Girls Wash Room tap 1 by Room 201c	WQG862	June 29, 2023	0.002	Passed	0.0540	Passed	Tap remediated	
Eastern Shore District High School	Girls Wash Room tap 2 by Room 201c	WQG862	June 30, 2023	0.013	Exceeded	0.2700	Passed	Hand washing only	
Eastern Shore District High School	Girls Wash Room tap 3 by Room 201c	WQG863	June 29, 2023	0.001	Passed	0.0470	Passed	Tap remediated	
Eastern Shore District High School	Food Lab 212 double compartment sink tap	ZPF664	June 28, 2024	-	Passed	0.0067	Passed		
Eastern Shore District High School	Food Lab 212 single compartment sink tap	ZPF665	June 28, 2024	-	Passed	0.0073	Passed		
Eastern Shore District High School	Gender Neutral Wash Room 212 tap	RXI414	February 18, 2022	-	Passed	0.1400	Passed		
Eastern Shore District High School	Class Room 213 tap	RXI415	February 18, 2022	0.001	Passed	0.1800	Passed		
Eastern Shore District High School	Class Room 123b tap	NAI361	June 26, 2020	0.003	Passed	0.6200	Passed		
Eastern Shore District High School	Class Room 122 tap	NAI362	June 26, 2020	0.005	Passed	0.1900	Passed		
Eastern Shore District High School	Girls Wash Room tap 1 by Janitors Closet Room C	RXI416	February 18, 2022	0.001	Passed	0.1500	Passed		
Eastern Shore District High School	Girls Wash Room tap 2 by Janitors Closet Room C	NAI364	June 26, 2020	0.002	Passed	0.0890	Passed		
Eastern Shore District High School	Janitors Closet Room C tap	RXI417	February 18, 2022	0.001	Passed	0.1300	Passed		
Eastern Shore District High School	Fountain by Janitors Room C	ZPF662	June 28, 2024	-	Passed	0.0880	Passed		
Eastern Shore District High School	Boys Wash Room tap by Room 119a	NAI367	June 26, 2020	0.002	Passed	0.0490	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Ecole Beaufort (SIAM)	Gender Neutral Wash Room 110 tap	QH0096	August 5, 2021	-	Passed	0.0390	Passed		
Ecole Beaufort (SIAM)	Gender Neutral Wash Room 216 tap	QH0097	August 5, 2021	-	Passed	0.0580	Passed		
Ecole Beaufort (SIAM)	Class Room 212 Wash Room tap	QH0098	August 5, 2021	-	Passed	0.0710	Passed		
Ecole Beaufort (SIAM)	Staff Room Wash Room tap	QH0099	August 5, 2021	-	Passed	0.0520	Passed		
Ecole Beaufort (SIAM)	Janitors Closet 204 tap	QH0101	August 5, 2021	-	Passed	0.0300	Passed		
Ecole Beaufort (SIAM)	Boys Wash Room tap 1	QH0102	August 5, 2021	0.002	Passed	0.2200	Passed		
Ecole Beaufort (SIAM)	Boys Wash Room tap 2	QH0103	August 5, 2021	0.001	Passed	0.3100	Passed		
Ecole Beaufort (SIAM)	Gender Neutral Wash Room 209	QH0104	August 5, 2021	0.001	Passed	0.2700	Passed		
Ecole Beaufort (SIAM)	Basement Boys Wash Room tap 1	QH0105	August 5, 2021	0.001	Passed	0.0570	Passed		
Ecole Beaufort (SIAM)	Basement Boys Wash Room tap 2	QH0106	August 5, 2021	-	Passed	0.0190	Passed		
Ecole Beaufort (SIAM)	Basement Boys Wash Room tap 3	QH0107	August 5, 2021	0.001	Passed	0.0180	Passed		
Ecole Beaufort (SIAM)	Basement Boys Wash Room tap 4	QH0108	August 5, 2021	-	Passed	0.0150	Passed		
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 1	QH0109	August 5, 2021	0.002	Passed	0.0570	Passed		
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 2	QH0110	August 5, 2021	0.002	Passed	0.0300	Passed		
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 3	QH0111	August 5, 2021	0.002	Passed	0.0240	Passed		
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 4	QH0112	August 5, 2021	0.001	Passed	0.0160	Passed		
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 5	QH0113	August 5, 2021	0.001	Passed	0.0120	Passed		
Ecole Beaufort (SIAM)	Basement Caretakers Office tap	QH0114	August 5, 2021	-	Passed	0.0160	Passed		
Ecole Beaufort (SIAM)	Hallway Sink by Room B203 tap	QH0115	August 5, 2021	0.001	Passed	0.0150	Passed		
Ecole Beaufort (SIAM)	Gender Neutral Wash Room B203 tap	QH0117	August 5, 2021	-	Passed	0.0100	Passed		
Ecole Beaufort (SIAM)	Staff Room tap	APT896	April 10, 2025	-	Passed	0.0150	Passed		
Ecole Beaufort (SIAM)	Fountain by Room 204	APT897	April 10, 2025	-	Passed	0.0012	Passed		
Ecole Beaufort (SIAM)	Fountain by B102	APT899	April 10, 2025	-	Passed	0.0024	Passed		
Ecole Beaufort (SIAM)	Fountain by Room B203	APT898	April 10, 2025	-	Passed	0.0150	Passed		
Elizabeth Sutherland School	Art Room tap 1	VPX687	April 21, 2023	-	Passed	0.0072	Passed	Tap remediated	
Elizabeth Sutherland School	Art Room tap 2	MQZ725	May 20, 2020	0.001	Passed	0.0330	Passed		
Elizabeth Sutherland School	Boys Locker Room tap 1	MQZ747	May 20, 2020	0.001	Passed	0.0970	Passed		
Elizabeth Sutherland School	Boys Locker Room tap 2	MQZ748	May 20, 2020	0.001	Passed	0.0560	Passed		
Elizabeth Sutherland School	Boys Wash Room tap 1 by Canteen	VPX702	April 21, 2023	-	Passed	0.0180	Passed	Tap remediated	
Elizabeth Sutherland School	Boys Wash Room tap 1 by Gym	VPX709	April 21, 2023	-	Passed	0.0200	Passed	Tap remediated	
Elizabeth Sutherland School	Boys Wash Room tap 1 by Janitors Closet	MQZ709	May 20, 2020	0.002	Passed	0.0740	Passed		
Elizabeth Sutherland School	Boys Wash Room tap 2 by Canteen	VPX703	April 21, 2023	-	Passed	0.0220	Passed	Tap remediated	
Elizabeth Sutherland School	Boys Wash Room tap 2 by Gym	MQZ742	May 20, 2020	0.003	Passed	0.0350	Passed		
Elizabeth Sutherland School	Boys Wash Room tap 2 by Janitors Closet	VPX696	April 21, 2023	-	Passed	0.0110	Passed	Tap remediated	
Elizabeth Sutherland School	Boys Wash Room tap 3 by Canteen	VPX704	April 21, 2023	-	Passed	0.0240	Passed	Tap remediated	
Elizabeth Sutherland School	Boys Wash Room tap 3 by Gym	MQZ743	May 20, 2020	0.001	Passed	0.0230	Passed		
Elizabeth Sutherland School	Boys Wash Room tap 3 by Janitors Closet	VPX697	April 21, 2023	-	Passed	0.0100	Passed	Tap remediated	
Elizabeth Sutherland School	Boys Wash Room tap 4 by Canteen	VPX705	April 21, 2023	-	Passed	0.0140	Passed	Tap remediated	
Elizabeth Sutherland School	Boys Wash Room tap 4 by Gym	MQZ744	May 20, 2020	0.004	Passed	0.0360	Passed		
Elizabeth Sutherland School	Boys Wash Room tap 4 by Janitors Closet	MQZ712	May 20, 2020	0.003	Passed	0.0590	Passed		
Elizabeth Sutherland School	Boys Wash Room tap 5 by Gym	MQZ745	May 20, 2020	0.001	Passed	0.0920	Passed		
Elizabeth Sutherland School	Boys Wash Room tap 6 by Gym	MQZ746	May 20, 2020	0.002	Passed	0.0240	Passed		
Elizabeth Sutherland School	Caretaker Room tap	APSD59	April 9, 2025	-	Passed	0.0056	Passed		
Elizabeth Sutherland School	Food Lab tap 1	APSD52	April 9, 2025	-	Passed	0.0059	Passed		
Elizabeth Sutherland School	Food Lab tap 2	APSD53	April 9, 2025	-	Passed	0.0170	Passed		
Elizabeth Sutherland School	Food Lab tap 3	APSD54	April 9, 2025	-	Passed	0.0200	Passed		
Elizabeth Sutherland School	Food Lab tap 4	APSD55	April 9, 2025	-	Passed	0.0160	Passed		
Elizabeth Sutherland School	Fountain by Canteen	APSD60	April 9, 2025	0.001	Passed	0.0420	Passed		
Elizabeth Sutherland School	Fountain by Gym	APSD62	May 16, 2024	-	Passed	0.0300	Passed		
Elizabeth Sutherland School	Fountain by Janitors Closet	APSD61	April 9, 2025	-	Passed	0.0710	Passed		
Elizabeth Sutherland School	Fountain by Main Office	APSD56	April 9, 2025	-	Passed	0.0440	Passed		
Elizabeth Sutherland School	Fountain in Modular	APSD63	April 9, 2025	-	Passed	0.0200	Passed		
Elizabeth Sutherland School	Girls Locker Room tap 1	NKX242	August 21, 2020	0.000	Passed	0.0130	Passed		
Elizabeth Sutherland School	Girls Locker Room tap 2	MQZ750	May 20, 2020	0.001	Passed	0.0150	Passed		
Elizabeth Sutherland School	Girls Locker Room tap 3	MQZ751	May 20, 2020	0.004	Passed	0.0900	Passed		
Elizabeth Sutherland School	Girls Wash Room tap 1 by Canteen	VPX699	April 21, 2023	0.001	Passed	0.0400	Passed	Tap remediated	
Elizabeth Sutherland School	Girls Wash Room tap 1 by Fan Room	MQZ703	May 20, 2020	0.001	Passed	0.1100	Passed		
Elizabeth Sutherland School	Girls Wash Room tap 1 by Gym	MQZ734	May 20, 2020	0.001	Passed	0.0820	Passed		
Elizabeth Sutherland School	Girls Wash Room tap 2 by Canteen	VPX700	April 21, 2023	-	Passed	0.0087	Passed	Tap remediated	
Elizabeth Sutherland School	Girls Wash Room tap 2 by Fan Room	MQZ704	May 20, 2020	0.001	Passed	0.0660	Passed		
Elizabeth Sutherland School	Girls Wash Room tap 2 by Gym	MQZ735	May 20, 2020	0.001	Passed	0.0860			

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Ellenvale Junior High School	Laundry tub tap Room 109	XDF311	September 23, 2023	-	Passed	0.0150	Passed	Out-of-Service	
Ellenvale Junior High School	Laundry tub tap Room 111	NLK023	August 24, 2020	0.001	Passed	0.0150	Passed		
Ellenvale Junior High School	Modular Janitors Closet	XBL569	September 19, 2023	-	Passed	0.0770	Passed		
Ellenvale Junior High School	Modular Room 306	XBL521	September 19, 2023	-	Passed	0.2300	Passed		
Ellenvale Junior High School	Modular Staff Room tap	ARIW34	May 29, 2025	-	Passed	0.0340	Passed		
Ellenvale Junior High School	Modular Staff Room Wash Room tap	XBL570	September 19, 2023	-	Passed	0.1000	Passed		
Ellenvale Junior High School	Modular Wash Room tap 1 by Room 305	XBL572	September 19, 2023	-	Passed	0.1100	Passed		
Ellenvale Junior High School	Modular Wash Room tap 1 by Room 306	XBL575	September 19, 2023	-	Passed	0.1100	Passed		
Ellenvale Junior High School	Modular Wash Room tap 2 by Room 305	XBL573	September 19, 2023	-	Passed	0.1000	Passed		
Ellenvale Junior High School	Modular Wash Room tap 2 by Room 306	XBL576	September 19, 2023	-	Passed	0.1100	Passed		
Ellenvale Junior High School	Modular Wash Room tap 3 by Room 305	XBL574	September 19, 2023	-	Passed	0.1000	Passed		
Ellenvale Junior High School	Modular Wash Room tap 3 by Room 306	XBL577	September 19, 2023	-	Passed	0.1100	Passed		
Ellenvale Junior High School	Modular Wash Room tap 4 by Room 306	XBL520	September 19, 2023	-	Passed	0.1200	Passed		
Ellenvale Junior High School	Staff Kitchen 103 tap	ARIW32	May 29, 2025	-	Passed	0.0160	Passed		
Ellenvale Junior High School	Staff Room 103 Female Staff Wash tap	MVH155	June 9, 2020	0.004	Passed	0.0950	Passed		
Ellenvale Junior High School	Staff Room 103 Male Staff Wash tap	XDF301	September 27, 2023	-	Passed	0.0690	Passed	Tap remediated	
Ellenvale Junior High School	Staff Wash Room by Room 212	MVH140	June 9, 2020	0.001	Passed	0.0890	Passed		
Ellenvale Junior High School	Staff Wash Room tap inside Room 101	XDF313	September 27, 2023	0.001	Passed	0.0700	Passed	Tap remediated	
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 1	XKA679	October 25, 2023	0.003	Passed	0.0670	Passed	Tap remediated	
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 2	XKA680	October 25, 2023	0.001	Passed	0.0430	Passed	Tap remediated	
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 3	XKA681	October 25, 2023	0.003	Passed	0.0500	Passed	Tap remediated	
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 4	XKA682	October 25, 2023	0.003	Passed	0.0550	Passed	Tap remediated	
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 1	XKA683	October 25, 2023	0.005	Exceeded	0.1500	Passed	Hand washing only	
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 2	XKA684	October 25, 2023	0.003	Passed	0.0710	Passed	Tap remediated	
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 3	XKA685	October 25, 2023	0.002	Passed	0.0330	Passed	Tap remediated	
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 4	XKA686	October 25, 2023	0.001	Passed	0.0300	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Boys Wash Room tap 1 by Room 208	XKA708	October 25, 2023	0.002	Passed	0.0490	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Boys Wash Room tap 2 by Room 208	XKA709	October 25, 2023	0.002	Passed	0.0530	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Boys Wash Room tap 3 by Room 208	XKA710	October 25, 2023	0.002	Passed	0.0740	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Boys Wash Room tap 4 by Room 208	XKA711	October 25, 2023	0.002	Passed	0.0820	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Caretakers Office 110 tap	NLS529	August 24, 2020	0.000	Passed	0.0050	Passed		
Eric Graves Memorial Junior High School	Caretakers Office 110 Wash Room tap	MVH222	June 9, 2020	0.004	Passed	0.4400	Passed		
Eric Graves Memorial Junior High School	Chemistry Lab tap 1 Room 210	MVH209	June 9, 2020	0.062	Exceeded	1.2000	Passed	Laboratory or Hand washing only	
Eric Graves Memorial Junior High School	Chemistry Lab tap 2 Room 210	MVH210	June 9, 2020	0.320	Exceeded	1.3000	Passed	Laboratory or Hand washing only	
Eric Graves Memorial Junior High School	Chemistry Lab tap 3 Room 210	MVH211	June 9, 2020	0.160	Exceeded	1.1000	Passed	Laboratory or Hand washing only	
Eric Graves Memorial Junior High School	Chemistry Lab tap 4 Room 210	MVH212	June 9, 2020	0.220	Exceeded	1.0000	Passed	Laboratory or Hand washing only	
Eric Graves Memorial Junior High School	Chemistry Lab tap 5 Room 210	MVH213	June 9, 2020	0.130	Exceeded	1.2000	Passed	Laboratory or Hand washing only	
Eric Graves Memorial Junior High School	Class Room tap Room 210	MVH208	June 9, 2020	0.003	Passed	0.0550	Passed		
Eric Graves Memorial Junior High School	Computer Lab 112 Gender Neutral Wash Room tap	XKA704	October 25, 2023	0.001	Passed	0.0220	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Computer Lab 112 tap	NLS527	August 24, 2020	0.001	Passed	0.0070	Passed		
Eric Graves Memorial Junior High School	Family Studies tap 1 Room 201	ARIU97	May 29, 2025	0.001	Passed	0.0180	Passed		
Eric Graves Memorial Junior High School	Family Studies tap 2 Room 201	ARIU98	May 29, 2025	0.001	Passed	0.0200	Passed		
Eric Graves Memorial Junior High School	Family Studies tap 3 Room 201	ARIU99	May 29, 2025	0.001	Passed	0.0220	Passed		
Eric Graves Memorial Junior High School	Family Studies tap 4 Room 201	ARIV00	May 29, 2025	0.001	Passed	0.0250	Passed		
Eric Graves Memorial Junior High School	Family Studies tap 5 Room 201	ARIV01	May 29, 2025	0.001	Passed	0.0210	Passed		
Eric Graves Memorial Junior High School	Fountain by Gym	ARIV06	May 29, 2025	0.002	Passed	0.2100	Passed		
Eric Graves Memorial Junior High School	Fountain by Room 108	ARIV04	May 29, 2025	-	Passed	0.0310	Passed		
Eric Graves Memorial Junior High School	Fountain by Room 202	ARIV02	May 29, 2025	0.002	Passed	0.0700	Passed		
Eric Graves Memorial Junior High School	Fountain by Room 208	ARIV03	May 29, 2025	-	Passed	0.0360	Passed		
Eric Graves Memorial Junior High School	Girls Wash Room tap 1 by Room 208	XKA695	October 25, 2023	0.013	Exceeded	0.1500	Passed	Hand washing only	
Eric Graves Memorial Junior High School	Girls Wash Room tap 2 by Room 208	XKA696	October 25, 2023	0.005	Passed	0.0770	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Girls Wash Room tap 3 by Room 208	XKA697	October 25, 2023	0.001	Passed	0.0540	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Girls Wash Room tap 4 by Room 208	XKA698	October 25, 2023	0.001	Passed	0.0290	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Gym Storage Room tap	XKA705	October 25, 2023	0.029	Exceeded	0.2400	Passed	Hand washing only	
Eric Graves Memorial Junior High School	Janitors Closet tap by Room 111	MVH223	June 9, 2020	0.003	Passed	0.1900	Passed		
Eric Graves Memorial Junior High School	Janitors Closet tap by Room 202	XKA707	October 25, 2023	0.001	Passed	0.0450	Passed	Tap remediated	
Eric Graves Memorial Junior High School	Janitors Closet tap by Room 215	MVH214	June 9						

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Fairview Junior High School	Gender Neutral Staff Wash Room tap by Room 228	MRO206	May 22, 2020	0.004	Passed	0.0720	Passed		
Fairview Junior High School	Gender Neutral Staff Wash Room tap by Room 230	MRO207	May 22, 2020	0.003	Passed	0.0370	Passed		
Fairview Junior High School	Gender Neutral Wash Room 140 tap	MRO444	May 22, 2020	0.002	Passed	0.0150	Passed		
Fairview Junior High School	Gender Neutral Wash Room tap by Room 110	VZ1212	May 22, 2020	0.001	Passed	0.0150	Passed		
Fairview Junior High School	Girls Locker Room 005 tap 1	MRO475	May 22, 2020	0.003	Passed	0.0076	Passed		
Fairview Junior High School	Girls Locker Room 005 tap 2	MRO476	May 22, 2020	0.001	Passed	0.0047	Passed		
Fairview Junior High School	Girls Wash Room tap 1 by Room 107	MRO460	May 22, 2020	0.002	Passed	0.0360	Passed		
Fairview Junior High School	Girls Wash Room tap 1 by Room 205	MRO196	May 22, 2020	0.004	Passed	0.1300	Passed		
Fairview Junior High School	Girls Wash Room tap 1 by Room 228	MRO203	May 22, 2020	0.002	Passed	0.0140	Passed		
Fairview Junior High School	Girls Wash Room tap 2 by Room 107	MRO461	May 22, 2020	0.001	Passed	0.0200	Passed		
Fairview Junior High School	Girls Wash Room tap 2 by Room 205	MRO197	May 22, 2020	0.002	Passed	0.1500	Passed		
Fairview Junior High School	Girls Wash Room tap 2 by Room 228	MRO204	May 22, 2020	0.002	Passed	0.0210	Passed		
Fairview Junior High School	Girls Wash Room tap 3 by Room 107	MRO462	May 22, 2020	0.001	Passed	0.0190	Passed		
Fairview Junior High School	Girls Wash Room tap 3 by Room 205	MRO198	May 22, 2020	0.001	Passed	0.0990	Passed		
Fairview Junior High School	Girls Wash Room tap 3 by Room 228	VZ1210	May 31, 2023	-	Passed	0.0110	Passed	Tap remediated	
Fairview Junior High School	Girls Wash Room tap 4 by Room 107	MRO463	May 22, 2020	0.001	Passed	0.0200	Passed		
Fairview Junior High School	Girls Wash Room tap 4 by Room 205	MRO199	May 22, 2020	0.003	Passed	0.0540	Passed		
Fairview Junior High School	Janitors Closet 009 tap	VZ1217	May 31, 2023	0.001	Passed	0.0560	Passed	Tap remediated	
Fairview Junior High School	Janitors Closet 131 tap	MRO221	May 22, 2020	0.002	Passed	0.1300	Passed		
Fairview Junior High School	Janitors Closet tap by Room 239	MRO202	May 22, 2020	0.002	Passed	0.0270	Passed		
Fairview Junior High School	Janitors Closet tap by Staff Wash Rooms	MRO190	May 22, 2020	0.003	Passed	0.0630	Passed		
Fairview Junior High School	Janitors Closet tap by Staff Wash Rooms	MRO449	May 22, 2020	0.002	Passed	0.0270	Passed		
Fairview Junior High School	Kitchen 230 tap 1	VZ1207	May 31, 2023	0.001	Passed	0.0230	Passed		
Fairview Junior High School	Kitchen 236 tap 1	AQKA33	April 30, 2025	-	Passed	0.0095	Passed		
Fairview Junior High School	Kitchen 236 tap 2	AQKA34	April 30, 2025	-	Passed	0.0087	Passed		
Fairview Junior High School	Kitchen 236 tap 3	AQKA35	April 30, 2025	-	Passed	0.0083	Passed		
Fairview Junior High School	Kitchen 236 tap 4	AQKA36	April 30, 2025	-	Passed	0.0078	Passed		
Fairview Junior High School	Kitchen 236 tap 5	AQKA37	April 30, 2025	-	Passed	0.0098	Passed		
Fairview Junior High School	Learning Centre Wash Room tap	MRO445	May 22, 2020	0.001	Passed	0.0120	Passed		
Fairview Junior High School	Male Staff Wash Room tap by Room 208	MRO188	May 22, 2020	0.002	Passed	0.0510	Passed		
Fairview Junior High School	Modular Staff Room (New)	AQKA42	April 30, 2025	-	Passed	0.0170	Passed		
Fairview Junior High School	Physical Education Wash Room 103 tap	VZ1215	May 31, 2023	0.001	Passed	0.0780	Passed	Tap remediated	
Fairview Junior High School	Science Room 246 tap	AQKA32	April 30, 2025	-	Passed	0.0083	Passed		
Fairview Junior High School	Science Room 247 tap	AQKA29	April 30, 2025	-	Passed	0.0140	Passed		
Fairview Junior High School	Science Room 248 tap 1	VZ1179	May 31, 2023	0.001	Passed	0.0540	Passed		
Fairview Junior High School	Science Room 248 tap 2	AQKA30	April 30, 2025	-	Passed	0.0230	Passed		
Fairview Junior High School	Science Room 248 tap 3	AQKA31	April 30, 2025	-	Passed	0.0320	Passed	Tap remediated	
Fairview Junior High School	Staff Room 144 tap	AQKA38	April 30, 2025	-	Passed	0.0053	Passed		
Fairview Junior High School	Staff Room 144 Wash Room 1 tap	MRO224	May 22, 2020	0.001	Passed	0.0150	Passed		
Fairview Junior High School	Staff Room 144 Wash Room 2 tap	MRO443	May 22, 2020	0.001	Passed	0.0200	Passed		
Fairview Junior High School	Staff Wash Room by Gender Neutral Wash Room	MRO448	May 22, 2020	0.001	Passed	0.0310	Passed		
Fairview Junior High School	Staff Wash Room tap in Office Room 137	MRO222	May 22, 2020	0.001	Passed	0.0820	Passed		
Fairview Junior High School	Wood Shop tap	MRO467	May 22, 2020	0.002	Passed	0.1800	Passed		
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 1	MUT708	June 5, 2020	0.002	Passed	0.0820	Passed		
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 3	MUT710	June 5, 2020	0.004	Passed	0.1300	Passed		
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 4	MUT711	June 5, 2020	0.003	Passed	0.1300	Passed		
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 8	MUT715	June 5, 2020	0.003	Passed	0.1900	Passed		
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 9	MUT716	June 5, 2020	0.002	Passed	0.1500	Passed		
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 10	MUT717	June 5, 2020	0.002	Passed	0.1200	Passed		
Five Bridges Junior High School	3rd Floor Chemistry Lab 300 tap 11	MUT718	June 5, 2020	0.002	Passed	0.1200	Passed		
Five Bridges Junior High School	Class Room 307 tap	MUT723	June 5, 2020	0.005	Passed	0.0560	Passed		
Five Bridges Junior High School	3rd Floor Staff Wash Room 1 tap	MUT724	June 5, 2020	0.002	Passed	0.0770	Passed		
Five Bridges Junior High School	3rd Floor Staff Wash Room 2 tap	MUT725	June 5, 2020	0.002	Passed	0.1000	Passed		
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 1	MUT726	June 5, 2020	0.002	Passed	0.1000	Passed		
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 2	MUT727	June 5, 2020	0.004	Passed	0.0910	Passed		
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 3	MUT728	June 5, 2020	0.003	Passed	0.0490	Passed		
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 4	MUT729	June 5, 2020	0.002	Passed	0.1000	Passed		
Five Bridges Junior High School	3rd Floor Janitors Closet tap	MUT731	June 5, 2020	0.001	Passed	0.1100	Passed		
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 1	MUT732	June 5, 2020	0.002	Passed	0.0770	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Gaetz Brook Junior High School	3rd Floor Boys Wash Room tap 1 by Janitors Closet	WQG508	June 27, 2023	0.001	Passed	0.1700	Passed	Tap remediated	
Gaetz Brook Junior High School	3rd Floor Boys Wash Room tap 2 by Janitors Closet	NAN929	June 30, 2020	0.001	Passed	0.1400	Passed		
Gaetz Brook Junior High School	3rd Floor Fountain by Girls Wash Room	WQG511	June 27, 2023	0.034	Exceeded	0.6300	Passed	Fountain out of service. Other sources available.	
Gaetz Brook Junior High School	Art Room tap	WQG501	June 27, 2023	0.002	Passed	0.5200	Passed	Tap remediated	
Gaetz Brook Junior High School	Boys Locker Room tap	NAN946	June 30, 2020	0.001	Passed	0.0900	Passed		
Gaetz Brook Junior High School	Class Room 300 tap 1	NAN932	June 30, 2020	1.400	Exceeded	1.9000	Passed	Hand washing only	
Gaetz Brook Junior High School	Class Room 300 tap 2	NAN933	June 30, 2020	0.024	Exceeded	0.2600	Passed	Hand washing only	
Gaetz Brook Junior High School	Class Room 300 tap 3	NAN934	June 30, 2020	0.013	Exceeded	0.4100	Passed	Hand washing only	
Gaetz Brook Junior High School	Class Room 300 tap 4	NAN935	June 30, 2020	0.039	Exceeded	0.5500	Passed	Hand washing only	
Gaetz Brook Junior High School	Class Room 300 tap 5	NAN936	June 30, 2020	0.110	Exceeded	1.3000	Passed	Hand washing only	
Gaetz Brook Junior High School	Fountain by 1st Floor Girls Wash Room	ADCF59	September 17, 2024	0.019	Exceeded	0.0460	Passed	Fountain out of service. Other sources available.	
Gaetz Brook Junior High School	Fountain in Boys Locker Room	NAN945	June 30, 2020	0.001	Passed	0.0990	Passed		
Gaetz Brook Junior High School	Gender Neutral Wash Room 306 tap	NAN920	June 30, 2020	0.002	Passed	0.1400	Passed		
Gaetz Brook Junior High School	Girls Locker Room tap	WQG504	June 27, 2023	0.001	Passed	0.2000	Passed	Tap remediated	
Gaetz Brook Junior High School	Girls Wash Room tap 1 by Room 105	WQG498	June 27, 2023	0.001	Passed	0.1400	Passed	Hand washing only	
Gaetz Brook Junior High School	Girls Wash Room tap 1 by Room 204	NAN938	June 30, 2020	0.001	Passed	0.1200	Passed		
Gaetz Brook Junior High School	Girls Wash Room tap 1 by Room 305	WQG509	June 27, 2023	-	Passed	0.1300	Passed	Tap remediated	
Gaetz Brook Junior High School	Girls Wash Room tap 2 by Room 105	NAN950	June 30, 2020	0.002	Passed	0.1400	Passed		
Gaetz Brook Junior High School	Girls Wash Room tap 2 by Room 204	NAN939	June 30, 2020	0.001	Passed	0.1200	Passed		
Gaetz Brook Junior High School	Girls Wash Room tap 2 by Room 305	WQG510	June 27, 2023	-	Passed	0.1400	Passed	Tap remediated	
Gaetz Brook Junior High School	Guidance Room tap	ADCF60	September 17, 2024	0.003	Passed	0.0130	Passed	Hand washing only	
Gaetz Brook Junior High School	Janitors Closet by Fountain	NAN941	June 30, 2020	0.001	Passed	0.1300	Passed		
Gaetz Brook Junior High School	Janitors Closet by fountain	NAN952	June 30, 2020	0.001	Passed	0.1200	Passed		
Gaetz Brook Junior High School	Janitors Closet tap by Fountain	NAN927	June 30, 2020	0.004	Passed	0.1500	Passed		
Gaetz Brook Junior High School	Janitors Closet tap in Art Room	NAN961	June 30, 2020	0.094	Exceeded	2.8000	Exceeded	Hand washing only	
Gaetz Brook Junior High School	Kitchen/Cafeteria handwashing tap	ADCF55	September 17, 2024	-	Passed	0.0100	Passed	Tap remediated	
Gaetz Brook Junior High School	Kitchen/Cafeteria tap 1	ADCF54	September 17, 2024	0.001	Passed	0.0180	Passed	Tap remediated	
Gaetz Brook Junior High School	Kitchen/Cafeteria triple compartment sink tap 1	WQG494	June 27, 2023	0.001	Passed	0.2000	Passed	Tap remediated	
Gaetz Brook Junior High School	Kitchen/Cafeteria triple compartment sink tap 2	ADCF57	September 17, 2024	0.001	Passed	0.0210	Passed	Tap remediated	
Gaetz Brook Junior High School	Kitchen/Cafeteria Wash Room tap	ADCF56	September 17, 2024	-	Passed	0.0056	Passed	Tap remediated	
Gaetz Brook Junior High School	Laundry Room 203 tub tap	WQG491	June 27, 2023	0.004	Passed	0.2300	Passed	Tap remediated	
Gaetz Brook Junior High School	Main Office Staff Wash Room tap	WQG505	June 27, 2023	0.001	Passed	0.5600	Passed	Tap remediated	
Gaetz Brook Junior High School	Ms. O'Connell Room tap	WQG507	June 27, 2023	0.040	Exceeded	1.6000	Passed	Hand washing only	
Gaetz Brook Junior High School	Photo Room tap	NAN960	June 30, 2020	3.300	Exceeded	4.9000	Exceeded	Hand washing only	
Gaetz Brook Junior High School	Sci Lab tap by Room 300	NAN931	June 30, 2020	0.054	Exceeded	0.1800	Passed	Hand washing only	
Gaetz Brook Junior High School	Staff Room Kitchen tap	ADCF61	September 17, 2024	-	Passed	0.0190	Passed		
Gaetz Brook Junior High School	Staff Room Wash Room 1 tap	WQG488	June 27, 2023	-	Passed	0.1300	Passed	Tap remediated	
Gaetz Brook Junior High School	Staff Room Wash Room 2 tap	NAN923	June 30, 2020	0.005	Passed	0.5900	Passed		
Gaetz Brook Junior High School	Tech Ed by Art Room tap	WQG489	June 27, 2023	0.004	Passed	0.1900	Passed	Tap remediated	
Gaetz Brook Junior High School	Tech Ed tap	WQG490	June 27, 2023	0.200	Exceeded	1.5000	Passed	Hand washing only	
George Bissett Elementary	Boys Wash Room 114 tap 1	MXK063	June 18, 2020	0.001	Passed	0.3800	Passed		
George Bissett Elementary	Boys Wash Room 114 tap 2	MXK064	June 18, 2020	-	Passed	0.5100	Passed		
George Bissett Elementary	Boys Wash Room 114 tap 3	MXK065	June 18, 2020	-	Passed	0.4100	Passed		
George Bissett Elementary	Boys Wash Room 114 tap 4	MXK066	June 18, 2020	0.003	Passed	0.4500	Passed		
George Bissett Elementary	Boys Wash Room 215 tap 1	MXK045	June 18, 2020	0.001	Passed	0.4800	Passed		
George Bissett Elementary	Boys Wash Room 215 tap 2	MXK046	June 18, 2020	0.001	Passed	0.2000</			

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Gorsebrook Junior High School	Basement Boys Wash Room tap 3	SCH601	March 15, 2022	0.001	Passed	0.0680	Passed		
Gorsebrook Junior High School	Basement Class Room 29 tap	SCH602	March 15, 2022	0.003	Passed	0.1200	Passed		
Gorsebrook Junior High School	Basement Food Lab tap 1	APYL48	April 16, 2025	-	Passed	0.0250	Passed		
Gorsebrook Junior High School	Basement Food Lab tap 2	APYL49	April 16, 2025	-	Passed	0.0540	Passed		
Gorsebrook Junior High School	Basement Food Lab tap 3	APYL50	April 16, 2025	-	Passed	0.0420	Passed		
Gorsebrook Junior High School	Basement Food Lab tap 4	APYL51	April 16, 2025	-	Passed	0.0430	Passed		
Gorsebrook Junior High School	Basement Girls Wash Room tap 1	MSZ193	May 28, 2020	0.003	Passed	0.2000	Passed		
Gorsebrook Junior High School	Basement Girls Wash Room tap 2	SCH603	March 15, 2022	0.002	Passed	0.2600	Passed		
Gorsebrook Junior High School	Basement Girls Wash Room tap 3	VTZ866	May 9, 2023	-	Passed	0.0310	Passed	Tap remediated	
Gorsebrook Junior High School	Boys Locker Room tap	SCH596	March 15, 2022	-	Passed	0.0660	Passed		
Gorsebrook Junior High School	Boys Wash Room tap 1 by Room 18	MSZ174	May 28, 2020	0.001	Passed	0.2500	Passed		
Gorsebrook Junior High School	Boys Wash Room tap 2 by Room 18	MSZ175	May 28, 2020	0.004	Passed	0.1100	Passed		
Gorsebrook Junior High School	Boys Wash Room tap 3 by Room 18	MSZ176	May 28, 2020	0.004	Passed	0.2200	Passed		
Gorsebrook Junior High School	Boys Wash Room tap 4 by Room 18	MSZ177	May 28, 2020	0.001	Passed	0.2500	Passed		
Gorsebrook Junior High School	Class Room 12 tap	MSZ171	May 28, 2020	0.002	Passed	0.2100	Passed		
Gorsebrook Junior High School	Female Staff Wash Room tap by Room 16	MSZ179	May 28, 2020	0.003	Passed	0.2300	Passed		
Gorsebrook Junior High School	Fountain by Gym	APYL46	April 16, 2025	-	Passed	0.0430	Passed		
Gorsebrook Junior High School	Fountain by Main Office	APYL45	April 16, 2025	-	Passed	0.0012	Passed		
Gorsebrook Junior High School	Fountain by Room 16	APYL47	April 16, 2025	-	Passed	0.0230	Passed		
Gorsebrook Junior High School	Gender Neutral Wash Room 1 tap by Room 3	MSZ166	May 28, 2020	0.001	Passed	0.2500	Passed		
Gorsebrook Junior High School	Gender Neutral Wash Room 2 tap by Room 3	MSZ167	May 28, 2020	0.004	Passed	0.2700	Passed		
Gorsebrook Junior High School	Girls Locker Room tap	MSZ164	May 28, 2020	0.003	Passed	1.9000	Passed		
Gorsebrook Junior High School	Girls Wash Room tap 1 by Room 16	MSZ180	May 28, 2020	0.002	Passed	0.1900	Passed		
Gorsebrook Junior High School	Girls Wash Room tap 2 by Room 16	MSZ181	May 28, 2020	0.004	Passed	0.0530	Passed		
Gorsebrook Junior High School	Girls Wash Room tap 3 by Room 16	MSZ182	May 28, 2020	0.002	Passed	0.3000	Passed		
Gorsebrook Junior High School	Girls Wash Room tap 4 by Room 16	MSZ183	May 28, 2020	0.001	Passed	0.0780	Passed		
Gorsebrook Junior High School	Girls Wash Room tap 5 by Room 16	SCH598	March 15, 2022	-	Passed	0.0820	Passed		
Gorsebrook Junior High School	Gym Gender Neutral Wash Room tap	MSZ162	May 28, 2020	0.002	Passed	0.1500	Passed		
Gorsebrook Junior High School	Gym Office tap	MSZ163	May 28, 2020	0.002	Passed	0.1400	Passed		
Gorsebrook Junior High School	Janitors Closet tap by Room 18	MSZ172	May 28, 2020	0.001	Passed	0.0530	Passed		
Gorsebrook Junior High School	Janitors Closet tap Room 30	MUV532	June 8, 2020	0.001	Passed	0.1300	Passed		
Gorsebrook Junior High School	Male Staff Wash Room tap by Room 18	MSZ173	May 28, 2020	0.002	Passed	0.0620	Passed		
Gorsebrook Junior High School	Resource Room 11 tap	VTZ861	May 9, 2023	-	Passed	0.0530	Passed		
Gorsebrook Junior High School	Resource Room 11 Wash Room tap 1	MSZ186	May 28, 2020	0.002	Passed	0.0490	Passed		
Gorsebrook Junior High School	Resource Room 11 Wash Room tap 2	MSZ187	May 28, 2020	0.001	Passed	0.0530	Passed		
Gorsebrook Junior High School	Storage Room 32 tap	SCH613	March 15, 2022	0.004	Passed	0.1000	Passed		
Gorsebrook Junior High School	Wood Work Room 28 tap	MUV533	June 8, 2020	-	Passed	0.2500	Passed		
Graham Creighton Junior High School	2nd Floor Boys Wash Room tap 1	MYA117	June 22, 2020	0.002	Passed	0.3300	Passed		
Graham Creighton Junior High School	2nd Floor Boys Wash Room tap 2	MYA118	June 22, 2020	-	Passed	0.1800	Passed		
Graham Creighton Junior High School	2nd Floor Fountain between Wash Rooms	ARIX47	May 29, 2025	-	Passed	0.0430	Passed		
Graham Creighton Junior High School	2nd Floor Girls Wash Room tap 1	MYA113	June 22, 2020	-	Passed	0.1500	Passed		
Graham Creighton Junior High School	2nd Floor Girls Wash Room tap 2	MYA114	June 22, 2020	-	Passed	0.1600	Passed		
Graham Creighton Junior High School	Administrative Office Wash Room tap	MYA071	June 22, 2020	0.002	Passed	0.2800	Passed		
Graham Creighton Junior High School	Art Room tap 1	MYA104	June 22, 2020	-	Passed	0.2800	Passed		
Graham Creighton Junior High School	Art Room tap 2	MYA105	June 22, 2020	0.001	Passed	0.1200	Passed		
Graham Creighton Junior High School	Boys Locker Room tap 1	MYA094	June 22, 2020	-	Passed	0.7100	Passed		
Graham Creighton Junior High School	Boys Locker Room tap 2	MYA095	June 22, 2020	0.001	Passed	0.3200	Passed		
Graham Creighton Junior High School	Boys Wash Room 208 tap 1	MYA129	June 22, 2020	0.001	Passed	0.5200	Passed		
Graham Creighton Junior High School	Boys Wash Room 208 tap 2	MYA130	June 22, 2020	0.001</					

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Grosvenor-Wentworth Park Elementary	Modular Staff Room tap	APT876	April 10, 2025	-	Passed	0.0290	Passed		
Grosvenor-Wentworth Park Elementary	Staff Room tap	APT871	April 10, 2025	-	Passed	0.0055	Passed		
Grosvenor-Wentworth Park Elementary	Staff Wash Room tap	VVK774	May 16, 2023	-	Passed	0.0069	Passed	Tap remediated	
Halifax Central Junior High School	1st Floor Boys Wash Room tap 1	MTN565	May 28, 2020	-	Passed	0.0220	Passed		
Halifax Central Junior High School	1st Floor Boys Wash Room tap 2	MTN566	May 28, 2020	-	Passed	0.0210	Passed		
Halifax Central Junior High School	1st Floor Boys Wash Room tap 3	MTN567	May 28, 2020	-	Passed	0.0210	Passed		
Halifax Central Junior High School	1st Floor Boys Wash Room tap 4	MTN568	May 28, 2020	-	Passed	0.0200	Passed		
Halifax Central Junior High School	1st Floor First Aid Room tap	APT869	April 10, 2025	-	Passed	0.0084	Passed		
Halifax Central Junior High School	Art Room tap Room 7	MTN569	May 28, 2020	0.004	Passed	0.7800	Passed		
Halifax Central Junior High School	Boys Locker Room tap 1	MTN588	May 28, 2020	-	Passed	0.0082	Passed		
Halifax Central Junior High School	Boys Locker Room tap 2	MTN589	May 28, 2020	-	Passed	0.0078	Passed		
Halifax Central Junior High School	Boys Wash Room tap 1 by Office	MTN615	May 28, 2020	-	Passed	0.0150	Passed		
Halifax Central Junior High School	Boys Wash Room tap 2 by Office	MTN616	May 28, 2020	-	Passed	0.0140	Passed		
Halifax Central Junior High School	Boys Wash Room tap 3 by Office	MTN617	May 28, 2020	-	Passed	0.0140	Passed		
Halifax Central Junior High School	Boys Wash Room tap 4 by Office	MTN618	May 28, 2020	-	Passed	0.0140	Passed		
Halifax Central Junior High School	Chemistry Lab tap 1	MTN619	May 28, 2020	0.001	Passed	0.0170	Passed		
Halifax Central Junior High School	Chemistry Lab tap 2	MTN620	May 28, 2020	0.001	Passed	0.0120	Passed		
Halifax Central Junior High School	Class Room tap Room 17	MTN602	May 28, 2020	-	Passed	0.0250	Passed		
Halifax Central Junior High School	Family Studies tap 1 Room 9	APT865	April 10, 2025	-	Passed	0.0460	Passed		
Halifax Central Junior High School	Family Studies tap 2 Room 9	APT866	April 10, 2025	-	Passed	0.0520	Passed		
Halifax Central Junior High School	Family Studies tap 3 Room 9	APT867	April 10, 2025	-	Passed	0.0640	Passed		
Halifax Central Junior High School	Fountain by Boys Wash Room	APT861	April 10, 2025	-	Passed	0.1600	Passed		
Halifax Central Junior High School	Fountain by Gym	APT862	April 10, 2025	-	Passed	0.0013	Passed		
Halifax Central Junior High School	Fountain by Room 4	APT863	April 10, 2025	-	Passed	0.0009	Passed		
Halifax Central Junior High School	Fountain by Room 9	APT864	April 10, 2025	-	Passed	0.0082	Passed		
Halifax Central Junior High School	Gender Neutral Wash Room tap	MTN590	May 28, 2020	-	Passed	0.0065	Passed		
Halifax Central Junior High School	Gender Neutral Wash Room tap Room 22	MTN613	May 28, 2020	-	Passed	0.0130	Passed		
Halifax Central Junior High School	Girls Locker Room tap 1	MTN572	May 28, 2020	-	Passed	0.0390	Passed		
Halifax Central Junior High School	Girls Locker Room tap 2	MTN587	May 28, 2020	-	Passed	0.0390	Passed		
Halifax Central Junior High School	Girls Wash Room tap 1 by Room 4	MTN592	May 28, 2020	0.001	Passed	0.1600	Passed		
Halifax Central Junior High School	Girls Wash Room tap 1 by Room 9	MTN606	May 28, 2020	0.001	Passed	0.1200	Passed		
Halifax Central Junior High School	Girls Wash Room tap 2 by Room 4	MTN593	May 28, 2020	0.001	Passed	0.0780	Passed		
Halifax Central Junior High School	Girls Wash Room tap 2 by Room 9	MTN607	May 28, 2020	0.001	Passed	0.1200	Passed		
Halifax Central Junior High School	Girls Wash Room tap 3 by Room 4	MTN594	May 28, 2020	0.001	Passed	0.0450	Passed		
Halifax Central Junior High School	Girls Wash Room tap 3 by Room 9	MTN608	May 28, 2020	0.001	Passed	0.0730	Passed		
Halifax Central Junior High School	Girls Wash Room tap 4 by Room 4	MTN595	May 28, 2020	-	Passed	0.0370	Passed		
Halifax Central Junior High School	Girls Wash Room tap 4 by Room 9	MTN609	May 28, 2020	-	Passed	0.0200	Passed		
Halifax Central Junior High School	Girls Wash Room tap 5 by Room 4	MTN596	May 28, 2020	-	Passed	0.0320	Passed		
Halifax Central Junior High School	Girls Wash Room tap 5 by Room 9	MTN610	May 28, 2020	-	Passed	0.0190	Passed		
Halifax Central Junior High School	Staff Room tap	APT868	April 10, 2025	-	Passed	0.0180	Passed		
Halifax Central Junior High School	Storage Room in Gym tap (right back corner)	NFZ852	July 30, 2020	0.003	Passed	0.0810	Passed		
Halifax Central Junior High School	Upstairs Fountain	VUA372	May 9, 2023	-	Passed	0.0006	Passed		
Halifax Central Junior High School	VP Office Wash Room tap	MTN614	May 28, 2020	0.002	Passed	0.0800	Passed		
Halifax Central Junior High School	Wood Shop sink tap	MTN570	May 28, 2020	0.001	Passed	0.5000	Passed		
Halifax West High School	Biology Lab A318 tap 1	MUI388	June 2, 2020	0.003	Passed	0.4300	Passed		
Halifax West High School	Biology Lab A318 tap 2	MUI389	June 2, 2020	0.001	Passed	0.5300	Passed		
Halifax West High School	Biology Lab A318 tap 3	MUI390	June 2, 2020	0.001	Passed	0.4300	Passed		
Halifax West High School	Biology Lab A318 tap 4	MUI391	June 2, 2020	-	Passed	0.8500	Passed		
Halifax West High School	Biology Lab A318 tap 5	MUI392	June 2, 2020	0.001	Passed	0.4100	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Halifax West High School	Gender Neutral Wash Room A226 tap 2	MUI296	June 2, 2020	0.001	Passed	0.1500	Passed		
Halifax West High School	Gender Neutral Wash Room A315 tap	MUI394	June 2, 2020	-	Passed	0.0660	Passed		
Halifax West High School	Gender Neutral Wash Room A332 tap	MUI193	June 2, 2020	-	Passed	0.0370	Passed		
Halifax West High School	Gender Neutral Wash Room C152 tap	MUI325	June 2, 2020	0.001	Passed	0.1800	Passed		
Halifax West High School	Gender Neutral Wash Room tap by Room A312	MUI330	June 2, 2020	-	Passed	0.1800	Passed		
Halifax West High School	Girls Locker Room 1 tap	MUI215	June 2, 2020	0.001	Passed	0.4500	Passed		
Halifax West High School	Girls Locker Room 2 tap	MUI218	June 2, 2020	0.002	Passed	0.2000	Passed		
Halifax West High School	Girls Wash Room A224 tap 1	MUI290	June 2, 2020	0.001	Passed	0.1200	Passed		
Halifax West High School	Girls Wash Room A224 tap 2	MUI291	June 2, 2020	-	Passed	0.1700	Passed		
Halifax West High School	Girls Wash Room A224 tap 3	MUI292	June 2, 2020	-	Passed	0.2100	Passed		
Halifax West High School	Girls Wash Room A224 tap 4	MUI293	June 2, 2020	-	Passed	0.1600	Passed		
Halifax West High School	Girls Wash Room A234 tap 1	MUI298	June 2, 2020	-	Passed	0.1300	Passed		
Halifax West High School	Girls Wash Room A234 tap 2	MUI299	June 2, 2020	-	Passed	0.1300	Passed		
Halifax West High School	Girls Wash Room A234 tap 3	MUI300	June 2, 2020	0.001	Passed	0.1300	Passed		
Halifax West High School	Girls Wash Room A234 tap 4	VYN830	May 30, 2023	-	Passed	0.0300	Passed	Tap remediated	
Halifax West High School	Girls Wash Room A313 tap 1	MUI327	June 2, 2020	0.003	Passed	0.2500	Passed		
Halifax West High School	Girls Wash Room A313 tap 2	MUI328	June 2, 2020	-	Passed	0.1700	Passed		
Halifax West High School	Girls Wash Room A313 tap 3	MUI329	June 2, 2020	-	Passed	0.1400	Passed		
Halifax West High School	Girls Wash Room A325 tap 1	MUI357	June 2, 2020	-	Passed	0.1700	Passed		
Halifax West High School	Girls Wash Room A325 tap 2	MUI358	June 2, 2020	-	Passed	0.1100	Passed		
Halifax West High School	Girls Wash Room A325 tap 3	MUI363	June 2, 2020	0.003	Passed	0.1100	Passed		
Halifax West High School	Girls Wash Room C162 tap 1	VYN866	May 30, 2023	-	Passed	0.0390	Passed	Tap remediated	
Halifax West High School	Girls Wash Room C162 tap 2	MUI315	June 2, 2020	-	Passed	0.2300	Passed		
Halifax West High School	Girls Wash Room C162 tap 3	MUI316	June 2, 2020	-	Passed	0.1800	Passed		
Halifax West High School	Girls Wash Room C172 tap 1	MUI317	June 2, 2020	-	Passed	0.170			

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - December, 2025

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Harbour View Elementary	Janitors Closet tap by Room 214	XBV863	September 20, 2023	-	Passed	0.0087	Passed	Tap remediated
Harbour View Elementary	Janitors Closet tap in Boiler Room	XBV811	September 20, 2023	-	Passed	0.0240	Passed	Tap remediated
Harbour View Elementary	Learning Centre Wash Room tap	MY1104	June 25, 2020	0.009	Exceeded	0.3200	Passed	Hand washing only
Harbour View Elementary	Library Wash Room tap	XBV894	September 20, 2023	0.003	Passed	0.0260	Passed	Tap remediated
Harbour View Elementary	Staff Room (Main office Kitchen)	ARIV45	May 29, 2025	-	Passed	0.0140	Passed	
Harbour View Elementary	Staff Room 308 tap 1	XBV823	September 20, 2023	0.001	Passed	0.0270	Passed	Tap remediated
Harbour View Elementary	Staff Room 308 tap 2	XBV812	September 20, 2023	0.027	Exceeded	0.0570	Passed	Hand washing only
Harbour View Elementary	Staff Room Female Wash Room tap 1	XBV825	September 20, 2023	0.001	Passed	0.0250	Passed	Tap remediated
Harbour View Elementary	Staff Room Female Wash Room tap 2	MY1109	June 25, 2020	0.005	Passed	0.2700	Passed	
Harbour View Elementary	Staff Room Male Wash Room tap 1	XBV826	September 20, 2023	0.006	Exceeded	0.0530	Passed	Hand washing only
Harbour View Elementary	Staff Room Male Wash Room tap 2	XBV827	September 20, 2023	0.014	Exceeded	0.1000	Passed	Hand washing only
Harbour View Elementary	Staff Wash Room by learning Centre	MY1105	June 25, 2020	-	Passed	0.0510	Passed	
Harbour View Elementary	Staff Wash Room tap in Main Office	MY1114	June 25, 2020	0.003	Passed	0.0970	Passed	
Harbour View Elementary	Staff Wash Room tap in Main Office	XBV824	September 20, 2023	0.004	Passed	0.0290	Passed	Tap remediated
Harbour View Elementary	Student Services Wash Room tap	XBV810	September 20, 2023	0.001	Passed	0.0150	Passed	Tap remediated
Harbour View Elementary	Upstairs Boys Wash Room tap 1	XBV806	September 20, 2023	0.001	Passed	0.0250	Passed	Tap remediated
Harbour View Elementary	Upstairs Boys Wash Room tap 2	XBV807	September 20, 2023	0.001	Passed	0.0490	Passed	Tap remediated
Harbour View Elementary	Upstairs Boys Wash Room tap 3	XBV808	September 20, 2023	0.002	Passed	0.0550	Passed	Tap remediated
Harbour View Elementary	Upstairs Boys Wash Room tap 4	XBV809	September 20,					

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Hawthorn Elementary	Fountain by Boys Wash Room	ARKK49	May 30, 2025	-	Passed	-	Passed		
Hawthorn Elementary	Fountain by Music Room	ARKK48	May 30, 2025	-	Passed	0.0013	Passed		
Hawthorn Elementary	Fountain by Room 19	ARKK50	May 30, 2025	-	Passed	0.0130	Passed		
Hawthorn Elementary	Gender Neutral Wash Room tap	MYYZ14	June 25, 2020	0.001	Passed	0.0720	Passed		
Hawthorn Elementary	Girls Wash Room tap 1 by Room 17	WIH410	July 7, 2023	0.004	Passed	0.0750	Passed	Tap remediated	
Hawthorn Elementary	Girls Wash Room tap 1 by Room 28	WIH402	July 7, 2023	0.001	Passed	0.0430	Passed	Tap remediated	
Hawthorn Elementary	Girls Wash Room tap 1 by Staff Wash Room	WIH415	July 7, 2023	-	Passed	0.0110	Passed	Tap remediated	
Hawthorn Elementary	Girls Wash Room tap 2 by Room 17	WIH411	July 7, 2023	0.004	Passed	0.0950	Passed	Tap remediated	
Hawthorn Elementary	Girls Wash Room tap 2 by Room 28	MYYZ16	June 25, 2020	0.005	Passed	0.2000	Passed		
Hawthorn Elementary	Girls Wash Room tap 2 by Staff Wash Room	WIH416	July 7, 2023	-	Passed	0.0170	Passed	Tap remediated	
Hawthorn Elementary	Girls Wash Room tap 3 by Room 17	WIH412	July 7, 2023	0.001	Passed	0.0300	Passed	Tap remediated	
Hawthorn Elementary	Girls Wash Room tap 3 by Room 28	WIH403	July 7, 2023	-	Passed	0.0280	Passed	Tap remediated	
Hawthorn Elementary	Girls Wash Room tap 3 by Staff Wash Room	MYYZ43	June 25, 2020	0.004	Passed	0.2400	Passed		
Hawthorn Elementary	Girls Wash Room tap 4 by Room 17	WIH413	July 7, 2023	0.002	Passed	0.0350	Passed	Tap remediated	
Hawthorn Elementary	Girls Wash Room tap 4 by Room 28								

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - December, 2025

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Holland Road Elementary	Class Room 126 tap	MWIO44	June 15, 2020	-	Passed	0.0340	Passed	
Holland Road Elementary	Class Room 126 Wash Room tap	MWIO43	June 15, 2020	0.001	Passed	0.1700	Passed	
Holland Road Elementary	Class Room 128 tap	MWIO46	June 15, 2020	0.001	Passed	0.1700	Passed	
Holland Road Elementary	Class Room 136 Wash Room tap	MWIO48	June 15, 2020	0.001	Passed	0.1600	Passed	
Holland Road Elementary	Class Room 170 tap	MWIO34	June 15, 2020	0.001	Passed	0.0700	Passed	
Holland Road Elementary	Class Room 171 tap	MWIO33	June 15, 2020	0.001	Passed	0.0770	Passed	
Holland Road Elementary	Class Room 172 tap	MWIO32	June 15, 2020	0.001	Passed	0.2500	Passed	
Holland Road Elementary	Fountain by Gym	ARNG78	June 3, 2025	-	Passed	0.0450	Passed	
Holland Road Elementary	Fountain by Library	ARNG79	June 3, 2025	-	Passed	0.0110	Passed	
Holland Road Elementary	Fountain by Room 170	ARNG80	June 3, 2025	-	Passed	0.0016	Passed	
Holland Road Elementary	Girls Locker Room tap by Room 149	MWIO63	June 15, 2020	0.002	Passed	0.0850	Passed	
Holland Road Elementary	Girls Wash Room 173 tap 1	MWIO38	June 15, 2020	0.004	Passed	0.0890	Passed	
Holland Road Elementary	Girls Wash Room 173 tap 2	MWIO39	June 15, 2020	-	Passed	0.0660	Passed	
Holland Road Elementary	Girls Wash Room tap 1 by Main Office	MWIO53	June 15, 2020	-	Passed	0.0440	Passed	
Holland Road Elementary	Girls Wash Room tap 2 by Main Office	MWIO54	June 15, 2020	0.002	Passed	0.0660	Passed	
Holland Road Elementary	Girls Wash Room tap 3 by Main Office	MWIO55	June 15, 2020	0.001	Passed	0.0240	Passed	
Holland Road Elementary	Gym Office 149 Wash Room tap	SPH549	May 11, 2022	0.004	Passed	0.1300	Passed	
Holland Road Elementary	Janitors Closet tap by Room 123	MWIO42	June 15, 2020	0.002	Passed	0.1300	Passed	
Holland Road Elementary	Kitchen 145 tap	ARNG81	June 3, 2025	-	Passed	0.0170	Passed	
Holland Road Elementary	Mechanical Room tap by Library	MWIO51	June 15, 2020	0.002	Passed	0.1000	Passed	
Holland Road Elementary	Music Room 130 tap	MWIO47	June 15, 2020	0.003	Passed	0.0970	Passed	
Holland Road Elementary	Primary Wash Room 169 tap	MWIO35	June 15, 2020	-	Passed	0.0680	Passed	
Holland Road Elementary	Staff Room tap	ARNG77	June 3, 2025	-	Passed	0.0130	Passed	
Holland Road Elementary	Staff Room Wash Room 1 tap	MWIO56	June 15, 2020	0.002	Passed	0.2200	Passed	
Holland Road Elementary	Staff Room Wash Room 2 tap	MWIO57	June 15, 2020	-	Passed	0.2400	Passed	
Horizon Elementary		MVY851	June 11, 2020	0.002	Passed	0.0950	Passed	
Horizon Elementary	2nd Floor Boys Wash Room tap 1 by Storage Room	WFH434	June 22, 2023	-	Passed	0.0075	Passed	Tap remediated
Horizon Elementary	2nd Floor Boys Wash Room tap 2 by Storage Room	MVY788	June 11, 2020	0.003	Passed	0.1300	Passed	
Horizon Elementary	2nd Floor Boys Wash Room tap 3 by Storage Room	WFH435	June 22, 2023	-	Passed	0.0086	Passed	Tap remediated
Horizon Elementary	2nd Floor Boys Wash Room tap 4 by Storage Room	WFH455	June 22, 2023	-	Passed	0.0087	Passed	Tap remediated
Horizon Elementary	2nd Floor Girls Wash Room tap 1 by Elevator	MVY795	June 11, 2020	0.004	Passed	0.0580	Passed	
Horizon Elementary	2nd Floor Girls Wash Room tap 2 by Elevator	WFH456	June 22, 2023	-	Passed	0.0120	Passed	Tap remediated
Horizon Elementary	2nd Floor Girls Wash Room tap 3 by Elevator	MVY797	June 11, 2020	0.002	Passed	0.1500	Passed	
Horizon Elementary	2nd Floor Girls Wash Room tap 4 by Elevator	MVY798	June 11, 2020	0.003	Passed	0.1000	Passed	
Horizon Elementary	2nd Floor Girls Wash Room tap 5 by Elevator	MVY799	June 11, 2020	0.000	Passed	0.0390	Passed	
Horizon Elementary	Boys Locker Room tap 1 in Rec Centre	WFH386	June 22, 2023	-	Passed	0.0090	Passed	Tap remediated
Horizon Elementary	Boys Locker Room tap 2 in Rec Centre	WFH387	June 22, 2023	-	Passed	0.0078	Passed	Tap remediated
Horizon Elementary	Boys Locker Room tap 3 in Rec Centre	MVY817	June 11, 2020	0.003	Passed	0.0490	Passed	
Horizon Elementary	Boys Wash Room tap 1 by Girls Wash Room	WFH389	June 22, 2023	0.002	Passed	0.0220	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 1 by Mech Room	WFH392	June 22, 2023	-	Passed	0.0080	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 1 in Rec Centre	WFH227	June 22, 2023	-	Passed	0.0750	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 2 by Girls Wash Room	WFH390	June 22, 2023	0.001	Passed	0.0150	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 2 by Mech Room	WFH249	June 22, 2023	-	Passed	0.0076	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 2 in Rec Centre	MVY803	June 11, 2020	0.002	Passed	0.2200	Passed	
Horizon Elementary	Boys Wash Room tap 3 by Mech Room	WFH250	June 22, 2023	-	Passed	0.0070	Passed	Tap remediated
Horizon Elementary	Boys Wash Room tap 4 by Mech Room	WFH251	June 22, 2023	-	Passed	0.0059	Passed	Tap remediated
Horizon Elementary	Cafeteria Double Sink tap	ARPI25	June 5, 2025	-	Passed	0.0082	Passed	
Horizon Elementary	Cafeteria Hand Washing Sink tap	ARPI26	June 5, 2025	-	Passed	0.0087	Passed	Tap remediated
Horizon Elementary	Class Room 1 tap	MVY800	June 11, 2020	0.002	Passed	0.3200	Passed	
Horizon Elementary	Class Room 102 tap	WFH258	June 22, 2023	-	Passed	0.0670	Passed	Tap remediated
Horizon Elementary	Class Room 104 tap	WFH426	June 22, 2023	-	Passed	0.0095	Passed	Tap remediated
Horizon Elementary	Class Room 105 Gender Neutral Wash Room tap	WFH256	June 22, 2023	-	Passed	0.0120	Passed	Tap remediated
Horizon Elementary	Class Room 105 tap	MVY831	June 11, 2020	0.002	Passed	0.4000	Passed	
Horizon Elementary	Class Room 113 tap	WFH428	June 22, 2023	-	Passed	0.0110	Passed	Tap remediated
Horizon Elementary	Class Room 113 Wash Room tap	WFH429	June 22, 2023	-	Passed	0.0090	Passed	Tap remediated
Horizon Elementary	Class Room 114 tap	MVY848	June 11, 2020	0.004	Passed	0.4300	Passed	
Horizon Elementary	Class Room 115 tap 1	MVY845	June 11, 2020	-	Passed	0.0670	Passed	
Horizon Elementary	Class Room 115 tap 2	MVY846	June 11, 2020	0.003	Passed	0.3500	Passed	
Horizon Elementary	Class Room 115 Wash Room tap	XLPT28	October 31, 2023	-	Passed	0.0210	Passed	Tap remediated
Horizon Elementary	Class Room 116 tap	WFH431	June 22, 2023	0.001	Passed	0.0300	Passed	Tap remediated
Horizon Elementary	Class Room 213 tap 1	MVY792	June 11, 2020	0.004	Passed	0.8900	Passed	
Horizon Elementary	Class Room 213 tap 2	WFH457	June 22, 2023	0.001	Passed	0.0094	Passed	Tap remediated
Horizon Elementary	Fountain by Boys Wash Room	ARPI38	June 5, 2025	-	Passed	0.0008	Passed	
Horizon Elementary	Fountain by Cafeteria	ARPI27	June 5, 2025	-	Passed	0.1200	Passed	
Horizon Elementary	Fountain by Girls Wash Room	ARPI39	June 5, 2025	-	Passed	0.0200	Passed	
Horizon Elementary	Fountain by Guidance Room	ARPI37	June 5, 2025	-	Passed	0.0006	Passed	
Horizon Elementary	Fountain by Gym and Boys Locker Room	ARPI30	June 5, 2025	-	Passed	0.0027	Passed	
Horizon Elementary	Fountain by Gym South Entrance	ARPI28	June 5, 2025	-	Passed	0.0015	Passed	
Horizon Elementary	Fountain by Service Room	ARPI35	June 5, 2025	-	Passed	0.0025	Passed	
Horizon Elementary	Fountain in Dance Studio	WFH383	June 22, 2023	0.001	Passed	0.3100	Passed	
Horizon Elementary	Girls Locker Room tap 1 in Rec Centre	MVY810	June 11, 2020	0.001	Passed	0.3800	Passed	
Horizon Elementary	Girls Locker Room tap 2 in Rec Centre	WFH228	June 22, 2023	0.001	Passed	0.0100	Passed	Tap remediated
Horizon Elementary	Girls Locker Room tap 3 in Rec Centre	WFH229	June 22, 2023	-	Passed	0.0100	Passed	Tap remediated
Horizon Elementary	Girls Wash Room tap 1 by Library	WFH253	June 22, 2023	-	Passed	0.0130	Passed	Tap remediated
Horizon Elementary	Girls Wash Room tap 1 in Rec Centre	MVY805	June 11, 2020	-	Passed	0.1200	Passed	
Horizon Elementary	Girls Wash Room tap 2 by Library	WFH254	June 22, 2023	-	Passed	0.0300	Passed	Tap remediated
Horizon Elementary	Girls Wash Room tap 2 in Rec Centre	MVY806	June 11, 2020	0.000	Passed	0.0300	Passed	
Horizon Elementary	Girls Wash Room tap 3 by Library	WFH255	June 22, 2023	-	Passed	0.0320	Passed	Tap remediated
Horizon Elementary	Gym Office (South) Wash Room tap	MVY814	June 11, 2020	0.005	Passed	0.1900	Passed	
Horizon Elementary	Infant Room Bar Sink tap	ARPI31	June 5, 2025	-	Passed	0.0082	Passed	
Horizon Elementary	Infant Room Kitchen Sink tap	ARPI32	June 5, 2025	-	Passed	0.0094	Passed	
Horizon Elementary	Janitors Closet tap inside Fan Room	MVY786	June 11, 2020	0.002	Passed	0.2100	Passed	
Horizon Elementary	Janitors Closet tap inside Mech Room	MVY825	June 11, 2020	-	Passed	0.0190	Passed	
Horizon Elementary	Music Room 110 tap	WFH391	June 22, 2023	-	Passed	0.0140	Passed	Tap remediated
Horizon Elementary	Rec Centre Kitchen tap	ARPI33	June 5, 2025	-	Passed	0.0260	Passed	
Horizon Elementary	Rec Centre Kitchen tap 2 (New)	ARPI34	June 5, 2025	-	Passed	0.0120	Passed	
Horizon Elementary	Room 103 Gender Neutral Wash Room tap	WFH257	June 22, 2023	-	Passed	0.0130	Passed	Tap remediated
Horizon Elementary	Staff Room Kitchen tap	ARPI36	June 5, 2025	-	Passed	0.0056	Passed	
Horizon Elementary	Staff Room Wash Room tap 1	MVY850	June 11, 2020	0.003	Passed	0.1300	Passed	
Horizon Elementary	Toddler Room Gender Neutral Wash Room tap 1	WFH225	June 22, 2023	-	Passed	0.0660	Passed	Tap remediated
Horizon Elementary	Toddler Room Gender Neutral Wash Room tap 2	WFH226	June 22, 2023	0.001	Passed	0.0330	Passed	
Horizon Elementary	Toddler Room tap	ARPI29	June 5, 2025	-	Passed	0.0071	Passed	
Humber Park Elementary	Janitors Closet tap Room 33	XGE303	October 11, 2023	0.001	Passed	0.1300	Passed	Tap remediated
Humber Park Elementary	Girls Gym Change Room tap	XGE306	October 11, 2023	0.003	Passed	0.1500	Passed	Tap remediated
Humber Park Elementary	Boys Gym Change Room tap	XGE305	October 11, 2023	0.002	Passed	0.1900	Passed	Tap remediated
Humber Park Elementary	Fountain by Gym	ZPR026	July 2, 2024	0.001	Passed	0.1500	Passed	
Humber Park Elementary	Boys Wash Room 8 tap 1	XGE308	October 11, 2023	-	Passed	0.0230	Passed	Tap remediated
Humber Park Elementary	Boys Wash Room 8 tap 2	XGE309	October 11, 2023	0.001	Passed	0.0450	Passed	Tap remediated
Humber Park Elementary	Boys Wash Room 8 tap 3	MXK123	June 18, 2020	0.004	Passed	0.0580	Passed	
Humber Park Elementary	Boys Wash Room 8 tap 4	MXK124	June 18, 2020	-	Passed	0.0260	Passed	
Humber Park Elementary	Janitors Closet 9 tap	MXK125	June 18, 2020	0.001	Passed	0.0100	Passed	
Humber Park Elementary	Fountain by Boys Wash Room / Room 7	ZPR027	July 2, 2024	0.001	Passed	0.0190	Passed	
Humber Park Elementary	Fountain by Girls Wash Room / Room 8	ZPR028	July 2, 2024	-	Passed	0.0170	Passed	
Humber Park Elementary	Girls Wash Room 7 tap 1	MXK130	June 18, 2020	0.003	Passed	0.0580	Passed	
Humber Park Elementary	Girls Wash Room 7 tap 2	MXK131	June 18, 2020	0.002	Passed	0.0350	Passed	
Humber Park Elementary	Girls Wash Room 7 tap 3	MXK132	June 18, 2020	0.001	Passed	0.0140	Passed	
Humber Park Elementary	Girls Wash Room 7 tap 4	MXK133	June 18, 2020	-	Passed	0.0110	Passed	
Humber Park Elementary	Staff Room Wash Room 1 tap	MXK134	June 18, 2020	0.001	Passed	0.0140	Passed	
Humber Park Elementary	Staff Room tap	ZPR029	July 2, 2024	-	Passed	0.0083	Passed	
Humber Park Elementary	Staff Room Wash Room 2 tap	MXK136	June 18, 2020	0.002	Passed	0.2100	Passed	
Ian Forsyth Elementary	Boys Wash Room 139 tap 1	XDW616	September 29, 2023	-	Passed	0.0110	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room 139 tap 2	MWIA35	June 15, 2020	0.001	Passed	0.0600	Passed	
Ian Forsyth Elementary	Boys Wash Room 139 tap 3	MWIA36	June 15, 2020	0.002	Passed	0.0690	Passed	
Ian Forsyth Elementary	Boys Wash Room 139 tap 4	MWIA37	June 15, 2020	0.003	Passed	0.1200	Passed	
Ian Forsyth Elementary	Boys Wash Room tap 1 by Room 111	XDW603	September 29, 2023	0.004	Passed	0.0630	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 1 by Room 125	XDW613	September 29, 2023	-	Passed	0.0043	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 2 by Room 111	XDW604	September 29, 2023	-	Passed	0.0090	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 2 by Room 125	XDW614	September 29, 2023	-	Passed	0.0049	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 3 by Room 111	XDW605	September 29, 2023	0.001	Passed	0.0160	Passed	Tap remediated
Ian Forsyth Elementary	Boys Wash Room tap 3 by Room 125	XDW615	September 29, 2023	0.001	Passed	0.0096	Passed	Tap remediated
Ian Forsyth Elementary	Class Room 129 tap	MWIA38	June 15, 2020	0.004	Passed	0.5400	Passed	
Ian Forsyth Elementary	Fountain by Room 105	ARKK81	May 30, 2025	-	Passed	0.0600	Passed	
Ian Forsyth Elementary	Fountain by 117	ARKK82	May 30, 2025	0.001	Passed	0.3300	Passed	
Ian Forsyth Elementary	Fountain by Room 126	ARKK77	May 30, 2025	-	Passed	0.0610	Passed	
Ian Forsyth Elementary	Fountain by Room 130	ARKK78	May 30, 2025	0.001	Passed	0.3500	Passed	
Ian Forsyth Elementary	Fountain by Room 140	ARKK79	May 30, 2025	0.001	Passed	0.0290	Passed	Fountain replaced
Ian Forsyth Elementary	Fountain on 2nd Floor (by Room 117)	ARKK80	May 30, 2025	-	Passed	0.0340	Passed	
Ian Forsyth Elementary	Girls Wash Room 142 tap 1	XLPO66	October 31, 2023	0.008	Exceeded	0.0340	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room 142 tap 2	XLPO67	October 31, 2023	0.008	Exceeded	0.0430	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room 142 tap 3	XLPO68	October 31, 2023	0.008	Exceeded	0.0390	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room 142 tap 4	XLPO69	October 31, 2023	0.017	Exceeded	0.0670	Passed	Hand washing only
Ian Forsyth Elementary	Girls Wash Room tap 1 by Room 106	XDW600	September 29, 2023	0.001	Passed	0.0330	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room tap 1 by Room 123	XLPO64	October 31, 2023	0.002	Passed	0.0210	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room tap 2 by Room 106	XDW601	September 29, 2023	0.001	Passed	0.0250	Passed	Tap remediated

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - December, 2025

School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Ian Forsyth Elementary	Girls Wash Room tap 2 by Room 123	XLP065	October 31, 2023	-	Passed	0.0081	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room tap 3 by Room 106	XDW602	September 29, 2023	0.001	Passed	0.0360	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room tap 3 by Room 123	XDW611	September 29, 2023	0.003	Passed	0.0190	Passed	Tap remediated
Ian Forsyth Elementary	Girls Wash Room tap 4 by Room 123	XDW612	September 29, 2023	0.001	Passed	0.0120	Passed	Tap remediated
Ian Forsyth Elementary	Gym Kitchen tap	ARKK76	May 30, 2025	0.001	Passed	0.0091	Passed	Tap remediated
Ian Forsyth Elementary	Janitors Closet 108 tap	NDP124	July 16, 2020	0.041	Exceeded	0.2800	Passed	Hand washing only
Ian Forsyth Elementary	Janitors Closet 127 tap	NDP230	July 16, 2020	0.069	Exceeded	0.4300	Passed	Hand washing only
Ian Forsyth Elementary	Janitors Closet 141 tap	MW1432	June 15, 2020	0.002	Passed	0.1800	Passed	
Ian Forsyth Elementary	Janitors Closet 206 tap	MW1424	June 15, 2020	0.037	Exceeded	0.2200	Passed	Hand washing only
Ian Forsyth Elementary	Main Office tap	ARKK84	May 30, 2025	0.001	Passed	0.0070	Passed	
Ian Forsyth Elementary	Main Office Wash Room tap	XDW594	September 29, 2023	0.002	Passed	0.0280	Passed	Tap remediated
Ian Forsyth Elementary	Sick Room 104 tap	XDW597	September 29, 2023	-	Passed	0.0055	Passed	Tap remediated
Ian Forsyth Elementary	Staff Room 103 tap	ARKK83	May 30, 2025	-	Passed	0.0020	Passed	Tap remediated
Ian Forsyth Elementary	Staff Room 103 Wash Room tap	XDW599	September 29, 2023	-	Passed	0.0073	Passed	Tap remediated
Ian Forsyth Elementary	Staff Room 204 Wash Room tap	XDW622	September 29, 2023	-	Passed	0.0014	Passed	Tap remediated
Ian Forsyth Elementary	VP Office 202 tap 1	XDW623	September 29, 2023	0.001	Passed	0.0340	Passed	Tap remediated
Ian Forsyth Elementary	VP Office 202 tap 2	XDW624	September 29, 2023	0.001	Passed	0.0310	Passed	Tap remediated
Inglis Street Elementary	Basement Boiler Room tap	MUV553	June 8, 2020	0.002	Passed	0.1300	Passed	
Inglis Street Elementary	Basement Class Room	MUV554	June 8, 2020	0.001	Passed	0.0490	Passed	
Inglis Street Elementary	Basement Fountain	APYL36	April 16, 2025	-	Passed	0.0300	Passed	
Inglis Street Elementary	Basement Janitors Closet tap	MTA122	May 28, 2020	0.001	Passed	0.2600	Passed	
Inglis Street Elementary	Boys Wash Room 200 tap 1	MTA116	May 28, 2020	0.002	Passed	0.2100	Passed	
Inglis Street Elementary	Boys Wash Room 200 tap 2	MTA117	May 28, 2020	0.001	Passed	0.0130	Passed	
Inglis Street Elementary	Boys Wash Room 200 tap 3	MTA118	May 28, 2020	0.002	Passed	0.0410	Passed	
Inglis Street Elementary	Boys Wash Room 200 tap 4	MTA119	May 28, 2020	0.002	Passed	0.1300	Passed	
Inglis Street Elementary	Boys Wash Room 301 tap 1	MTA105	May 28, 2020	0.001	Passed	0.0470	Passed	
Inglis Street Elementary	Boys Wash Room 301 tap 2	MTA106	May 28, 2020	0.003	Passed	0.0780	Passed	
Inglis Street Elementary	Boys Wash Room 301 tap 3	VT2937	May 9, 2023	-	Passed	0.0980	Passed	Tap remediated
Inglis Street Elementary	Caretaker Room Wash Room 312 tap	MTA096	May 28, 2020	0.001	Passed	0.0950	Passed	
Inglis Street Elementary	Class Room 302 tap	MTA104	May 28, 2020	0.002	Passed	0.2000	Passed	
Inglis Street Elementary	Class Room 305 tap	NLK012	August 24, 2020	0.000	Passed	0.0050	Passed	
Inglis Street Elementary	Class Room tap Room 112	MTA123	May 28, 2020	-	Passed	0.0210	Passed	
Inglis Street Elementary	Class Room Wash Room 206 tap	MTA111	May 28, 2020	-	Passed	0.0061	Passed	
Inglis Street Elementary	Fountain by Gym	APYL33	April 16, 2025	-	Passed	0.5000	Passed	
Inglis Street Elementary	Fountain by Room 209	APYL34	April 16, 2025	-	Passed	0.0640	Passed	
Inglis Street Elementary	Fountain by Room 311	APYL37	April 16, 2025	-	Passed	0.0720	Passed	
Inglis Street Elementary	Gender Neutral Wash Room tap 1 by Room 325	MTA124	May 28, 2020	0.001	Passed	0.0240	Passed	
Inglis Street Elementary	Gender Neutral Wash Room tap 2 by Room 325	MTA125	May 28, 2020	-	Passed	0.0200	Passed	
Inglis Street Elementary	Girls Wash Room 205 tap 1	MTA112	May 28, 2020	-	Passed	0.0120	Passed	
Inglis Street Elementary	Girls Wash Room 205 tap 2	MTA113	May 28, 2020	-	Passed	0.0063	Passed	
Inglis Street Elementary	Girls Wash Room 205 tap 3	MTA114	May 28, 2020	-	Passed	0.0054	Passed	
Inglis Street Elementary	Girls Wash Room 308 tap 1	MTA100	May 28, 2020	0.002	Passed	0.1600	Passed	
Inglis Street Elementary	Girls Wash Room 308 tap 2	MTA101	May 28, 2020	0.001	Passed	0.0730	Passed	
Inglis Street Elementary	Girls Wash Room 308 tap 3	MTA102	May 28, 2020	0.001	Passed	0.0400	Passed	
Inglis Street Elementary	Gym Office Wash Room tap	MTA121	May 28, 2020	0.002	Passed	0.1200	Passed	
Inglis Street Elementary	Janitors Closet 204 tap	MTA115	May 28, 2020	0.001	Passed	0.1500	Passed	
Inglis Street Elementary	Janitors Closet 307 tap	MTA099	May 28, 2020	0.001	Passed	0.0740	Passed	
Inglis Street Elementary	Principals Office Wash Room 209 tap	MTA108	May 28, 2020	-	Passed	0.0220	Passed	
Inglis Street Elementary	Staff Room 208 tap	APYL35	April 16, 2025	-	Passed	0.0180	Passed	
Inglis Street Elementary	YMCA Room Wash Room 311 tap	MTA097	May 28, 2020	-	Passed	0.0360	Passed	
Island View High School	Art Room 117 tap 1	MZD726	June 26, 2020	-	Passed	0.2500	Passed	
Island View High School	Art Room 117 tap 2	MZD727	June 26, 2020	-	Passed	0.1600	Passed	
Island View High School	Assistive Care Wash Room tap by Room 217	WGQ660	June 27, 2023	-	Passed	0.3200	Passed	
Island View High School	Assistive Care Wash Room tap by Room 315	WGQ678	June 27, 2023	-	Passed	0.8300	Passed	Tap remediated
Island View High School	Cafeteria Tap 1	ARPJ00	June 5, 2025	-	Passed	0.0530	Passed	
Island View High School	Cafeteria Tap 2	ARPJ01	June 5, 2025	-	Passed	0.1600	Passed	
Island View High School	Cafeteria Tap 3	ARPJ02	June 5, 2025	-	Passed	2.0000	Exceeded	
Island View High School	Chemistry Lab 309 tap 1	MZD680	June 25, 2020	-	Passed	0.0340	Passed	
Island View High School	Chemistry Lab 309 tap 2	MZD681	June 25, 2020	0.001	Passed	0.0730	Passed	
Island View High School	Chemistry Lab 309 tap 3	WGQ674	June 27, 2023	0.001	Passed	0.6000	Passed	Laboratory or Hand washing only
Island View High School	Chemistry Lab 309 tap 4	MZD683	June 25, 2020	-	Passed	0.0660	Passed	
Island View High School	Chemistry Lab 309 tap 5	MZD684	June 25, 2020	0.001	Passed	0.0810	Passed	
Island View High School	Chemistry Lab 309 tap 6	MZD685	June 25, 2020	0.001	Passed	0.0570	Passed	
Island View High School	Chemistry Lab 309 tap 7	MZD686	June 25, 2020	-	Passed	0.4900	Passed	
Island View High School	Chemistry Lab 309 tap 8	MZD687	June 25, 2020	0.001	Passed	0.0300	Passed	
Island View High School	Chemistry Lab 309 tap 9	MZD688	June 25, 2020	0.001	Passed	0.4200	Passed	
Island View High School	Class Room 213 tap	MZD705	June 25, 2020	0.001	Passed	0.2200	Passed	
Island View High School	Class Room 225 tap 1	MZD701	June 25, 2020	-	Passed	0.1100	Passed	
Island View High School	Class Room 225 tap 2	MZD702	June 25, 2020	0.004	Passed	0.8400	Passed	
Island View High School	Class Room 227 tap 1	MZD703	June 25, 2020	-	Passed	0.2600	Passed	
Island View High School	Class Room 227 tap 2	MZD704	June 25, 2020	0.002	Passed	0.5700	Passed	
Island View High School	Class Room 311A tap	MZD679	June 25, 2020	0.002	Passed	0.4900	Passed	
Island View High School	Class Room 327 tap 1	MZD668	June 25, 2020	-	Passed	0.1900	Passed	
Island View High School	Class Room 327 tap 2	XLP141	October 31, 2023	-	Passed	5.0000	Exceeded	Hand washing only
Island View High School	Fountain by Room 111	ARPJ99	June 5, 2025	-	Passed	0.2900	Passed	
Island View High School	Fountain by Room 211	ARPJ98	June 5, 2025	-	Passed	0.0870	Passed	
Island View High School	Fountain by Room 317	ARPJ03	June 5, 2025	-	Passed	0.2700	Passed	
Island View High School	Gender Neutral Wash Room 106B.1 tap	WGQ681	June 27, 2023	-	Passed	0.8300	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room 106J.1 tap	MZD716	June 26, 2020	-	Passed	0.0520	Passed	
Island View High School	Gender Neutral Wash Room 206A tap 1	MZD699	June 25, 2020	0.001	Passed	0.1400	Passed	
Island View High School	Gender Neutral Wash Room 206B tap 1	MZD698	June 25, 2020	0.001	Passed	0.1500	Passed	
Island View High School	Gender Neutral Wash Room 206C tap 1	MZD697	June 25, 2020	0.001	Passed	0.1200	Passed	
Island View High School	Gender Neutral Wash Room 206D tap 1	MZD696	June 25, 2020	0.004	Passed	0.3000	Passed	
Island View High School	Gender Neutral Wash Room 206E tap 1	MZD695	June 25, 2020	0.004	Passed	0.9300	Passed	
Island View High School	Gender Neutral Wash Room 206F tap 1	WGQ679	June 27, 2023	0.001	Passed	0.1100	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room 206G tap 1	MZD693	June 25, 2020	0.002	Passed	0.2600	Passed	
Island View High School	Gender Neutral Wash Room 206H tap 1	MZD692	June 25, 2020	0.003	Passed	0.6100	Passed	
Island View High School	Gender Neutral Wash Room 303 tap	MZD691	June 25, 2020	-	Passed	0.0720	Passed	
Island View High School	Gender Neutral Wash Room 304H.1 tap	MYZ388	June 25, 2020	0.001	Passed	0.0700	Passed	
Island View High School	Gender Neutral Wash Room tap 1 by Room 106F.1	MZD717	June 26, 2020	-	Passed	0.1200	Passed	
Island View High School	Gender Neutral Wash Room tap 2 by Room 106F.1	MZD718	June 26, 2020	0.001	Passed	0.2000	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304A	MZD666	June 25, 2020	0.004	Passed	0.3800	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304B	MZD665	June 25, 2020	0.001	Passed	0.1900	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304C	WGQ677	June 27, 2023	0.001	Passed	0.2100	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room tap Room 304D	WGQ676	June 27, 2023	-	Passed	0.7800	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room tap Room 304E	MZD662	June 25, 2020	0.001	Passed	0.1100	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304F	WGQ675	June 27, 2023	-	Passed	0.1600	Passed	Tap remediated
Island View High School	Gender Neutral Wash Room tap Room 304G	MZD660	June 25, 2020	0.003	Passed	0.6300	Passed	
Island View High School	Gym Gender Neutral Wash Room 1 tap	WGQ668	June 27, 2023	-	Passed	0.3400	Passed	Tap remediated
Island View High School	Gym Gender Neutral Wash Room 2 tap	WGQ669	June 27, 2023	0.001	Passed	0.4200	Passed	Tap remediated
Island View High School	Janitors Closet 112A.1 tap	WGQ686	June 27, 2023	-	Passed	0.3700	Passed	Tap remediated
Island View High School	Janitors Closet 114 tap	MZD724	June 26, 2020	0.001	Passed	0.2900	Passed	
Island View High School	Janitors Closet 208B.1 tap	MZD667	June 25, 2020	-	Passed	0.3800	Passed	
Island View High School	Janitors Closet 208B.1 tap	MZD700	June 25, 2020	-	Passed	0.0600	Passed	
Island View High School	Kitchen 112 tap 1	WGQ683	June 27, 2023	-	Passed	0.0680	Passed	
Island View High School	Kitchen 112 tap 2	WGQ684	June 27, 2023	-	Passed	0.0860	Passed	
Island View High School	Kitchen 112 tap 3	WGQ685	June 27, 2023	-	Passed	0.3600	Passed	
Island View High School	Life Sciences Lab 315.1 tap 1	ADUN93	September 24, 2024	-	Passed	0.2600	Passed	
Island View High School	Life Sciences Lab 315.1 tap 2	ADUN95	September 24, 2024	-	Passed	0.2400	Passed	
Island View High School	Life Sciences Lab 315.1 tap 3	ADUN96	September 24, 2024	-	Passed	1.7000	Passed	
Island View High School	Life Sciences Lab 315.1 tap 4	ADUN97	September 24, 2024	-	Passed	0.2400	Passed	
Island View High School	Life Sciences Lab 315.1 tap 5	MZD675	June 25, 2020	-	Passed	1.1000	Passed	
Island View High School	Life Sciences Lab 315.1 tap 6	WDQ672	June 27, 2023	-	Passed	0.9200	Passed	Tap remediated
Island View High School	Life Sciences Lab 315.1 tap 7	MZD677	June 25, 2020	-	Passed	0.1900	Passed	
Island View High School	Main Office Wash Room 1081 tap	MZD713	June 25, 2020	-	Passed	0.0600	Passed	
Island View High School	Media Room 111B.1 tap	MZD728	June 26, 2020	0.003	Passed	0.1300	Passed	
Island View High School	Music Room 118 tap	MZD725	June 26, 2020	0.001	Passed	0.7100	Passed	
Island View High School	Nutrition Lab 211 tap 1	ARPJ91	June 5, 2025	-	Passed	0.4800	Passed	
Island View High School	Nutrition Lab 211 tap 2	ARPJ92	June 5, 2025	-	Passed	0.3600	Passed	
Island View High School	Nutrition Lab 211 tap 3	ARPJ93	June 5, 2025	-	Passed	0.1000	Passed	
Island View High School	Nutrition Lab 211 tap 4	ARPJ94	June 5, 2025	-	Passed	2.7000	Exceeded	
Island View High School	Nutrition Lab 211 tap 5	ARPJ95	June 5, 2025	-	Passed	2.2000	Exceeded	
Island View High School	Nutrition Lab 211 tap 6	ADUN92	September 24, 2024	-	Passed	0.4000	Passed	
Island View High School	Nutrition Lab 211 Handwash	ARPJ96	June 5, 2025	-	Passed	0.4500	Passed	
Island View High School	Production Room 107 tap	MZD730	June 26, 2020	0.001	Passed	0.5200	Passed	
Island View High School	Recycle Room 105 tap	MZD731	June 26, 2020	0.001	Passed	1.1000	Passed	
Island View High School	Room 217 (New)	ARPJ97	June 5, 2025	-	Passed	0.2800	Passed	
Island View High School	Science Lab 103 tap 1	MZD855	June 26, 2020	-	Passed	1.5000	Passed	
Island View High School	Science Lab 103 tap 2	MZD856	June 26, 2020	-	Passed	0.4100	Passed	
Island View High School	Science Lab 103 tap 3	MZD857	June 26, 2020	-	Passed	0.0570	Passed	
Island View High School	Science Lab 103 tap 4	NAM732	June 30, 2020	0.002	Passed	0.0240	Passed	
Island View High School	Science Lab 103 tap 5	WGQ680	June 27, 2023	-	Passed	0.1300	Passed	Tap remediated
Island View High School	Science Lab 103 tap 6	NAM734	June 30, 2020	0.002	Passed	0.0620	Passed	
Island View High School	Science Lab 103 tap 7	NAM735	June 30, 2020	0.002	Passed	0.1500	Passed	

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Island View High School	Staff Room 305	ARPJ04	June 5, 2025	-	Passed	0.1000	Passed		
Island View High School	Staff Room 305 tap 1	WGQ687	June 27, 2023	-	Passed	0.0560	Passed		
Island View High School	Staff Room 305 tap 2	WGQ688	June 25, 2020	-	Passed	0.7300	Passed		
J.L. Isley High School	1st Floor Double Fountain 1	AQHW74	April 28, 2025	-	Passed	0.2700	Passed		
J.L. Isley High School	1st Floor Double Fountain 2	AQHW75	April 28, 2025	-	Passed	0.2200	Passed		
J.L. Isley High School	1st Floor Fountain by Gender Neutral Wash Rooms	AQHW73	April 28, 2025	-	Passed	0.0670	Passed		
J.L. Isley High School	1st Floor Gender Neutral Wash Rooms tap 1	XKT669	October 27, 2023	-	Passed	0.2400	Passed		
J.L. Isley High School	1st Floor Gender Neutral Wash Rooms tap 2	XKT670	October 27, 2023	-	Passed	0.2400	Passed		
J.L. Isley High School	1st Floor Gender Neutral Wash Rooms tap 3	XKT671	October 27, 2023	-	Passed	0.2400	Passed		
J.L. Isley High School	1st Floor Gender Neutral Wash Rooms tap 4	VPP703	April 20, 2023	-	Passed	0.2000	Passed		
J.L. Isley High School	1st Floor Gender Neutral Wash Rooms tap 5							Out-of-Service	
J.L. Isley High School	1st Floor Gender Neutral Wash Rooms tap 6	VPP704	April 20, 2023	-	Passed	0.2300	Passed		
J.L. Isley High School	2nd Floor Double Fountain 1	AQHW77	April 28, 2025	-	Passed	0.0096	Passed		
J.L. Isley High School	2nd Floor Double Fountain 2	XKT672	October 27, 2023	-	Passed	0.0770	Passed		
J.L. Isley High School	2nd Floor Fountain by Gender Neutral Wash Rooms	AQHW78	April 28, 2025	-	Passed	0.1100	Passed		
J.L. Isley High School	2nd Floor Gender Neutral Wash Rooms tap 1	VPP650	April 20, 2023	-	Passed	0.3700	Passed		
J.L. Isley High School	2nd Floor Gender Neutral Wash Rooms tap 2	VPP651	April 20, 2023	-	Passed	0.4400	Passed		
J.L. Isley High School	2nd Floor Gender Neutral Wash Rooms tap 3	VPP652	April 20, 2023	-	Passed	0.2600	Passed		
J.L. Isley High School	2nd Floor Gender Neutral Wash Rooms tap 4	VPP653	April 20, 2023	-	Passed	0.3200	Passed		
J.L. Isley High School	2nd Floor Gender Neutral Wash Rooms tap 5	VPP654	April 20, 2023	-	Passed	0.2700	Passed		
J.L. Isley High School	2nd Floor Gender Neutral Wash Rooms tap 6	VPP655	April 20, 2023	-	Passed	0.3000	Passed		
J.L. Isley High School	3rd Floor Double Fountain 1	AQHW82	April 28, 2025	-	Passed	0.0890	Passed		
J.L. Isley High School	3rd Floor Double Fountain 2	AQHW83	April 28, 2025	-	Passed	0.1200	Passed		
J.L. Isley High School	3rd Floor Fountain by Gender Neutral Wash Rooms	AQHW81	April 28, 2025	-	Passed	0.0930	Passed		
J.L. Isley High School	3rd Floor Gender Neutral Wash Rooms tap 1	VPP512	April 20, 2023	-	Passed	0.7200	Passed		
J.L. Isley High School	3rd Floor Gender Neutral Wash Rooms tap 2	VPP513	April 20, 2023	-	Passed				

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
John Martin Junior High School	Gender Neutral Wash Room by Girls Wash Room	WHU639	June 5, 2023	-	Passed	0.0160	Passed	Tap remediated	
John Martin Junior High School	Girls Wash Room tap 1 by Gender Neutral Wash Room	WHU636	June 5, 2023	0.007	Exceeded	0.1200	Passed	Hand washing only	
John Martin Junior High School	Girls Wash Room tap 1 by Gym	MYA987	June 22, 2020	0.120	Exceeded	0.6800	Passed	Hand washing only	
John Martin Junior High School	Girls Wash Room tap 1 by Resource Room	MYA984	June 22, 2020	0.002	Passed	0.1900	Passed		
John Martin Junior High School	Girls Wash Room tap 2 by Gender Neutral Wash Room	WHU637	June 5, 2023	0.006	Exceeded	0.1200	Passed	Hand washing only	
John Martin Junior High School	Girls Wash Room tap 2 by Gym	MYA988	June 22, 2020	0.020	Exceeded	0.2200	Passed	Hand washing only	
John Martin Junior High School	Girls Wash Room tap 2 by Resource Room	MYA985	June 22, 2020	-	Passed	0.1100	Passed		
John Martin Junior High School	Girls Wash Room tap 2 in Gym	WHX407	July 6, 2023	-	Passed	0.0093	Passed	Tap remediated	
John Martin Junior High School	Girls Wash Room tap 3 by Gender Neutral Wash Room	WHU638	June 5, 2023	0.007	Exceeded	0.1700	Passed	Hand washing only	
John Martin Junior High School	Girls Wash Room tap 3 by Gym	MYA989	June 22, 2020	0.002	Passed	0.0290	Passed		
John Martin Junior High School	Girls Wash Room tap 3 by Resource Room	MYA986	June 22, 2020	0.004	Passed	0.1100	Passed		
John Martin Junior High School	Girls Wash Room tap 3 in Gym	WHX408	July 6, 2023	-	Passed	0.0120	Passed	Tap remediated	
John Martin Junior High School	Girls Wash Room tap 4 by Gym	MYA990	June 22, 2020	0.001	Passed	0.0230	Passed		
John Martin Junior High School	Girls Wash Room tap 4 in Gym	WHX409	July 6, 2023	-	Passed	0.0120	Passed	Tap remediated	
John Martin Junior High School	Gym Office Wash Room tap	WHX606	July 6, 2023	-	Passed	0.0220	Passed	Tap remediated	
John Martin Junior High School	Handwashing sink in science Lab	MYR869	June 24, 2020	0.039	Exceeded	0.5800	Passed	Out-of-Service	
John Martin Junior High School	Janitors Closet inside caretaker Room	MYR810	June 24, 2020	0.001	Passed	0.0140	Passed		
John Martin Junior High School	Janitors Closet tap by Boiler Room	MYR835	June 24, 2020	0.002	Passed	0.0390	Passed		
John Martin Junior High School	Janitors Closet tap by Resource Room	MYA983	June 22, 2020	-	Passed	0.0150	Passed		
John Martin Junior High School	Janitors Supplies Room tap	MYR824	June 24, 2020	0.001	Passed	0.0230	Passed		
John Martin Junior High School	Kitchen/Cafeteria tap 1	ARKL31	May 30, 2025	-	Passed	0.0041	Passed		
John Martin Junior High School	Kitchen/Cafeteria tap 2	ARKL32	May 30, 2025	-	Passed	0.0037	Passed		
John Martin Junior High School	Lab sink in science Lab tap 3	MYR868	June 24, 2020	3.400	Exceeded	0.9100	Passed	Out-of-Service	
John Martin Junior High School	Office Staff Wash Room tap	WHX563	July 6, 2023	-	Passed	0.0270	Passed	Tap remediated	
John Martin Junior High School	Science Lab 1 tap 1	MYR847	June 24, 2020	0.160	Exceeded	0.1800	Passed	Laboratory or Hand washing only	
John Martin Junior High School	Science Lab 1 tap 2	NAI288	June 29, 2020	0.380	Exceeded	1.2000	Passed	Laboratory or Hand washing only	
John Martin Junior High School	Science Lab 1 tap 3	MYR848	June 24, 2020	0.200	Exceeded	2.3000	Exceeded	Laboratory or Hand washing only	
John Martin Junior High School	Science Lab 1 tap 4	MYR849	June 24, 2020	0.360	Exceeded	0.8100	Passed	Laboratory or Hand washing only	
John Martin Junior High School	Science Lab 1 tap 5	MYR850	June 24, 2020	0.140	Exceeded	2.0000	Exceeded	Laboratory or Hand washing only	
John Martin Junior High School	Science Lab 1 tap 6	MYR851	June 24, 2020	1.000	Exceeded	3.2000	Exceeded	Laboratory or Hand washing only	
John Martin Junior High School	Science Lab 2 tap 1	MYR856	June 24, 2020	0.340	Exceeded	2.1000	Exceeded	Laboratory or Hand washing only	
John Martin Junior High School	Science Lab 2 tap 2	MYR857	June 24, 2020	1.500	Exceeded	0.5500	Passed	Laboratory or Hand washing only	

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Kingswood Elementary	Boys Wash Room tap 1 by Room 106	MUU191	June 5, 2020	0.003	Passed	0.3100	Passed		
Kingswood Elementary	Boys Wash Room tap 1 by Room 114	VXQ502	May 25, 2023	-	Passed	0.0290	Passed	Tap remediated	
Kingswood Elementary	Boys Wash Room tap 1 by Room 225	MUU161	June 5, 2020	0.002	Passed	0.0500	Passed		
Kingswood Elementary	Boys Wash Room tap 1 by Room 232	VXQ510	May 25, 2023	-	Passed	0.0220	Passed	Tap remediated	
Kingswood Elementary	Boys Wash Room tap 2 by Room 106	VXQ500	May 25, 2023	-	Passed	0.0680	Passed	Tap remediated	
Kingswood Elementary	Boys Wash Room tap 2 by Room 114	VXQ503	May 25, 2023	-	Passed	0.0940	Passed	Tap remediated	
Kingswood Elementary	Boys Wash Room tap 2 by Room 225	MUU162	June 5, 2020	0.003	Passed	0.0910	Passed		
Kingswood Elementary	Boys Wash Room tap 2 by Room 232	VXQ511	May 25, 2023	-	Passed	0.1200	Passed	Tap remediated	
Kingswood Elementary	Cafeteria/Kitchen Handwashing tap	AQNX15	May 5, 2025	-	Passed	0.0270	Passed		
Kingswood Elementary	Cafeteria/Kitchen Single Compartment Sink tap	AQNX18	May 5, 2025	-	Passed	0.0190	Passed		
Kingswood Elementary	Cafeteria/Kitchen Triple Compartment Sink tap 1	AQNX16	May 5, 2025	-	Passed	0.0180	Passed		
Kingswood Elementary	Cafeteria/Kitchen Triple Compartment Sink tap 2	AQNX17	May 5, 2025	-	Passed	0.0160	Passed		
Kingswood Elementary	Cafeteria/Stage Kitchen tap 1	AQNX19	May 5, 2025	-	Passed	0.0130	Passed		
Kingswood Elementary	Cafeteria/Stage Kitchen tap 2	AQNX20	May 5, 2025	-	Passed	0.0130	Passed		
Kingswood Elementary	Class Room 101 tap	MUU198	June 5, 2020	-	Passed	0.0430	Passed		
Kingswood Elementary	Class Room 102 tap	MUU195	June 5, 2020	-	Passed	0.2500	Passed		
Kingswood Elementary	Class Room 103 tap	MUU199	June 5, 2020	-	Passed	0.2400	Passed		
Kingswood Elementary	Class Room 104 tap	MUU202	June 5, 2020	-	Passed	0.0590	Passed		
Kingswood Elementary	Class Room 110 tap	MUU188	June 5, 2020	-	Passed	0.0410	Passed		
Kingswood Elementary	Class Room 112 tap	MUU170	June 5, 2020	0.001	Passed	0.5000	Passed		
Kingswood Elementary	Class Room 113 tap	MUU171	June 5, 2020	-	Passed	0.3900	Passed		
Kingswood Elementary	Class Room 115 tap 1	MUU178	June 5, 2020	-	Passed	0.0680	Passed		
Kingswood Elementary	Class Room 115 tap 2	MUU179	June 5, 2020	-	Passed	0.5600	Passed		
Kingswood Elementary	Class Room 116 tap	MUU177	June 5, 2020	0.002	Passed	0.6800	Passed		
Kingswood Elementary	Class Room 117 tap	MUU173	June 5, 2020	-	Passed	0.3900	Passed		
Kingswood Elementary	Class Room 118 tap	MUU174	June 5, 2020	-	Passed	0.5000	Passed		
Kingswood Elementary	Class Room 119 tap	MUU176	June 5, 2020	-	Passed	0.3600	Passed		
Kingswood Elementary	Class Room 120 tap	MUU175	June 5, 2020	-	Passed	0.4700	Passed		
Kingswood Elementary	Class Room 167 tap	MUU187	June 5, 2020	-	Passed	0.0300	Passed		
Kingswood Elementary	Class Room 210 tap	MUU169	June 5, 2020	-	Passed	0.0350	Passed		
Kingswood Elementary									

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
LeMARCHant-St. Thomas Elementary	Stage tap 2	MUW273	June 8, 2020	-	Passed	0.0560	Passed		
Leslie Thomas Junior High School	1st Floor Boys Wash Room tap 1	SBZ983	March 14, 2022	0.003	Passed	0.0780	Passed		
Leslie Thomas Junior High School	1st Floor Boys Wash Room tap 2	SBZ984	March 14, 2022	0.002	Passed	0.0630	Passed		
Leslie Thomas Junior High School	1st Floor Girls Wash Room tap 1	SBZ985	March 14, 2022	-	Passed	0.0550	Passed		
Leslie Thomas Junior High School	1st Floor Girls Wash Room tap 2	MOP608	May 5, 2020	0.001	Passed	0.0760	Passed		
Leslie Thomas Junior High School	1st Floor Girls Wash Room tap 3	MOP609	May 5, 2020	0.002	Passed	0.0820	Passed		
Leslie Thomas Junior High School	2nd Floor Boys Wash Room tap 1	SBZ995	March 14, 2022	0.001	Passed	0.0550	Passed		
Leslie Thomas Junior High School	2nd Floor Boys Wash Room tap 2	SBZ996	March 14, 2022	0.001	Passed	0.0540	Passed		
Leslie Thomas Junior High School	2nd Floor Café tap	AQVY42	May 14, 2025	-	Passed	0.0490	Passed		
Leslie Thomas Junior High School	2nd Floor Girls Wash Room tap 1	SBZ994	March 14, 2022	-	Passed	0.0640	Passed		
Leslie Thomas Junior High School	2nd Floor Girls Wash Room tap 2	MOP590	May 5, 2020	0.002	Passed	0.0860	Passed		
Leslie Thomas Junior High School	3rd Floor Boys Wash Room tap 1	MOP577	May 5, 2020	0.003	Passed	0.1100	Passed		
Leslie Thomas Junior High School	3rd Floor Boys Wash Room tap 2	MOP578	May 5, 2020	0.003	Passed	0.0930	Passed		
Leslie Thomas Junior High School	3rd Floor Girls Wash Room tap 1	MOP579	May 5, 2020	0.004	Passed	0.0900	Passed		
Leslie Thomas Junior High School	3rd Floor Girls Wash Room tap 2	MOP580	May 5, 2020	0.002	Passed	0.0810	Passed		
Leslie Thomas Junior High School	3rd Floor Girls Wash Room tap 3	SBZ998	March 14, 2022	0.001	Passed	0.0560	Passed		
Leslie Thomas Junior High School	Class Room 106 tap	SBZ986	March 14, 2022	0.004	Passed	0.1900	Passed		
Leslie Thomas Junior High School	Class Room 107 tap	SBZ987	March 14, 2022	0.003	Passed	0.1000	Passed		
Leslie Thomas Junior High School	Class Room 108 tap							Out-of-Service	
Leslie Thomas Junior High School	Class Room 109 tap	MOP600	May 5, 2020	0.002	Passed	0.0760	Passed		
Leslie Thomas Junior High School	Class Room 110 tap	MOP598	May 5, 2020	0.002	Passed	0.8000	Passed		
Leslie Thomas Junior High School	Class Room 111 tap 1	MOP596	May 5, 2020	0.001	Passed	0.3800	Passed		
Leslie Thomas Junior High School	Class Room 111 tap 2	SBZ989	March 12, 2022	0.001	Passed	0.0990	Passed		
Leslie Thomas Junior High School	Class Room 113 tap	MOP595	May 5, 2020	0.002	Passed	0.2600	Passed		
Leslie Thomas Junior High School	Class Room 308 tap	SBZ997	March 14, 2022	0.001	Passed	0.0780	Passed		
Leslie Thomas Junior High School	Class Room 308 Wash Room 1 tap	MOP584	May 5, 2020	0.003	Passed	0.0780	Passed		
Leslie Thomas Junior High School	Class Room 308 Wash Room 2 tap	MOP585	May 5, 2020	0.002	Passed	0.0700	Passed		
Leslie Thomas Junior High School	Fountain by Room 1B	AQVY41	May 14, 2025	-	Passed	0.0560	Passed		
Leslie Thomas Junior High School	Fountain by Room 2A	AQVY43	May 14, 2025	-	Passed				

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Lockview High School	Male Wash Room tap 1 by section A	WGS451	June 30, 2023	0.006	Exceeded	0.1300	Passed	Hand washing only	
Lockview High School	Male Wash Room tap 1 F Pod	NCK194	July 13, 2020	0.002	Passed	0.0680	Passed		
Lockview High School	Male Wash Room tap 2 by section A	WGS452	June 30, 2023	0.009	Exceeded	0.1200	Passed	Hand washing only	
Lockview High School	Male Wash Room tap 2 F Pod	NCK195	July 13, 2020	0.007	Exceeded	0.0660	Passed	Hand washing only	
Lockview High School	Male Wash Room tap 3 by section A	WGS453	June 30, 2023	0.010	Exceeded	0.1400	Passed	Hand washing only	
Lockview High School	Male Wash Room tap 3 F Pod	NCK196	July 13, 2020	0.003	Passed	0.0630	Passed		
Lockview High School	Male Wash Room tap 4 by section A	WGS454	June 30, 2023	0.008	Exceeded	0.1200	Passed	Hand washing only	
Lockview High School	Multipurpose Room Wash Room E109 tap 1	NCK252	July 13, 2020	0.003	Passed	0.3600	Passed		
Lockview High School	Multipurpose Room Wash Room E109 tap 2	WGS460	June 30, 2023	-	Passed	0.0240	Passed	Tap remediated	
Lockview High School	Music Room tap Room F122	NCK062	July 13, 2020	0.002	Passed	0.8100	Passed		
Lockview High School	Office D125 tap	ARNH37	June 3, 2025	-	Passed	0.0270	Passed		
Lockview High School	Office Wash Room D115 tap	NCK029	July 13, 2020	0.002	Passed	0.2500	Passed		
Lockview High School	Office Wash Room D116 tap	WGS443	June 30, 2023	-	Passed	0.0680	Passed	Tap remediated	
Lockview High School	Office Wash Room D128 tap	NCK026	July 13, 2020	-	Passed	0.0760	Passed		
Lockview High School	Physics Lab B110 tap 1	WQG836	June 29, 2023	-	Passed	0.1300	Passed	Laboratory or hand washing only	
Lockview High School	Physics Lab B110 tap 2	NBQ739	July 8, 2020	0.005	Passed	0.4100	Passed		
Lockview High School	Physics Lab B111 tap 1	NBQ741	July 8, 2020	0.049	Exceeded	0.8200	Passed	Laboratory or hand washing only	
Lockview High School	Physics Lab B111 tap 2	NBQ742	July 8, 2020	0.006	Exceeded	0.0730	Passed	Laboratory or hand washing only	
Lockview High School	Physics Lab Prep Room B112 tap	WQG837	June 29, 2023	0.003	Passed	0.0970	Passed	Laboratory or hand washing only	
Lockview High School	Production Room F131 tap 1	WQG830	June 29, 2023	-	Passed	0.0400	Passed		
Lockview High School	Production Room F131 tap 2	WQG831	June 29, 2023	0.001	Passed	0.1500	Passed	Tap remediated	
Lockview High School	Science Lab B101 tap 1	NBQ683	July 8, 2020	0.001	Passed	0.7100	Passed		
Lockview High School	Science Lab B101 tap 10	NBQ692	July 8, 2020	0.018	Exceeded	1.1000	Passed	Laboratory or hand washing only	

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Madeline Symonds Middle School	Staff Room Wash Room 2026 tap	NAP024	July 3, 2020	-	Passed	0.2100	Passed		
Madeline Symonds Middle School	Staff Room Wash Room 2027 tap	NAP025	July 3, 2020	0.001	Passed	0.2200	Passed		
Madeline Symonds Middle School	Tech Ed Room 2039 tap	NAP023	July 3, 2020	-	Passed	0.3900	Passed		
Marine Drive Academy	1st Floor Fountain	ARUZ86	June 11, 2025	-	Passed	0.6700	Passed		
Marine Drive Academy	1st Floor Hallway tap	GXG682	October 13, 2023	-	Passed	0.4600	Passed		
Marine Drive Academy	2nd Floor Fountain by Gym	ARUZ72	June 11, 2025	0.001	Passed	1.3000	Passed		
Marine Drive Academy	2nd Floor Fountain	ARUZ73	June 11, 2025	-	Passed	0.6600	Passed		
Marine Drive Academy	3rd Floor Fountain	ARUZ82	June 11, 2025	-	Passed	0.3600	Passed		
Marine Drive Academy	3rd Floor Hallway tap	GXG680	October 13, 2023	-	Passed	0.4500	Passed		
Marine Drive Academy	Art Room 316 tap	QWP097	September 24, 2021	-	Passed	0.3700	Passed		
Marine Drive Academy	Boiler Room tap	QWP072	September 24, 2021	-	Passed	0.2900	Passed		
Marine Drive Academy	Cafeteria Room 206 tap 1	ARUZ69	June 11, 2025	-	Passed	0.1100	Passed		
Marine Drive Academy	Cafeteria Room 206 tap 2	ARUZ70	June 11, 2025	-	Passed	0.1100	Passed		
Marine Drive Academy	Cafeteria Room 206 tap 3	ARUZ71	June 11, 2025	0.001	Passed	0.1600	Passed		
Marine Drive Academy	Class Room 118	QWP076	September 24, 2021	-	Passed	0.3800	Passed		
Marine Drive Academy	Class Room 220 tap	QWP109	September 24, 2021	-	Passed	0.2100	Passed		
Marine Drive Academy	Class Room 220 Wash Room tap	QWP108	September 24, 2021	-	Passed	0.2400	Passed		
Marine Drive Academy	Class Room 221 tap	QWP107	September 24, 2021	-	Passed	0.3700	Passed		
Marine Drive Academy	Class Room 221 Wash Room tap	QWP070	September 24, 2021	0.001	Passed	0.3000	Passed		
Marine Drive Academy	Class Room 225 tap	QWP091	September 24, 2021	-	Passed	0.6500	Passed		
Marine Drive Academy	Class Room 226 tap (Learning Centre)	ARUZ75	June 11, 2025	-	Passed	0.3800	Passed		
Marine Drive Academy	Class Room 306 tap	QWP100	September 24, 2021	0.001	Passed	0.2000	Passed		
Marine Drive Academy	Class Room 307 tap	QWP078	September 24, 2021	0.001	Passed	0.3000	Passed		
Marine Drive Academy	Custodian Room 103 tap	QWP089	September 24, 2021	0.002	Passed	0.2800	Passed		
Marine Drive Academy	Food Lab Room 310 tap 1 (Nutrition Lab)	ARUZ76	June 11, 2025	-	Passed	0.0860	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Millwood High School	Class Room tap Room 240	MTN687	May 29, 2020	0.001	Passed	0.0280	Passed		
Millwood High School	Fountain by Girls Wash Room	ARBM30	May 21, 2025	-	Passed	0.0280	Passed		
Millwood High School	Fountain by Room 206	ARBM34	May 21, 2025	-	Passed	0.0370	Passed		
Millwood High School	Fountain in Modular	ARBM35	May 21, 2025	-	Passed	0.0360	Passed		
Millwood High School	Gender Neutral Wash Room by Room 202	WDJ128	June 20, 2023	0.001	Passed	0.4300	Passed	Tap remediated	
Millwood High School	Gender Neutral Wash Room tap Room 152	MTN736	May 29, 2020	0.002	Passed	0.0360	Passed		
Millwood High School	Gender Neutral Wash Room tap Room 202	MTN685	May 29, 2020	0.003	Passed	0.5800	Passed		
Millwood High School	Girls Locker Room tap 1 Room 150	MTN731	May 29, 2020	0.001	Passed	0.0330	Passed		
Millwood High School	Girls Locker Room tap 2 Room 150	MTN732	May 29, 2020	0.001	Passed	0.0350	Passed		
Millwood High School	Girls Locker Room tap 3 Room 150	MTN733	May 29, 2020	0.001	Passed	0.0400	Passed		
Millwood High School	Girls Wash Room tap 1 Room 120	WDJ120	June 20, 2023	-	Passed	0.0950	Passed	Tap remediated	
Millwood High School	Girls Wash Room tap 1 Room 205	WDJ126	June 20, 2023	0.001	Passed	0.0800	Passed	Tap remediated	
Millwood High School	Girls Wash Room tap 2 Room 120	MTN717	May 29, 2020	0.003	Passed	0.0540	Passed		
Millwood High School	Girls Wash Room tap 2 Room 205	MTN679	May 29, 2020	0.002	Passed	0.1000	Passed		
Millwood High School	Girls Wash Room tap 3 Room 120	MTN718	May 29, 2020	0.001	Passed	0.0570	Passed		
Millwood High School	Girls Wash Room tap 3 Room 205	MTN680	May 29, 2020	0.001	Passed	0.1100	Passed		
Millwood High School	Girls Wash Room tap 4 Room 120	MTN719	May 29, 2020	0.002	Passed	0.0540	Passed		
Millwood High School	Girls Wash Room tap 4 Room 205	MTN681	May 29, 2020	-	Passed	0.0790	Passed		
Millwood High School	Girls Wash Room tap 5 Room 120	WDJ121	June 20, 2023	-	Passed	0.0990	Passed	Tap remediated	
Millwood High School	Girls Wash Room tap 5 Room 205	MTN682	May 29, 2020	0.005	Passed	0.2000	Passed		
Millwood High School	Girls Wash Room tap 6 Room 120	MTN721	May 29, 2020	0.001	Passed	0.0260	Passed		
Millwood High School	Girls Wash Room tap 6 Room 205	MTN683	May 29, 2020	0.003	Passed	0.0400	Passed		
Millwood High School	Gym Office Wash Room tap Room 151	MTN735	May 29, 2020	0.002	Passed	0.0970	Passed		
Millwood High School	Jan								

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - December, 2025

Halifax Regional Centre for Education				
---------------------------------------	--	--	--	--

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Park West School	Modular Boys Wash Room tap 1	WAT090	June 6, 2023	-	Passed	0.0570	Passed		
Park West School	Modular Boys Wash Room tap 2	WAT091	June 6, 2023	-	Passed	0.0430	Passed		
Park West School	Modular Boys Wash Room tap 3	WAT092	June 6, 2023	-	Passed	0.0310	Passed		
Park West School	Modular Boys Wash Room tap 4	WAT093	June 6, 2023	-	Passed	0.0250	Passed		
Park West School	Modular Girls Wash Room tap 1	WAT086	June 6, 2023	0.001	Passed	0.0360	Passed		
Park West School	Modular Girls Wash Room tap 2	WAT087	June 6, 2023	-	Passed	0.0590	Passed		
Park West School	Modular Girls Wash Room tap 3	WAT088	June 6, 2023	-	Passed	0.0280	Passed		
Park West School	Modular Girls Wash Room tap 4	WAT089	June 6, 2023	-	Passed	0.0200	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Rocky Lake Junior High School	Cafeteria hand washing sink tap	ARBM55	May 21, 2025	-	Passed	0.0088	Passed		
Rocky Lake Junior High School	Cafeteria Janitors Closet tap	ARBM59	May 21, 2025	-	Passed	0.0170	Passed		
Rocky Lake Junior High School	Cafeteria triple sink tap 1	ARBM56	May 21, 2025	-	Passed	0.0064	Passed		
Rocky Lake Junior High School	Cafeteria triple sink tap 2	ARBM57	May 21, 2025	-	Passed	0.0053	Passed		
Rocky Lake Junior High School	Chemistry Lab 201 tap 1	MSG746	May 26, 2020	0.120	Exceeded	0.8700	Passed	Laboratory or Hand washing only	
Rocky Lake Junior High School	Chemistry Lab 201 tap 2	MSG747	May 26, 2020	0.004	Passed	0.0550	Passed	Laboratory or Hand washing only	
Rocky Lake Junior High School	Chemistry Lab 201 tap 3	MSG748	May 26, 2020	0.004	Passed	0.1300	Passed		
Rocky Lake Junior High School	Chemistry Lab 201 tap 4	MSG749	May 26, 2020	0.004	Passed	0.0530	Passed		
Rocky Lake Junior High School	Chemistry Lab 202 tap 1	MSG744	May 26, 2020	0.011	Exceeded	0.0710	Passed	Laboratory or Hand washing only	
Rocky Lake Junior High School	Chemistry Lab 202 tap 2	MSG745	May 26, 2020	0.007	Exceeded	0.0970	Passed		
Rocky Lake Junior High School	Chemistry Lab 203 tap 1	MSG738	May 26, 2020	0.058	Exceeded	0.1500	Passed	Laboratory or Hand washing only	
Rocky Lake Junior High School	Chemistry Lab 203 tap 2	MSG739	May 26, 2020	0.008	Exceeded	0.1800	Passed	Laboratory or Hand washing only	
Rocky Lake Junior High School	Chemistry Lab 203 tap 3	MSG740	May 26, 2020	0.063	Exceeded	0.3300	Passed	Laboratory or Hand washing only	
Rocky Lake Junior High School	Chemistry Lab 203 tap 4	MSG741	May 26, 2020	0.023	Exceeded	0.4500	Passed	Laboratory or Hand washing only	
Rocky Lake Junior High School	Chemistry Lab 204 Prep Room tap	MSG742	May 26, 2020	0.110	Exceeded	0.8600	Passed	Laboratory or Hand washing only	
Rocky Lake Junior High School	Class Room 103 tap	MTA209	May 28, 2020	-	Passed	0.0110	Passed		
Rocky Lake Junior High School	Class Room 104 tap	MTA214	May 28, 2020	-	Passed	0.9000	Passed		
Rocky Lake Junior High School	Class Room 205 tap	MSG737	May 26, 2020	-	Passed	1.1000	Passed		
Rocky Lake Junior High School	Fountain by 3rd Floor Wash Rooms	ARBM65	May 21, 2025	-	Passed	0.0330	Passed		
Rocky Lake Junior High School	Fountain by Cafeteria	ARBM62	May 21, 2025	0.001	Passed	0.0820	Passed		
Rocky Lake Junior High School	Fountain by Gym Wash Rooms	ARBM63	May 21, 2025	-	Passed	0.0340	Passed		
Rocky Lake Junior High School	Gender Neutral Wash Room 329 tap	MSG715	May 26, 2020	0.001	Passed	0.0330	Passed		
Rocky Lake Junior High School	Gender Neutral Wash Room tap by 1st Floor Wash Rooms	MSG773	May 26, 2020	0.001	Passed	0.3100	Passed		
Rocky Lake Junior High School	Girls Wash Room tap 1 connected to Gym	VZI859	May 31, 2023	-	Passed	0.0059	Passed		
Rocky Lake Junior High School	Girls Wash Room tap 2 connected to Gym	VZI860	May 31, 2023	-	Passed	0.0150	Passed		
Rocky Lake Junior High School	Girls Wash Room tap 3 connected to Gym	MSG756	May 26, 2020	0.002	Passed	0.0096	Passed		
Rocky Lake Junior High School	Girls Wash Room tap 4 connected to Gym	MSG757	May 26, 2020	0.001	Passed	0.0069	Passed		
Rocky Lake Junior High School	Gym Physical Education Office 1 tap	VZI857	May 31, 2023	0.003	Passed	0.1300	Passed		
Rocky Lake Junior High School	Gym Physical Education Office 2 tap	VZI858	May 31, 2023	-	Passed	0.0350	Passed		
Rocky Lake Junior High School	Janitors Closet tap by 3rd Floor Wash Rooms	MSG720	May 26, 2020	0.001	Passed	0.0130	Passed		
Rocky Lake Junior High School	Janitors Closet tap by Room 103	MTA205	May 28, 2020	0.001	Passed	0.0340	Passed		
Rocky Lake Junior High School	Janitors Closet tap by Room 203	MSG743	May 26, 2020	0.001	Passed	0.0700	Passed		
Rocky Lake Junior High School	Learning Centre 301 tap	vzi869	May 31, 2023	-	Passed	0.0100	Passed		
Rocky Lake Junior High School	Learning Centre Wash Room 219B tap	MSG730	May 26, 2020	-	Passed	0.0079	Passed		
Rocky Lake Junior High School	Main Office Staff Wash Room tap	MSG760	May 26, 2020	0.001	Passed	0.0300	Passed		
Rocky Lake Junior High School	Room 105 triple compartment sink tap 1	ARBM60	May 21, 2025	-	Passed	0.0980	Passed		
Rocky Lake Junior High School	Room 105 triple compartment sink tap 2	ARBM61	May 21, 2025	-	Passed	0.0960	Passed		
Rocky Lake Junior High School	Sick Room tap by Room 329	VZI862	May 31, 2023	-	Passed	0.0086	Passed		
Rocky Lake Junior High School	Staff Photocopy Room tap	SCH350	March 15, 2022	-	Passed	0.0160	Passed		
Rocky Lake Junior High School	Staff Room Female Wash Room tap 1	VZI872	May 31, 2023	0.001	Passed	0.0180	Passed	Tap remediated	
Rocky Lake Junior High School	Staff Room Female Wash Room tap 2	MSG729	May 26, 2020	0.003	Passed	0.0180	Passed		
Rocky Lake Junior High School	Staff Room Mens Wash Room tap	MSG727	May 26, 2020	-	Passed	0.0075	Passed		
Rocky Lake Junior High School	Staff Room tap	ARBM64	May 21, 2025	-	Passed	0.0075	Passed		
Rocky Lake Junior High School	Vice Principal Room tap	MSG761	May 26, 2020	0.003	Passed	0.0560	Passed		
Ross Road School	Art Room 120 Tap 1	ARTT20	June 10, 2025	-	Passed	0.0065	Passed		
Ross Road School	Art Room 120 Tap 2	ARTT21	June 10, 2025	-	Passed	0.0130	Passed		
Ross Road School	Art Room 120 Tap 3	ARTT22	June 10, 2025	-	Passed	0.0130	Passed		
Ross Road School	Art Room 120 Tap 4	ARTT23	June 10, 2025	-	Passed	0.0210	Passed		
Ross Road School	Art Room 120 Tap 5	ARTT24	June 10, 2025	-	Passed	0.0130	Passed		
Ross Road School	Boys Locker Room 140 tap	XGE237	October 11, 2023	-	Passed	0.0730	Passed	Tap remediated	
Ross Road School	Boys Wash Room tap 1 by Room 104	XGE228	October 11, 2023	-	Passed	0.0310	Passed	Tap remediated	
Ross Road School	Boys Wash Room tap 1 by Room 214	XGE243	October 11, 2023	-	Passed	0.0140	Passed	Tap remediated	
Ross Road School	Boys Wash Room tap 1 near Room 120	MXZ649	June 22, 2020	0.001	Passed	0.2400	Passed		
Ross Road School	Boys Wash Room tap 2 by Room 104	MXZ642	June 22, 2020	0.004	Passed	0.2400	Passed		
Ross Road School	Boys Wash Room tap 2 by Room 214	XGE233	October 11, 2023	-	Passed	0.0120	Passed	Tap remediated	
Ross Road School	Boys Wash Room tap 2 near Room 120	MXZ650	June 22, 2020	0.003	Passed	0.1800	Passed		
Ross Road School	Boys Wash Room tap 3 by Room 214	MXZ681	June 22, 2020	0.005	Passed	0.1500	Passed		
Ross Road School	Boys Wash Room tap 3 near Room 120	MXZ651	June 22, 2020	0.001	Passed	0.0470	Passed		
Ross Road School	Cafeteria/Kitchen tap 1	ARTT15	June 10, 2025	-	Passed	0.0390	Passed		
Ross Road School	Cafeteria/Kitchen tap 2	ARTT16	June 10, 2025	-	Passed	0.0380	Passed		
Ross Road School	Cafeteria/Kitchen tap 3	ARTT17	June 10, 2025	0.001	Passed	0.0440	Passed		
Ross Road School	Cafeteria/Kitchen tap 4	ARTT18	June 10, 2025	0.003	Passed	0.0660	Passed		
Ross Road School	Class Room 133 tap	MXZ667	June 22, 2020	0.002	Passed	0.1300	Passed		
Ross Road School	Class Room 134 tap	MXZ666	June 22, 2020	0.001	Passed	0.1400	Passed		
Ross Road School	Fountain by Boiler Room	ARTT25	June 10, 2025	-	Passed	0.0027	Passed		
Ross Road School	Fountain by Room 104	ARTT19	June 10, 2025	-	Passed	0.0340	Passed		
Ross Road School	Fountain by Room 214	ARTT27	June 10, 2025	-	Passed	0.0280	Passed		
Ross Road School	Fountain in Gym	ARTT26	June 10, 2025	-	Passed	0.0150	Passed		
Ross Road School	Gender Neutral Wash Room 217 tap	MXZ673	June 22, 2020	0.002	Passed	0.0870	Passed		
Ross Road School	Gender Neutral Wash Room tap by Room 107	MXZ643	June 22, 2020	0.003	Passed	0.1800	Passed		
Ross Road School	Girls Locker Room 141 tap	MXZ664	June 22, 2020	0.001	Passed	0.9300	Passed		
Ross Road School	Girls Wash Room tap 1 by Room 104	MXZ639	June 22, 2020	0.003	Passed	0.1200	Passed		
Ross Road School	Girls Wash Room tap 1 by Room 120	MXZ645	June 22, 2020	0.003	Passed	0.2200	Passed		
Ross Road School	Girls Wash Room tap 1 by Room 217	MXZ674	June 22, 2020	0.004	Passed	0.1800	Passed		
Ross Road School	Girls Wash Room tap 2 by Room 104	MXZ640	June 22, 2020	0.001	Passed	0.0280	Passed		
Ross Road School	Girls Wash Room tap 2 by Room 120	MXZ646	June 22, 2020	0.002	Passed	0.2100	Passed		
Ross Road School	Girls Wash Room tap 2 by Room 217	XGE241	October 11, 2023	-	Passed	0.0110	Passed	Tap remediated	
Ross Road School	Girls Wash Room tap 3 by Room 120	MXZ647	June 22, 2020	0.003	Passed	0.2000	Passed		
Ross Road School	Girls Wash Room tap 3 by Room 217	XGE242	October 11, 2023	-	Passed	0.0120	Passed	Tap remediated	
Ross Road School	Gym Office 138 tap	XGE236	October 11, 2023	-	Passed	0.1200	Passed	Tap remediated	
Ross Road School	Gym Office 139 tap	MXZ665	June 22, 2020	0.001	Passed	0.1200	Passed		
Ross Road School	Janitors Closet 135 tap	MXZ659	June 22, 2020	0.001	Passed	0.0560	Passed		
Ross Road School	Janitors Closet 214 tap	MXZ677	June 22, 2020	0.001	Passed	0.0500	Passed		
Ross Road School	Janitors Closet tap by Boys Wash Room	MXZ648	June 22, 2020	0.001	Passed	0.0260	Passed		
Ross Road School	Janitors Closet tap by Room 108	MXZ644	June 22, 2020	0.001	Passed	0.2000	Passed		
Ross Road School	Staff Room 111 Wash Room tap	MXZ638	June 22, 2020	-	Passed	0.0260	Passed		
Ross Road School	Staff Room 216 tap	ARTT28	June 10, 2025	-	Passed	0.0059	Passed		
Ross Road School	Tech Ed. Room tap	MXZ661	June 22, 2020	0.001	Passed	0.3300	Passed		
Sackville Heights Elementary	Art Room tap Room 1063	MYH131	June 23, 2020	-	Passed	0.3900	Passed		
Sackville Heights Elementary	Boys Locker Room tap in Gym	MYH123	June 23, 2020	-	Passed	0.0240	Passed		
Sackville Heights Elementary	Boys Wash Room tap 1 Room 1045	MYH157	June 23, 2020	0.002	Passed	0.1800	Passed		
Sackville Heights Elementary	Boys Wash Room tap 1 Room 1049	MYH150	June 23, 2020	0.001	Passed	0.1300	Passed		
Sackville Heights Elementary	Boys Wash Room tap 1 Room 2026	MYH176	June 23, 2020	0.001	Passed	0.1300	Passed		
Sackville Heights Elementary	Boys Wash Room tap 2 Room 1045	MYH158	June 23, 2020	0.003	Passed	0.3200	Passed		
Sackville Heights Elementary	Boys Wash Room tap 2 Room 1049	NXK291	October 15, 2020	-	Passed	0.0640	Passed	Tap remediated	
Sackville Heights Elementary	Boys Wash Room tap 2 Room 2026	MYH177	June 23, 2020	0.002	Passed	0.2100	Passed		
Sackville Heights Elementary	Boys Wash Room tap 3 Room 1049	MYH152	June 23, 2020	0.001	Passed	0.1700	Passed		
Sackville Heights Elementary	Boys Wash Room tap 3 Room 2026	MYH178	June 23, 2020	0.001	Passed	0.0810	Passed		
Sackville Heights Elementary	Class Room tap Room 1025	MYH138	June 23, 2020	0.001	Passed	0.1100	Passed		
Sackville Heights Elementary	Class Room tap Room 1026	MYH139	June 23, 2020	-	Passed	0.0520	Passed		
Sackville Heights Elementary	Class Room tap Room 1027	MYH141	June 23, 2020	-	Passed	0.0420	Passed		
Sackville Heights Elementary	Class Room tap Room 1028	MYH142	June 23, 2020	-	Passed	0.0640	Passed		
Sackville Heights Elementary	Class Room tap Room 1036	MYH133	June 23, 2020	-	Passed	0.6100	Passed		
Sackville Heights Elementary	Class Room tap Room 1037	MYH134	June 23, 2020	0.001	Passed	0.1200	Passed		
Sackville Heights Elementary	Class Room tap Room 1038	MYH135	June 23, 2020	0.001	Passed	0.1400	Passed		
Sackville Heights Elementary	Class Room tap Room 1039	MYH136	June 23, 2020	0.001	Passed	0.2100	Passed		
Sackville Heights Elementary	Class Room tap Room 2017	MYH164	June 23, 2020	0.001	Passed	0.0850	Passed		
Sackville Heights Elementary	Class Room tap Room 2018	MYH165	June 23, 2020	0.001	Passed	0.2100	Passed		
Sackville Heights Elementary	Class Room tap Room 2019	MYH166	June 23, 2020	0.001	Passed	0.1200	Passed		
Sackville Heights Elementary	Class Room tap Room 2020	MYH167	June 23, 2020	0.001	Passed	0.1300	Passed		
Sackville Heights Elementary	Class Room tap Room 2030	MYH160	June 23, 2020	-	Passed	0.3600	Passed		
Sackville Heights Elementary	Class Room tap Room 2031	MYH161	June 23, 2020	-	Passed	0.2400	Passed		
Sackville Heights Elementary	Class Room tap Room 2032	MYH162	June 23, 2020	-	Passed	0.2400	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Sackville Heights Elementary	Janitors Closet tap Room 1059	MYH129	June 23, 2020	-	Passed	0.0400	Passed		
Sackville Heights Elementary	Janitors Closet tap Room 2040	MYH171	June 23, 2020	-	Passed	0.0740	Passed		
Sackville Heights Elementary	Kitchen/Cafeteria 1066 tap 1	AQSI23	May 9, 2025	-	Passed	0.0100	Passed	Tap remediated	
Sackville Heights Elementary	Kitchen/Cafeteria 1066 tap 2	AQSI24	May 9, 2025	-	Passed	0.0150	Passed		
Sackville Heights Elementary	Kitchen/Cafeteria 1066 tap 3	AQSI25	May 9, 2025	-	Passed	0.0130	Passed		
Sackville Heights Elementary	Library Storage Room tap Room 1047	MYH154	June 23, 2020	0.004	Passed	0.2400	Passed		
Sackville Heights Elementary	Main Office Sick Room 1021 tap	WCT669	June 14, 2023	-	Passed	0.0330	Passed		
Sackville Heights Elementary	Main Office Wash Room tap Room 1018	MYH145	June 23, 2020	-	Passed	0.0410	Passed		
Sackville Heights Elementary	Modular 1 Boys Wash Room tap 1	WCT678	June 14, 2023	-	Passed	0.0300	Passed		

Halifax Regional Centre for Education									
Water Test Results Update - Lead and Copper - December, 2025									
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses	
Sackville High School	Class Room 312 tap 1	SCH575	March 15, 2022	0.001	Passed	0.0330	Passed		
Sackville High School	Class Room 312 tap 2	MSP877	June 13, 2023	0.005	Passed	0.5800	Passed		
Sackville High School	Class Room 312 tap 3	SCH576	March 15, 2022	-	Passed	0.0240	Passed		
Sackville High School	Class Room 313 tap 1	MSP879	May 27, 2020	0.003	Passed	0.2600	Passed		
Sackville High School	Class Room 313 tap 2	WCN268	June 13, 2023	0.002	Passed	0.3400	Passed	Tap remediated	
Sackville High School	Class Room tap 1 Room 238	MSP892	May 27, 2020	0.004	Passed	0.4000	Passed		
Sackville High School	Class Room tap 2 Room 238	MSP893	May 27, 2020	0.002	Passed	0.1700	Passed		
Sackville High School	Class Room tap Room 321	MSP881	May 27, 2020	0.004	Passed	0.8600	Passed		
Sackville High School	Class Room Wash Room 1 tap Room 238	MSP894	May 27, 2020	0.002	Passed	0.2200	Passed		

Halifax Regional Centre for Education

Water Test Results Update - Lead and Copper - December, 2025

Halifax Regional Centre for Education		
---------------------------------------	--	--

Halifax Regional Centre for Education		
---------------------------------------	--	--

Halifax Regional Centre for Education

Halifax Regional Centre for Education								
Water Test Results Update - Lead and Copper - December, 2025								
School	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses
Woodlawn High School	Boys Locker Room tap 1	WHU671	June 5, 2023	0.006	Exceeded	0.0880	Passed	Hand washing only
Woodlawn High School	Boys Locker Room tap 2	WHU672	June 5, 2023	0.002	Passed	0.0710	Passed	Tap remediated
Woodlawn High School	Boys Locker Room tap 3	MXH599	June 17, 2020	0.002	Passed	0.1500	Passed	
Woodlawn High School	Chemistry Lab 228 tap 1	MXH508	June 17, 2020	0.001	Passed	1.9000	Passed	
Woodlawn High School	Chemistry Lab 228 tap 10	MXH517	June 17, 2020	-	Passed	1.2000	Passed	
Woodlawn High School	Chemistry Lab 228 tap 2	MXH509	June 17, 2020	0.009	Exceeded	2.9000	Exceeded	Laboratory or Hand washing only
Woodlawn High School	Chemistry Lab 228 tap 3	MXH510	June 17, 2020	0.007	Exceeded	2.6000	Exceeded	Laboratory or Hand washing only
Woodlawn High School	Chemistry Lab 228 tap 4	MXH511	June 17, 2020	0.002	Passed	0.8400	Passed	
Woodlawn High School	Chemistry Lab 228 tap 5	MXH512	June 17, 2020	0.001	Passed	1.1000	Passed	
Woodlawn High School	Chemistry Lab 228 tap 6	MXH513	June 17, 2020	-	Passed	0.5600	Passed	
Woodlawn High School	Chemistry Lab 228 tap 7	MXH514	June 17, 2020	0.001	Passed	0.9800	Passed	
Woodlawn High School	Chemistry Lab 228 tap 8	MXH515	June 17, 2020	0.001	Passed	1.2000	Passed	
Woodlawn High School	Chemistry Lab 228 tap 9	MXH516	June 17, 2020	-	Passed	1.5000	Passed	
Woodlawn High School	Class Room 108 tap	MXH552	June 17, 2020	-	Passed	0.3700	Passed	
Woodlawn High School	Class Room 108 Wash Room 1 tap	MXH553	June 17, 2020	0.001	Passed	0.3500	Passed	
Woodlawn High School	Class Room 108 Wash Room 2 tap	MXH554	June 17, 2020	0.001	Passed	0.4200	Passed	
Woodlawn High School	Class Room 108 Wash Room 3 tap	MXH555	June 17, 2020		Passed	0.4000	Passed	
Woodlawn High School	Class Room 124 tap	MXH576	June 17, 2020	0.001	Passed	0.7100	Passed	
Woodlawn High School	Class Room 125 tap	MXH575	June 17, 2020	0.002	Passed	0.7300	Passed	
Woodlawn High School	Class Room 127 tap 1	MXH569	June 17, 2020	0.001	Passed	1.2000	Passed	
Woodlawn High School	Class Room 127 tap 2	MXH570	June 17, 2020	-	Passed	0.8800	Passed	
Woodlawn High School	Class Room 127 tap 3	MXH571	June 17, 2020	0.003	Passed	0.4800	Passed	
Woodlawn High School	Class Room 128 tap 1	MXH586	June 17, 2020	0.002	Passed	0.6200	Passed	
Woodlawn High School	Class Room 128 tap 2	WHU662	June 5, 2023	0.001	Passed	0.1500	Passed	Tap remediated
Woodlawn High School	Class Room 128 tap 3	WHU663	June 5, 2023	0.001	Passed	0.1400	Passed	Tap remediated
Woodlawn High School	Class Room 128 tap 4	MXH589	June 17, 2020	0.004	Passed	1.0000	Passed	
Woodlawn High School	Class Room 128 tap 5	MXH590	June 17, 2020	0.002	Passed	1.0000	Passed	
Woodlawn High School	Class Room 211 tap	WHU675	June 5, 2023	0.001	Passed	0.0240	Passed	Tap remediated
Woodlawn High School	Class Room 225 tap 1	MXH520	June 17, 2020	0.001	Passed	0.5100	Passed	
Woodlawn High School	Class Room 225 tap 2	MXH521	June 17, 2020	0.001	Passed	0.6100	Passed	
Woodlawn High School	Class Room 226 tap 1	WHU688	June 5, 2023	0.002	Passed	0.1000	Passed	Tap remediated
Woodlawn High School	Class Room 226 tap 2	MXH519	June 17, 2020	-	Passed	0.5700	Passed	
Woodlawn High School	Class Room 229 tap	MXH539	June 17, 2020	0.002	Passed	0.1900	Passed	
Woodlawn High School	Class Room 230 tap	WHU689	June 5, 2023	0.005	Passed	0.3500	Passed	Tap remediated
Woodlawn High School	Class Room 232 tap	MXH505	June 17, 2020	0.005	Passed	0.1200	Passed	
Woodlawn High School	Class Room tap left of Room 217	MXH525	June 17, 2020	0.004	Passed	1.6000	Passed	
Woodlawn High School	Fine Arts Office 4 Wash Room tap	MXH528	June 17, 2020	0.005	Passed	0.1800	Passed	
Woodlawn High School	Fine Arts Office 5 Wash Room tap	WHU701	June 5, 2023	0.006	Exceeded	0.1100	Passed	Hand washing only
Woodlawn High School	Fountain by Room 116	ARFC41	May 26, 2025	-	Passed	0.0008	Passed	
Woodlawn High School	Fountain by Room 217	ARFC43	May 26, 2025	-	Passed	0.0520	Passed	
Woodlawn High School	Fountain by Room 232	ARFC45	May 26, 2025	-	Passed	0.0006	Passed	
Woodlawn High School	Fountain in Gym	ARFC42	May 26, 2025	-	Passed	0.0019	Passed	
Woodlawn High School	Fountain near Room 124	ZOK158	June 26, 2024	-	Passed	0.0008	Passed	
Woodlawn High School	Gender Neutral Wash Room 1 tap near Room 124	WHU660	June 5, 2023	0.001	Passed	0.0660	Passed	Tap remediated
Woodlawn High School	Gender Neutral Wash Room 2 tap near Room 124	MXH583	June 17, 2020	0.003	Passed	0.0850	Passed	
Woodlawn High School	Girls Locker Room back tap	WHU670	June 5, 2023	0.013	Exceeded	0.3900	Passed	Hand washing only
Woodlawn High School	Girls Locker Room tap 1	WHU668	June 5, 2023		Passed	0.0410	Passed	Tap remediated
Woodlawn High School	Girls Locker Room tap 2	MXH593	June 17, 2020	0.004	Passed	0.2400	Passed	
Woodlawn High School	Girls Locker Room tap 3	WHU669	June 5, 2023	0.001	Passed	0.0440	Passed	Tap remediated
Woodlawn High School	Gym Office 1 Wash Room tap	MXH600	June 17, 2020	0.002	Passed	0.0370	Passed	
Woodlawn High School	Gym Office 11 Wash Room tap	WHU665	June 5, 2023	0.003	Passed	0.5500	Passed	Tap remediated
Woodlawn High School	Gym Office 12 Wash Room tap	MXH601	June 17, 2020	0.002	Passed	0.0480	Passed	
Woodlawn High School	Main Office Wash Room 1 tap	WHU674	June 5, 2023	-	Passed	0.0120	Passed	Tap remediated
Woodlawn High School	Main Office Wash Room 2 tap	MXH578	June 17, 2020	0.002	Passed	0.0440	Passed	
Woodlawn High School	Music Room 218 tap	WHU677	June 5, 2023	0.003	Passed	0.0830	Passed	
Woodlawn High School	Science Lab 231 tap 1	MXH540	June 17, 2020	0.004	Passed	0.4100	Passed	
Woodlawn High School	Science Lab 231 tap 10	MXH549	June 17, 2020	0.002	Passed	0.7300	Passed	
Woodlawn High School	Science Lab 231 tap 11	MXH550	June 17, 2020	0.007	Exceeded	0.4500	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 12	MXH551	June 17, 2020	0.006	Exceeded	0.9600	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 12	MXH541	June 17, 2020	0.018	Exceeded	0.6200	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 3	MXH542	June 17, 2020	0.021	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 4	MXH543	June 17, 2020	0.019	Exceeded	1.4000	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 5	MXH544	June 17, 2020	0.018	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 6	MXH545	June 17, 2020	0.014	Exceeded	0.4800	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 7	MXH546	June 17, 2020	0.006	Exceeded	0.6800	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 8	MXH547	June 17, 2020	0.009	Exceeded	0.8700	Passed	Laboratory or Hand washing only
Woodlawn High School	Science Lab 231 tap 9	MXH548	June 17, 2020	0.006	Exceeded	1.3000	Passed	Laboratory or Hand washing only
Woodlawn High School	Youth Room 219 tap	WHU679	June 5, 2023	0.001	Passed	0.0850	Passed	