



Halifax
Regional Centre for Education

RFP# 4249 - Addendum #1

Stage Floor Replacement – Spatz Theatre – Citadel High School

To: All Bidders

Date: July 5, 2024

From: Nancy Rideout, Purchasing Manager
Office: (902) 464-2000 ext. 2222
Email: nrideout@hrce.ca

The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:

Response to Vendor Questions & Clarifications:

1. At the front of the stage there are 3 sockets which house av and electrical outlets. Is the contractor responsible for replacing them? If so, can you please provide the sockets type required?

Response: The outlets can be decommissioned and removed.

2. Can we confirm if we are required to decommission the power to all three sockets?

Response: The outlets can be decommissioned and removed.

3. Will the curtains be removed by the theatre staff prior to the work starting or will that be part of the contractor's scope of work?

Response: The curtains will be removed prior to construction.

4. Please confirm the scope of work is to replace the tempered hardboard and any water damaged plywood not the sleepers and subfloor.

Response: Sleepers and subfloor are not to be removed, only water damaged materials.

5. We are suggesting that we use Gerflor Tarasafe Ultra a 2mm safety floor in a 15 x 20-foot section from the garage door into the storage room instead of the hardboard to prevent the water damage and wear that you face currently.

Response:

Attached Technical Data Sheet is acceptable.

Contractors must provide a price for the full stage replacement with hardboard as specified in the scope of work and provide a separate price for installing the Gerflor Tarasafe Ultra a 2mm safety floor in a 15 x 20-foot section from the garage door into the storage room.

6. Separate Price

Proponents are to submit a separate price for the work indicated.
This requirement will be fulfilled at the sole discretion of the HRCE.
Award of this work is subject to budget availability.

15x20 Foot section from garage door into the storage room using Gerflor Tarasafe Ultra 2mm

_____ /100 Dollars (\$_____)
(HST Excluded)

The Lump Sum price requested in the tender package must be completed on the Tender Price Form.

End of Addendum #1

PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:

Signature

Company Name

DESCRIPTION

Total thickness	ASTM F386-02	inch	0.08
	EN 428	mm	2.00
Wearlayer thickness	ASTM F410-02	inch	0.046
	EN 429	mm	1.16
Backing	ASTM 1303-04	-	-
Weight	-	lbs/sq.ft.	0.53
	EN 430	g/sq.m	2610
Width	-	feet - inch	6'6"
	EN 426	cm	200
Length	-	feet - inch	66'
	EN 426	m	20
Coverage / roll	-	sq.ft.	430.56
	-	sq.m	40

CLASSIFICATION

Reference specification	ASTM F1303-04	-	Type I Grade 1
Fire rating	ASTM E648-08	class	Class I
	CAN/ULC S102.2	-	-

PERFORMANCES

Bacteriostatic & fungistatic	-	-	Sanosol®
Surface treatment / maintenance	-	-	SparClean®
Abrasion	ASTM F510-04	mg	1.4
Wear resistance	EN 660.2	mm ³	≤ 2
Coefficient of friction	ASTM D2047-04	-	1
	ASTM C1028-96	-	0.69
Slip resistance wet: ramp test with oil	DIN 51 130	class	R10
Slip resistance – ramp test	EN 13845 (annex C)	class	ESb
Static load (175 psi)	ASTM F970-00	inch	0.004
Dimensional stability	-	-	Excellent
Impact insulation class	ASTM E989-06	-	46
Thermal conductivity	EN 12 524	W/(m.K)	0.25
Chemical & stain resistance	ASTM F925-02	-	Excellent Test results available upon request

ENVIRONMENT

Certification	-	-	Floorscore™
TVOC after 28 days	ISO 16000-6	µg/ m ³	< 100