



Halifax

Regional Centre for Education

**RFP# 4251 - Addendum #2
Curtain Wall Addition – Herring Cove Junior High**

To: All Bidders

Date: August 16, 2024

From: Nancy Rideout, Purchasing Manager
Office: (902) 464-2000 ext. 2222
Email: nrideout@hrce.ca

The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:

Question

Looking at the plans of New Curtain Wall assembly, we noticed that there is no joint at the slab edge showing between the new curtain wall assembly. Is there a joint that would require Firestopping at this location on level 2?

Answer

There is no need for a firestopping joint at the location specified because it is placed in-behind the existing concrete block wall.

Question

Please consider our request for equals as noted below:

Section 08 50 50 Aluminum Curtain Wall:

1. Item 2.5, please consider Anotec Series 3400HP [high performance] curtain wall framing and Series 80 operable windows as equals to the specified products.
2. Item 2.5.2.3, please consider the pivot shoe operator as provided by Anotec Manufacturing for their Series 80 operable windows as equal to the Bronzecraft operator specified.

Section 08 80 50 Glazing:

3. Item 2.1.1.1, please consider Low-E Guardian SN68 as provided by Prelco as an equal to the specified products.

Answer

These alternates are accepted. Amended General specification is enclosed.

End of Addendum #2 – RFP 4251

PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:

Signature

Company Name

Addendum No. 2
Issued: August 15, 2024

The Bid Documents shall be amended and new clauses and drawings added or deleted will become part of the Contract Document as follows:

1 General

- .1 Reference spec section **08 50 50 ALUMINUM CURTAIN WALL, ITEM 2.5**
 - .1 Add acceptable alternates:
 - .1 Anotec Series 3400HP [High Performance] curtain wall framing and Series 80 operable windows
 - .2 Pivot shoe operator provided by Anotec Manufacturing for their Series 80 operable windows
 - .2 Reference spec section **08 80 50 GLAZING, ITEM 2.1.1**
 - .1 Add acceptable alternates:
 - .1 Low-E Guardian SN68 provided by Prelco

Attachments: None

END ADDENDUM #2