



Halifax
Regional Centre for Education

**RFT# 4235 - Addendum #1
Boiler Replacement & Control Upgrades
Tantallon Sr. Elementary School**

To: All Bidders
Date: May 22, 2024
From: Nancy Rideout, Purchasing Manager
Office: (902) 464-2000 ext. 2222
Email: nrideout@hrce.ca

The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:

The closing date for this competition is extended till May 27, 2024 – 2pm (ATL)

Question #1 - Request for Alternates

Response:

Reference Section 23 52 01 – Condensing Boilers:

1. Add 2.11.2: Fulton EDR
2. Add 2.11.3: PK Solis **

** Please note that the PK Solis boiler is only available in 208v. Any impact to electrical cost should be reflected in contractors bid price. New Electrical Panel 1101 as part of this project will have 208v available.

Question #2

Is the intent to provide BAS controls (new space temperature sensors and control valves) in each of the rooms shown with an “AI – T-RM” and “AO – V-RAD” on drawing M102? Currently we only have BAS controls in the gym and a representative room on floors one and two.

Response:

Yes. That is the intent.

End of Addendum #1

PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:

Signature

Company Name